

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 29/Jun/2019 SATURDAY**

| I GENERATION (MUs)  |                |                  | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|------------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly          | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 126.373        | 4413.088         | 1) Gujrat                      | -5.734         | -101.597         |
| 2) Hydro            | 4.364          | 104.373          | 2) Madhya Pradesh              | 4.274          | 167.738          |
| 3) Gas              | 7.482          | 184.671          | 3) Chattisgarh                 | 3.880          | 99.140           |
| <b>Total MSPGCL</b> | <b>138.219</b> | <b>4702.132</b>  | 4) Maharashtra                 | 83.733         | 3313.326         |
| B) 1) APLM          | 47.830         | 1854.133         | 5) Goa (Amona)                 | -0.352         | -11.220          |
| 2) JSWEL            | 22.083         | 692.970          | <b>Total</b>                   | <b>85.801</b>  | <b>3467.387</b>  |
| 3) VIPL             | 0.000          | 0.000            | a) Mumbai Schedule             | 22.547         | 832.903          |
| 4) RPL(AMT)         | 14.649         | 571.630          | b) Mumbai Drawl                | 27.606         | 1031.109         |
| 5) WPCL             | 0.000          | 0.000            | c) MSEDCL Bilateral *          | 9.814          | 331.272          |
| 6) Other IPP        | 6.032          | 200.557          | Include PX                     | -3.083         | -95.775          |
| 7) PGPL             | 0.000          | 0.000            | d) Mumbai Bilateral *          | 22.547         | 832.903          |
| C) 1) TPCL Thermal  | 12.189         | 387.460          | Include PX                     | 5.806          | 323.018          |
| 2) TPCL Hydro       | 3.586          | 107.594          | Standby                        | 0.000          | 0.000            |
| 3) TPCL Gas         | 4.153          | 119.776          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 8.961          | 281.393          | 1) MSEDCL                      | 332.048        | 11561.606        |
| D) STATE            |                |                  | 2) Mumbai Discoms              | 56.495         | 1927.333         |
| 1) Thermal          | 238.117        | 8401.231         | <b>TOTAL STATE</b>             | <b>388.543</b> | <b>13488.939</b> |
| (A1+C1+C4+(B1-B6))  |                |                  |                                |                |                  |
| 2) Hydro (A2+C2)    | 7.950          | 211.967          |                                |                |                  |
| 3) Gas (A3+B7+C3)   | 11.635         | 304.447          |                                |                |                  |
| 4) Wind             | 41.976         | 934.223          |                                |                |                  |
| 6) SOLAR            | 3.064          | 169.683          |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>302.742</b> | <b>10021.551</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5269                      | 5350                  | 5450                      | 5240                      |
| MSPGCL Hydro             | 90                        | 80                    | 425                       | 44                        |
| MSPGCL Gas               | 357                       | 369                   | 219                       | 331                       |
| MSPGCL Total Generation  | 5716                      | 5799                  | 6094                      | 5615                      |
| Central Sector Receipt   | 3747                      | 3409                  | 4540                      | 2584                      |
| WIND                     | 2173                      | 2148                  | 1325                      | 1907                      |
| CPP / IPP Thermal        | 3525                      | 3509                  | 4119                      | 3620                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 426                       | 455                   | 0                         | 0                         |
| Exchange with Mumbai     | -1515                     | -1492                 | -1267                     | -794                      |
| <b>MSEDCL DEMAND MET</b> | <b>14072</b>              | <b>13828</b>          | <b>14811</b>              | <b>12932</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 14072                     | 13828                 | 14811                     | 12932                     |
| TPCL GENERATION          | 936                       | 958                   | 980                       | 654                       |
| AEML GENERATION          | 373                       | 374                   | 373                       | 373                       |
| <b>MUMBAI DEMAND</b>     | <b>2824</b>               | <b>2824</b>           | <b>2620</b>               | <b>1821</b>               |
| STATE DEMAND MET         | 16896                     | 16652                 | 17431                     | 14753                     |
| <b>STATE DEMAND</b>      | <b>16896</b>              | <b>16652</b>          | <b>17431</b>              | <b>14753</b>              |
| Frequency (Hz)           | 49.92                     | 49.92                 | 49.98                     | 50.02                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.15 Hz at 17.03 Hrs | 49.72 Hz at 00.03 Hrs | 49.97         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 29/Jun/2019

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 3.63         | 98.49          | 160      | 130      |
| Unit 7             | 0.00         | 74.78          | 0        | 0        |
| Unit 8             | 0.00         | 207.25         | 0        | 0        |
| Unit 9             | 9.38         | 263.75         | 430      | 290      |
| Unit 10            | 9.82         | 263.52         | 460      | 320      |
| <b>Total</b>       | <b>22.83</b> | <b>907.78</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 36.07          | 0        | 0        |
| Unit 4             | 9.12         | 286.72         | 500      | 355      |
| Unit 5             | 8.92         | 233.10         | 460      | 350      |
| <b>Total</b>       | <b>18.04</b> | <b>555.89</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 11.63          | 0        | 0        |
| Unit 8             | 0.00         | 11.77          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>23.39</b>   |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 2.38         | 121.68         | 163      | 0        |
| Unit 4             | 3.33         | 103.24         | 162      | 66       |
| Unit 5             | 8.74         | 272.08         | 385      | 325      |
| Unit 6             | 8.26         | 280.66         | 370      | 300      |
| Unit 7             | 8.77         | 203.39         | 379      | 335      |
| Unit 8             | 9.08         | 305.56         | 420      | 360      |
| Unit 9             | 9.00         | 299.68         | 420      | 360      |
| <b>Total</b>       | <b>49.56</b> | <b>1586.28</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 4.91         | 162.46         | 240      | 192      |
| Unit 4             | 4.87         | 159.31         | 227      | 174      |
| <b>Total</b>       | <b>9.78</b>  | <b>321.77</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 3.74         | 86.26          | 175      | 140      |
| Unit 2             | 3.28         | 84.72          | 150      | 100      |
| Unit 3             | 3.84         | 103.62         | 175      | 135      |
| Unit 4             | 3.69         | 105.13         | 180      | 140      |
| Unit 5             | 0.00         | 286.94         | 0        | 0        |
| <b>Total</b>       | <b>14.55</b> | <b>666.68</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 3.90         | 118.43         | 164      | 159      |
| Unit 4             | 3.94         | 119.63         | 169      | 160      |
| Unit 5             | 3.77         | 113.23         | 165      | 82       |
| <b>Total</b>       | <b>11.61</b> | <b>351.29</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 7.48         | 184.67         | 369      | 215      |
| <b>Total</b>       | <b>7.48</b>  | <b>184.67</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.00         | 0.01           | 0        | 0        |

| Generating unit | Generation   |                |          |          |
|-----------------|--------------|----------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.00</b>  | <b>0.01</b>    |          |          |
| <b>Koyna</b>    |              |                |          |          |
| Stage 1-2       | 1.32         | 38.92          | 195      | 30       |
| Stage 4         | 0.00         | 0.56           | 0        | 0        |
| Stage 3         | 1.31         | 11.95          | 180      | 0        |
| <b>Total</b>    | <b>2.63</b>  | <b>51.43</b>   |          |          |
| <b>Hydro</b>    |              |                |          |          |
| KDPH            | 0.06         | 8.60           | 9        | 0        |
| VTRNA           | 0.00         | 17.02          | 0        | 0        |
| TILLARI         | 0.00         | 0.97           | 0        | 0        |
| BHTGR/VEER      | 0.00         | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.34         | 6.53           | 40       | 0        |
| RNGR+BHTSA      | 0.00         | 1.71           | 0        | 0        |
| BHANDARDRA      | 0.00         | 1.48           | 0        | 0        |
| ELDARY          | 0.00         | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.00         | 2.14           | 0        | 0        |
| GHATGHAR        | 1.33         | 14.49          | 250      | 0        |
| <b>Total</b>    | <b>1.73</b>  | <b>52.95</b>   |          |          |
| <b>Wind</b>     |              |                |          |          |
| Total           | 41.98        | 934.22         | 0        | 0        |
| <b>Total</b>    | <b>41.98</b> | <b>934.22</b>  |          |          |
| <b>CPP</b>      |              |                |          |          |
| APML(Mus)       | 47.83        | 1854.13        | 0        | 0        |
| JSWEL(Mus)      | 22.08        | 692.97         | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 14.65        | 571.63         | 0        | 0        |
| WPCL(Mus)       | 0.00         | 0.00           | 0        | 0        |
| Other(Mus)      | 6.03         | 200.56         | 0        | 0        |
| <b>Total</b>    | <b>90.59</b> | <b>3319.29</b> |          |          |
| <b>SOLAR</b>    |              |                |          |          |
| Total           | 3.06         | 169.68         | 0        | 0        |
| <b>Total</b>    | <b>3.06</b>  | <b>169.68</b>  |          |          |
| <b>Tata</b>     |              |                |          |          |
| Trombay 5       | 7.41         | 244.36         | 319      | 304      |
| Trombay 6       | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A      | 2.62         | 75.45          | 116      | 67       |
| Trombay 7B      | 1.54         | 44.32          | 67       | 51       |
| Trombay 8       | 4.78         | 143.10         | 202      | 196      |
| TATA Hydro      | 3.59         | 107.59         | 300      | 10       |
| <b>Total</b>    | <b>19.93</b> | <b>614.83</b>  |          |          |
| <b>AEML</b>     |              |                |          |          |
| DTPS U-1&2      | 8.96         | 281.39         | 375      | 372      |
| <b>Total</b>    | <b>8.96</b>  | <b>281.39</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 126.37      | 4413.09       | MSPGCL Total        | 138.22      | 4702.13       |
|                |             |         | MSPGCL Thml+Gas | 133.86      | 4597.76       | Koyna 1,2 & 4 Total | 1.32        | 39.47         |
|                |             |         | MSPGCL Hydro    | 4.36        | 104.37        | State Total         | 302.74      | 10021.55      |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 29/Jun/2019

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5238        | 43   | 321  | 5602   | 2141  | 3821      | 0    | 0     | 2858        | 2876        | -1017                | 13423                 | 0                    | 13423                     | 2123             | 15546           | 49.90         |
| 2                  | 5247        | 73   | 333  | 5653   | 2149  | 3835      | 0    | 0     | 2655        | 2727        | -911                 | 13453                 | 0                    | 13453                     | 1991             | 15444           | 49.99         |
| 3                  | 5259        | 53   | 332  | 5644   | 2072  | 3801      | 0    | 0     | 2709        | 2483        | -825                 | 13175                 | 0                    | 13175                     | 1888             | 15063           | 50.01         |
| 4                  | 5240        | 44   | 331  | 5615   | 1907  | 3620      | 0    | 0     | 2692        | 2584        | -794                 | 12932                 | 0                    | 12932                     | 1821             | 14753           | 50.02         |
| 5                  | 5232        | 39   | 332  | 5603   | 1704  | 3637      | 0    | 0     | 2696        | 2828        | -790                 | 12982                 | 0                    | 12982                     | 1805             | 14787           | 50.01         |
| 6                  | 5290        | 160  | 333  | 5783   | 1587  | 3629      | 0    | 0     | 3209        | 3629        | -842                 | 13786                 | 0                    | 13786                     | 1859             | 15645           | 49.97         |
| 7                  | 5334        | 141  | 339  | 5814   | 1433  | 3787      | 0    | 29    | 4048        | 3919        | -844                 | 14138                 | 0                    | 14138                     | 1889             | 16027           | 49.94         |
| 8                  | 5393        | 178  | 367  | 5938   | 1640  | 3707      | 0    | 99    | 4112        | 3767        | -908                 | 14243                 | 0                    | 14243                     | 1984             | 16227           | 50.04         |
| 9                  | 5364        | 180  | 368  | 5912   | 1607  | 3572      | 0    | 195   | 3811        | 4020        | -1117                | 14189                 | 0                    | 14189                     | 2222             | 16411           | 50.00         |
| 10                 | 5319        | 391  | 366  | 6076   | 1743  | 3551      | 0    | 277   | 4046        | 3840        | -1326                | 14161                 | 0                    | 14161                     | 2513             | 16674           | 49.98         |
| 11                 | 5303        | 155  | 352  | 5810   | 2014  | 3536      | 0    | 322   | 4268        | 3875        | -1474                | 14083                 | 0                    | 14083                     | 2715             | 16798           | 49.99         |
| 12                 | 5269        | 90   | 357  | 5716   | 2173  | 3525      | 0    | 426   | 3941        | 3747        | -1515                | 14072                 | 0                    | 14072                     | 2824             | 16896           | 49.92         |
| 13                 | 5350        | 80   | 369  | 5799   | 2148  | 3509      | 0    | 455   | 3586        | 3409        | -1492                | 13828                 | 0                    | 13828                     | 2824             | 16652           | 49.92         |
| 14                 | 5346        | 105  | 348  | 5799   | 2125  | 3525      | 0    | 349   | 3188        | 3201        | -1362                | 13637                 | 0                    | 13637                     | 2699             | 16336           | 49.90         |
| 15                 | 5288        | 230  | 351  | 5869   | 2073  | 3537      | 0    | 325   | 3366        | 3380        | -1330                | 13854                 | 0                    | 13854                     | 2658             | 16512           | 49.95         |
| 16                 | 5144        | 195  | 351  | 5690   | 2097  | 3528      | 0    | 270   | 3478        | 3386        | -1318                | 13653                 | 0                    | 13653                     | 2653             | 16306           | 49.98         |
| 17                 | 5068        | 235  | 273  | 5576   | 2117  | 3519      | 0    | 195   | 3401        | 3777        | -1288                | 13896                 | 0                    | 13896                     | 2620             | 16516           | 50.04         |
| 18                 | 5059        | 380  | 229  | 5668   | 1618  | 3508      | 0    | 103   | 3897        | 4265        | -1252                | 13910                 | 0                    | 13910                     | 2588             | 16498           | 50.03         |
| 19                 | 5226        | 318  | 218  | 5762   | 1297  | 3596      | 0    | 19    | 4577        | 4626        | -1236                | 14064                 | 0                    | 14064                     | 2561             | 16625           | 49.96         |
| 20                 | 5450        | 425  | 219  | 6094   | 1325  | 4119      | 0    | 0     | 4717        | 4540        | -1267                | 14811                 | 0                    | 14811                     | 2620             | 17431           | 49.98         |
| 21                 | 5400        | 291  | 227  | 5918   | 1203  | 4455      | 0    | 0     | 4200        | 4048        | -1203                | 14421                 | 0                    | 14421                     | 2563             | 16984           | 49.94         |
| 22                 | 5329        | 330  | 215  | 5874   | 1281  | 4474      | 0    | 0     | 3602        | 3732        | -1149                | 14212                 | 0                    | 14212                     | 2453             | 16665           | 49.94         |
| 23                 | 5287        | 167  | 282  | 5736   | 1261  | 4412      | 0    | 0     | 3772        | 3618        | -1236                | 13791                 | 0                    | 13791                     | 2362             | 16153           | 49.95         |
| 24                 | 4938        | 61   | 269  | 5268   | 1261  | 4391      | 0    | 0     | 3576        | 3524        | -1110                | 13334                 | 0                    | 13334                     | 2260             | 15594           | 49.95         |
| MUs                | 126.37      | 4.36 | 7.48 | 138.22 | 41.98 | 90.59     | 0.00 | 3.06  | 86.40       | 85.80       | -27.61               | 332.05                | 0.00                 | 332.05                    | 56.49            | 388.54          | 49.97         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 29/Jun/2019**

**Position as on 6.30 Hrs of 30/Jun/2019**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                 | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                  |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |            | Continued. | Annual Overhaul                                  |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                  |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                                |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                          |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                      |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                      |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |            | Continued. | Compressor & Turbine Blade Failure.              |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | Poor Coal Receipt                                |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |            | Continued. | No Schedule.                                     |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule.(water shortage from 25/06/2019)   |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |            | Continued. | No Schedule                                      |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                    |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                    |               |
| MSPGCL                | Parli Unit 8            | 250      | 04/06/2019   | 00.00        |            | Continued. | Zero Schedule (converted to AOH from 25/06/2019) |               |
| MSPGCL                | Koyana Unit 5           | 80       | 17/06/2019   | 08.20        |            | Continued. | needle stuck up problem.                         |               |
| MSPGCL                | Koyana Unit 6           | 80       | 17/06/2019   | 08.40        |            | Continued. | needle stuck up problem.                         |               |
| IPP                   | Adani U-4               | 660      | 19/06/2019   | 16.09        |            | Continued. | MS Drain Bonnet Leakage.                         |               |
| MSPGCL                | Parli Unit 7            | 250      | 25/06/2019   | 09.45        |            | Continued. | Water Shortage                                   |               |
| MSPGCL                | Koradi Unit-8           | 660      | 26/06/2019   | 11.49        | 30/06/2019 | 01.45      | Boiler validity Extn. Work.                      |               |
| MSPGCL                | Khaparkheda Unit 5      | 500      | 27/06/2019   | 23.17        |            | Continued. | Boiler Tube Leakage                              |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 28/06/2019   | 18.35        |            | Continued. | Zero schedule.                                   |               |
| MSPGCL                | Koradi Unit 7           | 210      | 28/06/2019   | 22.50        |            | Continued. | Boiler Tube Leakage                              |               |
| IPP                   | RPL(AMT) U-2            | 270      | 29/06/2019   | 00.00        |            | Continued. | Zero schedule.                                   |               |
| IPP                   | RPL(AMT) U-5            | 270      | 29/06/2019   | 03.00        |            | Continued. | Zero Schedule.                                   |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 29/06/2019   | 16.23        |            | Continued. | Boiler Tube Leakage                              |               |
| MSPGCL                | Uran Unit 6             | 108      | 29/06/2019   | 16.30        | 29/06/2019 | 21.41      | Malfunction Co2 Fire fighting system.            |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 30/06/2019   | 03.56        | 30/06/2019 | 09.51      | Relay Maloperation.                              |               |
| MSPGCL                | Koradi Unit 10          | 660      | 30/06/2019   | 11.54        |            | Continued. | Air heater problem                               |               |
| IPP                   | RPL(AMT) U-1            | 270      | 30/06/2019   | 16.00        |            | Continued. | Zero Schedule                                    |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 29/Jun/2019**

**Statement-VII**

**Position as on 6.30 Hrs of 30/Jun/2019**

| Name of Line                                 | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                      |
|----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                       |
| Karad Solapur (PG)                           | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403              |
| Dhule Sar'Sarovar II                         | InterState                | 27/06/2019   | 19.16        |            | Continued. | HT          | Over Voltage                                                          |
| Akola Aurangabad(PG) I                       | InterState                | 29/06/2019   | 11.29        | 29/06/2019 | 18.39      | EO          | To Replacement Flashover String.                                      |
| Khadka-Aurangabad (Waluj)                    | IntraState                | 28/06/2019   | 17.03        | 29/06/2019 | 10.21      | HT          | Over Voltage                                                          |
| Jaigad-Karad Ckt-I                           | IntraState                | 28/06/2019   | 18.24        | 29/06/2019 | 09.30      | HT          | Over Voltage                                                          |
| Lonikand I - Koyna stage-IV                  | IntraState                | 29/06/2019   | 00.49        | 29/06/2019 | 09.20      | HT          | Over Voltage                                                          |
| Padghe - Nagothane - I                       | IntraState                | 29/06/2019   | 01.37        |            | Continued. | HT          | Over Voltage                                                          |
| Dhule - Bableshwar - II                      | IntraState                | 29/06/2019   | 08.09        | 29/06/2019 | 17.25      | PO          | Replacement oF Insulator String.                                      |
| Taptitanda Waluj                             | IntraState                | 29/06/2019   | 10.45        | 29/06/2019 | 13.46      | EO          | faulty String.                                                        |
| 125 MVAR Bus Reactor @ Warora                | IntraState                | 29/06/2019   | 12.38        | 29/06/2019 | 15.23      | HT          | Due To Fire detector trip led has glow On ctr fire protection system. |
| Khadka-Aurangabad (Waluj)                    | IntraState                | 29/06/2019   | 16.33        |            | Continued. | HT          | Over Voltage                                                          |
| Chandrapur-II - Nanded ckt II                | IntraState                | 30/06/2019   | 04.00        |            | Continued. | T           | Over Voltage                                                          |
| Jaigad-New Koyna Ckt-I                       | IntraState                | 30/06/2019   | 12.39        |            | Continued. | PO          | CVT Replacement work at Jaigad End                                    |
| Lonikand I - Koyna stage-IV                  | IntraState                | 30/06/2019   | 23.45        |            | Continued. | HT          | Over Voltage                                                          |
| <b>400 KV ICT Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                       |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe          | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                             |
| 400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2   | IntraState                | 12/04/2019   | 17.10        |            | Continued. | HT          | Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.                |
| 400/220/33 Kv 315 MVA ICT II @Chandrapur GCR | IntraState                | 24/06/2019   | 14.14        |            | Continued. | PO          | Oil Filtration Work due to High PPM.                                  |
| <b>220 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                       |
| Talandage - Chikodi                          | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                           |
| Mudshingi - Chikodi                          | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                          |
| PARLY (PG) - OLD GCR PARLI                   | InterState                | 29/06/2019   | 10.30        | 29/06/2019 | 13.55      | PO          | Tan Delta Measurement.                                                |
| BOISAR BORIVALI                              | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)                          |
| Balapur-Akola li                             | IntraState                | 20/06/2019   | 12.15        |            | Continued. | PO          | New Tower Erection Work And Stringing Work At Railway Crossing.       |
| Balapur-Akola I                              | IntraState                | 20/06/2019   | 12.15        |            | Continued. | PO          | New Tower Erection Work And Stringing Work At Railway Crossing.       |
| Miraj-Ichalkaranji I                         | IntraState                | 24/06/2019   | 12:14        |            | Continued. | T           | Tower Collapse.                                                       |
| Chandrapur GCR - Warora - I                  | IntraState                | 24/06/2019   | 14.01        |            | Continued. | HT          | Outage on Chandrapur ICT 2.                                           |
| Chandrapur GCR - Wani                        | IntraState                | 24/06/2019   | 19.28        | 29/06/2019 | 18.27      | HT          | Re orientation/ outage on Chandrapur ICT 2.                           |
| Uran - Kharghar I                            | IntraState                | 28/06/2019   | 15.57        | 29/06/2019 | 16.00      | HT          | Over Voltage                                                          |
| Nalasopara-Boisar                            | IntraState                | 29/06/2019   | 00.18        | 29/06/2019 | 17.05      | T           | Distance Protection                                                   |
| Goregaon Versova Line 2                      | IntraState                | 29/06/2019   | 00.19        | 29/06/2019 | 01.25      | T           | Relay maloperation.                                                   |
| Eklahara-(Ocr)(Nashik)-Navasari I            | IntraState                | 29/06/2019   | 05.02        | 29/06/2019 | 11.40      | T           | R-y-PH.4.72KA.Z1.32.23KM.Decapping                                    |
| Pusad - Hingoli                              | IntraState                | 29/06/2019   | 06.32        | 29/06/2019 | 10.22      | PO          | In view of bus 1 Outage at wardha PG end.                             |
| Pusad-WardhaPG(Deoli)                        | IntraState                | 29/06/2019   | 06.40        | 29/06/2019 | 10.15      | PO          | main bay Isolator Alinement.                                          |
| Khadka-Chalisgaon-1                          | IntraState                | 29/06/2019   | 08.22        | 29/06/2019 | 12.10      | PO          | Maint bus to isolator jumper.                                         |
| Jejuri- Ismt- Lonand                         | IntraState                | 29/06/2019   | 10.05        | 29/06/2019 | 12.54      | PO          | Replacement of Flashover Tension insulator.                           |
| Flagship-Nandedcity                          | IntraState                | 29/06/2019   | 10.13        | 29/06/2019 | 13.51      | PO          | for Attending C.T.leakage & Diagnostic Testing Work.                  |
| Eklahara-(Ocr)(Nashik)-Navasari I            | IntraState                | 29/06/2019   | 14.14        | 29/06/2019 | 16.00      | T           | Decapping At Loc No.104.                                              |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 29/Jun/2019**

**Statement-VII**

Position as on 6.30 Hrs of 30/Jun/2019

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                        |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------|
| Chandrapur GCR - Wani                     | IntraState                | 29/06/2019   | 19.39        |            | Continued. | HT          | Outage on Chandrapur ICT 2.                                                                                             |
| Talandge(400kv)- Ichalkaranji ckt-2       | IntraState                | 30/06/2019   | 10.35        | 30/06/2019 | 12.33      | PO          | Shifting on TBC DC Leakage Attending Work                                                                               |
| Apta - Hoc                                | IntraState                | 30/06/2019   | 21.04        | 30/06/2019 | 22.55      | T           | B phase meetring CT Fail                                                                                                |
| Uran - Hoc 1                              | IntraState                | 30/06/2019   | 21.04        | 30/06/2019 | 22.55      | T           | B phase meetring CT Fail                                                                                                |
| <b>220 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                         |
| 220/100 Kv 200 Mva Vijai Ict 3 @Padghe    | IntraState                | 29/06/2019   | 00.42        | 29/06/2019 | 02.56      | T           | Tripped On PRV.                                                                                                         |
| 220/33kV 125 MVA Transformer 5 @Aarey R/S | IntraState                | 29/06/2019   | 06.34        | 29/06/2019 | 12.42      | T           | Cable fault.                                                                                                            |
| 220/100 Kv 200MVA ICT-I @Padghe           | IntraState                | 29/06/2019   | 11.19        | 29/06/2019 | 13.00      | EO          | To Attend bucholz maint Work.                                                                                           |
| 220/132 KV 100MVA ICT-I @ Walchandnagar   | IntraState                | 29/06/2019   | 13.46        | 29/06/2019 | 17.15      | EO          | Attending Oil Leakage                                                                                                   |
| 220/100 Kv 200 MVA ICT IV @Padghe         | IntraState                | 29/06/2019   | 15.33        | 29/06/2019 | 17.28      | EO          | Rewrapping polythene paper.                                                                                             |
| 220/33kV 125 MVA Transformer 5 @Aarey R/S | IntraState                | 29/06/2019   | 16.33        | 29/06/2019 | 18.46      | EO          | For Reconnection of 33Kv Cable.                                                                                         |
| 220/132 kV 200 Mva ICT-II @Boisar -li     | IntraState                | 29/06/2019   | 17.31        | 29/06/2019 | 20.40      | EO          | Commissining of New relay.                                                                                              |
| 220/22kV 100MVA T/F-I @ Nalasopara        | IntraState                | 30/06/2019   | 02.50        |            | Continued. | T           | Diff operated, bucholz tripped, CTR Operated.                                                                           |
| <b>132 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                         |
| Kanhan Pench                              | InterState                | 29/06/2019   | 22.47        | 30/06/2019 | 16.55      | T           | Distance Protection                                                                                                     |
| Amalner - Nardhana                        | IntraState                | 23/06/2019   | 20.02        |            | Continued. | T           | DISTANCE PROTECTION NRD--> Y, PHASE, IY=8.33KA, IB=8.309KA, 45.86KM 5 NO TOWERS COLLAPSED TOWER NO 9 TO 13 FROM AMALNER |
| Gangakhed - Kandhar                       | IntraState                | 28/06/2019   | 14.14        | 29/06/2019 | 15.30      | T           | Kandhar= Distance protection, Z1, B-PH, 64.7KM, 912A, SOTF Gangakhed= Z2, B-PH, 7.91KM, 5.308KA.                        |
| Parbhani-Gangakhed                        | IntraState                | 29/06/2019   | 04.28        | 29/06/2019 | 04.43      | T           | Distance Protection Z1, R-E, 19.4KM IF=2.134KA.                                                                         |
| Deoli-Mahalaxmi                           | IntraState                | 29/06/2019   | 21.55        | 29/06/2019 | 22.22      | T           | Back up Protection.                                                                                                     |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage