

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 29/Aug/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	143.789	3789.291	1) Gujrat	14.361	375.960
2) Hydro	27.977	477.457	2) Madhya Pradesh	6.717	232.944
3) Gas	5.914	59.237	3) Chattisgarh	2.100	51.240
Total MSPGCL	177.680	4325.985	4) Maharashtra	184.365	4832.767
B) 1) APML	46.796	1585.165	5) Goa (Amona)	-1.551	-45.677
2) JSWEL	21.572	494.328	Total	205.992	5447.234
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.072	909.138
4) RPL(AMT)	25.699	778.128	b) Mumbai Drawl	32.899	1014.478
5) SWPGPL	12.221	292.673	c) MSEDCL Bilateral *	90.566	2696.312
6) Other IPP	6.671	180.761	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.056	909.112
C) 1) TPCL Thermal	14.208	355.092	Include PX	0.000	0.000
2) TPCL Hydro	7.544	170.588	Standby	0.016	0.026
3) TPCL Gas	2.661	76.721	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.413	269.180	1) MSEDCL	488.519	13294.346
D) STATE			2) Mumbai Discoms	67.725	1886.055
1) Thermal	281.369	7744.618	3) Other Discoms	10.494	292.161
(A1+C1+C4+(B1-B6))			TOTAL STATE	566.738	15472.562
2) Hydro (A2+C2)	35.521	648.045			
3) Gas (A3+B7+C3)	8.575	135.958			
4) Wind	19.407	1157.478			
6) SOLAR	15.874	339.233			
TOTAL STATE	360.746	10025.332			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6065	6059	5801	6017
MSPGCL Hydro	1536	1174	1508	221
MSPGCL Gas	167	148	287	248
MSPGCL Total Generation	7768	7381	7596	6486
Central Sector Receipt	10311	10375	7745	7686
WIND	438	431	946	1459
CPP / IPP Thermal	4721	4733	4751	4624
CPP / IPP Gas	0	0	0	0
SOLAR	1993	1977	0	0
Exchange with Mumbai	-1944	-1933	-1346	-1031
MSEDCL DEMAND MET	22817	22511	19203	18893
Load Shedding	0	0	2471	0
MSEDCL DEMAND	22817	22511	21674	18893
TPCL GENERATION	952	917	1253	716
AEML GENERATION	475	470	492	288
MUMBAI DEMAND	3371	3320	3091	2035
OTHER DISCOM DEMAND	470	453	489	331
STATE DEMAND MET	26658	26284	22783	21259
STATE DEMAND	26658	26284	25254	21259
Frequency (Hz)	50.02	50.00	49.91	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 17.03 Hrs	49.51 Hz at 22.21 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 29/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.59	91.92	165	130
Unit 8	12.61	286.76	565	487
Unit 9	11.53	352.83	520	432
Unit 10	0.00	0.00	0	0
Total	27.73	731.50		
Bhusawal				
Unit 3	2.93	88.48	140	100
Unit 4	9.77	242.77	450	360
Unit 5	9.01	268.12	415	305
Total	21.71	599.38		
Parli				
Unit 6	5.36	102.63	250	174
Unit 7	4.56	102.20	212	155
Unit 8	4.31	94.00	196	155
Total	14.24	298.84		
Chandrapur				
Unit 3	3.83	87.57	168	137
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	7.76	175.63	361	260
Unit 7	7.09	204.17	330	265
Unit 8	10.03	293.49	445	400
Unit 9	10.22	294.55	465	346
Total	38.93	1055.41		
Paras				
Unit 3	5.04	121.76	235	180
Unit 4	5.13	134.76	229	205
Total	10.17	256.53		
Khaparkheda				
Unit 1	3.32	66.82	155	100
Unit 2	2.49	77.96	121	80
Unit 3	3.71	102.79	165	135
Unit 4	3.56	114.03	163	126
Unit 5	10.60	283.06	450	410
Total	23.68	644.66		
Nasik				
Unit 3	0.00	46.24	0	0
Unit 4	3.66	89.65	161	141
Unit 5	3.68	67.08	159	143
Total	7.34	202.98		
Uran				
All Units	5.91	59.24	289	148
Total	5.91	59.24		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.33	21.62	51	0
Total	0.33	21.62		
Koyna				
Stage 1-2	5.46	88.11	380	30

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	13.01	160.05	750	0
Stage 3	3.88	59.19	240	0
Total	22.35	307.35		
Hydro				
KDPH	0.86	9.74	36	36
VTRNA	0.19	0.91	60	0
TILLARI	0.00	2.10	0	0
BHIRA T.R.	0.46	13.04	80	0
SMLHY_PTN	3.58	114.16	152	146
GHATGHAR	0.21	8.53	125	0
Total	5.30	148.49		
Wind				
Total	19.41	1157.48	0	0
Total	19.41	1157.48		
CPP				
APML(Mus)	46.80	1585.16	0	0
JSWEL(Mus)	21.57	494.33	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.70	778.13	0	0
SWPGPL-Mus	12.22	292.67	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.10	152.29	263	248
Other(Mus)	0.58	28.47	0	0
Total	112.96	3331.06		
SOLAR				
Total	15.87	339.23	0	0
Total	15.87	339.23		
Tata				
Trombay 5	9.24	234.54	451	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.54	45.71	108	38
Trombay 7B	1.12	31.01	65	35
TATA Hydro	7.54	170.59	443	141
Trombay 8	4.96	120.55	239	134
Total	24.41	602.40		
AEML				
DTPS U-1&2	10.41	269.18	501	288
Total	10.41	269.18		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	143.79	3789.29	MSPGCL Total	177.68	4325.98
			MSPGCL Thml+Gas	149.70	3848.53	Koyna 1,2 & 4 Total	18.47	248.16
			MSPGCL Hydro	27.98	477.46	State Total	360.75	10025.33

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 29/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5950	1013	235	7198	1499	4695	0	0	6749	6666	-885	18754	0	0	18754	2472	419	21645	50.00
2	5948	934	238	7120	1548	4711	0	0	6784	6704	-834	18879	0	0	18879	2276	370	21525	50.02
3	6006	780	241	7027	1558	4714	0	0	7075	7203	-949	19216	0	0	19216	2119	337	21672	49.98
4	6017	221	248	6486	1459	4624	0	0	7887	7686	-1031	18893	0	0	18893	2035	331	21259	49.96
5	6040	556	254	6850	1262	4663	0	0	8075	8027	-968	19476	0	0	19476	2031	358	21865	49.93
6	6059	1380	252	7691	1163	4722	0	0	8296	8315	-927	20587	0	0	20587	2155	377	23119	49.96
7	6046	1599	254	7899	706	4717	0	95	8953	8990	-790	21196	392	0	21588	2338	421	24347	49.93
8	6134	1385	251	7770	548	4689	0	523	9231	9195	-1009	21281	278	0	21559	2551	435	24545	50.01
9	6146	1119	257	7522	574	4698	0	1112	9455	9485	-1476	21459	0	0	21459	2876	456	24791	49.94
10	6113	1564	254	7931	531	4696	0	1651	9406	9513	-1820	22047	0	0	22047	3174	455	25676	49.97
11	6093	1410	210	7713	512	4722	0	1834	10219	10187	-1948	22533	0	5	22533	3329	487	26349	50.03
12	6065	1536	167	7768	438	4721	0	1993	10219	10311	-1944	22817	0	5	22817	3371	470	26658	50.02
13	6059	1174	148	7381	431	4733	0	1977	10413	10375	-1933	22511	0	9	22511	3320	453	26284	50.00
14	6051	410	175	6636	398	4687	0	1919	10745	10462	-2050	21595	0	4	21595	3206	457	25258	49.96
15	6095	730	201	7026	459	4730	0	1795	10176	10310	-1973	21902	553	0	22455	3243	445	26143	49.77
16	6014	869	261	7144	554	4732	0	1476	9496	9298	-1746	20991	1156	0	22147	3319	467	25933	49.93
17	5908	1125	261	7294	644	4735	0	1022	8989	9065	-1649	20621	1495	0	22116	3293	490	25899	49.97
18	5979	1330	285	7594	670	4739	0	428	8590	8852	-1593	20207	1507	0	21714	3224	483	25421	50.03
19	5891	1544	285	7720	874	4748	0	49	8151	8186	-1387	19710	1436	0	21146	3116	480	24742	49.96
20	5801	1508	287	7596	946	4751	0	0	7838	7745	-1346	19203	2471	0	21674	3091	489	25254	49.91
21	5815	1151	286	7252	773	4696	0	0	7526	7586	-1265	18577	2693	0	21270	2960	465	24695	49.98
22	5858	1437	289	7584	692	4610	0	0	7444	7602	-1183	18843	2306	0	21149	2822	462	24433	49.90
23	5859	1608	287	7754	602	4707	0	0	7353	7322	-1125	18806	2114	0	20920	2731	454	24105	49.80
24	5842	1594	288	7724	566	4719	0	0	7285	6907	-1068	18414	1351	0	19765	2673	434	22872	49.91
MUs	143.79	27.98	5.91	177.68	19.41	112.96	0.00	15.87	206.35	205.99	-32.90	488.52	17.75	0.02	506.27	67.73	10.49	584.49	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

220Kv Koparagoan 220/33KV 50MVA T/F 1&2 Over load.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 29/Aug/2023

Position as on 6.30 Hrs of 30/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault(converted to Capital overhaul from 00.00Hrs DT.27-07-2023)	13/09/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	Annual Overhaul	18/09/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	07/09/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	OVERHAUL	31/08/2023
IPP	Adani U-4	660	12/08/2023	23:44		Continued.	Annual Overhaul	05/09/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	30/08/2023
MSPGCL	Koyna Unit 7	80	13/08/2023	09:00		Continued.	Spherical Valve maintenance	02/09/2023
MSPGCL	Nasik Unit 3	210	13/08/2023	16:00		Continued.	Boiler Tube Leakage (Tolling from 15:00 hrs on Dt 14.08.2023.)	
IPP	RPL(AMT) U-4	270	22/08/2023	18:46		Continued.	Generator Stator Earth Fault	01/10/2023
IPP	Adani U-1	660	28/08/2023	21:21		Continued.	Due to APH A Hot SA heavy bellow leakage.	31/08/2023
MSPGCL	Uran Unit 6	108	29/08/2023	10:17	30/08/2023	20:55	Gas shortage	
MSPGCL	Koyna STG-IV Unit-4	250	30/08/2023	01:51	30/08/2023	04:15	Unit 4 governor oil sump tank temperature very high.	30/08/2023
MSPGCL	Koyna STG-IV Unit-4	250	30/08/2023	07:48	30/08/2023	10:15	Governor oil temp very high	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 29/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 30/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Tripping							
TIE BAY-420 OF ICT - 2 @ KORADI -2	IntraState	30/08/2023	10:00	30/08/2023	14:28	PO	1) Diagnostic testing of Circuit Breaker & Current Transformer at bay 420
400 KV MAINBAY Outages/Tripping							
MIAN BAY-421 OF ICT - 2 @ KORADI -2	IntraState	29/08/2023	10:38	29/08/2023	15:28	PO	1) Diagnostic testing of Circuit Breaker & Current Transformer at bay 421
400 KV LR Outages/Tripping							
LR of 400 kV-KHANDWA-DHULE Ckt -2	InterState	29/08/2023	10:29	29/08/2023	19:57	PO	Reactor AMP Work
400KV KORADI-BHUSAWAL (Koradi end)	IntraState	30/08/2023	06:20	30/08/2023	12:40	PO	Urgent string replacement work at Loc. No. 692 R phase due to a broken discs.
400 KV LINE Outages/Tripping							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49	30/08/2023	18:49	PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
DHULE - KHANDWA CKT - 2	InterState	29/08/2023	09:23	29/08/2023	19:57	PO	For Reactor AMP works KHANDWA-2 L/R@ DHULE-MS � as per OCC Sr. 937
PADGHE - BOISAR (PG)	InterState	29/08/2023	09:44	29/08/2023	21:09	HT	Outage by Powergrid
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of ȐYȐ phase Protection CT Of NTPP I (RPL 1)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	24/08/2023	06:20			HT	H/T to control loading
KHADKA-AURANGABAD (WALUJ)	IntraState	28/08/2023	20:12	29/08/2023	06:56	HT	H/T on overvoltage
DABHOL - NEW KOYNA CKT - 1	IntraState	29/08/2023	09:15	29/08/2023	19:55	PO	PID Faulty String insulators replacement
KHADKA-AURANGABAD (WALUJ)	IntraState	29/08/2023	21:16	30/08/2023	06:10	HT	H/T on Overvoltage
DABHOL - NEW KOYNA CKT - 1	IntraState	30/08/2023	11:20	30/08/2023	20:14	PO	PID Faulty String insulators replacement
PARLI-SOLAPUR (LAMBOTI)	IntraState	30/08/2023	11:21	30/08/2023	20:05	PO	(1) Main-1 distance relay testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work
KHADKA-AURANGABAD (WALUJ)	IntraState	30/08/2023	18:49			HT	H/T For Voltage management.
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	30/08/2023	05:38	30/08/2023	08:15	HT	Leakage attending work from R ph Neutral bushing
220 KV MAINBAY Outages/Tripping							
TBC @ HINJEWADI-2	IntraState	30/08/2023	09:22			PO	Half yearly maintenance
220 KV LINE Outages/Tripping							
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
AAREY - MSETCL BORIVALI CKT - 2	IntraState	15/08/2023	06:02			T	Tripped on Distance Protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 29/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 30/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
HINJAWADI I- CHINCHWAD	IntraState	29/08/2023	07:05	29/08/2023	19:00	PO	On. 24.08.23 Thursday a) Conductor paying out & Final sag (Location 160 to 161) ∩ Top Ckt b) Installation of Missing parts & final checking of Monopole (160 & 161) On. 25.08.23 Friday a) Conductor paying out & Final Sag (Location 161 a to 162) ∩ Top Ckt b) Installation of Missing parts & final checking of Monopole (161A&162) On. 26.08.23 Saturday Conductor paying out & Final sag(Location 161 to 161 A) ∩ Circuit I ∩ Top circuit On. 27.08.23 Sunday Conductor paying out & Final sag (Location 161 to 161 A) ∩ circuit ∩ II ∩ Top Circuit On. 28.08.23 Monday Conductor paying out & Final sag (Location 161 to 161 A) ∩ Circuit I ∩ Bottom Circuit On. 29.08.23 Tuesday Conductor paying out & Final sag (Location 161 to 161 A) ∩ circuit ∩ II ∩ Bottom Circuit
GHATGHAR - JINDAL	IntraState	29/08/2023	08:40	29/08/2023	19:30	PO	220kv Ghat-jindal line. For flashover disc Insulator replacement work at loc no 49,50. (B ph) 220KV Ghatghar-Washala line Required outage for safety to work on Jindal-Ghatghar line due to M/C tower.
WASHALA - GHATGHAR	IntraState	29/08/2023	08:44	29/08/2023	18:54	PO	220kv Ghat-jindal line. For flashover disc Insulator replacement work at loc no 49,50. (B ph) 220KV Ghatghar-Washala line Required outage for safety to work on Jindal-Ghatghar line due to M/C tower.
KEKATNIMBHORA - CHALISGAON CKT	IntraState	29/08/2023	09:28	29/08/2023	17:38	PO	Disc replacement work
PUSAD - HINGOLI	IntraState	29/08/2023	09:47	29/08/2023	11:11	PO	Routine Maintenance work
MALHARPETH SATARA MIDC	IntraState	29/08/2023	10:01	29/08/2023	16:51	PO	1.Quarterly Maintenance Work 2.B ph isolator to CT jump replacement work 3.LMU Replacement Work
BHAMBORI AMALNER	IntraState	29/08/2023	10:08	29/08/2023	13:09	PO	Routine Maintenance work
220 PARLI U-8 - NEW GCR PARLI CKT I	IntraState	29/08/2023	10:31	29/08/2023	16:13	PO	Testing work
220 KV GHATODI - HINGOLI	IntraState	29/08/2023	11:25	29/08/2023	13:07	PO	Routine Maintenance work
220KV HINGOLI -KURUNDA CKT	IntraState	29/08/2023	13:37	29/08/2023	17:48	PO	Routine Maintenance work
POPHLI PEDHMBE LINE- 2	IntraState	29/08/2023	13:37	29/08/2023	15:05	T	Bus fault @ pedambe
ADLABS - PEDAMBE	IntraState	29/08/2023	13:37	29/08/2023	15:21	T	Bus fault @ pedambe
MAIN BUS SECTION - 2 @ PEDAMBE	IntraState	29/08/2023	13:37	29/08/2023	14:44	T	Bus fault @ pedambe
PEDHAMBE ONI LINE	IntraState	29/08/2023	13:37	29/08/2023	15:10	T	Bus fault @ pedambe

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 29/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 30/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NERLE - PEDAMBE	IntraState	29/08/2023	13:37	29/08/2023	15:07	T	Bus fault @ pedambe
ALKUD - VITA	IntraState	29/08/2023	16:56	29/08/2023	23:31	PO	Chemical Washing of insulator strings
NEW KOYNA - PEDAMBE	IntraState	30/08/2023	08:42	30/08/2023	12:45	PO	To attend unwound conductor strands of B phase CT to LS isolator.
KARAD - NIGADE	IntraState	30/08/2023	09:19	30/08/2023	18:46	PO	Cold line washing of insulator strings
220 KV PARLI -U-8 - PARBHANI CKT	IntraState	30/08/2023	11:12	30/08/2023	14:06	PO	Replacement of R-ph Disc insulator string at Loc no. 291.
LOTEPARSHURAM- DASTURI LINE	IntraState	30/08/2023	14:39		Continued.	PO	For erection of new tower against rusted tower in lote (P) MIDC Area at loc no. 95, 96, 99, 102, 104
KANDALGAON - KOYNA (POPHALI)	IntraState	30/08/2023	14:41	30/08/2023	23:45	PO	For erection of new tower against rusted tower in Lote (P) MIDC Area at loc no. 95, 96, 99, 102, 104
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132-110 KV 100 MVA ICT 1	IntraState	29/08/2023	11:10	29/08/2023	16:36	PO	Oil leakage attending work
220/33 KV 50MVA PTR - 2 @ KALWAN	IntraState	29/08/2023	13:18	29/08/2023	19:13	PO	1) Annual relay testing work by MSETCL testing team.
220/132 KV 100 MVA ICT 2	IntraState	29/08/2023	14:27	29/08/2023	16:47	PO	Quarterly Maintenance work
220 / 105 / 33kv 250 MVA ICT 7 @ DHARAVI	IntraState	30/08/2023	08:17	30/08/2023	09:27	PO	PROJECT WORK-CSD Commissioning
220/132 KV 200 MVA ICT 1	IntraState	30/08/2023	09:57	30/08/2023	15:47	PO	Replacement of damaged jumper of Y-ph LV side - 3 nos. from CT to line isolator, CT to Auxiliary bus isolator CB to line isolator.
220/132KV 200MVA ICT 2 @ PANDHARPUR	IntraState	30/08/2023	10:00	30/08/2023	14:59	PO	Outage is required for OLTC OVERHAULLING WORK
220/33KV 25MVA PTR 1	IntraState	30/08/2023	10:23	30/08/2023	17:40	PO	For replacement of 33KV LVCT.
220/132-110 KV 100 MVA ICT 2	IntraState	30/08/2023	10:52	30/08/2023	17:50	PO	Oil Leakage attending work
220/33 KV 25MVA PTR2	IntraState	30/08/2023	17:54	30/08/2023	20:41	PO	For replacement of 33kv LV CT's
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
MAIN BUS - 1 @ PHALTAN MIDC- 220 KV	IntraState	30/08/2023	11:34			PO	220kv Bus PT Extension Work
132 KV LINE Outages/Trippings							
DHARANI - NEPANAGAR	InterState	29/08/2023	16:43	29/08/2023	17:48	T	Tripped on distance protection
KANHAN-PENCH	IntraState	29/08/2023	11:38	29/08/2023	17:14	EO	Over current earth fault relay is hanged and needs software updation on emergency basis by Testing unit Mankapur at 220kv Kanhan SS end.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage