

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 29/Sep/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	122.296	3327.407	1) Gujrat	13.017	291.481
2) Hydro	7.106	324.722	2) Madhya Pradesh	5.141	135.855
3) Gas	1.997	73.832	3) Chattisgarh	5.100	107.640
Total MSPGCL	131.399	3725.961	4) Maharashtra	163.560	4368.213
B) 1) APMIL	62.606	1820.598	5) Goa (Amona)	-0.735	-34.048
2) JSWEL	17.807	523.552	Total	186.083	4869.141
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.975	937.158
4) RPL(AMT)	25.196	507.908	b) Mumbai Drawl	34.873	1034.620
5) SWPGPL	7.655	146.048	c) MSEDCL Bilateral *	61.565	1687.691
6) Other IPP	4.564	158.420	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.975	936.942
C) 1) TPCL Thermal	11.901	323.012	Include PX	0.000	0.000
2) TPCL Hydro	4.408	145.655	Standby	0.000	0.215
3) TPCL Gas	2.353	24.889	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.502	259.904	1) MSEDCL	411.022	11303.770
D) STATE			2) Mumbai Discoms	63.037	1788.081
1) Thermal	261.527	7066.849	3) Other Discoms	9.412	261.613
(A1+C1+C4+(B1-B6))			TOTAL STATE	483.471	13353.464
2) Hydro (A2+C2)	11.514	470.377			
3) Gas (A3+B7+C3)	4.350	98.721			
4) Wind	8.781	588.159			
6) SOLAR	11.216	260.216			
TOTAL STATE	297.388	8484.322			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5027	4783	5665	4773
MSPGCL Hydro	198	143	1507	160
MSPGCL Gas	86	71	84	87
MSPGCL Total Generation	5311	4997	7256	5020
Central Sector Receipt	9031	8696	6718	6888
WIND	159	94	431	395
CPP / IPP Thermal	4633	4471	5887	4611
CPP / IPP Gas	0	0	0	0
SOLAR	1271	1456	0	0
Exchange with Mumbai	-1737	-1946	-1300	-977
MSEDCL DEMAND MET	18229	17354	18573	15660
Load Shedding	0	0	0	0
MSEDCL DEMAND	18229	17354	18573	15660
TPCL GENERATION	755	728	1200	550
AEML GENERATION	484	488	471	306
MUMBAI DEMAND	2976	3162	2971	1833
OTHER DISCOM DEMAND	439	414	419	277
STATE DEMAND MET	21644	20930	21963	17770
STATE DEMAND	21644	20930	21963	17770
Frequency (Hz)	50.00	50.01	50.00	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.12 Hz at 12.01 Hrs	49.77 Hz at 18.15 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 29/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	39.35	0	0
Unit 7	0.00	0.00	0	0
Unit 8	9.96	284.33	465	313
Unit 9	9.07	77.90	410	325
Unit 10	10.04	289.00	460	381
Total	29.07	690.58		
Bhusawal				
Unit 3	0.06	57.81	40	0
Unit 4	7.11	236.06	355	230
Unit 5	8.54	90.87	415	285
Total	15.72	384.74		
Parli				
Unit 6	4.80	126.41	235	146
Unit 7	4.41	105.28	217	140
Unit 8	3.34	105.28	159	126
Total	12.56	336.96		
Chandrapur				
Unit 3	3.31	85.95	161	122
Unit 4	3.03	87.30	162	0
Unit 5	5.65	156.15	315	155
Unit 6	7.85	170.86	400	290
Unit 7	3.12	166.22	322	0
Unit 8	0.00	49.00	0	0
Unit 9	9.15	268.34	439	282
Total	32.12	983.82		
Paras				
Unit 3	4.97	130.28	225	162
Unit 4	0.00	86.15	0	0
Total	4.97	216.42		
Khaparkheda				
Unit 1	2.85	77.58	135	110
Unit 2	2.37	46.40	115	85
Unit 3	3.57	92.37	167	129
Unit 4	3.30	87.98	176	115
Unit 5	8.44	234.84	430	270
Total	20.53	539.17		
Nasik				
Unit 3	1.93	34.49	139	0
Unit 4	2.97	59.70	144	103
Unit 5	2.44	81.51	135	0
Total	7.33	175.70		
Uran				
All Units	2.00	73.83	90	66
Total	2.00	73.83		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	15.09	25	25
Total	0.60	15.09		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.70	64.04	345	35
Stage 4	1.50	53.64	893	0
Stage 3	0.77	30.62	240	0
Total	3.97	148.31		
Hydro				
KDPH	0.20	7.61	18	0
VTRNA	0.00	19.47	0	0
TILLARI	0.00	12.89	0	0
BHIRA T.R.	0.33	11.13	60	0
SMLHY_PTN	2.01	104.21	89	80
GHATGHAR	0.00	6.01	0	0
Total	2.54	161.32		
Wind				
Total	8.78	588.16	0	0
Total	8.78	588.16		
CPP				
APML(Mus)	62.61	1820.60	0	0
JSWEL(Mus)	17.81	523.55	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.20	507.91	0	0
SWPGPL-Mus	7.66	146.05	0	0
Other(Mus)	4.56	158.42	0	0
Total	117.83	3156.53		
SOLAR				
Total	11.22	260.22	0	0
Total	11.22	260.22		
Tata				
Trombay 5	8.01	217.23	453	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.30	15.56	74	40
Trombay 7B	1.05	9.33	54	35
TATA Hydro	4.41	145.66	420	37
Trombay 8	3.89	105.78	233	131
Total	18.66	493.56		
AEML				
DTPS U-1&2	9.50	259.90	488	298
Total	9.50	259.90		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	122.30	3327.41	MSPGCL Total	131.40	3725.96
			MSPGCL Thml+Gas	124.29	3401.24	Koyna 1,2 & 4 Total	3.20	117.69
			MSPGCL Hydro	7.11	324.72	State Total	297.39	8484.32

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 29/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4841	160	87	5088	428	4602	0	0	7090	7119	-1147	15740	0	15740	2220	350	18310	50.00
2	4643	251	86	4980	438	4613	0	0	6782	6974	-1077	15609	0	15609	2042	319	17970	49.96
3	4942	160	86	5188	415	4637	0	0	6820	6710	-1040	15616	0	15616	1907	294	17817	49.99
4	4773	160	87	5020	395	4611	0	0	6862	6888	-977	15660	0	15660	1833	277	17770	49.99
5	5123	161	88	5372	407	4839	0	0	6919	7222	-969	16569	0	16569	1825	302	18696	49.99
6	5191	165	87	5443	411	5331	0	0	7382	7323	-989	17179	0	17179	1937	340	19456	50.00
7	5219	161	89	5469	378	5474	0	40	7984	8219	-1010	18191	0	18191	2103	379	20673	49.97
8	5228	205	90	5523	282	5031	0	357	9062	9215	-1378	18635	0	18635	2315	395	21345	50.00
9	5313	205	89	5607	240	4916	0	827	8815	8693	-1742	18106	0	18106	2665	435	21206	49.99
10	5027	198	86	5311	159	4633	0	1271	9029	9031	-1737	18229	0	18229	2976	439	21644	50.00
11	4772	199	76	5047	98	4518	0	1476	8967	9165	-1935	17920	0	17920	3167	449	21536	49.98
12	4939	154	66	5159	88	4587	0	1499	9079	8816	-2060	17661	0	17661	3293	428	21382	50.02
13	4783	143	71	4997	94	4471	0	1456	8779	8696	-1946	17354	0	17354	3162	414	20930	50.01
14	4699	147	70	4916	110	4401	0	1461	8806	8788	-2134	17142	0	17142	3049	400	20591	50.01
15	4804	143	80	5027	289	4495	0	1260	8954	8597	-2063	17207	0	17207	2960	398	20565	50.02
16	4690	144	82	4916	445	4595	0	925	8904	8639	-2095	17012	0	17012	3031	413	20456	49.97
17	4765	175	83	5023	670	4624	0	489	8385	8382	-1878	16887	0	16887	2993	423	20303	50.01
18	5334	286	83	5703	686	4965	0	154	7660	7148	-1499	16709	0	16709	2986	448	20143	49.98
19	5708	897	83	6688	444	5728	0	1	6908	6884	-1333	17963	0	17963	2982	449	21394	49.90
20	5665	1507	84	7256	431	5887	0	0	6719	6718	-1300	18573	0	18573	2971	419	21963	50.00
21	5605	662	84	6351	619	5805	0	0	6550	6396	-1167	17553	0	17553	2809	451	20813	50.03
22	5508	408	88	6004	506	5331	0	0	6874	6794	-1207	17018	0	17018	2741	410	20169	50.01
23	5375	203	86	5664	387	4912	0	0	6979	6850	-1033	16382	0	16382	2575	398	19355	49.98
24	5349	212	86	5647	361	4822	0	0	6631	6816	-1157	16108	0	16108	2495	381	18984	49.93
MUs	122.30	7.11	2.00	131.40	8.78	117.83	0.00	11.22	186.94	186.08	-34.87	411.02	0.00	411.02	63.04	9.41	483.47	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 29/Sep/2022

Position as on 6.30 Hrs of 30/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	01/10/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	01/10/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35		Continued.	Tripped on Furnace Pressure High(converted to Overhaul)	03/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Nasik Unit 3	210	17/09/2022	23:59	29/09/2022	07:20	wet coal	
IPP	RPL(AMT) U-2	270	18/09/2022	13:44		Continued.	Bottom Ash Evacuation problem.	03/10/2022
MSPGCL	Bhusawal Unit 3	210	26/09/2022	16:08	29/09/2022	21:58	Boiler Tube Leakage	30/09/2022
MSPGCL	Uran Unit 5	108	27/09/2022	17:11		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	28/09/2022	13:40	29/09/2022	12:11	SUPERHEATER (PRESSURE PARTS) SPRAY VALVE HEAVY LEAKAGE	29/09/2022
MSPGCL	Nasik Unit 5	210	29/09/2022	21:00		Continued.	Leakage Work	01/10/2022
MSPGCL	Chandrapur Unit 4	210	29/09/2022	22:09	30/09/2022	01:19	System problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 29/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 30/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	30/09/2022	01:37	30/09/2022	09:21	EO	To attend the Hotspot on Pole-2 Earth rod, P2 B phTF A , P2 Y ph TF 2B
400 KV TIEBAY Outages/Trippings							
TBC @ PADGHE	IntraState	29/09/2022	10:33	29/09/2022	20:42	HT	maintenance work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
PARLI(MS) - PARLI (PG) CKT -1	InterState	28/09/2022	11:36	29/09/2022	01:11	PO	AMP of line terminal equipment at Parli SS. Dia to be kept open for relay testing at Parli SS. A/R of 400kV Parli-Parli M-2 to be in non Auto.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	27/09/2022	10:25			HT	for load management
TBC @ PARLI	IntraState	29/09/2022	11:13	29/09/2022	16:52	PO	(1) relay testing. (2)Bay maintenance work.
TBC @ KORADI-1	IntraState	29/09/2022	11:52	29/09/2022	13:50	PO	To carry out TBC brekaer changeover trail of GT-6
NAGOTHANE - DABHOL CKT - 2	IntraState	29/09/2022	15:38	29/09/2022	22:59	EO	Oil likage on B-ph and hotspot on line isolator towards CT side R-ph
PADGHE - NAGOTHANE CKT - 2	IntraState	29/09/2022	18:52			T	Tripped on DP
400 KV ICT Outages/Trippings							
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	26/09/2022	11:32				Oil filtration, Oil leakage attending, Electrical Testing and painting of Station Transformer -8A Station Transformer -8A Bus duct servicing, maintenance and below replacement
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	26/09/2022	07:44			HT	for load management on Nashik BBLR
GOREGAON - AAREY CKT - 2	IntraState	29/09/2022	09:08	29/09/2022	16:15	PO	Under MMRC Line Diversion scheme for Metro-3 project Tightening of loose jumper connection observed during routine inspection.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	29/09/2022	09:55	29/09/2022	18:59	HT	For load management
THEUR- MAGAR PATTI CITY	IntraState	29/09/2022	09:58	29/09/2022	11:24	PO	Dismantling of existing 220kV Main Bus Section Isolator-2 & Bus to Bus rejumping work by Hotline unit so as to enable the work of foundation erection & commissioning of 245kV Hybrid switchgear.
THEUR- MAGAR PATTI CITY	IntraState	29/09/2022	09:58	29/09/2022	11:22	EO	Dismantling of existing 220kV Main Bus Section Isolator-2 & Bus to Bus rejumping work by Hotline unit so as to enable the work of foundation erection & commissioning of 245kV Hybrid switchgear.
LONIKAND (400 KV)-THEUR I	IntraState	29/09/2022	10:03	29/09/2022	11:22	EO	Dismantling of existing 220kV Main Bus Section Isolator-2 & Bus to Bus rejumping work by Hotline unit so as to enable the work of foundation erection & commissioning of 245kV Hybrid switchgear.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 29/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 30/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
LONIKAND (400 KV)-THEUR I	IntraState	29/09/2022	10:03	29/09/2022	11:22	PO	Dismantling of existing 220kV Main Bus Section Isolator-2 & Bus to Bus rejumping work by Hotline unit so as to enable the work of foundation erection & commissioning of 245kV Hybrid switchgear.
EKLAHARE (OCR) - PADGHE	IntraState	29/09/2022	10:33			PO	CB overhauling work
RANJANGAON - U TECH SUGAR CKT	IntraState	29/09/2022	11:05	29/09/2022	11:50	PO	Work of replacement of weak disc insulator strings found in PID Test at Loc No 298 (R Ph), 300 (Y Ph) & Broken Disc Insulator String at Loc No 216 (Y Ph) & 332 (Y Ph)
LONAND-BARAMATI	IntraState	29/09/2022	11:12	29/09/2022	12:42	PO	To increase ground clearance between loc. No.4 to 14 of B phase the work of conductor restring.
RANJANGAON-LONIKAND	IntraState	29/09/2022	11:28	29/09/2022	11:50	T	Distance Protection
TALOJA - PANCHANAND	IntraState	29/09/2022	11:31	29/09/2022	19:18	EO	To attend hotspot at Loc. Nos. 641, 647, 652/1, LILO Loc & 65533; 06, 12 & 14 by nut bolt replacement & by R ph conductor replacement between loc no. 14 to 15
BORIVALI - TARAPUR	IntraState	29/09/2022	12:39	29/09/2022	19:20	PO	Work of replacement of rusted hardware in balance span at location 28-50.
LONIKAND (400 KV)-THEUR I	IntraState	29/09/2022	17:28	29/09/2022	18:14	HT	For Emergency outage of Main bus section 3 @ Theur
THEUR-PHURSUNGI CKT II	IntraState	29/09/2022	17:28	29/09/2022	18:18	HT	For Emergency outage of Main bus section 3
THEUR-PHURSUNGI CKT I	IntraState	29/09/2022	17:28	29/09/2022	18:18	HT	For Emergency outage of Main bus section 3
PHURSUNGI-SERUM	IntraState	29/09/2022	17:28	29/09/2022	18:20	HT	For Emergency outage of Main bus section 3 @ Theur
TROMBAY - DHARAVI 9	IntraState	29/09/2022	17:43	30/09/2022	04:05	HT	For Emergency outage of Main bus section 2 @ Trombay tata
TROMBAY MSETCL TIE - 2	IntraState	29/09/2022	17:47	30/09/2022	03:57	HT	For Emergency outage of Main bus section 2 @ Trombay tata
TROMBAY MSETCL TIE - 1	IntraState	29/09/2022	17:48	30/09/2022	03:53	HT	For Emergency outage of Main bus section 2 @ Trombay tata
BUS - 2 @ TROMBAY	IntraState	29/09/2022	17:48	30/09/2022	03:53	EO	Main Bus 2 outage will be required as Tie line 1 traverses above Main Bus 2 and during attending Tie 1 Gantry string insulator
THEUR- MAGAR PATTI CITY	IntraState	29/09/2022	18:34	29/09/2022	18:52	HT	For Emergency outage of Main bus section 3 @ Theur
LONIKAND (400 KV)-THEUR I	IntraState	29/09/2022	18:34	29/09/2022	18:53	HT	For Emergency outage of Main bus section 3 @ Theur
KARAD - VITA CKT- 2	IntraState	30/09/2022	08:03			PO	For wiring, commissioning & charging of new 220 kV CGL make CB (200SFM50AA Sr No-58661C & taking load on own bay after charging of 220 kV CB
GOREGAON - AAREY CKT - 1	IntraState	30/09/2022	09:57			PO	Under MMRC Line Diversion scheme for Metro-3 project Tightening of loose jumper connection observed during routine inspection.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/132KV 200MVA ICT 2 @ PANDHARPUR	IntraState	28/09/2022	15:12	29/09/2022	00:40	PO	Outage is required for HV SIDE 220KV CB OVERHAULLING WORK

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 29/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 30/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 1 @ VASAI	IntraState	28/09/2022	21:00	29/09/2022	04:46	T	Tripped on differential protection since LV CB (GIS) blast
220/22 KV 50 MVA PTR 2 @ VASAI	IntraState	28/09/2022	22:20	29/09/2022	04:45	HT	to convert Outgoing 6 & 7 panel as Incomer-1 & 2 panel respectively.
220/132 KV 100 MVA ICT - 2 @ ALEPHATA	IntraState	29/09/2022	08:12	29/09/2022	11:27	PO	For CB timing and general maintenance work.
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	29/09/2022	11:00	29/09/2022	12:48	PO	ISOLATION OF TBC ISOLATOR OF ICT BAY BY REMOVING JUMPERS TO REPLACE ISOLATOR.
220/132 KV 100 MVA ICT - 1 @ ALEPHATA	IntraState	29/09/2022	11:45	29/09/2022	19:09	PO	For CB timing and general maintenance work.
220/33KV 50MVA PTR 2 @ BARAMATI	IntraState	29/09/2022	11:47	29/09/2022	15:00	PO	RELAY & DIAGNOSTIC TESTING WORK
220/33KV 50MVA PTR NO 1 @ BARAMATI	IntraState	29/09/2022	15:12	29/09/2022	18:59	PO	RELAY & DIAGNOSTIC TESTING WORK
250 MVA ICT-5 @ TROMBAY	IntraState	29/09/2022	17:42	30/09/2022	05:00	HT	For Emergency outage of Main bus section 2 @ Trombay tata
220 KV BUSBAR Outages/Trippings							
MAIN BUS SECTION - 2 @ THEUR	IntraState	29/09/2022	10:10	29/09/2022	18:52	PO	Dismantling of existing 220 kV Main Bus Section Isolator-2 and Bus to Bus re-jumpering work by Hotline unit so as to enable the work of foundation erection and commissioning of 245 kV Hybrid switchgear.
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
KHOPOLI - BHIVPURI CKT - 2	IntraState	30/09/2022	09:32			PO	attending hot spot on c ph vertical dropper at Khopoli

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage