

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 29/Dec/2020 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	145.848	4062.234	1) Gujrat	4.260	52.668
2) Hydro	8.283	270.889	2) Madhya Pradesh	8.041	201.465
3) Gas	5.736	183.861	3) Chattisgarh	5.760	176.620
Total MSPGCL	159.867	4516.984	4) Maharashtra	156.667	4106.109
B) 1) APLM	15.715	1331.867	5) Goa (Amona)	-0.740	-37.206
2) JSWEL	18.733	529.715	Total	173.988	4499.656
3) VIPL	0.000	0.000	a) Mumbai Schedule	14.317	485.396
4) RPL(AMT)	24.365	266.792	b) Mumbai Drawl	14.998	553.483
5) WPCL	6.139	212.667	c) MSEDCL Bilateral *	47.752	1094.705
6) Other IPP	18.023	509.086	Include PX	20.108	303.362
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	14.317	484.419
C) 1) TPCL Thermal	13.499	387.340	Include PX	8.573	275.303
2) TPCL Hydro	3.694	90.868	Standby	0.000	0.978
3) TPCL Gas	2.690	100.546	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.808	270.096	1) MSEDCL	414.348	11817.445
D) STATE			2) Mumbai Discoms	44.689	1402.332
1) Thermal	252.130	7569.797	TOTAL STATE	459.037	13219.777
(A1+C1+C4+(B1-B6))					
2) Hydro	11.977	361.757			
(A2+C2)					
3) Gas	8.426	284.407			
(A3+B7+C3)					
4) Wind	6.116	318.486			
6) SOLAR	6.400	185.675			
TOTAL STATE	285.049	8720.122			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6304	6322	6230	5503
MSPGCL Hydro	938	232	572	70
MSPGCL Gas	261	250	213	280
MSPGCL Total Generation	7502	6804	7014	5854
Central Sector Receipt	9083	9067	6588	5735
WIND	226	120	131	286
CPP / IPP Thermal	3920	3762	3908	2998
CPP / IPP Gas	0	0	0	0
SOLAR	864	999	3	0
Exchange with Mumbai	-712	-672	-647	-407
MSEDCL DEMAND MET	20884	20081	16997	14466
Load Shedding	0	0	0	0
MSEDCL DEMAND	20884	20081	16997	14466
TPCL GENERATION	1086	1086	1082	600
AEML GENERATION	499	501	499	283
MUMBAI DEMAND	2297	2259	2228	1290
STATE DEMAND MET	23180	22340	19225	15756
STATE DEMAND	23180	22340	19225	15756
Frequency (Hz)	50.01	50.02	50.03	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.2 Hz at 06.02 Hrs	49.87 Hz at 03.12 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation, Maximum, Minimum for 29/Dec/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.20	68.26	150	120
Unit 7	2.72	45.16	140	90
Unit 8	12.66	354.10	572	490
Unit 9	12.39	252.61	530	485
Unit 10	0.00	17.23	0	0
Total	30.98	737.37		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.85	286.60	480	405
Unit 5	0.00	252.84	0	0
Total	10.85	539.45		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.30	145.01	250	169
Unit 7	5.24	147.26	250	162
Unit 8	5.43	141.81	250	169
Total	15.97	434.09		
Chandrapur				
Unit 3	3.73	95.89	170	120
Unit 4	3.63	103.73	157	140
Unit 5	9.74	264.42	430	280
Unit 6	9.60	231.07	430	290
Unit 7	10.16	165.33	454	268
Unit 8	0.00	208.25	0	0
Unit 9	11.87	295.53	500	484
Total	48.72	1364.21		
Paras				
Unit 3	5.38	136.19	240	196
Unit 4	5.00	138.56	231	152
Total	10.38	274.75		
Khaparkheda				
Unit 1	3.32	98.14	150	125
Unit 2	4.00	109.70	180	145
Unit 3	4.14	30.10	177	154
Unit 4	4.35	120.28	193	140
Unit 5	9.60	260.86	430	370
Total	25.41	619.08		
Nasik				
Unit 3	0.00	7.70	0	0
Unit 4	3.54	85.59	198	126
Unit 5	0.00	0.00	0	0
Total	3.54	93.29		
Uran				
All Units	5.74	183.86	293	140
Total	5.74	183.86		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.54	5.92	27	11

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.54	5.92		
Koyna				
Stage 1-2	0.96	88.88	145	0
Stage 4	3.86	79.52	750	0
Stage 3	0.71	36.24	160	0
Total	5.53	204.65		
Hydro				
KDPH	0.44	9.04	19	19
VTRNA	0.00	0.00	0	0
TILLARI	0.00	1.83	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.26	5.44	40	0
RNGR+BHTSA	0.36	10.20	16	15
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.27	0.37	15	7
SMLHY_PTN	0.22	11.77	10	9
GHATGHAR	1.20	27.59	250	0
Total	2.75	66.24		
Wind				
Total	6.12	318.49	0	0
Total	6.12	318.49		
CPP				
APML(Mus)	15.72	1331.87	0	0
JSWEL(Mus)	18.73	529.72	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	24.36	266.79	0	0
WPCL(Mus)	6.14	212.67	0	0
Other(Mus)	18.02	509.09	0	0
Total	82.98	2850.13		
SOLAR				
Total	6.40	185.68	0	0
Total	6.40	185.68		
Tata				
Trombay 5	8.90	256.42	463	278
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.59	61.97	117	49
Trombay 7B	1.10	38.58	66	39
Trombay 8	4.60	130.92	233	135
TATA Hydro	3.69	90.87	321	0
Total	19.88	578.75		
AEML				
DTPS U-1&2	9.81	270.10	501	282
Total	9.81	270.10		

* Infirm Power		
Particulars	Daily (Mus)	Monthly

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	145.85	4062.23
MSPGCL Thml+Gas	151.58	4246.10
MSPGCL Hydro	8.28	270.89

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	159.87	4516.98
Koyna 1,2 & 4 Total	4.82	168.41
State Total	285.05	8720.12

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 29/Dec/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDING	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5687	52	230	5968	249	3009	0	0	5834	5877	-589	14514	0	14514	1471	15986	50.01
2	5985	66	270	6322	296	3002	0	0	6012	5440	-492	14567	0	14567	1368	15935	49.98
3	5620	70	279	5970	327	3019	0	0	6078	5700	-447	14569	0	14569	1311	15880	49.99
4	5503	70	280	5854	286	2998	0	0	6045	5735	-407	14466	0	14466	1290	15756	50.01
5	5582	70	270	5922	322	3020	0	0	6311	6405	-411	15257	0	15257	1294	16551	49.99
6	5911	70	290	6272	333	3054	0	0	7095	6819	-494	15984	0	15984	1370	17354	49.97
7	6104	82	269	6456	402	3110	0	4	8034	7943	-530	17384	0	17384	1479	18863	50.00
8	6221	534	280	7036	438	3520	0	66	8227	8064	-343	18780	0	18780	1643	20423	50.01
9	6270	974	292	7536	365	3922	0	323	8043	8350	-469	20028	0	20028	1882	21910	50.02
10	6328	1280	293	7902	349	3905	0	619	8279	8159	-624	20310	0	20310	2118	22428	50.02
11	6294	1260	252	7806	337	3878	0	849	8632	8577	-693	20753	0	20753	2268	23021	50.01
12	6304	938	261	7502	226	3920	0	864	9143	9083	-712	20884	0	20884	2297	23180	50.01
13	6322	232	250	6804	120	3762	0	999	9156	9067	-672	20081	0	20081	2259	22340	50.02
14	6232	118	260	6610	81	3482	0	954	9174	9067	-678	19516	0	19516	2151	21666	50.01
15	6166	228	248	6642	77	3444	0	792	9276	9364	-688	19630	0	19630	2142	21772	49.93
16	6146	138	259	6542	71	3818	0	555	9038	8947	-593	19340	0	19340	2141	21481	49.91
17	6134	240	259	6632	64	3692	0	287	8627	7979	-564	18091	0	18091	2146	20237	49.87
18	6219	516	251	6986	84	3898	0	85	7146	6852	-560	17345	0	17345	2154	19499	50.00
19	6230	572	213	7014	131	3908	0	3	6380	6588	-647	16997	0	16997	2228	19225	50.03
20	6239	368	140	6746	159	3872	0	0	6344	6234	-659	16353	0	16353	2206	18559	50.05
21	6070	98	150	6318	161	3358	0	0	6377	6418	-879	15375	0	15375	2117	17492	50.03
22	6191	152	150	6494	297	3170	0	0	6066	6273	-1058	15176	0	15176	1947	17123	50.01
23	6152	78	140	6370	431	3176	0	0	5918	5579	-966	14589	0	14589	1774	16363	50.01
24	5938	78	150	6166	510	3040	0	0	5868	5468	-823	14361	0	14361	1633	15994	49.99
MUs	145.85	8.28	5.74	159.87	6.12	82.98	0.00	6.40	177.10	173.99	-15.00	414.35	0.00	414.35	44.69	459.04	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 29/Dec/2020

Position as on 6.30 Hrs of 30/Dec/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-2	250	23/11/2020	08.00		Continued.	Capital Overhaul	
MSPGCL	Chandrapur Unit-8	500	20/12/2020	00.00		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
IPP	JSW (J) U2	300	01/11/2020	04.44		Continued.	No Schedule	
MSPGCL	Nasik Unit 3	210	03/12/2020	06.45		Continued.	Economizer Tube Leakage. (Zero Schedule from 18:45hrs of 05.12.2020)	
IPP	Adani U-4	660	15/12/2020	23.48		Continued.	Zero schedule.	
IPP	Adani U-5	660	16/12/2020	03.50		Continued.	Zero schedule.	
IPP	Adani U-1	660	16/12/2020	10.58		Continued.	Withdrawal For RSD.	
IPP	Adani U-3	660	23/12/2020	23.59		Continued.	Turbine Bearing Vibration.	
MSPGCL	Bhusawal Unit 5	500	24/12/2020	21.15		Continued.	Due to clinker formed inside the bottom ash hopper	
MSPGCL	Koradi Unit 10	660	25/12/2020	10.56		Continued.	Boiler Tube Leakage	
CPP	SWPGL U-3	135	28/12/2020	00.00		Continued.	ID Fan Problem	
MSPGCL	Koyna Unit 6	80	28/12/2020	12.00	29/12/2020	01.30	Bus Bar Protection operated	
MSPGCL	Koyna Unit 2	70	28/12/2020	12.10	30/12/2020	20.35	Bus Bar Protection operated	
MSPGCL	Koyna Unit 3	70	28/12/2020	12.10	30/12/2020	20.50	Bus Bar Protection operated	
MSPGCL	Koyna Unit 7	80	28/12/2020	12.10	29/12/2020	02.10	Bus Bar Protection operated	
MSPGCL	Koyna Unit 4	70	28/12/2020	12.10	30/12/2020	19.55	Bus Bar Protection operated	
MSPGCL	Koyna Unit 8	80	28/12/2020	12.10	29/12/2020	01.40	Bus Bar Protection operated	
MSPGCL	Koyna Unit 5	80	28/12/2020	12.10	30/12/2020	16.40	Bus Bar Protection operated	
MSPGCL	Koyna Unit 1	70	28/12/2020	12.10	30/12/2020	20.15	Bus Bar Protection operated	
MSPGCL	Uran Unit 5	108	29/12/2020	18.44		Continued.	Gas shortage	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 29/Dec/2020

Position as on 6.30 Hrs of 30/Dec/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit 6	210	30/12/2020	03.09	30/12/2020	08.16	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 6	500	30/12/2020	07.07		Continued.	Boiler Tube Leakage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 29/Dec/2020

Statement-VII

Position as on 6.30 Hrs of 30/Dec/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Ektuni - Akola II Ckt I	IntraState	30/12/2020	09.51	30/12/2020	19.36	PO	Annual Maintenance Work
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	28/12/2020	17.52	29/12/2020	09.35	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	29/12/2020	09.49	30/12/2020	09.05	PO	Replacement of damaged earthwire, Replacement PID suspicious disc insulator and other maintenance work.
Kolhapur(M)-Kolhapur(GIS) ckt1	InterState	29/12/2020	10.44	29/12/2020	19.59	PO	Annual Maintenance Work
Dhule Sar'Sarovar I	InterState	30/12/2020	19.22		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	16/09/2020	23.34		Continued.	HT	Over Voltage (Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Jaigad-Karad Ckt-I	IntraState	27/09/2020	18.59		Continued.	T	Distance Protection(Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Khadka-Aurangabad (Waluj)	IntraState	28/12/2020	19.34	29/12/2020	07.06	HT	Over Voltage
Dhule - Bableshwar - II	IntraState	28/12/2020	20.35	29/12/2020	06.44	HT	Over Voltage
New Koyna - Dabhol-I	IntraState	29/12/2020	04.13	29/12/2020	18.59	T	Over Voltage
Koradi-Khaperkheda li	IntraState	29/12/2020	11.05	29/12/2020	13.12	PO	Diagnostic Testing of Circuit Breaker.
Dhule - Bableshwar - II	IntraState	29/12/2020	19.39	30/12/2020	08.59	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt I	IntraState	29/12/2020	22.10	30/12/2020	05.38	EO	To Attending Hot Spot On Line Isolator.
Chandrapur - Khaperkheda	IntraState	30/12/2020	06.25		Continued.	PO	Reshifting of line from ERS to existing line for restoration.
Kala Kudus Ckt-I	IntraState	30/12/2020	11.05	30/12/2020	19.03	PO	AMP OF KALA KUDUS line 1 Equipments/Relay testing at Kudus End.
New Koyna - Dabhol-I	IntraState	30/12/2020	11.24		Continued.	T	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	30/12/2020	23.23		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/09/2020	09.58		Continued.	PO	Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220kv 315MVA ICT-III @ Kharghar	IntraState	28/12/2020	05.08	29/12/2020	00.18	HT	Air release
400/220 Kv 500 MVA ICT II @Lamboti	IntraState	29/12/2020	11.46	29/12/2020	14.30	EO	Attending Oil Leakage
400/220 Kv 500 MVA ICT II @Jejuri	IntraState	29/12/2020	12.24	29/12/2020	13.03	EO	As The Monkey is sitting on Radiator of B-PHASE Unit.
400/220 Kv 500 Mva Ict 1 @Lamboti	IntraState	30/12/2020	10.09	30/12/2020	16.40	PO	SFRA Testing.
400/220 KV 315MVA ICT II @ Parali (Girwali)	IntraState	30/12/2020	10.26	30/12/2020	17.15	PO	Bay maintenance work.
400/220 kV 500 MVA ICT III @ Jejuri	IntraState	30/12/2020	10.34	30/12/2020	12.51	PO	To investigate the imbalance in currents in 408 bay CTs
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Tillari Amona	InterState	29/12/2020	06.11	29/12/2020	06.41	T	Tripped at Amona end only
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 29/Dec/2020

Statement-VII

Position as on 6.30 Hrs of 30/Dec/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage	
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06			Continued.	PO	Erection of Tower Due to Railway Crossing
Trombay - Kalwa	IntraState	16/12/2020	06.43			Continued.	PO	HTLS work.
Chinchwad- Parvati	IntraState	21/12/2020	12.06			Continued.	PO	CB Overhauling work
Kandalgaon - Koyna (Pophali)	IntraState	28/12/2020	12.10	30/12/2020	20.10		T	Bus Fault at Pophali end
Koyna (Pophali) - Kdph	IntraState	28/12/2020	12.10	30/12/2020	20.45		T	Bus Fault at Pophali end
Pophli Pedhmbe Line- 1	IntraState	28/12/2020	12.10	30/12/2020	19.50		T	Bus Fault at Pophali end
Dahanu Ghodbunder Line 1	IntraState	29/12/2020	07.15			Continued.	PO	Shifting of line from its existing position to newly constructed temporary towers under DFCCIL Modification / Diversion works.(Tripped While Taking Into Service at 00.24 Hrs 30.12.2020).
WALCHANDNAGAR - PHALTAN MIDC	IntraState	29/12/2020	10.55	29/12/2020	14.45		PO	For CB Cabling and testing work.
Bombay Dyeing - Sahara	IntraState	29/12/2020	14.20	29/12/2020	15.45		PO	Emergency LA Replacement Work At 220Kv Sahara S/STN.
Trombay Salsette 1 Backbay	IntraState	30/12/2020	07.42	30/12/2020	21.19		PO	Replacement of 0.5 Moose ACSR conductor in span Gantry Structure to loc. 01 at Trombay end.
Kalmeshwar - JSW	IntraState	30/12/2020	09.33	30/12/2020	13.46		PO	AMR project work
Dhamangaon New- Tss -I	IntraState	30/12/2020	09.57	30/12/2020	12.05		PO	Isolator maintenance Work.
Ghugus- Lloyds	IntraState	30/12/2020	10.46	30/12/2020	16.17		PO	For diagnostic testing Work at ghugus & lloyds End.
Kharghar - Nerul	IntraState	30/12/2020	14.01	30/12/2020	18.18		EO	To attend Hot Spot
Lonand Sona Alloys	IntraState	30/12/2020	16.22	30/12/2020	18.43		PO	AMR meter commissioning
Kandalgaon - Sona Alloys	IntraState	30/12/2020	16.24	30/12/2020	17.47		PO	AMR meter commissioning
220 KV ICT Outages/Trippings								
220/100 Kv 100 Mva Cgl Ict 2 @Tambati	IntraState	27/12/2020	11.11			Continued.	PO	HV circuit Breaker overhauling
220/132kv 100MVA ICT II @Satara Midc	IntraState	29/12/2020	08.36	30/12/2020	01.43		PO	For attending oil leakage by cold welding work.
220/132kv 100mva Ict 1 @Peth	IntraState	29/12/2020	09.01	29/12/2020	12.42		PO	Neutral bushing base plate oil leakage attending work.
220/132 Kv 150 Mva Cgl Ptr No 7 @Chinchwad	IntraState	29/12/2020	09.50	29/12/2020	18.59		PO	OLTC overhauling.
220/100 Kv 200 MVA ICT-IV@Kalwa	IntraState	29/12/2020	11.54	29/12/2020	14.30		EO	To Attending CT Oil Leakage.
220/132 Kv 200 Mva Emco Ict 2 @Ambazari	IntraState	30/12/2020	09.24	30/12/2020	13.05		EO	Attending Oil Leakage
220/132 Kv 200mva Cgl Ptr No 3 @Chinchwad	IntraState	30/12/2020	10.35	30/12/2020	18.35		PO	OLTC overhauling.
220/132 KV 100MVA ICT-II @Walchandnagar	IntraState	30/12/2020	11.18	30/12/2020	18.19		PO	Diagnostic & Relay Testing Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage