

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 29/Dec/2021 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	123.275	3963.787	1) Gujrat	-6.081	-223.251
2) Hydro	8.436	226.859	2) Madhya Pradesh	5.294	46.728
3) Gas	2.220	140.523	3) Chattisgarh	6.730	169.080
Total MSPGCL	133.931	4331.169	4) Maharashtra	147.567	3963.625
B) 1) APLM	69.092	1810.577	5) Goa (Amona)	-1.597	-46.418
2) JSWEL	11.701	389.099	Total	151.913	3909.764
3) VIPL	0.000	0.000	a) Mumbai Schedule	19.577	703.692
4) RPL(AMT)	26.715	760.591	b) Mumbai Drawl	25.710	756.607
5) SWPGPL	5.917	215.752	c) MSEDCL Bilateral *	58.495	1439.341
6) Other IPP	38.830	1096.097	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	19.577	703.692
C) 1) TPCL Thermal	6.192	223.904	Include PX	0.000	3.902
2) TPCL Hydro	5.162	127.626	Standby	0.000	0.000
3) TPCL Gas	3.071	85.668	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.062	279.267	1) MSEDCL	414.518	11867.639
D) STATE			2) Mumbai Discoms	48.197	1473.065
1) Thermal	289.784	8739.074	3) Other Discoms	9.800	284.110
(A1+C1+C4+(B1-B6))			TOTAL STATE	472.515	13624.814
2) Hydro	13.598	354.485			
3) Gas	5.291	226.191			
4) Wind	6.131	220.606			
6) SOLAR	5.798	174.701			
TOTAL STATE	320.602	9715.057			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	5485	5367	5651	4302
MSPGCL Hydro	408	335	799	211
MSPGCL Gas	89	89	90	94
MSPGCL Total Generation	5982	5791	6540	4607
Central Sector Receipt	8286	7704	5828	5360
WIND	130	108	228	256
CPP / IPP Thermal	6793	6743	6942	5337
CPP / IPP Gas	0	0	0	0
SOLAR	894	916	0	0
Exchange with Mumbai	-1376	-1424	-1102	-811
MSEDCL DEMAND MET	17120	16275	14703	11978
Load Shedding	0	0	0	0
MSEDCL DEMAND	17120	16275	14703	11978
TPCL GENERATION	778	704	855	391
AEML GENERATION	328	311	444	318
MUMBAI DEMAND	2482	2439	2401	1520
OTHER DISCOM DEMAND	359	356	373	277
STATE DEMAND MET	23191	22277	20837	16269
STATE DEMAND	23191	22277	20837	16269
Frequency (Hz)	50.02	50.02	50.00	50.06

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.27 Hz at 03.01 Hrs	49.75 Hz at 05.10 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 29/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.44	103.43	175	115
Unit 7	0.00	0.00	0	0
Unit 8	0.00	336.83	0	0
Unit 9	0.00	237.40	0	0
Unit 10	12.40	377.70	553	415
Total	15.85	1055.37		
Bhusawal				
Unit 3	3.22	66.24	165	115
Unit 4	8.80	251.94	450	280
Unit 5	9.23	253.86	475	275
Total	21.26	572.04		
Parli				
Unit 6	4.25	66.04	211	153
Unit 7	4.12	47.92	209	148
Unit 8	4.30	99.56	218	151
Total	12.66	213.52		
Chandrapur				
Unit 3	3.50	71.84	165	122
Unit 4	2.94	92.46	136	115
Unit 5	7.74	172.14	390	289
Unit 6	9.19	229.21	450	265
Unit 7	7.41	221.88	330	281
Unit 8	0.60	219.25	213	0
Unit 9	10.23	271.55	465	306
Total	41.62	1278.33		
Paras				
Unit 3	4.17	125.42	224	135
Unit 4	4.18	126.83	223	138
Total	8.35	252.25		
Khaparkheda				
Unit 1	3.08	29.36	140	115
Unit 2	0.00	25.46	0	0
Unit 3	3.82	43.00	192	126
Unit 4	0.00	29.76	0	0
Unit 5	9.95	278.50	455	285
Total	16.85	406.08		
Nasik				
Unit 3	0.00	53.64	0	0
Unit 4	3.40	37.92	195	117
Unit 5	3.28	94.64	184	116
Total	6.68	186.21		
Uran				
All Units	2.22	140.52	115	87
Total	2.22	140.52		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.63	7.85	31	20
Total	0.63	7.85		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.06	65.06	440	35
Stage 4	0.69	25.99	255	0
Stage 3	0.39	20.64	160	0
Total	3.14	111.69		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.06	0	0
TILLARI	0.52	9.89	58	0
BHIRA T.R.	0.32	7.51	40	0
SMLHY_PTN	4.46	97.70	195	174
GHATGHAR	0.00	0.00	0	0
Total	5.30	115.17		
Wind				
Total	6.13	220.61	0	0
Total	6.13	220.61		
CPP				
APML(Mus)	69.09	1810.58	0	0
JSWEL(Mus)	11.70	389.10	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.72	760.59	0	0
SWPGPL-Mus	5.92	215.75	0	0
Other(Mus)	38.83	1096.10	0	0
Total	152.26	4272.12		
SOLAR				
Total	5.80	174.70	0	0
Total	5.80	174.70		
Tata				
Trombay 5	6.19	202.10	261	255
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.78	50.67	95	62
Trombay 7B	1.29	35.00	60	49
Trombay 8	0.00	21.80	0	0
TATA Hydro	5.16	127.63	441	0
Total	14.42	437.20		
AEMIL				
DTPS U-1&2	8.06	279.27	444	307
Total	8.06	279.27		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	123.28	3963.79	MSPGCL Total	133.93	4331.17
			MSPGCL Thml+Gas	125.50	4104.31	Koyna 1,2 & 4 Total	2.75	91.05
			MSPGCL Hydro	8.44	226.86	State Total	320.60	9715.06

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 29/Dec/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4307	215	115	4637	223	5292	0	0	5410	5536	-859	14536	0	14536	1613	293	16442	50.02
2	4302	211	94	4607	256	5337	0	0	5498	5360	-811	14472	0	14472	1520	277	16269	50.06
3	4530	212	93	4835	283	5424	0	0	5467	5430	-748	14971	0	14971	1448	253	16672	50.06
4	4578	232	94	4904	264	5371	0	0	5564	5240	-715	14819	0	14819	1399	245	16463	50.09
5	4575	230	95	4900	255	5561	0	0	5663	5543	-727	15258	0	15258	1413	274	16945	50.02
6	4654	228	94	4976	316	6435	0	0	5872	5766	-806	16377	0	16377	1494	310	18181	49.95
7	5111	305	96	5512	298	6667	0	2	5910	6079	-776	17452	0	17452	1613	330	19395	50.01
8	5738	507	94	6339	273	6817	0	84	6559	6513	-877	18791	0	18791	1784	358	20933	49.94
9	5837	458	94	6389	206	6720	0	295	7008	7017	-1067	19197	0	19197	2071	363	21631	49.97
10	5799	724	92	6615	110	6761	0	563	7451	7389	-1171	19898	0	19898	2328	369	22595	50.02
11	5788	531	91	6410	154	6847	0	788	8348	7785	-1310	20309	0	20309	2456	365	23130	50.04
12	5485	408	89	5982	130	6793	0	894	8372	8286	-1376	20350	0	20350	2482	359	23191	50.02
13	5367	335	89	5791	108	6743	0	916	7885	7704	-1424	19482	0	19482	2439	356	22277	50.02
14	4886	288	87	5261	115	6791	0	803	7716	8041	-1373	19301	0	19301	2302	337	21940	50.06
15	5184	295	87	5566	97	6760	0	691	7840	7907	-1372	19298	0	19298	2306	351	21955	50.02
16	5560	272	88	5920	122	6853	0	477	7379	7419	-1346	19077	0	19077	2309	368	21754	50.00
17	5681	278	89	6048	106	6951	0	251	6550	6552	-1225	18304	0	18304	2311	379	20994	50.01
18	5511	343	89	5943	122	6842	0	34	6072	5922	-1132	17345	0	17345	2333	386	20064	50.00
19	5651	799	90	6540	228	6942	0	0	5629	5828	-1102	18063	0	18063	2401	373	20837	50.00
20	5701	646	91	6438	300	6950	0	0	5550	5572	-1176	17708	0	17708	2355	376	20439	49.98
21	5567	227	92	5886	426	6766	0	0	5705	4872	-1150	16423	0	16423	2186	377	18986	50.04
22	4693	238	91	5022	614	6030	0	0	5696	5433	-1151	15591	0	15591	2034	357	17982	50.02
23	4398	230	93	4721	539	5405	0	0	5608	5408	-1069	14680	0	14680	1870	324	16874	49.98
24	4372	224	93	4689	586	5197	0	0	5485	5311	-947	14514	0	14514	1730	322	16566	49.99
MUs	123.28	8.44	2.22	133.93	6.13	152.26	0.00	5.80	154.24	151.91	-25.71	416.22	0.00	416.22	48.20	8.10	472.51	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 29/Dec/2021

Position as on 6.30 Hrs of 30/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 8	500	25/12/2021	00:01	29/12/2021	18:11	CW DEBRIS FILTER INSPECTION AND MAINTENENCE WORK	
IPP	SWPGL U-2	135	25/12/2021	00:09		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Koradi Unit 8	660	25/12/2021	09:56	30/12/2021	12:00	Boiler Tube Leakage	
MSPGCL	Nasik Unit 3	210	27/12/2021	20:30		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit 9	660	27/12/2021	23:45		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 4	210	28/12/2021	10:00		Continued.	Boiler Tube Leakage	31/12/2021
MSPGCL	Uran Unit 8	108	29/12/2021	00:27	30/12/2021	03:55	Withdrawn	
MSPGCL	Koyna STG-IV Unit-1	250	29/12/2021	01:07	29/12/2021	10:50	on speed disscrepancy measurement fault	
MSPGCL	Chandrapur Unit 8	500	29/12/2021	18:24	29/12/2021	20:16	GENERATOR DAVR,ULR OPERATED FIELD BREAKER OPEN DUE TO JERK ON BUS I & II	
MSPGCL	Koradi Unit 6	210	30/12/2021	11:26	30/12/2021	19:12	CONDENSER VACUUM LOW.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 29/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 30/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Tripping							
TIE BAY - 402 OF BUS REACTOR @ ALKUD	IntraState	29/12/2021	10:25	29/12/2021	17:43	PO	QM & DIAGNOSTIC TESTING WORK
400 KV MAINBAY Outages/Tripping							
MAIN BAY - 401 OF BUS REACTOR @ ALKUD	IntraState	29/12/2021	10:25	29/12/2021	17:53	PO	QM & DIAGNOSTIC TESTING WORK
MAIN BAY (404) OF KALA CKT 1 @ KUDUS	IntraState	29/12/2021	10:42	29/12/2021	15:35	PO	AMP OF 404 Main Bay of 400 KV Padghe Kudus Line 2 at Kudus MSETCL SS.
400 KV LINE Outages/Tripping							
PADGHA - BOISAR (PG)	InterState	30/12/2021	10:03		Continued.	PO	1) Bay maintenance work 2) Diagnostic Testing work 3) MTAMC work 4) replacement of main line Jumper from CT to Gantry
TBC 2 @ CHANDRAPUR	IntraState	20/12/2021	08:58			PO	1) For replacement of 400KV old overaged PG Isolators (Bus-1 & Aux. Bus Isolators.) 2) Servicing and overhauling of 400KV BHEL make quadruple CB. 3) Measurement of Timing, DCRM and CRM of CB.
TBC @ KORADI-1	IntraState	24/12/2021	13:40			EO	"Heavy air leakage in ABB make 400 kV CB R pole observed and CB got lockout due to 0 bar air pressure in CB. To attend the heavy air leakage of ABB make 400 kV CB R pole emergency outage is required on 400 kV TBC Bay ."
NEW KOYNA - DABHOL CKT - 1	IntraState	29/12/2021	03:00	29/12/2021	16:23	T	TRIPPED ON OVER VOLTAGE
125 MVAR BUS REACTOR @ ALKUD	IntraState	29/12/2021	09:40	29/12/2021	17:43	PO	QM & Diagnostic testing work
PADGHE - NAGOTHANE CKT - 1	IntraState	29/12/2021	10:03	30/12/2021	08:42	PO	1) For replacement /repair of C-Bus B-Ph PG Isolator as rotary insulator of isolator is damaged 2) Bay maintenance work
PADGHE - NAGOTHANE CKT - 2	IntraState	29/12/2021	12:58	29/12/2021	13:24	T	tripped while testing
CHANDRAPUR - KHAPERKHEDA	IntraState	30/12/2021	06:06		Continued.	PO	Restraining between loc.no. 8 & 16 for increasing ground clearance of conductor
JAIGAD - KARAD CKT - 1	IntraState	30/12/2021	20:47		Continued.	HT	over outage
LONIKAND I - KOYNA STAGE-IV	IntraState	30/12/2021	21:07		Continued.	HT	over voltage
400 KV ICT Outages/Tripping							
400/220/33 KV 500 MVA ICT - 3 @ JEJURI	IntraState	30/12/2021	11:12	30/12/2021	13:19	PO	ICT-III 220 kV CB testing.
400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	IntraState	30/12/2021	16:44	30/12/2021	16:43		For attending hot Spot on R & Y Ph. LV Side Bushings
220 KV LINE Outages/Tripping							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 29/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 30/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
BABHALESHWAR - UTECH SUGAR	IntraState	26/12/2021	22:30	29/12/2021	19:43	PO	29A, 29B isolator servicing and alignment and mechanism box replacement . Jump opening and reconnection for Main bus I and Main bus II by Hot line Unit,Nasik
WAGHIVALI - DHARAVI 7	IntraState	27/12/2021	08:16		Continued.	PO	FOR NMIA WORK
WAGHIVALI - DHARAVI 7	IntraState	27/12/2021	08:16		Continued.	PO	NMIA work
COLOURCHEM - TEMGHAR	IntraState	29/12/2021	08:18	30/12/2021	19:42	PO	To carry out erection of Monopole Structure at Loc no.18 and stringing work in between loc no.17 & 19 at M/s Lodha Paradise thane.
TALOJA II - OCIL 2	IntraState	29/12/2021	08:20	29/12/2021	19:55	PO	Bay maintenance work and testing of 220kV CT/PTs
MAIN BUS - 1 @ VERSOVA	IntraState	29/12/2021	09:10	29/12/2021	20:28	PO	1) Annual maintenance of 220kV Main Bus-1 side isolators and equipments. 2) Checking of alignment and maintenance of isolator 489A of Versova Ghodbunder Line i.e. Bay -4. 3) Checking of alignment and maintenance of isolator 1289A of Versova Goregaon Line-1i.e. Bay-12
ALKUD - VITA	IntraState	29/12/2021	09:10	29/12/2021	17:53	PO	Providing and fixing of suspension clamps at various locations
LAMBOTI - PANDHARPUR	IntraState	29/12/2021	10:15	29/12/2021	18:06	PO	Outages is required for Quarterly Maintenance
ANANDNAGAR - PALAVA	IntraState	29/12/2021	10:30	29/12/2021	13:16	EO	Attending Hotspot at Wavetrap R phase bottom side
BUS COUPLER @ VERSOVA	IntraState	29/12/2021	10:30	29/12/2021	20:28	PO	1)Facilitating outage of 220kV Main Bus 1. 2) Annual maintenance of Bus 1 connected isolator of Buscoupler bay.
NAGOTHANE - ACCIL	IntraState	29/12/2021	11:11	29/12/2021	17:43	PO	Routine maintenance work and emergency tree cutting work
PANDHARPUR - MALINAGAR	IntraState	29/12/2021	12:13	29/12/2021	15:01	PO	Outages is required for Quarterly Maintenance
KANDALGAON - PIRANGUT	IntraState	29/12/2021	13:00	29/12/2021	17:50	PO	Replacement of faulty LMU, Diagnostic testing work, Bay maintenance work
MUMEWADI -HALKARNI 1 LINE	IntraState	29/12/2021	16:29	29/12/2021	16:56	T	Tripped on Distance protection
BABLESHWAR-BABLESHWAR(400KV)-I	IntraState	29/12/2021	23:32		Continued.	PO	29A, 29B isolator servicing and alignment and mechanism box replacement . Jump opening and reconnection for Main bus I and Main bus II by Hot line Unit,Nasik

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 29/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 30/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VITA - KHANAPUR LINE	IntraState	30/12/2021	09:07	30/12/2021	17:38	PO	1. Cold line washing work 2. Restraining of conductor Loc No.150-166 3. Conversion of SSN to DSN work at Loc No.121,122,172,173,174
MAHAD - KANDALGAON	IntraState	30/12/2021	10:14	30/12/2021	14:25	PO	Leveling of Ground to maintain ground clearance at Loc.No.9-11 and other line maintenance work.
MAIN BUS - 2 @ VERSOVA	IntraState	30/12/2021	10:37	30/12/2021	19:20	PO	1. Annual maintenance of 220 kV Main Bus-2. 2. Checking of alignment and maintenance of isolator 189B of Versova Boisar Line i.e. Bay-1 3. Checking of alignment and maintenance of isolator 689B of 100 MVA Tr-1 i.e. Bay-6.
PHURSUNGI-PARVATI	IntraState	30/12/2021	12:05	30/12/2021	19:05	PO	1) Fixing repair sleeve due to conductor damaged between loc. no. 94-95, 95-96,82-83 2) Replacemenet of STN string at loc. No.9 due to string disc insulator broken.
BHIGWAN - SHIRSHUPHAL CKT	IntraState	30/12/2021	13:22	30/12/2021	18:53	PO	NT SWITCH REPLACEMENT WORK
KALWA - AIROLI KNOWLEDGE PARK	IntraState	30/12/2021	14:46	30/12/2021	18:58	EO	To Replace R ph LA as LCM values found high i.e 3720 micro amp.
MAHAD-KALAMBANI(TSS)	IntraState	30/12/2021	15:15	30/12/2021	19:30	PO	Leveling of Ground to maintain ground clearance at Loc.No.9-11 and other line maintenance work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	27/12/2021	09:41	29/12/2021	19:05	PO	1. Retrofitting of REF relay for MTAMC pending work 2. Diagnostic testing work 3. Painting of ICT
250 MVA ICT-4 @ TROMBAY	IntraState	29/12/2021	09:04	29/12/2021	22:10	PO	ATTENDIN HOT SPOT ON LINE SIDE GOD
220/132 KV 100MVA ICT - 1 @ MANMAD	IntraState	29/12/2021	10:00	29/12/2021	14:10	PO	Measurement of C & Tan Delta Values, SFRA & misc maintenance work.
220/100 KV 100MVA NO 4 @ CHINCHWAD	IntraState	29/12/2021	11:45	29/12/2021	17:30	PO	For CTR MAKE NIFPS Maintenance
220/22 KV 50 MVA PTR 1 @ WADKHAL (GIS)	IntraState	29/12/2021	11:54	29/12/2021	17:33	PO	For cold welding work for attending oil leakages
220/132 KV 100MVA ICT - 2 @ MANMAD	IntraState	29/12/2021	14:30	29/12/2021	17:30	PO	Measurement of C & Tan Delta Values, SFRA & misc maintenance work.
220/132 KV 200MVA ICT NO 1 @ THEUR	IntraState	30/12/2021	10:24	30/12/2021	16:44	PO	Half Yearly maintenance of HV LV bay work. NFPS maintenance work by M/s. CTR

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage