

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 29/Dec/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	167.933	4461.529	1) Gujrat	-5.443	-174.440
2) Hydro	18.465	347.919	2) Madhya Pradesh	3.738	49.563
3) Gas	3.247	119.577	3) Chattisgarh	6.310	154.750
Total MSPGCL	189.645	4929.025	4) Maharashtra	191.680	5048.933
B) 1) APLM	27.575	1703.836	5) Goa (Amona)	-1.309	-37.446
2) JSWEL	15.944	379.692	Total	194.976	5041.360
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.465	797.358
4) RPL(AMT)	25.536	806.683	b) Mumbai Drawl	27.232	926.333
5) SWPGPL	8.492	243.401	c) MSEDCL Bilateral *	83.382	2127.003
6) Other IPP	45.083	1280.358	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.465	796.853
C) 1) TPCL Thermal	11.409	322.482	Include PX	0.000	0.000
2) TPCL Hydro	4.050	109.726	Standby	0.000	0.504
3) TPCL Gas	1.780	44.636	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.026	283.680	1) MSEDCL	486.514	13775.901
D) STATE			2) Mumbai Discoms	53.498	1686.860
1) Thermal	310.998	9481.661	3) Other Discoms	9.600	273.155
(A1+C1+C4+(B1-B6))			TOTAL STATE	549.612	15735.916
2) Hydro	22.515	457.645			
3) Gas	5.027	164.213			
4) Wind	3.707	263.181			
6) SOLAR	12.388	327.853			
TOTAL STATE	354.635	10694.553			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	7338	7332	7080	6631
MSPGCL Hydro	1869	330	1632	110
MSPGCL Gas	133	131	135	137
MSPGCL Total Generation	9340	7793	8847	6878
Central Sector Receipt	8878	9618	7180	7298
WIND	106	79	96	168
CPP / IPP Thermal	5494	5147	5536	4828
CPP / IPP Gas	0	0	0	0
SOLAR	1630	1778	6	0
Exchange with Mumbai	-1184	-1526	-1054	-1157
MSEDCL DEMAND MET	23832	22480	20153	17620
Load Shedding	0	0	0	0
MSEDCL DEMAND	23832	22480	20153	17620
TPCL GENERATION	1052	721	1097	510
AEML GENERATION	501	499	493	297
MUMBAI DEMAND	2737	2746	2644	1964
OTHER DISCOM DEMAND	431	409	459	395
STATE DEMAND MET	27001	25635	23255	19979
STATE DEMAND	27001	25635	23255	19979
Frequency (Hz)	49.98	49.98	49.99	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 16.03 Hrs	49.46 Hz at 13.50 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 29/Dec/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	5.10	144.70	215	205
Unit 7	0.00	0.00	0	0
Unit 8	14.14	376.35	635	553
Unit 9	12.10	374.52	525	464
Unit 10	12.54	362.25	550	480
Total	43.88	1257.83		
Bhusawal				
Unit 3	3.30	27.83	160	70
Unit 4	10.90	295.92	495	355
Unit 5	9.82	295.64	455	300
Total	24.02	619.39		
Parli				
Unit 6	4.70	128.62	238	146
Unit 7	4.89	131.46	248	144
Unit 8	3.08	98.76	158	118
Total	12.67	358.85		
Chandrapur				
Unit 3	3.34	95.69	175	120
Unit 4	3.30	89.73	151	120
Unit 5	7.18	190.27	310	285
Unit 6	9.06	223.43	425	287
Unit 7	0.00	0.00	0	0
Unit 8	11.33	258.48	499	415
Unit 9	11.76	303.87	500	459
Total	45.97	1161.46		
Paras				
Unit 3	4.80	129.30	246	126
Unit 4	5.55	135.37	250	203
Total	10.35	264.67		
Khaparkheda				
Unit 1	2.92	80.46	130	110
Unit 2	3.19	80.64	146	117
Unit 3	3.84	102.69	179	128
Unit 4	3.39	94.49	152	128
Unit 5	11.50	261.42	490	460
Total	24.84	619.71		
Nasik				
Unit 3	0.00	23.31	0	0
Unit 4	3.20	91.63	149	120
Unit 5	3.02	64.68	139	114
Total	6.21	179.62		
Uran				
All Units	3.25	119.58	140	130
Total	3.25	119.58		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.31	5.26	46	0
Total	0.31	5.26		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	5.30	105.88	525	40
Stage 4	7.42	106.74	755	0
Stage 3	2.57	45.89	320	0
Total	15.28	258.52		
Hydro				
KDPH	0.43	8.78	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.29	14.19	58	0
BHIRA T.R.	0.24	6.18	40	0
SMLHY_PTN	1.23	37.90	53	49
GHATGHAR	0.68	17.09	125	0
Total	2.87	84.14		
Wind				
Total	3.71	263.18	0	0
Total	3.71	263.18		
CPP				
APML(Mus)	27.58	1703.84	0	0
JSWEL(Mus)	15.94	379.69	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.54	806.68	0	0
SWPGPL-Mus	8.49	243.40	0	0
Other(Mus)	45.08	1280.36	0	0
Total	122.63	4413.97		
SOLAR				
Total	12.39	327.85	0	0
Total	12.39	327.85		
Tata				
Trombay 5	7.45	211.81	429	256
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.95	25.04	48	36
Trombay 7B	0.83	19.60	41	32
TATA Hydro	4.05	109.73	395	12
Trombay 8	3.96	110.68	229	131
Total	17.24	476.84		
AEMIL				
DTPS U-1&2	9.03	283.68	501	297
Total	9.03	283.68		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	167.93	4461.53	MSPGCL Total	189.64	4929.02
			MSPGCL Thml+Gas	171.18	4581.11	Koyna 1,2 & 4 Total	12.71	212.62
			MSPGCL Hydro	18.46	347.92	State Total	354.64	10694.55

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 29/Dec/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6341	166	138	6645	264	4603	0	0	7705	7665	-973	17847	0	17847	1791	357	19995	49.97
2	6420	174	138	6732	216	4466	0	0	7752	7811	-882	18004	0	18004	1674	339	20017	49.97
3	6434	179	140	6753	183	4508	0	0	7881	7806	-792	18148	0	18148	1585	309	20043	49.97
4	6505	167	140	6812	155	4479	0	0	7986	7863	-754	18245	0	18245	1540	310	20095	49.96
5	6879	315	139	7333	177	4662	0	0	7736	7699	-745	18802	0	18802	1548	324	20674	49.97
6	7114	437	139	7690	149	4993	0	0	7764	7846	-846	19476	0	19476	1649	356	21481	49.93
7	7228	995	139	8362	245	5386	0	3	7755	7538	-939	20212	0	20212	1773	384	22368	49.95
8	7262	1392	138	8792	283	5595	0	159	7844	7771	-873	21315	0	21315	1967	413	23694	49.94
9	7306	1734	139	9179	225	5567	0	652	7690	7669	-891	21970	0	21970	2316	431	24717	49.97
10	7281	1873	134	9288	156	5549	0	1283	7723	8052	-1102	22804	0	22804	2540	422	25766	49.91
11	7338	1869	133	9340	106	5494	0	1630	8417	8878	-1184	23832	0	23832	2737	431	27001	49.98
12	7407	1404	131	8942	86	5487	0	1843	8875	9160	-1492	23600	0	23600	2801	426	26827	50.03
13	7332	330	131	7793	79	5147	0	1778	9976	9618	-1526	22480	0	22480	2746	409	25635	49.98
14	7054	164	130	7348	80	4934	0	1700	10071	9999	-1573	22088	0	22088	2577	400	25065	49.64
15	7207	305	134	7646	80	4883	0	1576	10325	10213	-1659	22341	0	22341	2600	398	25339	49.91
16	7314	515	131	7960	82	5154	0	1119	9987	10190	-1589	22488	0	22488	2620	427	25536	50.06
17	7199	1246	131	8576	70	5496	0	540	8234	8034	-1292	20971	0	20971	2620	454	24044	50.05
18	7124	1430	133	8687	95	5530	0	99	7260	7231	-1087	20109	0	20109	2590	446	23145	50.04
19	7080	1632	135	8847	96	5536	0	6	7009	7180	-1054	20153	0	20153	2644	459	23255	49.99
20	7071	1374	133	8578	166	5474	0	0	7007	7294	-1038	20032	0	20032	2435	443	22909	49.98
21	6999	309	136	7444	199	5149	0	0	7309	7278	-1216	18425	0	18425	2419	430	21273	50.06
22	6827	235	134	7196	182	4880	0	0	7246	7244	-1304	17768	0	17768	2260	429	20458	49.97
23	6580	110	134	6824	165	4829	0	0	7427	7639	-1264	17783	0	17783	2101	410	20294	49.96
24	6631	110	137	6878	168	4828	0	0	7394	7298	-1157	17620	0	17620	1964	395	19979	49.98
MUs	167.93	18.46	3.25	189.64	3.71	122.63	0.00	12.39	194.37	194.98	-27.23	486.51	0.00	486.51	53.50	9.60	549.61	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 29/Dec/2022

Position as on 6.30 Hrs of 30/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
IPP	Adani U-5	660	10/12/2022	23:56		Continued.	COH activities.	10/01/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/01/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40	29/12/2022	22:16	Zero Schedule.	
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	03/01/2023
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022	
MSPGCL	Uran Unit 6	108	20/12/2022	17:00		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	25/12/2022	17:45		Continued.	Bottom Ash evacuation problem	02/01/2023
IPP	Adani U-3	660	27/12/2022	13:57	30/12/2022	04:21	APH-A Hot PA bellow leakage.	30/12/2022
IPP	SWPGPL U-4	135	28/12/2022	00:00		Continued.	BOTTOM ASH EVACUATION PROBLEM	03/01/2023
IPP	Adani U-4	660	28/12/2022	12:46		Continued.	APH-B gear box abnormal sound.	01/01/2023
MSPGCL	Chandrapur Unit 9	500	30/12/2022	07:51		Continued.	Heavy steam leakage at turbine side	
AEML	AEML Unit 1	250	30/12/2022	12:50	30/12/2022	17:17	Generator 01 PT Failure.	
MSPGCL	Paras Unit 4	250	30/12/2022	22:09		Continued.	Boiler Tube Leakage	02/01/2023
MSPGCL	Chandrapur Unit 6	500	30/12/2022	23:31		Continued.	Flame Failure	01/01/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 29/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 30/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY (702) OF ICT-1 & FUTURE BAY @ KORADI 3	IntraState	29/12/2022	09:46	29/12/2022	17:56	PO	Annual Maintenance of Bay Equipment
765 KV LR Outages/Trippings							
LR (707) OF KORADI CKT - 1@ TIRORA	IntraState	28/12/2022	09:10	30/12/2022	17:21	PO	for attending SF6 gas leakage.
765 KV LINE Outages/Trippings							
BUS - 1 @ TIRODA	IntraState	30/12/2022	11:38		Continued.	PO	Tan delta measurement of Bus CVT & Bus isolator maintenance work
765 KV ICT Outages/Trippings							
765/400KV 1500MVA ICT @ AKOLA 2	IntraState	30/12/2022	11:14	30/12/2022	18:46	PO	Taking Spare ICT in Service in place of B-ph ICT as per CEA guideline
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
BUSBAR PROTECTION SCHEME @ DEEPNAGAR	IntraState	28/12/2022	17:04	30/12/2022	19:35	PO	For cable termination, wiring, testing & configuration of new Station TF (STN-6B) in existing 400 KV Busbar Panel in r/o 660 MW Unit.
400 KV LINE Outages/Trippings							
KOLHAPUR - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
KORADI 2-WARDHA (PG)	InterState	29/12/2022	12:41	29/12/2022	19:49	PO	Isolator upgradation work of 41489A isolator under substation package SS11 (Construction outage)
PARLI(MS) - PARLI (PG) CKT -1	InterState	30/12/2022	06:23	30/12/2022	20:35	PO	POST OCC: BYPASSING OF 400KV PARLI(PG)-PARLI(M) 400KV D/C AND 400KV PARLI(PG)-PARLI (NEW) D/C QUAD LINE AT THE OUT SKIRT OF PARLI(PG) S/S SO AS TO FORM PARLI(M)-PARLI(NEW) 400KV D/C LINE
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
LONIKAND I - CHAKAN	IntraState	28/12/2022	09:47	30/12/2022	04:00	PO	O/H & Serviceing of 29A PG Isolator & Replacement of PGI mechanism box.
TBC @ KHADKA	IntraState	29/12/2022	09:48	29/12/2022	16:15	PO	FOR CB ompressor overhauling work and routine maintenance works.
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	29/12/2022	10:49	29/12/2022	18:29	PO	PG isolator overhauling work
JEJURI- KOYNA STAGE-IV	IntraState	29/12/2022	11:47	29/12/2022	18:41	PO	PID Faulty disc insulator replacement work & Cold line washing work
NAGOTHANE - DABHOL CKT - 2	IntraState	29/12/2022	12:02	29/12/2022	18:33	PO	Cold washing work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 29/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 30/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
AKOLA - KHADKA (BHUSAWAL)	IntraState	30/12/2022	08:30	30/12/2022	17:31	PO	for breaker pneumatic system & breaker compressor overhauling work by agency line will be in service through TBC A/R required in non auto mode at both end
LONIKAND I - KOYNA STAGE-IV	IntraState	30/12/2022	11:55	30/12/2022	18:10	PO	PID Faulty disc insulator replacement work & Cold line washing work
400 KV ICT Outages/Tripping							
400/220KV 105 MVA SPARE ICT - 1 @ BABHALESHWAR	IntraState	29/12/2022	10:55	29/12/2022	17:08	PO	Bushing C & Tan D
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	30/12/2022	11:41	30/12/2022	18:33	EO	To attend Hotspot at B-ph 29B Isolator Jaw by opening jumper by Hotline unit
220 KV TIEBAY Outages/Tripping							
BUS SECTIONALIZER @ NANDED CITY	IntraState	29/12/2022	12:12	29/12/2022	15:41	PO	Half yearly maintenance work
220 KV MAINBAY Outages/Tripping							
220KV SHIVAJINAGAR - MALEGAON	IntraState	30/12/2022	18:23	30/12/2022	22:33	PO	For replacement of PID detected critical strings
220 KV LINE Outages/Tripping							
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	29/12/2022	10:06	29/12/2022	12:52	HT	H/T DUE TO HIGH O/D
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
EKLAHARE (OCR) - PADGHE	IntraState	19/12/2022	18:12			HT	HT for Load Management
TROMBAY CARNAC - 6	IntraState	29/12/2022	10:44	29/12/2022	17:24	PO	for B-phase LA replacement at Trombay Generating station.
LAMBOTI - KARKAMB	IntraState	29/12/2022	12:26			PO	Outage is required For replacement of old Tower at Loc no. 432 & 436 by new B+6 type tower due to low ground clearance along with necessary stringing work.
NERLE- POPHALI	IntraState	29/12/2022	12:30	29/12/2022	15:48	PO	Diagnostic testing work,WT jump bolted to palm replacement & Line isolator alignment work.
LAMBOTI - PANDHARPUR	IntraState	29/12/2022	12:42			PO	Outage is required for replacement of old Tower at Loc no. 432 & 436 by new B+6 type tower due to low ground clearance along with necessary stringing work.
BORIVALI - BOISAR II LINE	IntraState	29/12/2022	13:44	29/12/2022	18:26	T	TRIPPED ON DISTANCE PROTECTION
ONI KHAREPATAN LINE	IntraState	30/12/2022	09:14	30/12/2022	18:51	PO	Cold washing of Line insulators.
JAMBHUL - ANANDNAGAR	IntraState	30/12/2022	10:00	30/12/2022	17:26	PO	Works to be carried out 1) Replacement of 198kV LAs by Agency 2) Routine Maintenance Work
NAGOTHANE - SPCL	IntraState	30/12/2022	10:06	30/12/2022	16:53	PO	ISOLATOR OVERHAULING AND BAY MAINTENANCE WORK AT SPCL END.
URAN - APTA 3	IntraState	30/12/2022	11:09	30/12/2022	14:25	PO	CT Tan delta and diagnostic testing work at Apta end.
PADGHE - KAMBA 2	IntraState	30/12/2022	11:30	30/12/2022	18:36		1. Diagnostic testing work 2. Bay maintenance work 3. Isolator maintenance work 4. Attending hotspot (if any) 5. Pending MTAMC work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 29/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 30/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
ADLABS - PEDAMBE	IntraState	30/12/2022	11:40	30/12/2022	19:53	PO	Damaged jumper nut bolt replacement, Cold washing of insulator strings and Outage trre cutting work and other line maintenance work.
TROMBAY - SALSETTE CKT - 1	IntraState	30/12/2022	23:38		Continued.	PO	For KVPTL project work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 200 MVA ICT 2 @ PADGHE	IntraState	29/12/2022	11:14	29/12/2022	19:03	PO	1. Diagnostic testing work 2. Bay maintenance work 3. Checking oil leakage from TOP 4. CTR servicing & checking 5. Attending hotspot (if any)
220/132KV 100MVA ICT 2 @ CHAKAN PHASE II	IntraState	29/12/2022	11:18	29/12/2022	15:58	PO	Half yearly maintenance and Dignostic testing work .
220/100 KV 200 MVA ICT 2 @ APTA	IntraState	29/12/2022	12:20	29/12/2022	16:55	PO	OLTC Overhauling and diagnostic testing work.
220/132 KV 200MVA PTR NO 3 @ CHINCHWAD	IntraState	30/12/2022	10:04	30/12/2022	17:09	PO	132KV ITC make L.V (R,Y,B) phase C.T replacement work
220/100 KV 100 MVA ICT 2 @ VASAI II	IntraState	30/12/2022	10:52	30/12/2022	14:27	PO	For CTR overhauling and N2 Cylinder replacement by Agency
220 KV BUSBAR Outages/Trippings							
GIS BUS - 2 @ SALSETTE	IntraState	30/12/2022	21:14	30/12/2022	22:04	PO	FOR TEST CHARGING 125 MAVR REACTOR BAY AND REACTOR
110 KV LINE Outages/Trippings							
AMBERNATH - KALYAN CKT - 2	IntraState	29/12/2022	06:58	29/12/2022	09:30	PO	opening OFA tap jumpers
AMBERNATH - KALYAN CKT - 1	IntraState	29/12/2022	16:31	29/12/2022	19:22	PO	Opening OFA tap jumpers
AMBERNATH - KALYAN CKT - 2	IntraState	30/12/2022	20:48	30/12/2022	22:39	PO	FOR RECONNECTION OF NORTH OFA TAP JUMPER

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage