

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 30/Jan/2024 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	180.023	4891.490	1) Gujrat	-3.594	-123.024
2) Hydro	18.595	303.744	2) Madhya Pradesh	2.613	71.402
3) Gas	7.113	205.482	3) Chattisgarh	5.370	160.990
Total MSPGCL	205.731	5400.716	4) Maharashtra	166.928	5142.247
B) 1) APLM	46.717	1647.262	5) Goa (Amona)	-1.850	-47.430
2) JSWEL	27.472	744.049	Total	169.467	5204.185
3) VIPL	0.000	0.000	a) Mumbai Schedule	25.715	841.107
4) RPL(AMT)	31.698	827.581	b) Mumbai Drawl	29.211	947.050
5) SWPGPL	12.333	361.313	c) MSEDCL Bilateral *	70.771	2030.198
6) Other IPP	47.752	1305.391	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	25.715	840.655
C) 1) TPCL Thermal	9.381	347.453	Include PX	0.000	0.000
2) TPCL Hydro	4.702	117.640	Standby	0.000	0.452
3) TPCL Gas	3.034	82.186	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.344	192.050	1) MSEDCL	520.661	14937.374
D) STATE			2) Mumbai Discoms	56.672	1686.365
1) Thermal	365.720	10316.589	3) Other Discoms	10.400	308.258
(A1+C1+C4+(B1-B6))			TOTAL STATE	587.733	16931.997
2) Hydro	23.297	421.384			
(A2+C2)					
3) Gas	10.147	287.668			
(A3+B7+C3)					
4) Wind	4.173	285.372			
6) SOLAR	14.929	416.813			
TOTAL STATE	418.266	11727.826			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	8004	7528	7361	7297
MSPGCL Hydro	1480	337	1524	208
MSPGCL Gas	290	285	291	303
MSPGCL Total Generation	9774	8150	9176	7808
Central Sector Receipt	8148	7953	7020	6018
WIND	146	121	200	132
CPP / IPP Thermal	7096	6995	7061	6700
CPP / IPP Gas	0	0	0	0
SOLAR	1872	2239	23	0
Exchange with Mumbai	-1423	-1519	-1250	-996
MSEDCL DEMAND MET	25151	23497	21726	19309
Load Shedding	0	0	0	0
MSEDCL DEMAND	25151	23497	21726	19309
TPCL GENERATION	987	850	1013	378
AEML GENERATION	456	483	466	307
MUMBAI DEMAND	2866	2852	2729	1681
OTHER DISCOM DEMAND	462	442	504	353
STATE DEMAND MET	28479	26791	24959	21343
STATE DEMAND	28479	26791	24959	21343
Frequency (Hz)	49.98	49.94	49.96	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 16:03 Hrs	49.7 Hz at 07:26 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 30/Jan/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.46	129.06	195	170
Unit 8	15.51	371.90	662	627
Unit 9	14.61	389.74	643	557
Unit 10	14.72	409.64	655	550
Total	49.30	1300.34		
Bhusawal				
Unit 3	0.07	49.85	67	0
Unit 4	11.78	294.19	505	400
Unit 5	11.87	286.54	500	475
Total	23.71	630.58		
Parli				
Unit 6	5.26	133.12	250	157
Unit 7	4.66	120.16	248	140
Unit 8	5.10	110.52	250	149
Total	15.02	363.80		
Chandrapur				
Unit 3	3.04	98.75	145	109
Unit 4	3.96	56.94	175	140
Unit 5	9.69	252.56	440	315
Unit 6	7.60	221.46	335	274
Unit 7	8.34	163.62	402	290
Unit 8	10.07	269.75	428	392
Unit 9	11.66	298.25	495	474
Total	54.35	1361.33		
Paras				
Unit 3	4.96	157.73	221	169
Unit 4	5.52	167.01	240	214
Total	10.48	324.74		
Khaparkheda				
Unit 1	4.34	108.18	185	175
Unit 2	0.00	27.92	0	0
Unit 3	4.17	115.37	177	162
Unit 4	4.63	128.88	197	190
Unit 5	6.26	304.61	485	0
Total	19.42	684.94		
Nasik				
Unit 3	0.00	24.60	0	0
Unit 4	4.09	102.27	188	124
Unit 5	3.65	98.89	174	118
Total	7.74	225.76		
Uran				
All Units	7.11	205.48	308	283
Total	7.11	205.48		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.22	10.80	47	0
Total	0.22	10.80		
Koyna				
Stage 1-2	4.19	72.58	580	45

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	6.62	68.62	1000	0
Stage 3	2.24	30.75	240	0
Total	13.05	171.94		
Hydro				
KDPH	0.86	21.33	36	36
VTRNA	0.19	3.06	61	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	3.08	72.87	130	126
GHATGHAR	1.19	23.74	250	0
Total	5.33	121.00		
Wind				
Total	4.17	285.37	0	0
Total	4.17	285.37		
CPP				
APML(Mus)	46.72	1647.26	0	0
JSWEL(Mus)	27.47	744.05	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.70	827.58	0	0
SWPGPL-Mus	12.33	361.31	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.95	154.40	267	196
Other(Mus)	39.40	1122.33	0	0
JPL	2.40	28.66	137	72
Total	165.97	4885.60		
SOLAR				
Total	14.93	416.81	0	0
Total	14.93	416.81		
Tata				
Trombay 5	9.38	252.28	470	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.81	49.39	108	39
Trombay 7B	1.22	32.80	65	35
TATA Hydro	4.70	117.64	377	26
Trombay 8	0.00	95.17	0	0
Total	17.12	547.28		
AEML				
DTPS U-1&2	10.34	192.05	498	307
Total	10.34	192.05		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	180.02	4891.49	MSPGCL Total	205.73	5400.72
			MSPGCL Thml+Gas	187.14	5096.97	Koyna 1,2 & 4 Total	10.81	141.20
			MSPGCL Hydro	18.60	303.74	State Total	418.27	11727.83

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 30/Jan/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7194	208	303	7705	247	6368	0	0	6415	6511	-1186	19245	0	0	19245	1908	400	21553	49.99
2	7390	208	303	7901	145	6601	0	0	6263	6019	-1084	19210	0	0	19210	1768	372	21350	49.98
3	7297	208	303	7808	132	6700	0	0	6272	6018	-996	19309	0	0	19309	1681	353	21343	49.99
4	7328	218	305	7851	191	6696	0	0	6213	6083	-947	19535	0	0	19535	1629	339	21503	50.00
5	7490	218	306	8014	241	6679	0	0	6559	6419	-958	20038	0	0	20038	1641	357	22036	50.01
6	7654	208	306	8168	272	6757	0	0	7320	7506	-1023	21291	0	0	21291	1761	389	23442	49.99
7	7936	491	308	8735	225	7065	0	1	6681	7064	-789	21898	0	0	21898	1994	403	24295	49.97
8	7984	1983	305	10272	177	7104	0	135	6804	6994	-821	23445	0	0	23445	2186	417	26047	49.90
9	8036	2025	303	10364	186	7095	0	612	7382	7458	-1099	24177	0	0	24177	2467	438	27083	49.95
10	7973	1793	297	10063	155	7081	0	1295	7839	7975	-1246	24857	0	8	24857	2718	466	28041	49.99
11	8004	1480	290	9774	146	7096	0	1872	8032	8148	-1423	25151	0	13	25151	2866	462	28479	49.98
12	7965	834	292	9091	111	7105	0	2143	8046	8108	-1518	24594	0	13	24594	2901	446	27941	49.93
13	7528	337	285	8150	121	6995	0	2239	7670	7953	-1519	23497	0	12	23497	2852	442	26791	49.94
14	7199	332	284	7815	104	6682	0	2184	7835	8208	-1641	22933	0	9	22933	2727	419	26079	49.99
15	7416	349	283	8048	127	6861	0	1877	7755	7922	-1607	22780	0	5	22780	2760	448	25988	49.98
16	7434	512	284	8230	170	7034	0	1450	7802	7810	-1511	22704	0	3	22704	2775	479	25958	50.00
17	7423	1212	287	8922	173	7015	0	831	6982	6947	-1322	22094	0	0	22094	2761	472	25327	50.01
18	7429	1170	290	8889	204	7059	0	266	6792	6835	-1235	21525	0	0	21525	2724	493	24742	50.00
19	7361	1524	291	9176	200	7061	0	23	7081	7020	-1250	21726	0	0	21726	2729	504	24959	49.96
20	7329	1724	293	9346	157	7065	0	1	7057	6926	-1240	21760	0	0	21760	2691	495	24946	49.91
21	7347	691	298	8336	146	7067	0	0	6339	6324	-1123	20265	0	0	20265	2533	485	23283	49.88
22	7244	435	298	7977	140	7015	0	0	6045	6349	-1092	19926	0	0	19926	2367	463	22756	49.90
23	7083	227	296	7606	155	6914	0	0	6389	6524	-1296	19463	0	0	19463	2195	440	22098	50.00
24	6979	208	303	7490	248	6857	0	0	6514	6346	-1285	19240	0	0	19240	2038	416	21694	49.97
MUs	180.02	18.59	7.11	205.73	4.17	165.97	0.00	14.93	168.09	169.47	-29.21	520.66	0.00	0.06	520.66	56.67	10.40	587.73	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

ELR carried out due to 132KV BBLSR-Rahuri line overload.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 30/Jan/2024

Position as on 6.30 Hrs of 31/Jan/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	29/02/2024
MSPGCL	Khaparkheda Unit 2	210	10/01/2024	23:30		Continued.	Annual Overhaul	06/02/2024
Total Capacity MSPGCL		398						
TPC-G								
TPC-G	Trombay 8	250	21/01/2024	21:28		Continued.	Annual Overhaul	21/02/2024
Total Capacity TPC-G		250						
IPP								
IPP	Adani U-3	660	31/12/2023	23:59		Continued.	COH activities	05/02/2024
Total Capacity IPP		660						
CENT.SECTOR								
CENT.SECTOR	Tarapur 3	540	11/01/2024	21:45		Continued.	Annual Overhaul	29/02/2024
Total Capacity CENT.SECTOR		540						
Total Capacity PLANNED OUTAGE		1848						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	16/01/2024	20:29		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Nasik Unit 3	210	18/01/2024	16:56		Continued.	Tolling	
MSPGCL	Ghatghar Unit-1	125	29/01/2024	19:00	30/01/2024	18:20	GM LINK FAULT AND GOVENOR HEAVY FAULT	31/01/2024
MSPGCL	Bhusawal Unit 3	210	30/01/2024	00:39		Continued.	Boiler clinker formation	01/02/2024
MSPGCL	Khaparkheda Unit 5	500	30/01/2024	13:13		Continued.	Boiler Tube Leakage	02/02/2024
Total Capacity MSPGCL		1273						
IPP								
IPP	JPL Unit 1	150	13/01/2024	01:00		Continued.	Due to low net sale realisation.	31/01/2024
IPP	Adani U-1	660	29/01/2024	01:30		Continued.	Due to APH-A inlet bellow leakage.	31/01/2024
Total Capacity IPP		810						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea.	01/05/2024

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 30/Jan/2024

Position as on 6.30 Hrs of 31/Jan/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							The outage extended for repair and re-fueling.	
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2403						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 31/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (405) OF SWICHING SS CKT - 2 & NANDED - 1 @ CHANDRAPUR 2	IntraState	16/01/2024	11:43			PO	replacement of non pir breker with pir breaker
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-2	InterState	20/12/2023	12:11			HT	For ongoing project of "Upgradation of 400kV Line Bays (02 Nos) of Parli (PG) I&II at Parli (MSETCL) from existing current rating of 2000A to 3150A to suit the reconductoring with Twin HTLS�
KORADI 2-WARDHA (PG)	InterState	30/01/2024	18:06	30/01/2024	22:32	HT	emergency work by PG
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	26/11/2023	19:17			HT	HT Load Management
TARAPUR - BOISAR (PG) CKT - 1	IntraState	24/01/2024	08:43			PO	Bullet Train Diversion works. Simultaneous outage of 400KV Tarapur- Boisar # 1 & 2 are required. Dia to be kept open at both ends.
TARAPUR - BOISAR (PG) CKT - 2	IntraState	24/01/2024	09:15			PO	Bullet Train Diversion works. Simultaneous outage of 400KV Tarapur- Boisar # 1 & 2 are required. Dia to be kept open at both ends.
KHADKA-AURANGABAD (WALUJ)	IntraState	29/01/2024	22:57	30/01/2024	07:15	HT	H/T on overvoltage
CHANDRAPUR - KHAPERKHEDA	IntraState	30/01/2024	10:28	30/01/2024	17:14	PO	Replacement of faulty disc insulator found in PID testing at Loc No 361.
KHADKA-AURANGABAD (WALUJ)	IntraState	30/01/2024	21:52	31/01/2024	08:06	HT	H/T on overvoltage
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	30/12/2023	23:20	30/01/2024	22:58	T	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	30/12/2023	23:21			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	30/12/2023	23:22			HT	Line handtrip for safety purpose for HTLS conversion of 400 kv Kalwa Padghe II line.(Formation of 400 kv Kharghar- Talegaon-Padghe Tap line)
400KV/21KV GT - 3 @ TIRORA	IntraState	01/01/2024	10:45			PO	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay euipments.
400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	IntraState	30/01/2024	09:08	30/01/2024	20:55	PO	1.Maintenance and alignment of CBI, PG Isolators. 2. Routine maintenance of ICT

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 31/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	30/01/2024	10:06	30/01/2024	15:37	PO	Erection of CS Type Gantry Beam Structure for RRS Scheme of ICTs
400/220/20 KV 500MVA ICT - 3 @ KALWA	IntraState	30/01/2024	11:23	30/01/2024	15:44	PO	400KV CB DCRM test after shifting the ICT on TBC.
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	IntraState	30/01/2024	12:23	30/01/2024	15:00	EO	To attend Hot Spot
400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	IntraState	31/01/2024	09:20			PO	1.Maintenance and alignment of CBI, PG Isolators. 2. Routine maintenance of ICT
400 KV BUSBAR Outages/Trippings							
BUSBAR PROTECTION @ BABHALESHWAR	IntraState	30/01/2024	14:25			PO	Integration of 400/220KV ICT-5 VH bay and Spare ICT-3 bay into Existing 40KV Numerical ZVI Bus Bar at 40KV Babhaleshwar.
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
220 KV LINE Outages/Trippings							
BAPGAON - KALWA	IntraState	31/12/2023	18:05			T	Distance Protection
CHEMBUR (AEML) - NERUL (M)	IntraState	18/01/2024	23:29			PO	LILO removal by Bunching at Tower No 720 .Post this Line shall be configured as MSETCL NERUL-MSETCL TROMBAY Line. LILO arrangement shall be normalized on 09.02.2024 after debunching
TROMBAY (M) - CHEMBUR CKT - 3	IntraState	18/01/2024	23:36				LILO removal by Bunching at Tower No 720 . Post this Line shall be configured as MSETCL NERUL-MSETCL TROMBAY Line. LILO arrangement shall be normalized on 09.02.2024 after debunching
TROMBAY - VIKHROLI (GIS) CKT - 1	IntraState	26/01/2024	11:04			PO	Disconnect loops towards cross jumper side and close main loops at loc. 34. Remove cross jumper between loc. 52(TS) to 49(TDS). Loop closing at loc. 52(TS). Loop closing at loc. 48, 49 & 52 of TDS
KARAD - KADEGAON	IntraState	29/01/2024	11:43	30/01/2024	16:57	PO	Quarterly maintenance work & bus isolator alignment work through hot line.
KALWA - PANCHANAND	IntraState	30/01/2024	08:53			PO	1) Stringing of 3 nos. of conductor and stringing of OPGW wire between Loc no. 565 to 659. 2) Dismantling of 2 nos. tower at Pisarve Parvel Raigad.
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	30/01/2024	09:55	30/01/2024	20:00	PO	Damaged conductor to be attended by applying mid span joint at loc no. 111,129 & 124- Repair sleeve work and other line maintenance work.
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	30/01/2024	09:55			PO	Overhauling of CB of line
KANHAN-BHANDARA 1	IntraState	30/01/2024	10:10	30/01/2024	16:48	PO	Replacement of R phase CT
MAIN BUS - 2 @ TALANDGE	IntraState	30/01/2024	10:30			PO	Faulty Insulator string replacement work. Isolator alignment work.
BOTHE - SWARAJ CO GEN	IntraState	30/01/2024	10:53	30/01/2024	13:40	PO	Tan delta testing of line CT & CRM,CB timing test

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Jan/2024

Statement-VII

Position as on 6.30 Hrs of 31/Jan/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
URAN - KHARGHAR 2	IntraState	30/01/2024	11:17	30/01/2024	16:22	PO	"Routine line maintenance work. For Relay and diagnostic Testing at Uran End"
MHAISHAL- JATH	IntraState	30/01/2024	15:01	30/01/2024	16:23	PO	Replacement of LMU/LMDU
MULUND - GIS BHANDUP	IntraState	30/01/2024	15:34			PO	Replacement of 800/1A CT to 1600/1A CT & Additional Cable Bushing chamber installation at Mulund Line Bay.
MIRAJ - ICHALKARANJI	IntraState	30/01/2024	17:17	30/01/2024	23:34	PO	220KV Miraj Line kept off for proper load management at 220kV Tilawani S/S during outage period of outage on 220kV Talandage- Tilawani-2
BORIVALI - BOISAR II LINE	IntraState	30/01/2024	17:27	30/01/2024	22:51	T	Tripped ondistance protection
TALANDGE - ICHALKARANJI 2	IntraState	30/01/2024	17:28	30/01/2024	23:26	PO	Cleaning, tightening of Jumpering of 10 No Tension towers & replacement of nut bolts if required.
KARAD - VITA CKT- 1	IntraState	31/01/2024	08:31			PO	Cold line Washing of Insulator strings
VITA - HIWARWADI	IntraState	31/01/2024	08:31			PO	Cold Line Washing of Insulator Strings
LAMBOTI - KARKAMB	IntraState	31/01/2024	09:25			PO	Outage is required for Cold line cleaning of disc insulator from loc no. 01 to 99
SADAWAGHAPUR KARAD CKT 1	IntraState	31/01/2024	09:28			PO	Tan delta test of CTs & quarterly maintenance work
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132 KV 150 MVA ICT @ BOISAR-II	IntraState	23/01/2024	07:15			PO	Scheme work of replacement of 150MVA 220/132kV ICT by new 200MVA 220/132kV ICT.
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	30/01/2024	10:23	30/01/2024	17:45	PO	ICT painting work
220/33KV 50MVA PTR 1 @ MIRAJ	IntraState	30/01/2024	10:25	30/01/2024	18:43	PO	For diagnostic testing work
220/100 KV 200 MVA ICT 2 @ PAL- DOMBIVALI	IntraState	30/01/2024	10:44	30/01/2024	17:26	PO	For annual maintenance work of NIFPS & WRM Testing of ICT.
100 MVA 220/132 KV ICT - I @ NARANGWADI	IntraState	30/01/2024	11:03	30/01/2024	14:36	PO	Quarterly maintenance work
100 MVA 220/132 KV ICT - I	IntraState	30/01/2024	12:22	30/01/2024	16:22	PO	To attend Oil Leakage
220 KV BUSBAR Outages/Trippings							
BUS-1@GIS BHANDUP	IntraState	23/01/2024	19:58			PO	220kV GIS -Bhandup-Borivali Line is on 220kV Bus Section 1. Outage is required for Replacement of 800/1A CT to 1600/1A CT & Additional Cable Bushing chamber Installation at Borivali Line Bay.
BUS-1@GIS BHANDUP	IntraState	30/01/2024	15:32			PO	Outage is required for safety purpose (220 kV GIS Bhandup-Borivali line is on Bus Section-1) for Replacement of 800/1A CT to 1600/1A CT & Additional Cable Bushing chamber installation at Mulund Line.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 2	IntraState	06/01/2024	07:25			PO	Conductor replacement in span Kalyan to Loc 15 and Kalwa at loc. 71

