

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 30/Mar/2021 TUESDAY**

| I GENERATION (MUs)  |                |                  | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|------------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly          | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 129.918        | 4857.785         | 1) Gujrat                      | 6.638          | 81.699           |
| 2) Hydro            | 18.267         | 540.596          | 2) Madhya Pradesh              | 15.080         | 421.242          |
| 3) Gas              | 6.646          | 192.711          | 3) Chattisgarh                 | 3.570          | 101.690          |
| <b>Total MSPGCL</b> | <b>154.831</b> | <b>5591.092</b>  | 4) Maharashtra                 | 159.774        | 4251.403         |
| B) 1) APLM          | 57.698         | 1739.005         | 5) Goa (Amona)                 | -1.590         | -39.063          |
| 2) JSWEL            | 12.696         | 413.833          | <b>Total</b>                   | <b>183.472</b> | <b>4816.971</b>  |
| 3) VIPL             | 0.000          | 0.000            | a) Mumbai Schedule             | 26.446         | 779.379          |
| 4) RPL(AMT)         | 29.504         | 903.744          | b) Mumbai Drawl                | 28.426         | 818.091          |
| 5) SWPGPL           | 7.998          | 249.230          | c) MSEDCL Bilateral *          | 48.210         | 1073.442         |
| 6) Other IPP        | 22.810         | 710.798          | Include PX                     | 16.219         | 126.846          |
| 7) PGPL             | 0.000          | 0.000            | d) Mumbai Bilateral *          | 26.446         | 778.821          |
| C) 1) TPCL Thermal  | 14.294         | 318.340          | Include PX                     | 4.197          | 326.251          |
| 2) TPCL Hydro       | 3.898          | 137.938          | Standby                        | 0.000          | 0.558            |
| 3) TPCL Gas         | 3.671          | 101.528          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 10.260         | 341.860          | 1) MSEDCL                      | 471.393        | 14110.328        |
| <b>D) STATE</b>     |                |                  | 2) Mumbai Discoms              | 60.549         | 1717.758         |
| 1) Thermal          | 285.178        | 9534.595         | <b>TOTAL STATE</b>             | <b>531.942</b> | <b>15828.086</b> |
| (A1+C1+C4+(B1-B6))  |                |                  |                                |                |                  |
| 2) Hydro (A2+C2)    | 22.165         | 678.534          |                                |                |                  |
| 3) Gas (A3+B7+C3)   | 10.317         | 294.239          |                                |                |                  |
| 4) Wind             | 22.557         | 272.182          |                                |                |                  |
| 6) SOLAR            | 8.253          | 231.564          |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>348.470</b> | <b>11011.114</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5532                      | 5265                  | 4968                      | 5464                      |
| MSPGCL Hydro             | 1253                      | 963                   | 1107                      | 300                       |
| MSPGCL Gas               | 267                       | 258                   | 270                       | 281                       |
| MSPGCL Total Generation  | 7052                      | 6486                  | 6345                      | 6045                      |
| Central Sector Receipt   | 9286                      | 9225                  | 7037                      | 6398                      |
| WIND                     | 452                       | 683                   | 992                       | 1152                      |
| CPP / IPP Thermal        | 5673                      | 5397                  | 5669                      | 5417                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 1089                      | 1151                  | 0                         | 0                         |
| Exchange with Mumbai     | -1454                     | -1555                 | -1017                     | -1080                     |
| <b>MSEDCL DEMAND MET</b> | <b>22098</b>              | <b>21387</b>          | <b>19026</b>              | <b>17932</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 22098                     | 21387                 | 19026                     | 17932                     |
| TPCL GENERATION          | 1086                      | 956                   | 1145                      | 630                       |
| AEML GENERATION          | 498                       | 498                   | 500                       | 282                       |
| <b>MUMBAI DEMAND</b>     | <b>3038</b>               | <b>3009</b>           | <b>2662</b>               | <b>1992</b>               |
| STATE DEMAND MET         | 25136                     | 24396                 | 21688                     | 19924                     |
| <b>STATE DEMAND</b>      | <b>25136</b>              | <b>24396</b>          | <b>21688</b>              | <b>19924</b>              |
| Frequency (Hz)           | 50.07                     | 50.05                 | 50.00                     | 50.02                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.27 Hz at 18.02 Hrs | 49.77 Hz at 14.49 Hrs | 50.02         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 30/Mar/2021

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 3.78         | 96.80          | 180      | 135      |
| Unit 7             | 3.27         | 83.61          | 150      | 120      |
| Unit 8             | 8.31         | 303.37         | 400      | 273      |
| Unit 9             | 8.46         | 309.98         | 420      | 250      |
| Unit 10            | 0.00         | 289.65         | 0        | 0        |
| <b>Total</b>       | <b>23.82</b> | <b>1083.40</b> |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 4.03         | 120.34         | 185      | 125      |
| Unit 4             | 11.92        | 294.35         | 500      | 485      |
| Unit 5             | 11.88        | 343.80         | 500      | 480      |
| <b>Total</b>       | <b>27.84</b> | <b>758.50</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 6             | 2.88         | 135.97         | 209      | 0        |
| Unit 7             | 5.58         | 141.20         | 249      | 198      |
| Unit 8             | 4.00         | 165.98         | 245      | 0        |
| <b>Total</b>       | <b>12.46</b> | <b>443.15</b>  |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 0.00         | 82.04          | 0        | 0        |
| Unit 4             | 0.00         | 54.66          | 0        | 0        |
| Unit 5             | 0.00         | 247.88         | 0        | 0        |
| Unit 6             | 9.60         | 297.88         | 425      | 265      |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 11.87        | 317.30         | 500      | 490      |
| Unit 9             | 10.98        | 337.51         | 470      | 436      |
| <b>Total</b>       | <b>32.46</b> | <b>1337.28</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 0.00         | 142.47         | 0        | 0        |
| Unit 4             | 5.38         | 109.74         | 250      | 122      |
| <b>Total</b>       | <b>5.38</b>  | <b>252.22</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 2.22         | 80.36          | 115      | 0        |
| Unit 2             | 2.57         | 108.80         | 120      | 90       |
| Unit 3             | 3.19         | 134.65         | 150      | 120      |
| Unit 4             | 1.95         | 124.89         | 142      | 0        |
| Unit 5             | 9.89         | 315.21         | 445      | 370      |
| <b>Total</b>       | <b>19.83</b> | <b>763.91</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 4.05         | 107.10         | 198      | 128      |
| Unit 5             | 4.10         | 112.23         | 201      | 127      |
| <b>Total</b>       | <b>8.14</b>  | <b>219.33</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 6.65         | 192.71         | 292      | 258      |
| <b>Total</b>       | <b>6.65</b>  | <b>192.71</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.17         | 5.25           | 26       | 0        |
| <b>Total</b>       | <b>0.17</b>  | <b>5.25</b>    |          |          |
| <b>Koyna</b>       |              |                |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 4.46          | 126.27         | 490      | 40       |
| Stage 4         | 4.42          | 165.44         | 875      | 0        |
| Stage 3         | 1.76          | 63.51          | 160      | 0        |
| <b>Total</b>    | <b>10.64</b>  | <b>355.22</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.86          | 23.18          | 36       | 36       |
| VTRNA           | 1.02          | 19.34          | 60       | 0        |
| TILLARI         | 0.58          | 14.52          | 58       | 0        |
| BHIRA T.R.      | 0.09          | 6.93           | 50       | 0        |
| SMLHY_PTN       | 5.07          | 86.95          | 225      | 190      |
| GHATGHAR        | 0.00          | 18.30          | 0        | 0        |
| <b>Total</b>    | <b>7.62</b>   | <b>169.23</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 22.56         | 272.18         | 0        | 0        |
| <b>Total</b>    | <b>22.56</b>  | <b>272.18</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 57.70         | 1739.00        | 0        | 0        |
| JSWEL(Mus)      | 12.70         | 413.83         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 29.50         | 903.74         | 0        | 0        |
| SWPGPL-Mus      | 8.00          | 249.23         | 0        | 0        |
| Other(Mus)      | 22.81         | 710.80         | 0        | 0        |
| <b>Total</b>    | <b>130.71</b> | <b>4016.61</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 8.25          | 231.56         | 0        | 0        |
| <b>Total</b>    | <b>8.25</b>   | <b>231.56</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 9.54          | 158.78         | 483      | 280      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.25          | 60.98          | 117      | 61       |
| Trombay 7B      | 1.42          | 40.55          | 67       | 48       |
| Trombay 8       | 4.75          | 159.56         | 237      | 138      |
| TATA Hydro      | 3.90          | 137.94         | 374      | 25       |
| <b>Total</b>    | <b>21.86</b>  | <b>557.81</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 10.26         | 341.86         | 501      | 281      |
| <b>Total</b>    | <b>10.26</b>  | <b>341.86</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 129.92      | 4857.78       | MSPGCL Total        | 154.83      | 5591.09       |
|                |             |         | MSPGCL Thml+Gas | 136.56      | 5050.50       | Koyna 1,2 & 4 Total | 8.88        | 291.71        |
|                |             |         | MSPGCL Hydro    | 18.27       | 540.60        | State Total         | 348.47      | 11011.11      |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 30/Mar/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5656        | 337   | 281  | 6274   | 1267  | 5684      | 0    | 0     | 6750        | 6679        | -1209                | 18695                 | 0                    | 18695                     | 2402             | 21097           | 50.02         |
| 2                  | 5550        | 305   | 281  | 6136   | 1195  | 5709      | 0    | 0     | 6829        | 6434        | -1242                | 18232                 | 0                    | 18232                     | 2216             | 20448           | 50.00         |
| 3                  | 5431        | 304   | 282  | 6017   | 1233  | 5470      | 0    | 0     | 6726        | 6790        | -1135                | 18375                 | 0                    | 18375                     | 2080             | 20455           | 50.01         |
| 4                  | 5464        | 300   | 281  | 6045   | 1152  | 5417      | 0    | 0     | 6247        | 6398        | -1080                | 17932                 | 0                    | 17932                     | 1992             | 19924           | 50.02         |
| 5                  | 5526        | 297   | 292  | 6115   | 1195  | 5524      | 0    | 0     | 6358        | 6587        | -1033                | 18388                 | 0                    | 18388                     | 1943             | 20331           | 50.03         |
| 6                  | 5559        | 458   | 282  | 6299   | 1219  | 5598      | 0    | 0     | 7003        | 7073        | -1064                | 19125                 | 0                    | 19125                     | 1977             | 21102           | 50.03         |
| 7                  | 5739        | 514   | 283  | 6536   | 1083  | 5686      | 0    | 17    | 7959        | 7590        | -909                 | 20003                 | 0                    | 20003                     | 2008             | 22011           | 50.03         |
| 8                  | 5607        | 345   | 283  | 6235   | 715   | 5716      | 0    | 197   | 8432        | 8396        | -1049                | 20210                 | 0                    | 20210                     | 2111             | 22321           | 50.08         |
| 9                  | 5741        | 718   | 291  | 6750   | 503   | 5744      | 0    | 489   | 7766        | 8247        | -1213                | 20520                 | 0                    | 20520                     | 2396             | 22916           | 50.06         |
| 10                 | 5727        | 1446  | 270  | 7443   | 498   | 5720      | 0    | 835   | 7460        | 7815        | -1191                | 21120                 | 0                    | 21120                     | 2735             | 23855           | 50.07         |
| 11                 | 5683        | 1455  | 279  | 7417   | 504   | 5705      | 0    | 987   | 8271        | 8525        | -1365                | 21773                 | 0                    | 21773                     | 2957             | 24730           | 50.07         |
| 12                 | 5532        | 1253  | 267  | 7052   | 452   | 5673      | 0    | 1089  | 9214        | 9286        | -1454                | 22098                 | 0                    | 22098                     | 3038             | 25136           | 50.07         |
| 13                 | 5265        | 963   | 258  | 6486   | 683   | 5397      | 0    | 1151  | 9922        | 9225        | -1555                | 21387                 | 0                    | 21387                     | 3009             | 24396           | 50.05         |
| 14                 | 5078        | 806   | 267  | 6151   | 710   | 4570      | 0    | 1082  | 9810        | 9182        | -1476                | 20219                 | 0                    | 20219                     | 2912             | 23131           | 50.04         |
| 15                 | 5151        | 712   | 276  | 6139   | 923   | 4392      | 0    | 962   | 9656        | 9275        | -1504                | 20187                 | 0                    | 20187                     | 2939             | 23126           | 49.87         |
| 16                 | 5239        | 884   | 266  | 6389   | 949   | 4277      | 0    | 753   | 9289        | 9156        | -1426                | 20098                 | 0                    | 20098                     | 2941             | 23039           | 49.96         |
| 17                 | 5256        | 997   | 268  | 6521   | 1129  | 4855      | 0    | 495   | 8126        | 8190        | -1181                | 20009                 | 0                    | 20009                     | 2916             | 22925           | 50.03         |
| 18                 | 5323        | 1120  | 278  | 6721   | 1187  | 5422      | 0    | 185   | 6904        | 7114        | -1141                | 19488                 | 0                    | 19488                     | 2825             | 22313           | 50.02         |
| 19                 | 4998        | 811   | 269  | 6078   | 940   | 5684      | 0    | 11    | 6680        | 6699        | -1061                | 18351                 | 0                    | 18351                     | 2702             | 21053           | 50.02         |
| 20                 | 4968        | 1107  | 270  | 6345   | 992   | 5669      | 0    | 0     | 7013        | 7037        | -1017                | 19026                 | 0                    | 19026                     | 2662             | 21688           | 50.00         |
| 21                 | 5174        | 478   | 280  | 5932   | 981   | 5711      | 0    | 0     | 6768        | 6976        | -1030                | 18570                 | 0                    | 18570                     | 2478             | 21048           | 50.01         |
| 22                 | 5438        | 618   | 290  | 6346   | 957   | 5702      | 0    | 0     | 6714        | 6796        | -1174                | 18627                 | 0                    | 18627                     | 2395             | 21022           | 49.98         |
| 23                 | 5395        | 925   | 270  | 6590   | 1073  | 5692      | 0    | 0     | 6757        | 6898        | -940                 | 19313                 | 0                    | 19313                     | 2444             | 21757           | 49.95         |
| 24                 | 5418        | 1114  | 282  | 6814   | 1017  | 5689      | 0    | 0     | 6951        | 7104        | -977                 | 19647                 | 0                    | 19647                     | 2471             | 22118           | 50.02         |
| MUs                | 129.92      | 18.27 | 6.65 | 154.83 | 22.56 | 130.71    | 0.00 | 8.25  | 183.61      | 183.47      | -28.43               | 471.39                | 0.00                 | 471.39                    | 60.55            | 531.94          | 50.02         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 30/Mar/2021**

**Position as on 6.30 Hrs of 31/Mar/2021**

| Generating Company   | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                       | Expected Date |
|----------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------------------------------------------------------------|---------------|
| <b>FORCED OUTAGE</b> |                         |          |              |              |            |            |                                                                        |               |
| IPP                  | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                |               |
| PGPL                 | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                            |               |
| PGPL                 | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                            |               |
| IPP                  | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                 |               |
| IPP                  | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                                          |               |
| IPP                  | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                                          |               |
| MSPGCL               | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                  |               |
| MSPGCL               | Nasik Unit 3            | 210      | 03/12/2020   | 06.45        |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).    |               |
| MSPGCL               | Koyna Unit 11           | 80       | 19/01/2021   | 10.05        |            | Continued. | Tripped on stator earth fault (will not be available till dt.18.04.21) |               |
| IPP                  | JSW (J) U1              | 300      | 01/02/2021   | 18.00        |            | Continued. | Due to turbine vibration high                                          |               |
| MSPGCL               | Chandrapur Unit 7       | 500      | 20/02/2021   | 23.43        |            | Continued. | Generator Earth Fault.                                                 |               |
| IPP                  | Adani U-2               | 660      | 04/03/2021   | 00.10        |            | Continued. | Increase Hydrogen Consumption                                          |               |
| MSPGCL               | Chandrapur Unit 4       | 210      | 16/03/2021   | 08.08        |            | Continued. | Boiler Tube Leakage                                                    |               |
| MSPGCL               | Uran Unit B0            | 120      | 20/03/2021   | 00.03        |            | Continued. | Gas shortage                                                           |               |
| MSPGCL               | Uran Unit 8             | 108      | 20/03/2021   | 00.05        |            | Continued. | Gas shortage                                                           |               |
| MSPGCL               | Chandrapur Unit 5       | 500      | 25/03/2021   | 15.51        |            | Continued. | Boiler Tube Leakage                                                    |               |
| IPP                  | JSW (J) U2              | 300      | 26/03/2021   | 01.13        |            | Continued. | No Schedule                                                            |               |
| MSPGCL               | Parli Unit 6            | 250      | 27/03/2021   | 02.25        | 30/03/2021 | 01.53      | Coal mill problem.                                                     |               |
| MSPGCL               | Chandrapur Unit 3       | 210      | 29/03/2021   | 11.15        |            | Continued. | Boiler Tube Leakage                                                    |               |
| MSPGCL               | Koradi Unit 10          | 660      | 29/03/2021   | 11.35        | 31/03/2021 | 01.07      | Heavy leakage in gland steam cooler.                                   |               |
| MSPGCL               | Paras Unit 3            | 250      | 29/03/2021   | 18.00        | 31/03/2021 | 01.12      | Clinker information.                                                   |               |
| MSPGCL               | Khaparkheda Unit 4      | 210      | 30/03/2021   | 12.01        | 30/03/2021 | 20.50      | Generator Earth fault Protection                                       |               |
| MSPGCL               | Parli Unit 8            | 250      | 30/03/2021   | 17.46        | 31/03/2021 | 00.00      | Furnace Pressure High                                                  |               |
| MSPGCL               | Khaparkheda Unit 1      | 210      | 30/03/2021   | 18.09        | 30/03/2021 | 20.20      | Flame Failure                                                          |               |
| MSPGCL               | Koradi Unit 10          | 660      | 31/03/2021   | 05.31        |            | Continued. | Boiler Feed pump problem                                               |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Tripping for 30/Mar/2021**

**Statement-VII**

Position as on 6.30 Hrs of 31/Mar/2021

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                         |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------|
| <b>400 KV LINE Outages/Tripping</b>               |                           |              |              |            |            |             |                                                          |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403 |
| Akola Aurangabad(PG) I                            | InterState                | 18/03/2021   | 12.13        |            | Continued. | PO          | SAMRUDHI MAHAMARG PROJECT WORK.                          |
| Akola Aurangabad(PG) II                           | InterState                | 18/03/2021   | 14.34        |            | Continued. | PO          | SAMRUDHI MAHAMARG PROJECT WORK.                          |
| Dhule Sar'Sarovar II                              | InterState                | 29/03/2021   | 10.16        | 30/03/2021 | 06.32      | HT          | Over Voltage                                             |
| Kolhapur(M)-Kolhapur(GIS) ckt1                    | InterState                | 30/03/2021   | 09.42        | 31/03/2021 | 01.37      | PO          | PLCC and Testing work                                    |
| Dhule(MS)- Dhule(BDTCL) -1                        | InterState                | 30/03/2021   | 10.03        | 30/03/2021 | 15.02      | PO          | SCADA upgradation and AMP work                           |
| Dhule(MS)- Dhule(BDTCL) -II                       | InterState                | 30/03/2021   | 17.34        | 30/03/2021 | 21.14      | PO          | SCADA upgradation and AMP work                           |
| Dhule Sar'Sarovar I                               | InterState                | 30/03/2021   | 22.03        |            | Continued. | HT          | Over Voltage                                             |
| BABHALESHWAR - RPL(NASHIK) CKT - 1                | IntraState                | 18/03/2021   | 15.48        |            | Continued. | EO          | Attending Hot Spot                                       |
| Karad - Jaigad - II                               | IntraState                | 30/03/2021   | 09.34        | 30/03/2021 | 17.09      | PO          | Additional Earthing                                      |
| New Koyna -Koyna Stage IV-I                       | IntraState                | 30/03/2021   | 12.40        | 30/03/2021 | 17.14      | PO          | Fixing of repair sleeves on bus conductor                |
| <b>400 KV ICT Outages/Tripping</b>                |                           |              |              |            |            |             |                                                          |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/08/2020   | 09.58        |            | Continued. | PO          | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.    |
| <b>220 KV LINE Outages/Tripping</b>               |                           |              |              |            |            |             |                                                          |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)              |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                   |
| Parli 3 (Old Gcr)-Girwali Ckt 2                   | IntraState                | 25/03/2021   | 10.28        |            | Continued. | PO          | Railway crossing tower erection work                     |
| Kharghar-Borivali ckt II                          | IntraState                | 30/03/2021   | 08.47        | 30/03/2021 | 23.20      | PO          | Crossings of OPGW                                        |
| Satara (MIDC)-Ajinkyatara                         | IntraState                | 30/03/2021   | 10.30        | 30/03/2021 | 12.32      | PO          | Quarterly Maintenance Work                               |
| WARDHA - WARDHA (PG) (Deoli)                      | IntraState                | 30/03/2021   | 13.56        | 30/03/2021 | 16.55      | T           | Distance Protection                                      |
| Jejuri ( 400 Kv)-Jejuri ckt-I                     | IntraState                | 30/03/2021   | 17.26        | 30/03/2021 | 19.21      | PO          | Testing Work                                             |
| <b>220 KV ICT Outages/Tripping</b>                |                           |              |              |            |            |             |                                                          |
| 220/33kv 100mva Transformer 1 @Versova R/S        | IntraState                | 30/03/2021   | 07.50        | 30/03/2021 | 21.30      | PO          | Commissioning of New GIS Board                           |
| 220/33kv 125 MVA Transformer 4 @Ghodbunder R/S    | IntraState                | 30/03/2021   | 08.51        |            | Continued. | PO          | Annual Bay Maintenance work                              |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage