

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 30/Apr/2016 SATURDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 113.935        | 3183.138        | 1) Gujrat                      | -5.490         | -147.327         |
| 2) Hydro            | 10.017         | 356.583         | 2) Madhya Pradesh              | 13.854         | 435.911          |
| 3) Gas              | 10.292         | 295.621         | 3) Chattisgarh                 | 6.520          | 227.400          |
| <b>Total MSPGCL</b> | <b>134.244</b> | <b>3835.342</b> | 4) Maharashtra Net             | 98.134         | 3039.735         |
| B) 1) APML          | 50.273         | 1793.107        | 5) Goa (Amona)                 | -0.474         | -15.724          |
| 2) JSWEL            | 22.351         | 749.233         | 6) TAPS 1&2 Injection          | 3.567          | 104.375          |
| 3) VIPL             | 14.037         | 386.400         | 7) RGPPL Injection             | 11.655         | 349.573          |
| 4) RPL(AMT)         | 17.667         | 488.889         | 8) Pench (MS)                  | 0.182          | 3.614            |
| 5) WPCL             | 4.305          | 135.157         | 9) Pench (Excess)              | -0.182         | -3.614           |
| 6) Other IPP        | 6.159          | 204.832         | <b>Total</b>                   | <b>127.584</b> | <b>3990.329</b>  |
| C) 1) TPCL Thermal  | 15.828         | 474.095         | a) Mumbai Schedule             | 25.194         | 804.175          |
| 2) TPCL Hydro       | 2.492          | 96.844          | b) Mumbai Drawl                | 27.943         | 914.471          |
| 3) TPCL Gas         | 4.266          | 122.033         | c) MSEDCL Bilateral *          | 32.563         | 953.650          |
| 4) R-INFRA Thermal  | 11.478         | 199.035         | Include PX                     | -0.025         | -70.587          |
| <b>D) STATE</b>     |                |                 | d) Mumbai Bilateral *          | 25.194         | 803.625          |
| 1) Thermal          | 256.033        | 7613.886        | Include PX                     | 2.387          | 172.663          |
| (A1+C1+C4+(B1-B6))  |                |                 | Include Standby                | 0.000          | 0.550            |
| 2) Hydro (A2+C2)    | 12.509         | 453.427         | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 3) Gas (A3+C3)      | 14.558         | 417.654         | 1) MSEDCL                      | 363.609        | 11112.108        |
| 4) Wind             | 13.605         | 403.323         | 2) Mumbai Discoms              | 62.003         | 1806.484         |
| 6) SOLAR            | 1.327          | 39.967          | <b>TOTAL STATE</b>             | <b>425.612</b> | <b>12918.592</b> |
| <b>TOTAL STATE</b>  | <b>298.032</b> | <b>8928.257</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 21 Hrs | D. Night Minimum at 2 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4938                      | 4935                  | 4417                      | 4713                      |
| MSPGCL Hydro             | 1407                      | 1383                  | 649                       | 397                       |
| MSPGCL Gas               | 409                       | 429                   | 427                       | 441                       |
| MSPGCL Total Generation  | 6754                      | 6747                  | 5493                      | 5551                      |
| Central Sector Receipt   | 5504                      | 5411                  | 5285                      | 4976                      |
| WIND                     | 308                       | 414                   | 913                       | 406                       |
| CPP / IPP                | 4870                      | 4902                  | 4860                      | 4729                      |
| SOLAR                    | 185                       | 117                   | 0                         | 0                         |
| Exchange with Mumbai     | -1386                     | -1384                 | -1290                     | -1049                     |
| <b>MSEDCL DEMAND MET</b> | <b>16235</b>              | <b>16207</b>          | <b>15262</b>              | <b>14613</b>              |
| Load Shedding            | 1                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 16236                     | 16207                 | 15262                     | 14613                     |
| TPCL GENERATION          | 1068                      | 1075                  | 1031                      | 837                       |
| R-INFRA GENERATION       | 506                       | 510                   | 402                       | 514                       |
| <b>MUMBAI DEMAND</b>     | <b>2960</b>               | <b>2969</b>           | <b>2723</b>               | <b>2400</b>               |
| STATE DEMAND MET         | 19195                     | 19176                 | 17984                     | 17013                     |
| <b>STATE DEMAND</b>      | <b>19196</b>              | <b>19176</b>          | <b>17984</b>              | <b>17013</b>              |
| Frequency (Hz)           | 49.96                     | 49.85                 | 49.97                     | 50.01                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|----------------------|---------------|---------------------|
| 50.24 Hz at 18:02 Hrs | 49.7 Hz at 15:12 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 30/Apr/2016

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 8.16         | 71.11         | 353      | 210      |
| <b>Total</b>       | <b>8.16</b>  | <b>71.11</b>  |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 2             | 3.44         | 109.81        | 155      | 135      |
| Unit 3             | 0.00         | 84.98         | 0        | 0        |
| Unit 4             | 10.79        | 316.61        | 500      | 345      |
| Unit 5             | 11.00        | 316.56        | 510      | 350      |
| <b>Total</b>       | <b>25.24</b> | <b>827.96</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 4.68         | 136.25        | 200      | 165      |
| Unit 4             | 4.44         | 112.67        | 191      | 160      |
| Unit 5             | 10.12        | 301.99        | 435      | 370      |
| Unit 6             | 10.90        | 136.98        | 475      | 395      |
| Unit 7             | 0.00         | 258.13        | 0        | 0        |
| <b>Total</b>       | <b>30.15</b> | <b>946.01</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 6.01         | 168.97        | 258      | 222      |
| Unit 4             | 6.06         | 164.24        | 261      | 236      |
| <b>Total</b>       | <b>12.07</b> | <b>333.21</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 4.02         | 120.47        | 175      | 155      |
| Unit 2             | 4.12         | 110.28        | 180      | 160      |
| Unit 3             | 4.73         | 132.76        | 210      | 161      |
| Unit 4             | 4.56         | 132.26        | 210      | 158      |
| Unit 5             | 7.48         | 147.20        | 400      | 190      |
| <b>Total</b>       | <b>24.90</b> | <b>642.97</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 4.52         | 124.97        | 205      | 165      |
| Unit 4             | 4.43         | 130.11        | 200      | 163      |
| Unit 5             | 4.47         | 106.79        | 203      | 162      |
| <b>Total</b>       | <b>13.42</b> | <b>361.87</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 10.29        | 295.62        | 450      | 408      |
| <b>Total</b>       | <b>10.29</b> | <b>295.62</b> |          |          |

| Generating unit   | Generation    |                |          |          |
|-------------------|---------------|----------------|----------|----------|
|                   | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>PENCH (MS)</b> |               |                |          |          |
| Pench (MS)        | 0.18          | 3.61           | 33       | 0        |
| <b>Total</b>      | <b>0.18</b>   | <b>3.61</b>    |          |          |
| <b>Koyna</b>      |               |                |          |          |
| Stage 1-2         | 3.89          | 125.90         | 470      | 40       |
| Stage 4           | 0.00          | 87.25          | 749      | 0        |
| Stage 3           | 2.83          | 51.05          | 160      | 0        |
| <b>Total</b>      | <b>6.72</b>   | <b>264.20</b>  |          |          |
| <b>Hydro</b>      |               |                |          |          |
| KDPH              | 0.62          | 19.12          | 26       | 25       |
| VTRNA             | 0.14          | 14.54          | 61       | 0        |
| TILLARI           | 0.36          | 7.35           | 60       | 0        |
| BHTGR/VEER        | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.        | 0.24          | 5.82           | 40       | 0        |
| RNGR+BHTSA        | 0.02          | 5.72           | 1        | 0        |
| BHANDARDRA        | 0.19          | 0.98           | 34       | 0        |
| ELDARY            | 0.00          | 0.69           | 0        | 0        |
| SMLHY_PTN         | 0.11          | 17.13          | 5        | 4        |
| GHATGHAR          | 1.62          | 21.04          | 250      | 0        |
| <b>Total</b>      | <b>3.30</b>   | <b>92.38</b>   |          |          |
| <b>Wind</b>       |               |                |          |          |
| Total             | 13.60         | 403.32         | 0        | 0        |
| <b>Total</b>      | <b>13.60</b>  | <b>403.32</b>  |          |          |
| <b>CPP</b>        |               |                |          |          |
| APML(Mus)         | 50.27         | 1793.11        | 0        | 0        |
| JSWEL(Mus)        | 22.35         | 749.23         | 0        | 0        |
| VIPL(Mus)         | 14.04         | 386.40         | 0        | 0        |
| RPLAMT(Mus)       | 17.67         | 488.89         | 0        | 0        |
| WPCL(Mus)         | 4.30          | 135.16         | 0        | 0        |
| Other(Mus)        | 6.16          | 204.83         | 0        | 0        |
| <b>Total</b>      | <b>114.79</b> | <b>3757.62</b> |          |          |
| <b>SOLAR</b>      |               |                |          |          |
| Total             | 1.33          | 39.97          | 0        | 0        |
| <b>Total</b>      | <b>1.33</b>   | <b>39.97</b>   |          |          |
| <b>Tata</b>       |               |                |          |          |
| Trombay 5         | 10.02         | 302.71         | 444      | 329      |
| Trombay 6         | 0.00          | 0.06           | 0        | 0        |
| Trombay 7A        | 2.74          | 76.94          | 116      | 94       |
| Trombay 7B        | 1.53          | 45.10          | 65       | 57       |
| Trombay 8         | 5.81          | 171.33         | 249      | 234      |
| TATA Hydro        | 2.49          | 96.84          | 276      | 6        |
| <b>Total</b>      | <b>22.59</b>  | <b>692.97</b>  |          |          |
| <b>R-INFRA</b>    |               |                |          |          |
| 1-2               | 11.48         | 199.04         | 516      | 401      |
| <b>Total</b>      | <b>11.48</b>  | <b>199.04</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
| Chandrapur 8   | 0.00        | 0.00    | MSPGCL Thermal  | 113.94      | 3183.14       | MSPGCL Total        | 134.24      | 3835.34       |
| Chandrapur 9   | 0.00        | 0.00    | MSPGCL Thml+Gas | 124.23      | 3478.76       | Koyna 1,2 & 4 Total | 3.89        | 213.15        |
| Koradi 9       | 0.00        | 0.00    | MSPGCL Hydro    | 10.02       | 356.58        | State Total         | 298.03      | 8928.26       |
| Parli 8        | 0.00        | 0.00    |                 |             |               |                     |             |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Hourly Load Data As on 30/Apr/2016**

**Annexure-2**

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |       | TOTAL  | WIND  | CPP /<br>IPP | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|-------|--------|-------|--------------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS   |        |       |              |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4655        | 989   | 440   | 6084   | 528   | 4730         | 0     | 5419        | 5496        | -1292                | 15546                 | 0                    | 15546                     | 2626             | 18172           | 49.99         |
| 2                  | 4713        | 397   | 441   | 5551   | 406   | 4729         | 0     | 5287        | 4976        | -1049                | 14613                 | 0                    | 14613                     | 2400             | 17013           | 50.01         |
| 3                  | 4894        | 202   | 431   | 5527   | 536   | 4740         | 0     | 5159        | 5191        | -857                 | 15136                 | 0                    | 15136                     | 2221             | 17358           | 50.01         |
| 4                  | 4790        | 111   | 441   | 5342   | 536   | 4689         | 0     | 5131        | 5239        | -835                 | 14971                 | 0                    | 14971                     | 2140             | 17111           | 50.00         |
| 5                  | 4626        | 405   | 431   | 5462   | 598   | 4543         | 0     | 5124        | 5310        | -819                 | 15094                 | 0                    | 15094                     | 2058             | 17152           | 50.01         |
| 6                  | 4911        | 321   | 431   | 5663   | 575   | 4718         | 0     | 5121        | 4948        | -684                 | 15220                 | 1                    | 15221                     | 2061             | 17282           | 50.00         |
| 7                  | 4930        | 436   | 439   | 5805   | 542   | 4735         | 2     | 5189        | 4926        | -653                 | 15357                 | 1                    | 15358                     | 2032             | 17390           | 50.05         |
| 8                  | 4905        | 407   | 435   | 5747   | 428   | 4754         | 35    | 5221        | 4951        | -677                 | 15238                 | 0                    | 15238                     | 2059             | 17297           | 50.03         |
| 9                  | 4930        | 415   | 450   | 5795   | 447   | 4755         | 87    | 5283        | 5156        | -904                 | 15336                 | 0                    | 15336                     | 2283             | 17619           | 50.00         |
| 10                 | 4968        | 608   | 417   | 5993   | 317   | 4766         | 125   | 5452        | 6112        | -1197                | 16116                 | 0                    | 16116                     | 2633             | 18748           | 50.01         |
| 11                 | 4939        | 1365  | 420   | 6724   | 299   | 4887         | 157   | 5491        | 5522        | -1372                | 16217                 | 0                    | 16217                     | 2877             | 19094           | 49.97         |
| 12                 | 4938        | 1407  | 409   | 6754   | 308   | 4870         | 185   | 5488        | 5504        | -1386                | 16235                 | 1                    | 16236                     | 2960             | 19196           | 49.96         |
| 13                 | 4948        | 1352  | 413   | 6713   | 322   | 4857         | 190   | 5503        | 5244        | -1390                | 15936                 | 1                    | 15937                     | 2974             | 18911           | 49.98         |
| 14                 | 4947        | 1225  | 408   | 6580   | 408   | 4852         | 153   | 5480        | 5242        | -1368                | 15867                 | 0                    | 15867                     | 2938             | 18805           | 49.99         |
| 15                 | 4936        | 1130  | 414   | 6480   | 361   | 4881         | 169   | 5552        | 5494        | -1382                | 16003                 | 0                    | 16003                     | 2973             | 18976           | 49.93         |
| 16                 | 4935        | 1383  | 429   | 6747   | 414   | 4902         | 117   | 5564        | 5411        | -1384                | 16207                 | 0                    | 16207                     | 2969             | 19176           | 49.85         |
| 17                 | 4839        | 799   | 419   | 6057   | 466   | 4889         | 75    | 5516        | 5420        | -1347                | 15560                 | 0                    | 15560                     | 2926             | 18486           | 49.99         |
| 18                 | 4557        | 252   | 432   | 5241   | 674   | 4777         | 29    | 5439        | 5229        | -1311                | 14639                 | 0                    | 14639                     | 2825             | 17464           | 50.01         |
| 19                 | 4217        | 176   | 423   | 4816   | 959   | 4611         | 3     | 5357        | 5581        | -1360                | 14610                 | 0                    | 14610                     | 2666             | 17276           | 50.02         |
| 20                 | 4402        | 819   | 435   | 5656   | 1080  | 4706         | 0     | 5425        | 5124        | -1363                | 15203                 | 0                    | 15203                     | 2756             | 17959           | 49.99         |
| 21                 | 4417        | 649   | 427   | 5493   | 913   | 4860         | 0     | 5426        | 5285        | -1290                | 15262                 | 0                    | 15262                     | 2723             | 17984           | 49.97         |
| 22                 | 4415        | 385   | 430   | 5230   | 842   | 4846         | 0     | 5419        | 5616        | -1414                | 15120                 | 0                    | 15120                     | 2685             | 17805           | 49.99         |
| 23                 | 4416        | 476   | 440   | 5332   | 884   | 4845         | 0     | 5468        | 5212        | -1317                | 14956                 | 0                    | 14956                     | 2607             | 17563           | 49.93         |
| 24                 | 4707        | 641   | 437   | 5785   | 762   | 4852         | 0     | 5416        | 5395        | -1292                | 15502                 | 0                    | 15502                     | 2615             | 18117           | 49.96         |
| MUs                | 113.94      | 16.35 | 10.29 | 140.58 | 13.61 | 114.79       | 1.33  | 128.93      | 127.58      | -27.94               | 369.94                | 0.00                 | 369.95                    | 62.01            | 431.95          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 30/Apr/2016**

**Position as on 6.30 Hrs of 01/May/2016**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                            | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                             |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synchronised 07.04.2016 (12.03hrs To 12.30hrs)After overhaul |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 10/09/2015   | 12.55        |            | Continued. | Refuelling work                                                                                                             |               |
| MSPGCL                | Koyna Unit 10           | 80       | 29/12/2015   | 08:00        |            | Continued. | Annual Overhaul                                                                                                             |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                             |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                                                                                                               |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                                                                                                                |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                                                                                                                |               |
| IPP                   | Dhariwal                | 300      | 28/05/2014   | 02.27        |            | Continued. | No schedule                                                                                                                 |               |
| MSPGCL                | Chandrapur Unit 1       | 210      | 28/08/2014   | 07:15        |            | Continued. | Economic Shutdown.                                                                                                          |               |
| MSPGCL                | Koradi Unit 6           | 210      | 20/03/2015   | 01.02        |            | Continued. | Economic shutdown                                                                                                           |               |
| MSPGCL                | Parli Unit 3            | 210      | 14/06/2015   | 12.58        |            | Continued. | Water Shortage                                                                                                              |               |
| MSPGCL                | Parli Unit 6            | 250      | 25/06/2015   | 15.03        |            | Continued. | Water Shortage                                                                                                              |               |
| MSPGCL                | Parli Unit 4            | 210      | 05/07/2015   | 18.45        |            | Continued. | Water Shortage                                                                                                              |               |
| MSPGCL                | Parli Unit 5            | 210      | 06/07/2015   | 14.55        |            | Continued. | Water Shortage.                                                                                                             |               |
| MSPGCL                | Parli Unit 7            | 250      | 08/07/2015   | 12.08        |            | Continued. | Water Shortage                                                                                                              |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 10/11/2015   | 12.10        |            | Continued. | Drum level low                                                                                                              |               |
| RGPL                  | Dabhol 3B               | 230      | 07/01/2016   | 17:51        |            | Continued. | Change Over.                                                                                                                |               |
| MSPGCL                | Chandrapur Unit 2       | 210      | 12/01/2016   | 04.47        |            | Continued. | Boiler Tube Leakage                                                                                                         |               |
| CPP                   | WPCL U-1                | 135      | 16/02/2016   | 17.09        |            | Continued. | Change Over , No Schedule                                                                                                   |               |
| MSPGCL                | Koradi Unit 5           | 200      | 18/02/2016   | 11.21        |            | Continued. | MSEDCL Zero Shedule.                                                                                                        |               |
| IPP                   | WPCL U-2                | 135      | 29/02/2016   | 21.46        |            | Continued. | Change over against Unit III                                                                                                |               |
| MSPGCL                | Koradi Unit 7           | 210      | 01/03/2016   | 23.55        |            | Continued. | Zero Schedule Given by MSEDCL.                                                                                              |               |
| MSPGCL                | Koyna Unit 11           | 80       | 11/03/2016   | 13.53        |            | Continued. | stator earth fault                                                                                                          |               |
| MSPGCL                | Koradi Unit 9           | 660      | 21/03/2016   | 00.47        |            | Continued. | Ash Evacuation problem                                                                                                      |               |
| IPP                   | Adani U-3               | 660      | 20/04/2016   | 03.33        |            | Continued. | Furnace Pressure High                                                                                                       |               |
| IPP                   | RPL(AMT) U-1            | 270      | 20/04/2016   | 17.14        |            | Continued. | Zero Schedule Given by MSEDCL.                                                                                              |               |
| IPP                   | RPL(AMT) U-3            | 270      | 20/04/2016   | 20.50        |            | Continued. | Zero Schedule Given by MSEDCL.                                                                                              |               |
| IPP                   | JSW (J) U1              | 300      | 22/04/2016   | 09.43        | 30/04/2016 | 16.18      | Air Pre Heater Problem.                                                                                                     |               |
| MSPGCL                | Uran Unit 7             | 108      | 23/04/2016   | 15.11        |            | Continued. | Gas shortage                                                                                                                |               |
| RGPL                  | Dabhol 2B               | 230      | 26/04/2016   | 13.12        |            | Continued. | P.M.WORK                                                                                                                    |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 28/04/2016   | 20.36        |            | Continued. | Boiler Tube Leakage                                                                                                         |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 29/04/2016   | 11.43        | 01/05/2016 | 02.39      | Boiler Tube Leakage                                                                                                         |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 30/Apr/2016**

**Position as on 6.30 Hrs of 01/May/2016**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage    | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------|---------------|
| MSPGCL             | Khaparkheda Unit 5      | 500      | 01/05/2016   | 18.16        |           | Continued. | Boiler Tube Leakage |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 30/Apr/2016**

**Statement-VII**

Position as on 6.30 Hrs of 01/May/2016

| Name of Line                         | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|--------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Chandrapur - Padghe Hvdc Pole 2      | IntraState                | 30/04/2016   | 23.30        | 01/05/2016 | 1.48       | PO          | Trauble Shooting DG-2 Problem & Taking Capacity Test Of Value Cooling UPS Battery Set.                              |
| Chandrapur - Padghe Hvdc Pole 1      | IntraState                | 01/05/2016   | 01.54        | 01/05/2016 | 04.01      | PO          | Trauble Shooting DG-1 Problem & Taking Capacity Test Of Value Cooling UPS Battery Set.                              |
| <b>400 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Dhule Sar'Sarovar I                  | InterState                | 27/04/2016   | 18.02        |            | Continued. | HT          | Over Voltage (RFC At 18:50 30.04.2016)                                                                              |
| Dabhol Nagothane I                   | InterState                | 29/04/2016   | 04.08        | 30/04/2016 | 14.11      | T           | Distance Protection                                                                                                 |
| Koradi Satpur                        | InterState                | 30/04/2016   | 12.24        | 30/04/2016 | 15.27      | EO          | Attending Oil Leakage                                                                                               |
| Dabhol Newkoyana li                  | InterState                | 30/04/2016   | 14.42        | 30/04/2016 | 22.00      | PO          | Replacement Of Insulator String At LOC.No. 1&8.                                                                     |
| Chandrapur Bhadravati III            | InterState                | 01/05/2016   | 07.34        | 01/05/2016 | 10.25      | T           | Tripped over voltage At Bhadravati End, DT Recived At Chandrapur End.                                               |
| Chandrapur Bhadravati III            | InterState                | 01/05/2016   | 16.33        |            | Continued. | T           | Tripped over voltage At Bhadravati End, DT Recived At Chandrapur End.                                               |
| Kolhapur Solapur(PG) I               | InterState                | 01/05/2016   | 17.12        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Babhaleshwar-Taptitanda ckt-I        | IntraState                | 24/04/2016   | 18.11        |            | Continued. | HT          | Hand Tripped                                                                                                        |
| Akola II - Taptitanda ckt-I          | IntraState                | 27/04/2016   | 11.41        |            | Continued. | PO          | Dismantalling of Conductor Reorintetion.                                                                            |
| Bhusawal-Aurangabad                  | IntraState                | 27/04/2016   | 17.07        | 30/04/2016 | 10.40      | HT          | Over Voltage                                                                                                        |
| karad -kolhapur-I                    | IntraState                | 29/04/2016   | 16.08        | 30/04/2016 | 08.54      | HT          | Over Voltage                                                                                                        |
| Karad - Jaigad - II                  | IntraState                | 29/04/2016   | 16.35        | 30/04/2016 | 06.34      | HT          | Over Voltage                                                                                                        |
| karad -kolhapur-I                    | IntraState                | 30/04/2016   | 16.50        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Karad - Jaigad - II                  | IntraState                | 30/04/2016   | 17.14        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Bhusawal-Aurangabad                  | IntraState                | 30/04/2016   | 17.16        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Nagothane - Dabhol I                 | IntraState                | 01/05/2016   | 03.25        | 01/05/2016 | 15.32      | T           | Tripped On Distance Protection (LOC.No 2,3 Y-Phase String Decaping).                                                |
| Babhleshwar - RIPL(Nashik)           | IntraState                | 01/05/2016   | 12.32        | 01/05/2016 | 21.56      | PO          | Maintenance Work.                                                                                                   |
| <b>220 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Nasik Navsari I                      | InterState                | 10/04/2016   | 11.25        |            | Continued. | HT          | To control Load of Bus Coupler                                                                                      |
| Borivali - Tarapur                   | InterState                | 01/05/2016   | 07.26        | 01/05/2016 | 12.42      | T           | Safety Purpose Code 5/17.                                                                                           |
| Chandrapur GCR - Warora - I          | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| GIS Bhandup - Borivali               | IntraState                | 11/01/2016   | 07.42        |            | Continued. | PO          | Tower Erection Work.                                                                                                |
| Padghe - Vasai                       | IntraState                | 24/01/2016   | 08.32        |            | Continued. | PO          | For Formation of Temp. Padgha-Borivali (Charge upto 51/1).                                                          |
| Bableshtar- Ranjangaon               | IntraState                | 03/02/2016   | 07.12        |            | Continued. | HT          | To Control BBLSR ICT O/L                                                                                            |
| Bableshtar- Alephata                 | IntraState                | 19/03/2016   | 19.44        |            | Continued. | HT          | To control BBLSR ICT Loading                                                                                        |
| Pedambe-Nerle                        | IntraState                | 11/04/2016   | 13.10        |            | Continued. | PO          | CT Oil Leakage                                                                                                      |
| Nagar-Bose I                         | IntraState                | 30/04/2016   | 07.48        | 30/04/2016 | 12.17      | PO          | Quarterly Maintainance Work                                                                                         |
| Mumewadi-Belewadi                    | IntraState                | 01/05/2016   | 06.34        | 01/05/2016 | 18.55      | PO          | Tower Erection Work                                                                                                 |
| Kalwa - Borivali                     | IntraState                | 01/05/2016   | 06.40        | 01/05/2016 | 13.39      | PO          | String Replacement Work.                                                                                            |
| Hamidwada-Mumewadi                   | IntraState                | 01/05/2016   | 06.50        | 01/05/2016 | 18.42      | PO          | Tower Erection Work.                                                                                                |
| Ongc Uran - Jnpt                     | IntraState                | 01/05/2016   | 08.32        | 01/05/2016 | 14.15      | PO          | Maintenance Work.                                                                                                   |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 30/Apr/2016**

**Statement-VII**

Position as on 6.30 Hrs of 01/May/2016

| Name of Line                            | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                         |
|-----------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|--------------------------------------------------------------------------|
| Uran - Jnpt                             | IntraState                   | 01/05/2016      | 08.34           | 01/05/2016 | 14.17         | PO             | Maintenance Work.                                                        |
| Raymond - TKES                          | IntraState                   | 01/05/2016      | 09.28           | 01/05/2016 | 17.56         | PO             | Maintenance Work.                                                        |
| Chalisgaon-Malegaon                     | IntraState                   | 01/05/2016      | 13.25           | 01/05/2016 | 16.45         | T              | Y & B Phase Fault Fire Between<br>LOC No. 84 To 85                       |
| <b>220 KV ICT Outages/Trippings</b>     |                              |                 |                 |            |               |                |                                                                          |
| 220/100 Kv 200 MVA ICT III<br>@Borivali | IntraState                   | 21/09/2014      | 09.16           |            | Continued.    | T              | Failed on internal Fault(Now<br>repaired and ready for<br>commissioning) |
| <b>100 KV LINE Outages/Trippings</b>    |                              |                 |                 |            |               |                |                                                                          |
| 100KV Kalwa - Sify                      | IntraState                   | 01/05/2016      | 07.15           | 01/05/2016 | 09.07         | PO             | Routine Maintenance Work                                                 |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage