

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 30/Apr/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	161.712	4982.529	1) Gujrat	-3.156	-114.524
2) Hydro	19.246	864.886	2) Madhya Pradesh	8.038	270.410
3) Gas	5.972	192.507	3) Chattisgarh	3.930	136.810
Total MSPGCL	186.930	6039.922	4) Maharashtra	192.187	5352.092
B) 1) APLM	75.335	2084.705	5) Goa (Amona)	-1.566	-46.774
2) JSWEL	22.270	610.953	Total	199.433	5598.014
3) VIPL	0.000	0.000	a) Mumbai Schedule	36.284	908.849
4) RPL(AMT)	28.184	923.751	b) Mumbai Drawl	39.157	1022.989
5) SWPGPL	9.492	245.849	c) MSEDCL Bilateral *	84.075	2169.092
6) Other IPP	26.410	961.397	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	36.284	904.951
C) 1) TPCL Thermal	15.607	475.550	Include PX	0.000	0.858
2) TPCL Hydro	3.681	125.566	Standby	0.000	3.898
3) TPCL Gas	2.639	93.236	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.084	347.654	1) MSEDCL	536.065	15862.203
D) STATE			2) Mumbai Discoms	72.168	2065.002
1) Thermal	350.094	10632.388	3) Other Discoms	9.243	272.624
(A1+C1+C4+(B1-B6))			TOTAL STATE	617.476	18199.829
2) Hydro (A2+C2)	22.927	990.452			
3) Gas (A3+B7+C3)	8.611	285.743			
4) Wind	26.416	431.858			
6) SOLAR	9.995	261.367			
TOTAL STATE	418.043	12601.808			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6715	6518	6647	6945
MSPGCL Hydro	422	408	966	468
MSPGCL Gas	247	236	247	256
MSPGCL Total Generation	7384	7162	7860	7668
Central Sector Receipt	9906	9971	7590	7914
WIND	493	626	1282	782
CPP / IPP Thermal	6645	6671	6760	6606
CPP / IPP Gas	0	0	0	0
SOLAR	1229	1314	0	342
Exchange with Mumbai	-1974	-1992	-1622	-1282
MSEDCL DEMAND MET	23273	23354	21449	21629
Load Shedding	0	0	0	0
MSEDCL DEMAND	23273	23354	21449	21629
TPCL GENERATION	925	904	1005	771
AEML GENERATION	478	467	454	462
MUMBAI DEMAND	3377	3363	3081	2515
OTHER DISCOM DEMAND	409	398	421	401
STATE DEMAND MET	27060	27116	24950	24546
STATE DEMAND	27060	27116	24950	24546
Frequency (Hz)	49.94	50.01	50.03	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 18.05 Hrs	49.7 Hz at 00.13 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 30/Apr/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.24	123.71	200	160
Unit 7	0.00	0.00	0	0
Unit 8	14.27	401.76	605	503
Unit 9	13.33	409.18	595	512
Unit 10	13.46	190.00	585	530
Total	45.31	1124.66		
Bhusawal				
Unit 3	3.08	78.69	135	110
Unit 4	8.57	271.87	430	280
Unit 5	8.14	273.98	400	280
Total	19.78	624.54		
Parli				
Unit 6	0.00	120.03	0	0
Unit 7	4.45	136.12	227	112
Unit 8	3.26	99.90	151	129
Total	7.71	356.05		
Chandrapur				
Unit 3	4.28	125.55	186	172
Unit 4	3.78	113.20	165	149
Unit 5	8.50	248.68	385	325
Unit 6	0.00	215.35	0	0
Unit 7	8.96	269.16	395	335
Unit 8	10.90	315.86	480	426
Unit 9	9.28	303.12	439	287
Total	45.69	1590.92		
Paras				
Unit 3	3.99	156.14	212	127
Unit 4	4.55	149.59	217	136
Total	8.54	305.72		
Khaparkheda				
Unit 1	3.06	93.14	140	105
Unit 2	3.69	99.54	160	150
Unit 3	4.36	116.43	187	176
Unit 4	3.20	100.90	155	123
Unit 5	11.18	326.73	480	430
Total	25.48	736.74		
Nasik				
Unit 3	4.02	117.09	187	125
Unit 4	1.71	74.49	170	0
Unit 5	3.46	52.31	165	118
Total	9.19	243.89		
Uran				
All Units	5.97	192.51	267	217
Total	5.97	192.51		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.10	3.79	24	0
Total	0.10	3.79		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.12	186.68	515	40
Stage 4	5.32	325.89	1000	0
Stage 3	2.21	111.08	320	0
Total	11.66	623.65		
Hydro				
KDPH	0.37	22.23	16	16
VTRNA	0.87	24.01	60	0
TILLARI	0.58	14.79	58	0
BHIRA T.R.	0.28	5.96	77	0
SMLHY_PTN	5.38	163.10	248	179
GHATGHAR	0.00	7.35	0	0
Total	7.49	237.45		
Wind				
Total	26.42	431.86	0	0
Total	26.42	431.86		
CPP				
APML(Mus)	75.34	2084.70	0	0
JSWEL(Mus)	22.27	610.95	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	28.18	923.75	0	0
SWPGPL-Mus	9.49	245.85	0	0
Other(Mus)	26.41	961.40	0	0
Total	161.69	4826.66		
SOLAR				
Total	10.00	261.37	0	0
Total	10.00	261.37		
Tata				
Trombay 5	10.13	315.44	445	400
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.49	55.68	85	52
Trombay 7B	1.15	37.56	56	43
TATA Hydro	3.68	125.57	299	35
Trombay 8	5.48	160.11	235	219
Total	21.93	694.35		
AEML				
DTPS U-1&2	11.08	347.65	497	420
Total	11.08	347.65		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	161.71	4982.53	MSPGCL Total	186.93	6039.92
			MSPGCL Thml+Gas	167.68	5175.04	Koyna 1,2 & 4 Total	9.44	512.57
			MSPGCL Hydro	19.25	864.89	State Total	418.04	12601.81

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 30/Apr/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6715	2072	256	9044	1383	6794	0	0	7842	7836	-1593	23106	0	23106	3117	358	26580	49.92
2	6700	1864	267	8830	1417	6762	0	0	7927	7938	-1504	23115	0	23115	2912	328	26356	49.99
3	6723	1630	257	8610	1390	6793	0	0	7636	7737	-1389	22824	0	22824	2739	318	25880	49.98
4	6795	1056	256	8106	1302	6783	0	0	7744	7777	-1284	22399	0	22399	2583	285	25268	49.99
5	6876	802	257	7934	1221	6796	0	0	7985	8237	-1249	22626	0	22626	2515	314	25454	49.99
6	6907	968	267	8142	1088	6782	0	0	7961	8204	-1293	22602	0	22602	2541	321	25464	49.94
7	6996	954	257	8208	865	6718	0	54	8000	8073	-1239	22316	0	22316	2485	363	25164	50.00
8	6945	468	256	7668	782	6606	0	342	7656	7914	-1282	21629	0	21629	2515	401	24546	50.03
9	6742	322	267	7332	592	6184	0	697	7793	8253	-1505	21149	0	21149	2706	404	24258	50.07
10	6877	450	267	7594	490	6501	0	1009	8356	8635	-1666	22151	0	22151	2997	412	25560	49.95
11	6775	412	237	7424	438	6639	0	1225	9154	9562	-1876	22997	0	22997	3263	416	26676	49.98
12	6715	422	247	7384	493	6645	0	1229	9663	9906	-1974	23273	0	23273	3377	409	27060	49.94
13	6518	408	236	7162	626	6671	0	1314	10271	9971	-1992	23354	0	23354	3363	398	27116	50.01
14	6549	386	217	7152	787	6729	0	1298	9978	9473	-1961	23082	0	23082	3295	396	26772	50.03
15	6622	390	237	7248	972	6800	0	1114	9804	9501	-2060	23170	0	23170	3373	406	26948	49.87
16	6635	748	227	7610	1069	6861	0	915	9293	9091	-2070	23073	0	23073	3430	404	26906	49.93
17	6762	654	227	7642	1395	6866	0	543	8501	8655	-1853	22819	0	22819	3353	429	26602	49.93
18	6736	542	246	7524	1620	6713	0	226	7667	7761	-1711	21688	0	21688	3207	446	25340	50.02
19	6605	460	237	7302	1570	6762	0	29	6834	7199	-1611	20810	0	20810	3060	441	24312	50.06
20	6647	966	247	7860	1282	6760	0	0	7206	7590	-1622	21449	0	21449	3081	421	24950	50.03
21	6768	752	237	7756	1300	6874	0	0	7261	7351	-1606	21259	0	21259	3076	417	24752	49.99
22	6773	520	267	7560	1370	6873	0	0	7158	7456	-1559	21295	0	21295	3038	404	24738	49.97
23	6683	740	246	7668	1541	6880	0	0	7419	7859	-1596	21961	0	21961	3045	391	25398	50.00
24	6648	1262	257	8166	1423	6899	0	0	7449	7454	-1662	21917	0	21917	3097	363	25378	49.97
MUs	161.71	19.25	5.97	186.93	26.42	161.69	0.00	10.00	196.56	199.43	-39.16	536.06	0.00	536.06	72.17	9.24	617.48	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 30/Apr/2022

Position as on 6.30 Hrs of 01/May/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	03/05/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit 5	108	20/04/2022	16::27		Continued.	Gas shortage	
MSPGCL	Parli Unit 6	250	28/04/2022	05:35	01/05/2022	01:15	Boiler Tube Leakage	30/04/2022
IPP	RPL(AMT) U-3	270	28/04/2022	16:15	30/04/2022	12:17	BOTTOM ASH EVACUATION PROBLEM.	30/04/2022
MSPGCL	Chandrapur Unit 6	500	29/04/2022	00:15		Continued.	Boiler Tube Leakage	02/05/2022
MSPGCL	Nasik Unit 4	210	30/04/2022	11:46	01/05/2022	06:17	Main Steam Line Leakage	
MSPGCL	Parli Unit 7	250	01/05/2022	05:22		Continued.	Boiler Tube Leakage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 30/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 01/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY - 402 OF BUS REACTOR @ ALKUD	IntraState	29/04/2022	15:25			EO	For breaker replacement work
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	01/05/2022	13:47	01/05/2022	20:02	T	Tripped on Distance Protection.
CHANDRAPUR - BHADRAVATI CKT - 4	InterState	01/05/2022	16:28	01/05/2022	18:51	T	Tripped on Distance Protection.
TBC @ CHAKAN	IntraState	27/04/2022	13:16	30/04/2022	18:39	EO	Replacement of R, Y and B phases of 89C PG isolators of 400 KV TBC is to be done as their operating mechanisms are mechanically jammed and are difficult to dislodge.
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	28/04/2022	21:34	30/04/2022	04:58	T	TRIPPED ON DIST PROTECTION
BABHALESHWAR - PADGHE CKT-1	IntraState	30/04/2022	04:07	30/04/2022	10:33	EO	1. To attend Hot-Spot at jumpers of Cut-point Towers. Loc. No. 780; 755 under 500kV HVDC TL O&M Sub Division, Junner. 2. To attend Hot-Spot at jumpers of Cut-point Towers. Loc. No. 866; 40 under 500kV HVDC TL O&M Sub Division, Padghe. 3. Hot spot to be attended at 400kV Padghe Substation Y ph CT : 89deg Bph CT : 103deg A bus Yph B bus side 102deg
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	30/04/2022	11:21			HT	HT for Load Management
KORADI - KHADKA	IntraState	30/04/2022	12:10	30/04/2022	14:08	T	Distance Protection
KORADI-NANDGAONPETH (RPL)	IntraState	30/04/2022	12:12	30/04/2022	13:51	T	Distance Protection
LONIKAND I - CHAKAN	IntraState	30/04/2022	19:08	30/04/2022	20:54	EO	To replace priority weak insulator strings at tower loc 36 R phase (8 nos of disc weak), 36 B phase (7 nos of disc weak) detected by PID scanning on date 23.04.2022 . Outage required.
PARLI-SOLAPUR (LAMBOTI)	IntraState	01/05/2022	09:35	01/05/2022	17:04	EO	Flashover is observed on middle phase of location-219
LONIKAND I - KOYNA STAGE-IV	IntraState	01/05/2022	10:26	01/05/2022	10:57	T	TRIPPED ON DIST.PROTECTION
JEJURI- KOYNA STAGE-IV	IntraState	01/05/2022	10:30	01/05/2022	11:01	T	TRIPPED ON DIST.PROTECTION
CHANDRAPUR 2 - WARORA CKT-2	IntraState	01/05/2022	16:15	01/05/2022	18:28	T	Tripped on Distance Protection.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	01/05/2022	16:21	01/05/2022	17:49	T	Tripped on Distance Protection.
400 KV ICT Outages/Trippings							
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	29/04/2022	22:25	30/04/2022	00:48	EO	Hotspot attending work on LV R Ph (133 deg.celsius), Y Ph (98 degree celsius) bushings
400/220/20 KV 500MVA ICT - 3 @ KALWA	IntraState	01/05/2022	07:07	01/05/2022	19:36	PO	All diagnostic testing work, RTV coating required to avoid NDR tripping.
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	01/05/2022	20:15	01/05/2022	22:24	EO	Error observed in LV back up relay; needs to be attended urgently
400 KV BR Outages/Trippings							
80 MVAr Bus reactor @ Talandge	IntraState	24/04/2022	18:45			T	Differential Trip
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 30/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 01/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
NERUL - SEAWOOD CABLE CKT - 2	IntraState	30/04/2022	10:33	30/04/2022	16:44	PO	R & Y Phase CT replacement at Railway end by Railways
MAHAD-KALAMBANI(TSS)	IntraState	30/04/2022	10:49	30/04/2022	20:10	PO	Outage tree cutting work at Loc.No.163-164,190-191,201-204,205-207,211-212,213-214,219-220,229-230,231-232 and other line maintenance work.
BOISAR II - TARAPUR	IntraState	30/04/2022	11:32			PO	Replacement of existing 0.5 ACSR MOOSE Conductor at loc. No. 11- 28, replacement of heavily Rusted Hardware , heavily rusted earth-wire and all insulator strings of the line
BORIVALI - BOISAR (PG)	IntraState	30/04/2022	20:37	30/04/2022	23:01	EO	Replacement of damaged B-Ph jumper between Line Isolator and C.B.
CHAKAN - CHINCHWAD 2	IntraState	01/05/2022	00:20	01/05/2022	20:30	PO	Erection of two nos of monopole (without cross arm) at loc 19 & 20 within corridor of DC line. Outage needed for safety clearance only. No destringing or restringing will be done.
CHINCHWAD-2 - TELCO	IntraState	01/05/2022	00:44	01/05/2022	21:34	PO	Erection of two nos of monopole (without cross arm) at loc 19 & 20 within corridor of DC line. Outage needed for safety clearance only. No destringing or restringing will be done.
ANANDNAGAR - PALAVA	IntraState	01/05/2022	05:02	01/05/2022	09:30	PO	For R-Phase Wave Trap bottom side Critical hot spot attending work and bay R& M work
URAN - JNPT	IntraState	01/05/2022	09:02	01/05/2022	14:19	EO	M/s JNPT has proposed annual shutdown for their maintenance work. In opportunity outage MSETCL will carry out maintenance work
ONGC URAN - JNPT	IntraState	01/05/2022	09:02	01/05/2022	14:19	EO	Annual Shutdown Maintenance work of M/s JNPT and MSETCL will carry out work under opportunity outage
RAYMOND - TKEC	IntraState	01/05/2022	09:15	01/05/2022	16:15	PO	Maintenance work at consumer end.
KAMBA - VASAI	IntraState	01/05/2022	09:17	01/05/2022	14:22	EO	1) Loc No.3-4 DP 2 Y-PH insulator string replacement work due to spark observed on 1st string. (Image Attached) 2) Cold Line washing near Sureksha city, Vasai area. (For Y- phase identified LA IR test, bay maintenance work will be carried out in opportunity at 220KV Vasai ss)
ADLABS - PEDAMBE	IntraState	01/05/2022	10:30	01/05/2022	20:11	PO	Outage tree cutting work at Loc.No.163-164,184-186,199-200,211-213,279-280,281-282,290-291,293-294,298-302 and other line maintenance work.
RANJANGAON - U TECH SUGAR CKT	IntraState	01/05/2022	12:18	01/05/2022	17:45	PO	Work of attending Hot Spots at various Locations (All Hot Spots between 70 to 90 deg) & Fixing of Repair Sleeves to conductor.
RANJANGAON-FIAT 1	IntraState	01/05/2022	12:50	01/05/2022	16:25	PO	For Annual Relay testing work at consumer End

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 01/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
RANJANGAON-FIAT 2	IntraState	01/05/2022	16:40	01/05/2022	18:20	PO	For Annual Relay testing work at consumer End
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferrential protection and Declare faulty
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	01/03/2022	18:17			T	Differential Protection
220/22 KV 50 MVA PTR 2	IntraState	30/04/2022	09:15	30/04/2022	17:24	EO	Replacement of LV CT Y Phase due to heavy Oil Leakage.
220/132KV 100MVA ICT 1@ PETH	IntraState	30/04/2022	10:04	30/04/2022	13:13	PO	Quarterly maintenance & premonsoon maintenance work
220/132 KV 150 MVA ICT 1 @ SATANA	IntraState	30/04/2022	10:18	30/04/2022	11:31	PO	Premonsoon & bay maintenance work
220/132 KV 200 MVA ICT 2 @ SATANA	IntraState	30/04/2022	16:18	30/04/2022	17:42	PO	premonsoon & bay maintenance work
220/132 KV 150 MVA ICT-2 @BHENDA	IntraState	30/04/2022	18:18	30/04/2022	20:34	EO	To check the only measurement of Existing Main Buchholz relay with spare Buchholz relay (Spare Buchholz relay available under Division) for replacement due to tripping contacts are faulty of existing Main buchholz relay.
220/22 KV 50 MVA PTR 1 @ MULUND	IntraState	01/05/2022	05:18	01/05/2022	10:29	EO	1. EMERGENCY OUTAGE FOR 50MVA T/F- 1 LV 2B ₂ PH DROPPER JUMER HOTSPOT ATTENDING WORK.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 01/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
TATA AMBERNATH MSETCL NERAL	IntraState	01/05/2022	00:45	01/05/2022	02:48	HT	Emergency Outage for Attending Hotspots.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage