

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 30/May/2016 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 138.686        | 3877.284        | 1) Gujrat                      | 0.609          | -85.033          |
| 2) Hydro            | 11.385         | 293.103         | 2) Madhya Pradesh              | 14.931         | 390.674          |
| 3) Gas              | 6.724          | 288.333         | 3) Chattisgarh                 | 7.530          | 205.500          |
| <b>Total MSPGCL</b> | <b>156.795</b> | <b>4458.720</b> | 4) Maharashtra Net             | 112.243        | 3021.581         |
| B) 1) APML          | 14.614         | 812.854         | 5) Goa (Amona)                 | -0.922         | -23.098          |
| 2) JSWEL            | 27.349         | 812.302         | 6) TAPS 1&2 Injection          | 3.588          | 72.977           |
| 3) VIPL             | 14.251         | 372.558         | 7) RGPPL Injection             | 11.637         | 347.922          |
| 4) RPL(AMT)         | 6.338          | 418.296         | 8) Pench (MS)                  | 0.135          | 1.338            |
| 5) WPCL             | 2.660          | 84.799          | 9) Pench (Excess)              | -0.135         | -1.338           |
| 6) Other IPP        | 4.983          | 155.987         | <b>Total</b>                   | <b>149.481</b> | <b>3929.185</b>  |
| C) 1) TPCL Thermal  | 16.793         | 475.579         | a) Mumbai Schedule             | 30.052         | 757.533          |
| 2) TPCL Hydro       | 4.117          | 83.698          | b) Mumbai Drawl                | 35.136         | 945.210          |
| 3) TPCL Gas         | 2.519          | 115.518         | c) MSEDCL Bilateral *          | 41.408         | 1044.051         |
| 4) R-INFRA Thermal  | 11.971         | 336.517         | Include PX                     | 2.069          | -3.190           |
| <b>D) STATE</b>     |                |                 | d) Mumbai Bilateral *          | 30.052         | 757.533          |
| 1) Thermal          | 237.645        | 7346.176        | Include PX                     | 4.498          | 89.204           |
| (A1+C1+C4+(B1-B6))  |                |                 | Include Standby                | 0.000          | 0.000            |
| 2) Hydro            | 15.502         | 376.801         | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 3) Gas              | 9.243          | 403.851         | 1) MSEDCL                      | 369.365        | 10826.328        |
| 4) Wind             | 26.430         | 686.660         | 2) Mumbai Discoms              | 70.536         | 1956.492         |
| 6) SOLAR            | 1.600          | 40.177          | <b>TOTAL STATE</b>             | <b>439.901</b> | <b>12782.820</b> |
| <b>TOTAL STATE</b>  | <b>290.420</b> | <b>8853.665</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 5 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5808                      | 5895                  | 5534                      | 5856                      |
| MSPGCL Hydro             | 1223                      | 829                   | 597                       | 81                        |
| MSPGCL Gas               | 281                       | 274                   | 281                       | 281                       |
| MSPGCL Total Generation  | 7312                      | 6998                  | 6412                      | 6218                      |
| Central Sector Receipt   | 7223                      | 7684                  | 6484                      | 5308                      |
| WIND                     | 605                       | 958                   | 1063                      | 1159                      |
| CPP / IPP                | 2914                      | 2897                  | 2945                      | 2886                      |
| SOLAR                    | 193                       | 135                   | 0                         | 0                         |
| Exchange with Mumbai     | -1655                     | -1722                 | -1376                     | -1193                     |
| <b>MSEDCL DEMAND MET</b> | <b>16592</b>              | <b>16950</b>          | <b>15528</b>              | <b>14378</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 16592                     | 16950                 | 15528                     | 14378                     |
| TPCL GENERATION          | 1154                      | 1284                  | 1124                      | 686                       |
| R-INFRA GENERATION       | 491                       | 495                   | 513                       | 402                       |
| <b>MUMBAI DEMAND</b>     | <b>3300</b>               | <b>3501</b>           | <b>3013</b>               | <b>2281</b>               |
| STATE DEMAND MET         | 19892                     | 20451                 | 18541                     | 16659                     |
| <b>STATE DEMAND</b>      | <b>19892</b>              | <b>20451</b>          | <b>18541</b>              | <b>16659</b>              |
| Frequency (Hz)           | 49.99                     | 49.99                 | 49.89                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.14 Hz at 06.03 Hrs | 49.76 Hz at 19.54 Hrs | 49.96         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 30/May/2016

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 5             | 0.00         | 22.34          | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 3.71         | 61.79          | 165      | 135      |
| Unit 8             | 7.93         | 295.52         | 355      | 280      |
| <b>Total</b>       | <b>11.64</b> | <b>379.65</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 2             | 3.30         | 65.52          | 145      | 130      |
| Unit 3             | 4.04         | 118.15         | 180      | 160      |
| Unit 4             | 12.00        | 308.11         | 505      | 490      |
| Unit 5             | 12.04        | 305.69         | 510      | 500      |
| <b>Total</b>       | <b>31.38</b> | <b>797.46</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| Unit 3             | 4.55         | 130.45         | 199      | 171      |
| Unit 4             | 4.38         | 128.84         | 185      | 177      |
| Unit 5             | 2.52         | 240.44         | 380      | 0        |
| Unit 6             | 7.09         | 269.27         | 450      | 0        |
| Unit 7             | 10.68        | 242.78         | 451      | 427      |
| <b>Total</b>       | <b>29.22</b> | <b>1011.78</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 5.86         | 135.85         | 250      | 238      |
| Unit 4             | 6.04         | 168.56         | 258      | 247      |
| <b>Total</b>       | <b>11.90</b> | <b>304.40</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 3.80         | 106.09         | 165      | 145      |
| Unit 2             | 3.90         | 113.12         | 175      | 140      |
| Unit 3             | 4.50         | 123.14         | 192      | 179      |
| Unit 4             | 4.35         | 111.05         | 191      | 162      |
| Unit 5             | 11.87        | 297.92         | 500      | 480      |
| <b>Total</b>       | <b>28.42</b> | <b>751.33</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 4.46         | 126.42         | 200      | 160      |
| Unit 4             | 4.57         | 119.20         | 201      | 167      |
| Unit 5             | 4.49         | 119.71         | 196      | 168      |
| <b>Total</b>       | <b>13.53</b> | <b>365.34</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 6.72         | 288.33         | 296      | 265      |
| <b>Total</b>       | <b>6.72</b>  | <b>288.33</b>  |          |          |

| Generating unit   | Generation   |                |          |          |
|-------------------|--------------|----------------|----------|----------|
|                   | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>PENCH (MS)</b> |              |                |          |          |
| Pench (MS)        | 0.14         | 1.34           | 43       | 0        |
| <b>Total</b>      | <b>0.14</b>  | <b>1.34</b>    |          |          |
| <b>Koyna</b>      |              |                |          |          |
| Stage 1-2         | 4.89         | 98.16          | 465      | 40       |
| Stage 4           | 1.91         | 82.10          | 519      | 0        |
| Stage 3           | 1.97         | 41.39          | 198      | 0        |
| <b>Total</b>      | <b>8.77</b>  | <b>221.65</b>  |          |          |
| <b>Hydro</b>      |              |                |          |          |
| KDPH              | 0.46         | 14.84          | 19       | 19       |
| VTRNA             | 0.00         | 0.29           | 0        | 0        |
| TILLARI           | 0.12         | 10.05          | 60       | 0        |
| BHTGR/VEER        | 0.00         | 0.00           | 0        | 0        |
| BHIRA T.R.        | 0.16         | 4.75           | 80       | 0        |
| RNGR+BHTSA        | 0.24         | 5.29           | 10       | 9        |
| BHANDARDRA        | 0.00         | 3.17           | 0        | 0        |
| ELDARY            | 0.00         | 0.00           | 0        | 0        |
| SMLHY_PTN         | 0.04         | 4.57           | 2        | 1        |
| GHATGHAR          | 1.60         | 28.50          | 240      | 0        |
| <b>Total</b>      | <b>2.62</b>  | <b>71.46</b>   |          |          |
| <b>Wind</b>       |              |                |          |          |
| Total             | 26.43        | 686.66         | 0        | 0        |
| <b>Total</b>      | <b>26.43</b> | <b>686.66</b>  |          |          |
| <b>CPP</b>        |              |                |          |          |
| APML(Mus)         | 14.61        | 812.85         | 0        | 0        |
| JSWEL(Mus)        | 27.35        | 812.30         | 0        | 0        |
| VIPL(Mus)         | 14.25        | 372.56         | 0        | 0        |
| RPLAMT(Mus)       | 6.34         | 418.30         | 0        | 0        |
| WPCL(Mus)         | 2.66         | 84.80          | 0        | 0        |
| Other(Mus)        | 4.98         | 155.99         | 0        | 0        |
| <b>Total</b>      | <b>70.20</b> | <b>2656.80</b> |          |          |
| <b>SOLAR</b>      |              |                |          |          |
| Total             | 1.60         | 40.18          | 0        | 0        |
| <b>Total</b>      | <b>1.60</b>  | <b>40.18</b>   |          |          |
| <b>Tata</b>       |              |                |          |          |
| Trombay 5         | 10.98        | 303.83         | 487      | 353      |
| Trombay 6         | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A        | 1.41         | 73.31          | 63       | 56       |
| Trombay 7B        | 1.11         | 42.21          | 49       | 44       |
| Trombay 8         | 5.81         | 171.75         | 249      | 215      |
| TATA Hydro        | 4.12         | 83.70          | 454      | 0        |
| <b>Total</b>      | <b>23.43</b> | <b>674.80</b>  |          |          |
| <b>R-INFRA</b>    |              |                |          |          |
| 1-2               | 11.97        | 336.52         | 514      | 402      |
| <b>Total</b>      | <b>11.97</b> | <b>336.52</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
| Chandrapur 8   | 2.24        | 6.75    | MSPGCL Thermal  | 138.69      | 3877.28       | MSPGCL Total        | 156.80      | 4458.72       |
| Chandrapur 9   | 0.00        | 1.92    | MSPGCL Thml+Gas | 145.41      | 4165.62       | Koyna 1,2 & 4 Total | 6.80        | 180.26        |
| Koradi 9       | 10.36       | 258.66  | MSPGCL Hydro    | 11.38       | 293.10        | State Total         | 290.42      | 8853.66       |
| Parli 8        | 0.00        | 0.00    |                 |             |               |                     |             |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Hourly Load Data As on 30/May/2016**

**Annexure-2**

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP /<br>IPP | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|--------------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       |              |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5729        | 265   | 279  | 6273   | 1626  | 2897         | 0     | 5372        | 5604        | -1552                | 14848                 | 0                    | 14848                     | 2874             | 17722           | 49.96         |
| 2                  | 5691        | 250   | 280  | 6221   | 1539  | 2953         | 0     | 5436        | 5448        | -1361                | 14800                 | 0                    | 14800                     | 2649             | 17449           | 49.98         |
| 3                  | 5784        | 71    | 280  | 6135   | 1516  | 2966         | 0     | 5771        | 5290        | -1202                | 14705                 | 0                    | 14705                     | 2488             | 17193           | 49.95         |
| 4                  | 5841        | 71    | 280  | 6192   | 1441  | 2918         | 0     | 5475        | 5165        | -1141                | 14575                 | 0                    | 14575                     | 2362             | 16937           | 49.97         |
| 5                  | 5856        | 81    | 281  | 6218   | 1159  | 2886         | 0     | 5182        | 5308        | -1193                | 14378                 | 0                    | 14378                     | 2281             | 16659           | 50.00         |
| 6                  | 5881        | 71    | 282  | 6234   | 1076  | 2905         | 0     | 5442        | 5782        | -1142                | 14855                 | 0                    | 14855                     | 2289             | 17144           | 50.02         |
| 7                  | 6085        | 76    | 296  | 6457   | 1039  | 2942         | 6     | 5698        | 5565        | -904                 | 15105                 | 0                    | 15105                     | 2243             | 17348           | 50.01         |
| 8                  | 5831        | 76    | 283  | 6190   | 930   | 2945         | 50    | 5959        | 6128        | -992                 | 15251                 | 0                    | 15251                     | 2337             | 17588           | 49.98         |
| 9                  | 5801        | 136   | 288  | 6225   | 846   | 2947         | 114   | 6016        | 6623        | -1389                | 15366                 | 0                    | 15366                     | 2721             | 18087           | 49.98         |
| 10                 | 5826        | 1106  | 289  | 7221   | 814   | 2947         | 149   | 6020        | 6618        | -1650                | 16099                 | 0                    | 16099                     | 3038             | 19137           | 49.97         |
| 11                 | 5808        | 1223  | 281  | 7312   | 605   | 2914         | 193   | 6738        | 7223        | -1655                | 16592                 | 0                    | 16592                     | 3300             | 19892           | 49.99         |
| 12                 | 5800        | 767   | 274  | 6841   | 574   | 2914         | 206   | 7074        | 7315        | -1676                | 16174                 | 0                    | 16174                     | 3411             | 19585           | 49.91         |
| 13                 | 5885        | 806   | 274  | 6965   | 549   | 2901         | 214   | 7206        | 7376        | -1709                | 16296                 | 0                    | 16296                     | 3477             | 19773           | 49.93         |
| 14                 | 5940        | 628   | 275  | 6843   | 457   | 2901         | 204   | 7122        | 7486        | -1695                | 16196                 | 0                    | 16196                     | 3367             | 19563           | 49.95         |
| 15                 | 5865        | 896   | 265  | 7026   | 722   | 2909         | 183   | 7220        | 7061        | -1729                | 16172                 | 0                    | 16172                     | 3485             | 19657           | 49.92         |
| 16                 | 5895        | 829   | 274  | 6998   | 958   | 2897         | 135   | 7222        | 7684        | -1722                | 16950                 | 0                    | 16950                     | 3501             | 20451           | 49.99         |
| 17                 | 5937        | 593   | 274  | 6804   | 968   | 2908         | 97    | 6703        | 6770        | -1758                | 15789                 | 0                    | 15789                     | 3495             | 19284           | 49.96         |
| 18                 | 5902        | 442   | 280  | 6624   | 1220  | 2897         | 44    | 5904        | 5649        | -1700                | 14734                 | 0                    | 14734                     | 3364             | 18098           | 49.96         |
| 19                 | 5598        | 240   | 284  | 6122   | 1305  | 2933         | 5     | 5543        | 5499        | -1547                | 14317                 | 0                    | 14317                     | 3044             | 17361           | 49.98         |
| 20                 | 5534        | 597   | 281  | 6412   | 1063  | 2945         | 0     | 5765        | 6484        | -1376                | 15528                 | 0                    | 15528                     | 3013             | 18541           | 49.89         |
| 21                 | 5456        | 889   | 279  | 6624   | 1474  | 2947         | 0     | 5859        | 5815        | -1402                | 15458                 | 65                   | 15523                     | 2955             | 18478           | 49.93         |
| 22                 | 5438        | 372   | 279  | 6089   | 1528  | 2939         | 0     | 5796        | 5884        | -1472                | 14968                 | 0                    | 14968                     | 2906             | 17874           | 49.94         |
| 23                 | 5614        | 345   | 282  | 6241   | 1547  | 2941         | 0     | 5853        | 5762        | -1558                | 14933                 | 65                   | 14998                     | 2919             | 17917           | 49.88         |
| 24                 | 5689        | 555   | 284  | 6528   | 1574  | 2943         | 0     | 5768        | 5942        | -1611                | 15376                 | 65                   | 15441                     | 3017             | 18458           | 49.94         |
| MUs                | 138.69      | 11.39 | 6.72 | 156.79 | 26.53 | 70.19        | 1.60  | 146.14      | 149.48      | -35.14               | 369.46                | 0.20                 | 369.66                    | 70.54            | 440.20          | 49.96         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center,Airoli (MSETCL) Statement-VI

## Details of Generating Unit Outages/Trippings for 30/May/2016

Position as on 6.30 Hrs of 31/May/2016

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                  | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                   |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 10/09/2015   | 12.55        |            | Continued. | Refuelling work                                                                                                   |               |
| MSPGCL                | Koyna Unit 10           | 80       | 29/12/2015   | 08:00        |            | Continued. | Annual Overhaul                                                                                                   |               |
| CENT.SECTOR           | TARAPUR-3               | 540      | 23/05/2016   | 20.30        |            | Continued. | Annual Maintenance Work.                                                                                          |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                   |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                                                                                                     |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                                                                                                      |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                                                                                                      |               |
| IPP                   | Dhariwal                | 300      | 28/05/2014   | 02.27        |            | Continued. | No schedule                                                                                                       |               |
| MSPGCL                | Koradi Unit 6           | 210      | 20/03/2015   | 01.02        |            | Continued. | Economic shutdown                                                                                                 |               |
| MSPGCL                | Parli Unit 6            | 250      | 25/06/2015   | 15.03        |            | Continued. | Water Shortage                                                                                                    |               |
| MSPGCL                | Parli Unit 4            | 210      | 05/07/2015   | 18.45        |            | Continued. | Water Shortage                                                                                                    |               |
| MSPGCL                | Parli Unit 5            | 210      | 06/07/2015   | 14.55        |            | Continued. | Water Shortage.                                                                                                   |               |
| MSPGCL                | Parli Unit 7            | 250      | 08/07/2015   | 12.08        |            | Continued. | Water Shortage                                                                                                    |               |
| RGPL                  | Dabhol 3B               | 230      | 07/01/2016   | 17:51        |            | Continued. | Change Over.                                                                                                      |               |
| CPP                   | WPCL U-1                | 135      | 16/02/2016   | 17.09        |            | Continued. | No Schedule                                                                                                       |               |
| IPP                   | WPCL U-2                | 135      | 29/02/2016   | 21.46        |            | Continued. | Change over against Unit III                                                                                      |               |
| MSPGCL                | Koyna Unit 11           | 80       | 11/03/2016   | 13.53        | 30/05/2016 | 16.30      | stator earth fault                                                                                                |               |
| IPP                   | Adani U-3               | 660      | 20/04/2016   | 03.33        |            | Continued. | Furnace Pressure High                                                                                             |               |
| CPP                   | WPCL U-4                | 135      | 03/05/2016   | 00.00        |            | Continued. | ESP Back Filter DP High                                                                                           |               |
| IPP                   | Adani U-5               | 660      | 05/05/2016   | 23.09        |            | Continued. | Due to Unavailblity of Water.                                                                                     |               |
| RGPL                  | Dabhol 3X               | 290      | 07/05/2016   | 18.40        |            | Continued. | Low Vaccum                                                                                                        |               |
| RGPL                  | Dabhol 3A               | 230      | 07/05/2016   | 18.44        |            | Continued. | Low Vaccum                                                                                                        |               |
| IPP                   | Adani U-1               | 660      | 13/05/2016   | 22.53        |            | Continued. | Water Shortage                                                                                                    |               |
| IPP                   | RPL(AMT) U-4            | 270      | 21/05/2016   | 16.15        |            | Continued. | Zero Schedule                                                                                                     |               |
| IPP                   | RPL(AMT) U-3            | 270      | 21/05/2016   | 18.10        |            | Continued. | Zero Schedule                                                                                                     |               |
| IPP                   | RPL(AMT) U-1            | 270      | 24/05/2016   | 00.00        |            | Continued. | Zero Schedule From MSEDCL                                                                                         |               |
| IPP                   | RPL(AMT) U-5            | 270      | 24/05/2016   | 00.05        |            | Continued. | Zero Schedule From MSEDCL                                                                                         |               |
| MSPGCL                | Koradi Unit 5           | 200      | 24/05/2016   | 00.05        | 31/05/2016 | 07.00      | Zero Schedule From MSEDCL                                                                                         |               |
| MSPGCL                | Uran Unit 7             | 108      | 24/05/2016   | 17.42        |            | Continued. | Generation Bearing Vibration High.                                                                                |               |
| IPP                   | Adani U-2               | 660      | 25/05/2016   | 21.22        |            | Continued. | Water Shortage.                                                                                                   |               |
| MSPGCL                | Chandrapur Unit 6       | 500      | 26/05/2016   | 22.00        | 30/05/2016 | 02.20      | Clinker Formation.                                                                                                |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 30/May/2016**

**Position as on 6.30 Hrs of 31/May/2016**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage               | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------|---------------|
| MSPGCL             | Chandrapur Unit-8       | 500      | 29/05/2016   | 22.13        | 30/05/2016 | 03.57      | Drum level low                 |               |
| MSPGCL             | Uran Unit B0            | 120      | 29/05/2016   | 23.17        |            | Continued. | Gas shortage                   |               |
| MSPGCL             | Uran Unit 8             | 108      | 29/05/2016   | 23.19        |            | Continued. | Gas shortage                   |               |
| MSPGCL             | Chandrapur Unit 5       | 500      | 30/05/2016   | 07.05        |            | Continued. | Boiler Tube Leakage            |               |
| MSPGCL             | Chandrapur Unit-8       | 500      | 30/05/2016   | 18.00        |            | Continued. | Turbine bearing Vabration high |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 30/May/2016**

**Statement-VII**

**Position as on 6.30 Hrs of 31/May/2016**

| Name of Line                         | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|--------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Dhule Sar'Sarovar I                  | InterState                | 29/05/2016   | 17.16        | 30/05/2016 | 08.30      | HT          | Over Voltage                                                                                                        |
| Dhule Sar'Sarovar II                 | InterState                | 30/05/2016   | 09.17        |            | Continued. | PO          | work at SSNL end(RFC 17.50Hrs)                                                                                      |
| Ektuni-Bableshwar ckt II             | IntraState                | 19/05/2016   | 09.44        |            | Continued. | HT          | To Control BBLR Padghe Loading.                                                                                     |
| Taptitanda-Ektuni ckt 2              | IntraState                | 28/05/2016   | 10.30        |            | Continued. | PO          | Dismantalling of Tower.                                                                                             |
| Karad-Jaigad - I                     | IntraState                | 28/05/2016   | 16.37        | 30/05/2016 | 08.47      | HT          | Over Voltage                                                                                                        |
| Khadka-Aurangabad (Waluj)            | IntraState                | 28/05/2016   | 22.17        | 30/05/2016 | 10.13      | HT          | Over Voltage                                                                                                        |
| karad -kolhapur-II                   | IntraState                | 29/05/2016   | 16.08        | 30/05/2016 | 08.43      | HT          | Over Voltage                                                                                                        |
| Lonikand I - Koyna stage-IV          | IntraState                | 30/05/2016   | 07.28        | 30/05/2016 | 19.40      | PO          | Insulator Replacement Work                                                                                          |
| karad -kolhapur-I                    | IntraState                | 30/05/2016   | 16.17        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Karad - Jaigad - II                  | IntraState                | 30/05/2016   | 16.20        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Bhusawal-Aurangabad                  | IntraState                | 30/05/2016   | 16.55        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Lonikand I - Koyna stage-IV          | IntraState                | 31/05/2016   | 06.58        |            | Continued. | PO          | Repl.of Disc Insulator String                                                                                       |
| <b>400 KV ICT Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                     |
| 400/220 KV 500 MVA ICT- I @Warora    | IntraState                | 06/05/2016   | 14.37        |            | Continued. | PO          | To Dismantle & Transport To Bahaleshwar.                                                                            |
| 400/220 KV 500 MVA ICT- II @Warora   | IntraState                | 13/05/2016   | 14.39        |            | Continued. | PO          | For Dismanteling Of ICT-I                                                                                           |
| 400/220 Kv 500 MVA ICT 3 @Kolhapur   | IntraState                | 30/05/2016   | 11.00        | 30/05/2016 | 19.38      | PO          | Routine Maintenance Work                                                                                            |
| 400/220 Kv 600 MVA ICT-II @Kalwa     | IntraState                | 31/05/2016   | 05.43        |            | Continued. | PO          | WTI/OTI Calibration                                                                                                 |
| <b>220 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Nasik Navsari I                      | InterState                | 16/05/2016   | 18.32        |            | Continued. | HT          | O/L of Interconnector betn. Nsk OCR & GCR                                                                           |
| Chandrapur GCR - Warora - I          | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| GIS Bhandup - Borivali               | IntraState                | 11/01/2016   | 07.42        |            | Continued. | PO          | Tower Erection Work.                                                                                                |
| Padghe - Vasai                       | IntraState                | 24/01/2016   | 08.32        |            | Continued. | PO          | For Formation of Temp. Padgha-Borivali (Charge upto 51/1).                                                          |
| Bableshwar- Ranjangaon               | IntraState                | 03/02/2016   | 07.12        |            | Continued. | HT          | To Control BBLSR ICT O/L                                                                                            |
| Bableshwar- Alephata                 | IntraState                | 19/03/2016   | 19.44        |            | Continued. | HT          | To control BBLSR ICT Loading                                                                                        |
| Badnera-Akola I                      | IntraState                | 30/05/2016   | 07.05        | 30/05/2016 | 18.50      | PO          | Repl.of Disc Insulator String                                                                                       |
| Loteparshuram- Dasturi Line          | IntraState                | 30/05/2016   | 09.14        | 30/05/2016 | 18.47      | PO          | Line Maintenance work                                                                                               |
| Main Bus @ Dasturi                   | IntraState                | 30/05/2016   | 09.40        | 30/05/2016 | 18.47      | PO          | Routine Maintenance Work                                                                                            |
| Dasturi-Kandalgaon Line              | IntraState                | 30/05/2016   | 09.40        | 30/05/2016 | 19.05      | PO          | Line Maintenance work                                                                                               |
| Kandalgaon - Topworth                | IntraState                | 30/05/2016   | 09.40        |            | Continued. | PO          | Modification of Supply to Pioneer Gas                                                                               |
| Main Bus @ Kharepatan                | IntraState                | 30/05/2016   | 10.10        | 30/05/2016 | 17.18      | PO          | Insulator washing                                                                                                   |
| Kharepatan -Pawas Line               | IntraState                | 30/05/2016   | 10.10        | 30/05/2016 | 17.18      | PO          | Insulator washing                                                                                                   |
| Butibori - Wardha                    | IntraState                | 30/05/2016   | 11.20        | 30/05/2016 | 15.56      | EO          | To attend Hot Spot                                                                                                  |
| Mumewadi -Halkarni I                 | IntraState                | 30/05/2016   | 11.26        | 30/05/2016 | 14.40      | PO          | Testing Work                                                                                                        |
| Oni Kharepatan Line                  | IntraState                | 30/05/2016   | 12.32        | 30/05/2016 | 17.51      | PO          | Insulator washing                                                                                                   |
| Nanded- Bhokar I                     | IntraState                | 30/05/2016   | 13.02        | 30/05/2016 | 15.27      | PO          | Testing Work                                                                                                        |
| <b>220 KV ICT Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                     |
| 220/100 Kv 200 MVA ICT III @Borivali | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Failed on internal Fault(Now repaired and ready for                                                                 |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 30/May/2016**

**Statement-VII**

Position as on 6.30 Hrs of 31/May/2016

| Name of Line                             | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage            |
|------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|-----------------------------|
|                                          |                              |                 |                 |            |               |                | commissioning)              |
| 220/132 kV 200MVA ICT II @ Girwali       | IntraState                   | 30/05/2016      | 08.47           | 30/05/2016 | 16.45         | PO             | Routine Maintenance Work    |
| 220/132 Kv 200 Mva Bb Ict 2<br>@Chikhali | IntraState                   | 30/05/2016      | 11.57           | 30/05/2016 | 15.54         | PO             | Tan Delta Measurment of CTs |