

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 30/Jun/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	135.386	4672.462	1) Gujrat	-3.940	-190.743
2) Hydro	9.665	372.979	2) Madhya Pradesh	8.158	136.069
3) Gas	6.583	128.747	3) Chattisgarh	2.950	80.460
Total MSPGCL	151.634	5174.188	4) Maharashtra	164.447	4956.349
B) 1) APML	50.271	1971.165	5) Goa (Amona)	-1.196	-28.830
2) JSWEL	14.329	500.864	Total	170.419	4953.305
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.651	1005.607
4) RPL(AMT)	21.525	748.940	b) Mumbai Drawl	36.524	1107.549
5) SWPGPL	9.142	252.383	c) MSEDCL Bilateral *	86.538	2181.800
6) Other IPP	8.358	379.867	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.651	1005.386
C) 1) TPCL Thermal	10.744	429.201	Include PX	0.000	2.021
2) TPCL Hydro	1.909	116.101	Standby	0.000	0.221
3) TPCL Gas	2.020	36.741	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.392	307.154	1) MSEDCL	421.964	13696.626
D) STATE			2) Mumbai Discoms	60.589	1996.749
1) Thermal	259.147	9262.036	3) Other Discoms	9.093	278.777
(A1+C1+C4+(B1-B6))			TOTAL STATE	491.646	15972.152
2) Hydro	11.574	489.080			
3) Gas	8.603	165.488			
4) Wind	33.010	826.161			
6) SOLAR	8.893	276.079			
TOTAL STATE	321.227	11018.844			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5344	5547	5743	5809
MSPGCL Hydro	561	626	507	253
MSPGCL Gas	267	279	274	281
MSPGCL Total Generation	6172	6452	6524	6343
Central Sector Receipt	8404	8165	7324	5589
WIND	1173	707	1702	1193
CPP / IPP Thermal	3829	3752	4464	4836
CPP / IPP Gas	0	0	0	0
SOLAR	1118	1196	0	0
Exchange with Mumbai	-1922	-1810	-1663	-1102
MSEDCL DEMAND MET	18360	18081	17952	16550
Load Shedding	0	0	0	0
MSEDCL DEMAND	18360	18081	17952	16550
TPCL GENERATION	738	727	632	529
AEML GENERATION	439	466	392	373
MUMBAI DEMAND	3099	3003	2687	2004
OTHER DISCOM DEMAND	414	381	399	309
STATE DEMAND MET	21873	21465	21038	18863
STATE DEMAND	21873	21465	21038	18863
Frequency (Hz)	50.00	50.03	49.96	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.31 Hz at 13.04 Hrs	49.82 Hz at 14.38 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 30/Jun/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.68	113.59	145	0
Unit 7	0.00	0.00	0	0
Unit 8	12.64	365.15	544	514
Unit 9	0.00	292.53	0	0
Unit 10	11.97	345.09	520	476
Total	27.28	1116.35		
Bhusawal				
Unit 3	3.12	95.64	150	110
Unit 4	10.02	304.16	445	355
Unit 5	0.00	267.67	0	0
Total	13.14	667.48		
Parli				
Unit 6	5.02	128.60	241	152
Unit 7	4.09	128.53	209	144
Unit 8	0.00	74.95	0	0
Total	9.11	332.08		
Chandrapur				
Unit 3	3.05	90.17	133	120
Unit 4	3.00	60.59	134	114
Unit 5	7.88	248.56	362	285
Unit 6	8.25	226.13	395	265
Unit 7	0.00	113.41	0	0
Unit 8	11.24	325.31	482	440
Unit 9	10.76	271.92	459	420
Total	44.19	1336.08		
Paras				
Unit 3	4.53	144.14	208	141
Unit 4	4.90	130.82	226	162
Total	9.42	274.97		
Khaparkheda				
Unit 1	3.26	95.37	150	115
Unit 2	3.52	100.74	155	130
Unit 3	4.18	124.25	182	142
Unit 4	0.00	13.16	0	0
Unit 5	10.99	322.96	480	400
Total	21.95	656.48		
Nasik				
Unit 3	3.63	111.69	175	119
Unit 4	3.32	89.22	154	118
Unit 5	3.34	88.11	155	119
Total	10.29	289.02		
Uran				
All Units	6.58	128.75	285	264
Total	6.58	128.75		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	5.67	14	0
Total	0.15	5.67		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.06	84.70	380	35
Stage 4	0.00	61.14	0	0
Stage 3	1.00	36.47	240	0
Total	3.06	182.31		
Hydro				
KDPH	0.00	11.56	0	0
VTRNA	0.71	7.14	60	0
TILLARI	0.58	8.68	58	0
BHIRA T.R.	0.10	6.04	57	0
SMLHY_PTN	5.06	149.45	218	194
GHATGHAR	0.00	2.13	0	0
Total	6.45	184.99		
Wind				
Total	33.01	826.16	0	0
Total	33.01	826.16		
CPP				
APML(Mus)	50.27	1971.16	0	0
JSWEL(Mus)	14.33	500.86	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	21.52	748.94	0	0
SWPGPL-Mus	9.14	252.38	0	0
Other(Mus)	8.36	379.87	0	0
Total	103.62	3853.22		
SOLAR				
Total	8.89	276.08	0	0
Total	8.89	276.08		
Tata				
Trombay 5	6.90	278.46	357	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.10	22.23	48	43
Trombay 7B	0.92	14.51	40	37
TATA Hydro	1.91	116.10	144	18
Trombay 8	3.85	150.74	222	130
Total	14.67	582.04		
AEML				
DTPS U-1&2	9.39	307.15	466	318
Total	9.39	307.15		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	135.39	4672.46	MSPGCL Total	151.63	5174.19
			MSPGCL Thml+Gas	141.97	4801.21	Koyna 1,2 & 4 Total	2.06	145.85
			MSPGCL Hydro	9.66	372.98	State Total	321.23	11018.84

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 30/Jun/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5810	253	281	6344	1561	5004	0	0	5641	5735	-1325	16956	0	16956	2294	363	19613	50.02
2	5806	253	271	6330	1353	4783	0	0	5817	5796	-1215	16712	0	16712	2125	335	19172	49.99
3	5809	253	281	6343	1193	4836	0	0	5549	5589	-1102	16550	0	16550	2004	309	18863	49.97
4	5799	262	271	6332	1171	4837	0	0	5677	5788	-1017	16806	0	16806	1937	305	19048	50.03
5	5825	262	283	6370	1160	4868	0	0	5824	6001	-987	17094	0	17094	1910	318	19322	50.00
6	5806	412	285	6503	1119	4890	0	0	6452	6918	-1105	17985	0	17985	1998	340	20323	50.01
7	5812	608	285	6705	1085	4739	0	88	7345	7724	-1244	18709	0	18709	2130	388	21227	50.00
8	5851	264	283	6398	1108	4744	0	374	7703	7595	-1368	18463	0	18463	2273	388	21124	50.01
9	5844	313	272	6429	1308	4440	0	698	7729	7971	-1652	18765	0	18765	2605	429	21799	50.06
10	5639	380	273	6292	1387	4024	0	931	8074	7832	-1762	18273	0	18273	2905	431	21609	50.04
11	5344	561	267	6172	1173	3829	0	1118	8289	8404	-1922	18360	0	18360	3099	414	21873	50.00
12	5544	684	268	6496	778	3746	0	1154	8279	8339	-1930	18182	0	18182	3112	401	21695	49.99
13	5547	626	279	6452	707	3752	0	1196	8486	8165	-1810	18081	0	18081	3003	381	21465	50.03
14	5220	614	268	6102	1110	3724	0	1106	8245	8041	-1719	17992	0	17992	2837	372	21201	50.11
15	5094	600	280	5974	1710	3473	0	878	8404	8128	-1906	17875	0	17875	2843	382	21100	49.93
16	5454	420	270	6144	1857	3658	0	712	8177	7644	-1905	17721	0	17721	2850	389	20960	49.99
17	5377	360	264	6001	1957	3513	0	462	7761	7446	-1875	17114	0	17114	2815	390	20319	49.98
18	5636	372	274	6282	1934	3669	0	149	7314	7311	-1865	17082	0	17082	2775	398	20255	50.02
19	5746	584	265	6595	2017	4214	0	27	6794	7100	-1839	17683	0	17683	2751	431	20865	50.04
20	5743	507	274	6524	1702	4464	0	0	7369	7324	-1663	17952	0	17952	2687	399	21038	49.96
21	5777	316	264	6357	1428	4613	0	0	7160	7133	-1572	17546	0	17546	2588	413	20547	50.00
22	5670	260	273	6203	1436	4606	0	0	6537	6503	-1354	17011	0	17011	2450	383	19844	50.02
23	5622	248	276	6146	1437	4647	0	0	6046	6112	-1201	16762	0	16762	2354	379	19495	50.06
24	5611	253	276	6140	1319	4552	0	0	5926	5820	-1186	16289	0	16289	2244	356	18889	50.07
MUs	135.39	9.67	6.58	151.63	33.01	103.63	0.00	8.89	170.60	170.42	-36.52	421.96	0.00	421.96	60.59	9.09	491.65	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 30/Jun/2022

Position as on 6.30 Hrs of 01/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkhedha Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	20/07/2022
MSPGCL	Koyna STG-IV Unit-2	250	13/06/2022	00:00		Continued.	Commissioning and installation of New TSLG governor	01/07/2022
IPP	RPL(AMT) U-5	270	15/06/2022	00:00		Continued.	Annual Overhaul	25/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Parli Unit 8	250	25/06/2022	00:00		Continued.	Short overhauling	10/07/2022
IPP	Adani U-2	660	25/06/2022	04:18		Continued.	Stator Earth Fault (Converted into AOH from 00:00Hrs dt.01/07/2022.	22/07/2022
MSPGCL	Koyna Unit 6	80	28/06/2022	13:20	30/06/2022	17:25	enjector replacement	01/07/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Turbine Gland steam temperature not maintained	18/07/2022
MSPGCL	Ghatghar Unit-2	125	18/06/2022	10:00		Continued.	for Hydraulic Intake Gate Work	03/07/2022
MSPGCL	Uran Unit B0	120	24/06/2022	06:28		Continued.	Excitation channel fault(Converted to Gas Shortage from 26-06-22)	
MSPGCL	Uran Unit 8	108	24/06/2022	15:33		Continued.	Gas shortage	
MSPGCL	Koradi Unit 9	660	27/06/2022	13:45		Continued.	Air Filter Problem	04/07/2022
IPP	SWPGPL U-1	135	29/06/2022	00:51	30/06/2022	21:28	Turbine vibration	
MSPGCL	Bhusawal Unit 5	500	29/06/2022	12:09		Continued.	CLINKER FORMATION	01/07/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	05/07/2022
MSPGCL	Koradi Unit 6	210	30/06/2022	21:35		Continued.	Boiler Tube Leakage	02/07/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 30/Jun/2022

Position as on 6.30 Hrs of 01/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	SWPGPL U-4	135	30/06/2022	23:23		Continued.	Vibration High in feed pump.	
IPP	SWPGPL U-1	135	01/07/2022	00:07		Continued.	Turbine Vibration	
TPC-G	Trombay 7B	60	01/07/2022	04:53		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	01/07/2022	05:14		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 01/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kV 1500MVA ICT-2 @ EKTUNI	IntraState	30/06/2022	10:16	30/06/2022	20:16	PO	Diagnostic testing & routine maintenance work. CTR Fire fighting (NIFPS) work.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	16/06/2022	11:23			PO	1) Premonsoon maintenance work& 2) Routine Bay Maintenance.
400 KV LINE Outages/Trippings							
WARORA - WARDHA (PG)	InterState	20/06/2022	10:10			PO	1. Tower Erection of loc. No. 01 under 400 kV Wardha-Warora line. 2. Connecting 400kV Warora (MSETCL) to 400kV Warora (PGCIL)
PARLI - KARJAT CKT - 2	IntraState	30/06/2022	00:12	30/06/2022	09:34	EO	Replacement of faulty string
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	30/06/2022	07:24			HT	H/T FOR CONTROLLING LINE LOADING
LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	IntraState	30/06/2022	10:22	30/06/2022	17:52	PO	Replacement of damaged CB Auxiliary Switch Contact by new
CHANDRAPUR-PARLI CKT-3	IntraState	30/06/2022	11:05			EO	To attend the hot spot having temperature of more than 119 Degree Celsius on 4-way clamps of Hanger Rod assembly of Y-ph Main Bus-2 Isolator by hot line tehcnique.
400 KV ICT Outages/Trippings							
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	IntraState	30/06/2022	09:43	30/06/2022	19:32	PO	NIFPS(CTR) Servicing & Maintenance work by external agency.
400/11kV STN-4B @ DEEPNAGAR	IntraState	30/06/2022	10:20	30/06/2022	18:32	EO	Outage required for 89T Y-Phase Isolator BPI replacement.
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	IntraState	30/06/2022	10:45	30/06/2022	15:51	PO	Jumper replacement work in between A & B isolator
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	30/06/2022	12:07	30/06/2022	17:25	PO	Measurement of length of capillary & size of pocket, verification of existing RTD point, pressure & mounting, PCD and holes, MOG OSR & Buccholz size & mounting.
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ PHURSUNGI	IntraState	30/06/2022	09:22	30/06/2022	20:02	PO	Twin jumpering work from Main bus A to 29A & CT to 29B isolator stub bus jumps crossing 220kV Main Bus A.
BUS SECTION @ BHOSARI II	IntraState	30/06/2022	11:26	30/06/2022	17:40	PO	Replacement of EHV Y phase CT due to higher tan delta under LE Scheme
220 KV LINE Outages/Trippings							
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
TATA BORIVLI MSETCL BORIVLI - 4	IntraState	27/06/2022	10:00	30/06/2022	21:58	PO	PROJECT WORK-CRP REPLACEMENT AT MSETCL END
WAGHIVALI - DHARAVI 7	IntraState	30/06/2022	00:22	30/06/2022	05:24	PO	Third Party work in vicinity of line at loc.40A (S G Barve crossing Kurla) of Mumbai Metro 2B civil concreting work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 30/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 01/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - DHARAVI 8	IntraState	30/06/2022	00:23	30/06/2022	05:25	PO	Third Party work in vicinity of line at loc.40A (S G Barve crossing Kurla) of Mumbai Metro 2B civil concreting work.
KHAREPATAN -PAWAS LINE	IntraState	30/06/2022	06:04	30/06/2022	06:54	T	Distance Protection
APTA - KALWA	IntraState	30/06/2022	07:19	30/06/2022	20:07	PO	220 KV Road side Auxiliary bus(C BUS) conductor replacement work.
KALWA - PANCHANAND	IntraState	30/06/2022	07:25	30/06/2022	20:28	PO	220 KV Road side Auxiliary bus(C BUS) conductor replacement work.
MAIN BUS - 1 @ AAREY	IntraState	30/06/2022	09:16	30/06/2022	13:01	PO	For attending operational issue of 1389A (Bus-1 side) disconnector .
BUS COUPLER @ AAREY	IntraState	30/06/2022	09:16	30/06/2022	13:01	PO	For attending observation of Main Air compressor of CB752 nonworking issue.
PARGAON(KATHAPUR)-LONIKAND	IntraState	30/06/2022	09:30	30/06/2022	20:43	T	TRIPPED AT KATHAPUR END ONLY. TO PREVENT OVER LOADING OF ICTs AT BBLR END.
AAREY - MSETCL BORIVALI CKT - 1	IntraState	30/06/2022	09:42	30/06/2022	13:25	PO	For attending operational issue of 1389A disconnector
BOMBAY DYEING - SAHARA	IntraState	30/06/2022	12:05	30/06/2022	18:48	PO	1) Fixing of bird divertor. 2) Line signature upto loc.130
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/100 KV 200 MVA ICT 3 @ KALWA	IntraState	28/06/2022	08:51			PO	220 KV Road side Auxiliary bus(C BUS) conductor replacement work.
220/22 KV 50 MVA PTR NO 4 @ THEUR	IntraState	30/06/2022	09:45	30/06/2022	16:01	PO	Diagnostic testing work
220/132 KV 100 MVA ICT - 2 @ ALEPHATA	IntraState	30/06/2022	10:19	30/06/2022	14:54	PO	For CT Tan Delta measurement & general maintenance work
220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA	IntraState	30/06/2022	13:14	30/06/2022	17:30	PO	For CFT IR value, HV CT Tan Delta , removing bird nest & general maintenance work
220/22KV 50MVA PTR 1	IntraState	30/06/2022	22:58	01/07/2022	01:18	PO	Overhauling of OLTC
220/22KV 50MVA PTR 2	IntraState	01/07/2022	01:26	01/07/2022	03:51	PO	Overhauling of OLTC
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ PHURSUNGI	IntraState	30/06/2022	09:22	30/06/2022	19:24	PO	Twin jumpering work from Main bus A to 29A & CT to 29B isolator stub bus jumps crossing 220kV Main Bus A.
132 KV LINE Outages/Trippings							
KANHAN-MANSAR	IntraState	30/06/2022	10:15	30/06/2022	14:47	EO	for attending compressor pipe air leakage .
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 30/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 01/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
KALWA KALYAN	IntraState	30/06/2022	08:12	30/06/2022	17:01	PO	Tower Erection at Runwal Garden Project- Line Diversion for customer funded projects
BHIRA (T) - KHOPOLI 2	IntraState	01/07/2022	05:19			PO	Inspection of Gantry insulators at Khopoli

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage