

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 30/Jun/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	135.804	4704.802	1) Gujrat	-3.661	-69.515
2) Hydro	5.309	334.189	2) Madhya Pradesh	4.569	174.688
3) Gas	0.000	114.922	3) Chattisgarh	0.570	88.080
Total MSPGCL	141.113	5153.913	4) Maharashtra	142.072	6031.625
B) 1) APLM	51.452	1944.183	5) Goa (Amona)	-1.089	-39.454
2) JSWEL	17.490	677.659	Total	142.461	6185.424
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.953	1266.427
4) RPL(AMT)	24.370	788.541	b) Mumbai Drawl	39.258	1385.540
5) SWPGPL	9.998	315.169	c) MSEDCL Bilateral *	105.451	3532.900
6) Other IPP	6.144	174.346	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.953	1265.928
C) 1) TPCL Thermal	9.510	356.250	Include PX	0.000	0.000
2) TPCL Hydro	2.388	141.547	Standby	0.000	0.499
3) TPCL Gas	2.417	57.937	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.043	266.502	1) MSEDCL	415.833	15136.644
D) STATE			2) Mumbai Discoms	61.616	2207.776
1) Thermal	262.811	9227.452	3) Other Discoms	9.955	314.324
(A1+C1+C4+(B1-B6))			TOTAL STATE	487.404	17658.744
2) Hydro (A2+C2)	7.697	475.736			
3) Gas (A3+B7+C3)	2.417	172.859			
4) Wind	60.987	1166.717			
6) SOLAR	11.031	430.556			
TOTAL STATE	344.943	11473.320			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5511	4705	6234	5834
MSPGCL Hydro	218	160	312	176
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	5728	4866	6546	6010
Central Sector Receipt	7073	7297	5837	4408
WIND	2783	2810	2643	2514
CPP / IPP Thermal	4241	3935	5284	4550
CPP / IPP Gas	0	0	0	0
SOLAR	1153	1367	0	0
Exchange with Mumbai	-2024	-2195	-1628	-1146
MSEDCL DEMAND MET	18522	17643	18252	15993
Load Shedding	0	0	0	0
MSEDCL DEMAND	18522	17643	18252	15993
TPCL GENERATION	543	558	813	490
AEML GENERATION	300	312	345	311
MUMBAI DEMAND	2867	3065	2786	1947
OTHER DISCOM DEMAND	433	436	431	344
STATE DEMAND MET	21822	21144	21468	18284
STATE DEMAND	21822	21144	21468	18284
Frequency (Hz)	49.98	50.05	50.01	50.08

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 13.05 Hrs	49.7 Hz at 05.40 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 30/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.60	130.13	170	125
Unit 8	11.26	329.49	533	367
Unit 9	11.53	306.25	520	384
Unit 10	11.47	377.14	544	377
Total	37.85	1143.00		
Bhusawal				
Unit 3	3.08	78.22	150	120
Unit 4	9.55	301.98	465	280
Unit 5	9.49	322.71	480	275
Total	22.12	702.91		
Parli				
Unit 6	0.00	122.47	0	0
Unit 7	0.00	129.24	0	0
Unit 8	0.00	71.84	0	0
Total	0.00	323.55		
Chandrapur				
Unit 3	3.08	93.73	151	115
Unit 4	3.17	93.60	153	121
Unit 5	0.00	0.00	0	0
Unit 6	7.60	241.83	390	281
Unit 7	7.69	265.46	388	290
Unit 8	9.44	323.75	479	277
Unit 9	10.00	324.50	488	309
Total	40.99	1342.87		
Paras				
Unit 3	4.31	139.23	210	140
Unit 4	4.36	127.24	209	141
Total	8.67	266.47		
Khaparkheda				
Unit 1	0.02	71.98	25	0
Unit 2	2.47	82.15	119	82
Unit 3	3.68	97.68	180	131
Unit 4	3.60	113.93	180	125
Unit 5	10.19	322.37	455	350
Total	19.95	688.11		
Nasik				
Unit 3	0.00	10.09	0	0
Unit 4	3.18	115.80	177	108
Unit 5	3.03	111.99	160	117
Total	6.21	237.89		
Uran				
All Units	0.00	114.92	0	0
Total	0.00	114.92		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	2.03	0	0
Total	0.00	2.03		
Koyna				
Stage 1-2	1.13	84.08	100	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	81.22	0	0
Stage 3	0.74	39.39	156	0
Total	1.87	204.68		
Hydro				
KDPH	0.18	7.34	8	8
VTRNA	0.00	31.53	0	0
TILLARI	0.00	5.71	0	0
BHIRA T.R.	0.42	8.91	77	0
SMLHY_PTN	2.84	71.22	130	109
GHATGHAR	0.00	2.76	0	0
Total	3.44	127.47		
Wind				
Total	60.99	1166.72	0	0
Total	60.99	1166.72		
CPP				
APML(Mus)	51.45	1944.18	0	0
JSWEL(Mus)	17.49	677.66	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.37	788.54	0	0
SWPGPL-Mus	10.00	315.17	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.25	113.43	200	152
Other(Mus)	1.90	60.91	0	0
Total	109.45	3899.90		
SOLAR				
Total	11.03	430.56	0	0
Total	11.03	430.56		
Tata				
Trombay 5	6.34	238.70	268	257
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.38	32.18	108	39
Trombay 7B	1.04	25.76	64	36
TATA Hydro	2.39	141.55	244	5
Trombay 8	3.17	117.55	140	129
Total	14.32	555.73		
AEML				
DTPS U-1&2	8.04	266.50	482	290
Total	8.04	266.50		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	135.80	4704.80	MSPGCL Total	141.11	5153.91
			MSPGCL Thml+Gas	135.80	4819.72	Koyna 1,2 & 4 Total	1.13	165.30
			MSPGCL Hydro	5.31	334.19	State Total	344.94	11473.32

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 30/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5801	182	0	5982	2177	4753	0	0	5065	4770	-1296	16009	0	0	16009	2203	377	18590	50.03
2	5856	178	0	6034	2386	4678	0	0	4841	4683	-1266	16158	0	0	16158	2087	357	18602	49.97
3	5964	176	0	6140	2430	4692	0	0	4709	4283	-1168	16025	0	0	16025	1984	352	18362	50.07
4	5834	176	0	6010	2514	4550	0	0	4758	4408	-1146	15993	0	0	15993	1947	344	18284	50.08
5	5885	176	0	6062	2686	4492	0	0	4864	4740	-1137	16506	0	0	16506	1938	337	18780	49.98
6	6073	176	0	6250	2708	4625	0	0	5515	5637	-1250	17606	0	0	17606	2038	363	20008	49.84
7	6106	176	0	6282	2465	4867	0	127	6464	6225	-1404	18147	0	0	18147	2196	415	20758	49.98
8	6232	206	0	6438	2369	4848	0	489	6582	6232	-1495	18458	0	0	18458	2361	423	21242	50.03
9	5989	222	0	6212	2668	4497	0	832	6589	6435	-1775	18433	0	0	18433	2626	435	21494	50.03
10	5511	218	0	5728	2783	4241	0	1153	6831	7073	-2024	18522	0	0	18522	2867	433	21822	49.98
11	4753	204	0	4956	2844	3853	0	1371	7420	7484	-2192	17872	0	0	17872	3029	444	21346	50.01
12	4690	168	0	4858	2884	3831	0	1317	7468	7878	-2226	18095	0	0	18095	3088	446	21630	50.02
13	4705	160	0	4866	2810	3935	0	1367	7046	7297	-2195	17643	0	0	17643	3065	436	21144	50.05
14	4666	220	0	4886	2821	3941	0	1192	6405	6749	-2073	17084	0	0	17084	2952	431	20468	50.05
15	4716	168	0	4884	2736	3965	0	1082	6739	7074	-2042	17272	0	0	17272	2924	427	20622	49.95
16	4773	178	0	4952	2796	4106	0	1049	6997	7139	-2007	17589	0	0	17589	2881	446	20916	50.01
17	5034	252	0	5286	2886	4194	0	631	6694	6711	-1968	17278	0	0	17278	2841	462	20582	49.93
18	5905	286	0	6192	2609	4375	0	349	6193	5965	-1945	17078	0	0	17078	2848	466	20392	50.00
19	6085	316	0	6400	2669	4696	0	72	6231	5802	-1763	17438	0	0	17438	2814	438	20690	50.04
20	6234	312	0	6546	2643	5284	0	0	6175	5837	-1628	18252	0	0	18252	2786	431	21468	50.01
21	6299	354	0	6652	2671	5381	0	0	5725	5289	-1490	18083	0	0	18083	2691	420	21194	49.98
22	6213	352	0	6564	2200	5102	0	0	5203	4987	-1361	17055	0	0	17055	2590	438	20082	50.00
23	6258	282	0	6540	1778	5045	0	0	5110	5057	-1272	16729	0	0	16729	2484	420	19632	50.02
24	6222	170	0	6392	1454	5503	0	0	5072	4706	-1135	16506	0	0	16506	2376	413	19296	50.00
MUs	135.80	5.31	0.00	141.11	60.99	109.45	0.00	11.03	144.70	142.46	-39.26	415.83	0.00	0.00	415.83	61.62	9.96	487.40	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 30/Jun/2023

Position as on 6.30 Hrs of 01/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Parli Unit 8	250	18/06/2023	23:55		Continued.	Annual Overhaul	15/07/2023
MSPGCL	Khaparkhedha Unit 1	210	30/06/2023	00:18		Continued.	Annual Overhaul	24/07/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	29/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyana STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	
MSPGCL	Uran Unit 7	108	24/06/2023	19:03		Continued.	On boiler protection	
IPP	JSW (J) U2	300	27/06/2023	23:44		Continued.	No schedule	
MSPGCL	Parli Unit 6	250	29/06/2023	00:45		Continued.	Zero Schedule	
MSPGCL	Parli Unit 7	250	29/06/2023	14:31		Continued.	On Zero Schedule	
TPC-G	Trombay 5	500	01/07/2023	11:51		Continued.	Coal feeding problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 01/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	27/06/2023	09:46			HT	H/T for load Management.
BABHALESHWAR - RPL(NSK) CKT - 2	IntraState	29/06/2023	09:18	30/06/2023	20:18	PO	Diagnostic testing of 400kv NTPP II bay outdoor equipment & relay
CHANDRAPUR GCR - CHANDRAPUR HVDC - 2	IntraState	29/06/2023	14:23	30/06/2023	19:24	EO	To attend hotspot on R-ph Pantograph Isolator (Bus-1 Isolator) of 400kv GCR Chandrapur- HVDC Ckt NO.-2 bay
JAIGAD - KARAD CKT - 1	IntraState	29/06/2023	22:12	30/06/2023	08:20	HT	H/T on Overvoltage
LONIKAND I - KOYNA STAGE-IV	IntraState	30/06/2023	00:36	30/06/2023	08:32	HT	H/T on overvoltage
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	30/06/2023	09:34	30/06/2023	19:14	PO	For replacement of insulator strings at loc. No. 262 & Loc no. 264 for found faulty in online PID.
KORADI II - KORADI III CKT - 2	IntraState	30/06/2023	10:41	30/06/2023	19:53	PO	Annual Maintenance of Line equipment at Koradi III SS
JAIGAD - KARAD CKT - 2	IntraState	30/06/2023	20:35	01/07/2023	08:06	HT	H/T for controlling overvoltages.
KHADKA-AURANGABAD (WALUJ)	IntraState	30/06/2023	21:03	01/07/2023	09:20	HT	H/T For controlling overvoltages.
LONIKAND I - KOYNA STAGE-IV	IntraState	30/06/2023	21:07	01/07/2023	08:17	HT	H/T For controlling overvoltages.
JEJURI - KARAD	IntraState	01/07/2023	09:24	01/07/2023	17:37	PO	PID Faulty string replacement work
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	01/07/2023	09:25	01/07/2023	20:33	PO	Replacement of Faulty Insulator string at LOC 264 (Found in PID)
CHANDRAPUR - KHAPERKHEDA	IntraState	01/07/2023	11:07		Continued.	EO	To attend hotspot on Yph wavetrap of 400kv Chandrapur-Khaperkheda Ckt.
JAIGAD - KARAD CKT - 1	IntraState	01/07/2023	21:14		Continued.	HT	H/T FOR O/V
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	30/06/2023	09:09	30/06/2023	20:48	PO	C Bus isolator overhauling work, Q/M of bay
400/220/33KV 315MVA ICT - 3 @ LONIKAND	IntraState	01/07/2023	08:55	01/07/2023	19:24	PO	CT Replacement work
220 KV TBC Outages/Trippings							
BUS COUPLER @ SAYNE	IntraState	01/07/2023	09:23	01/07/2023	11:26	PO	Bay Diagnostic Testing & Quarterly Maintenance.
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220 KV LINE Outages/Trippings							
JEUR - SOLAPUR PG	InterState	30/06/2023	09:47	30/06/2023	17:41	PO	.Line Terminal equipments AMP at Solapur Substation.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 01/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
GOREGAON - AAREY CKT - 2	IntraState	17/06/2023	18:14			PO	Shifting of existing 220kV AIS Bay no. 2 to New GIS Bay no. 19 under MERC approved Aarey 220kV AIS to GIS conversion project scheme.
URAN - KHARGHAR 1	IntraState	23/06/2023	17:36			PO	LILo and commissioning of 220kV Ulwe GIS
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	29/06/2023	13:04			PO	For providing 2nd source to 220KV Bapgaon S/stn by making bunching on 220 KV AKP Nashik line at loc. 397 during the work of:Erection of cable termination kit and LA on newly erected CTT Monopole on 220 KV Kalwa Bapgaon line in between Loc No-398 to 399 for the Work of newly proposed 220KV GIS substation of M/s. Estela Enterprises Pvt. Ltd
BAPGAON - KALWA	IntraState	29/06/2023	13:06			PO	Erection of cable termination kit and LA on newly erected CTT Monopole on 220 KV Kalwa Bapgaon line in between Loc No-398 to 399 for the Work of newly proposed 220KV GIS substation of M/s. Estela Enterprises Pvt. Ltd
BHUGAON- WARDHA	IntraState	30/06/2023	08:08	30/06/2023	11:25	HT	CT tan delta, CRM of CB testing work.
NAGOTHANE - SPCL	IntraState	30/06/2023	08:16	30/06/2023	18:33	T	Tripped on distance protection
IPCL - SPCL	IntraState	30/06/2023	08:16	30/06/2023	09:32	T	Tripped on distance protection
WARORA-BHUGAON CKT - 1	IntraState	30/06/2023	10:44	30/06/2023	15:39	HT	To repair the damaged conductor.
KHARGHAR - BORIVALI CKT - 2	IntraState	30/06/2023	12:05	30/06/2023	17:45	PO	For the replacement of old hardwares at various critical locations.
MULUND - GIS BHANDUP	IntraState	30/06/2023	12:56	30/06/2023	16:29	PO	For the replacement of old hardwares at various critical locations.
KANDALGAON - KOYNA (POPHALI)	IntraState	30/06/2023	16:05	30/06/2023	19:20	PO	For Loc no 96 Top, middle and bottom ph insulator string binding with cross arm by wire rope (Ceiling) because existing support rusted.
CHALISGAON - SAYNE	IntraState	30/06/2023	16:41	30/06/2023	18:09	HT	Pre-monsoon maintenance work near railway crossing tower LOC no. 5&6.
MAHAPE - RELIANCE GIS	IntraState	01/07/2023	08:25	01/07/2023	17:48	PO	Routine Bay Maintenance work at both ends of substation.
WPCL-WARORA 2	IntraState	01/07/2023	09:32	01/07/2023	19:19	EO	1. Hot spot attending on SWPGPL Circuit-2 Y-Phase Bus-1 isolator at MSETCL Warora. 2. Ckt-2 Bus-1 Isolator B-phase male contact replacement with spare 3. Ckt-2 Bus-1 isolator alignment and Line isolator maintenance. 4. Ckt-2 Line isolator maintenance at SWPGPL end.
TROMBAY - CARNAC - 7	IntraState	01/07/2023	09:37	01/07/2023	12:50	PO	B-PH CT Clamp replacement
NAGOTHANE - SPCL	IntraState	01/07/2023	11:30	01/07/2023	16:48	EO	B-PH LA REPLACEMENT WORK

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 30/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 01/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MUDSHINGI - CHIKODI	IntraState	01/07/2023	11:55	01/07/2023	19:14	EO	For safety purpose only for jump replacement work of 220kV Talandge- Mudshingi ckt-1 on multicircuit tower no. 12- Yph, MC- 16 - Y & B ph, MC- 22, Bph. On MC towers upper circuit is 220kV Talandge- Mudshingi ckt-1 & lower circuit is 220kV Mudshingi - Chikodi line. For jump work on upper circuit, outage on lower circuit also required as safety purpose. Outage was proposed for dt. 26.06.2023 in monthly outage proposal but NOC was not received from NLDC. Outage on 20kV Talandge- Mudshingi ckt-1 is also proposed for dt.01.07.2023 and is approved by SLDC Kalwa.
NIWALI - PAWAS LINE	IntraState	01/07/2023	12:25	01/07/2023	19:45	T	Tripped on distance protection
TALANDGE - MUDSHINGI CKT - 1	IntraState	01/07/2023	12:26	01/07/2023	18:40	PO	To attend jump work at loc no. M/C- 12, Y ph, MC-22, B ph., loc no. 305, B ph.
MAIN BUS - 1 @ AAREY	IntraState	01/07/2023	19:47	01/07/2023	20:56	EO	Shifting of existing 220kV AIS Bay no. 6 to New GIS Bay no. 22 under MERC approved Aarey 220kV AIS to GIS conversion project scheme.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132-110 KV 100 MVA ICT 2	IntraState	21/06/2023	11:00			EO	Replacement of HV CB
220/132 KV 200 MVA ICT 1 @ MALEGAON	IntraState	30/06/2023	09:18	30/06/2023	12:47	PO	For NIFPS Maintenance of ICT
220/132-110/11KV 200MVA VID ICT 1 @ MIRAJ	IntraState	30/06/2023	10:10	30/06/2023	14:12	PO	Relay testing Work
220/132 KV 200 MVA ICT 2 @ MALEGAON	IntraState	01/07/2023	09:52	01/07/2023	16:01	PO	for NIFPS maintenance of ICT
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage