

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 30/Jul/2021 FRIDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 72.783         | 2945.975        | 1) Gujrat                      | -1.903         | -194.756         |
| 2) Hydro            | 8.729          | 373.200         | 2) Madhya Pradesh              | 11.004         | 181.170          |
| 3) Gas              | 6.290          | 144.970         | 3) Chattisgarh                 | 5.760          | 128.510          |
| <b>Total MSPGCL</b> | <b>87.802</b>  | <b>3464.145</b> | 4) Maharashtra                 | 120.514        | 4055.408         |
| B) 1) APML          | 60.220         | 1877.821        | 5) Goa (Amona)                 | -1.290         | -29.285          |
| 2) JSWEL            | 20.847         | 554.934         | <b>Total</b>                   | <b>134.085</b> | <b>4141.047</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 27.253         | 849.434          |
| 4) RPL(AMT)         | 17.426         | 650.779         | b) Mumbai Drawl                | 31.222         | 877.205          |
| 5) SWPGPL           | 2.759          | 140.326         | c) MSEDCL Bilateral *          | 32.466         | 988.004          |
| 6) Other IPP        | 5.192          | 194.721         | Include PX                     | 7.203          | 146.391          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 27.253         | 846.678          |
| C) 1) TPCL Thermal  | 10.009         | 333.103         | Include PX                     | 12.236         | 392.442          |
| 2) TPCL Hydro       | 4.755          | 139.485         | Standby                        | 0.000          | 2.756            |
| 3) TPCL Gas         | 2.640          | 75.478          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 6.847          | 205.105         | 1) MSEDCL                      | 365.610        | 11500.139        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 55.473         | 1630.376         |
| 1) Thermal          | 196.083        | 6902.764        | <b>TOTAL STATE</b>             | <b>421.083</b> | <b>13130.515</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro            | 13.484         | 512.685         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 8.930          | 220.448         |                                |                |                  |
| (A3+B7+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 65.029         | 1189.497        |                                |                |                  |
| 6) SOLAR            | 3.472          | 164.074         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>286.998</b> | <b>8989.468</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 10 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 2 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 3363                      | 3187                  | 3344                      | 2660                      |
| MSPGCL Hydro             | 438                       | 431                   | 436                       | 308                       |
| MSPGCL Gas               | 254                       | 264                   | 263                       | 263                       |
| MSPGCL Total Generation  | 4055                      | 3882                  | 4043                      | 3231                      |
| Central Sector Receipt   | 6477                      | 6094                  | 5021                      | 4966                      |
| WIND                     | 2870                      | 2944                  | 2841                      | 2501                      |
| CPP / IPP Thermal        | 4935                      | 4220                  | 5127                      | 4085                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 372                       | 410                   | 0                         | 0                         |
| Exchange with Mumbai     | -1496                     | -1673                 | -1292                     | -1077                     |
| <b>MSEDCL DEMAND MET</b> | <b>17213</b>              | <b>15877</b>          | <b>15740</b>              | <b>13706</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 17213                     | 15877                 | 15740                     | 13706                     |
| TPCL GENERATION          | 839                       | 849                   | 836                       | 556                       |
| AEML GENERATION          | 285                       | 285                   | 286                       | 286                       |
| <b>MUMBAI DEMAND</b>     | <b>2620</b>               | <b>2807</b>           | <b>2414</b>               | <b>1919</b>               |
| STATE DEMAND MET         | 19833                     | 18684                 | 18154                     | 15625                     |
| <b>STATE DEMAND</b>      | <b>19833</b>              | <b>18684</b>          | <b>18154</b>              | <b>15625</b>              |
| Frequency (Hz)           | 49.99                     | 50.07                 | 50.00                     | 49.99                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.24 Hz at 13.03 Hrs | 49.88 Hz at 14.25 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 30/Jul/2021

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 6.23         | 270.97         | 455      | 0        |
| Unit 9             | 8.36         | 220.16         | 415      | 280      |
| Unit 10            | 8.34         | 226.48         | 440      | 300      |
| <b>Total</b>       | <b>22.92</b> | <b>717.62</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 6.08         | 206.70         | 420      | 0        |
| Unit 5             | 6.97         | 167.80         | 405      | 95       |
| <b>Total</b>       | <b>13.05</b> | <b>374.50</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 0.00         | 22.08          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>22.08</b>   |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 2.98         | 96.10          | 140      | 122      |
| Unit 4             | 2.92         | 81.26          | 159      | 115      |
| Unit 5             | 6.87         | 219.25         | 330      | 275      |
| Unit 6             | 6.92         | 217.63         | 320      | 275      |
| Unit 7             | 0.00         | 112.06         | 0        | 0        |
| Unit 8             | 10.13        | 281.95         | 455      | 310      |
| Unit 9             | 0.00         | 138.21         | 0        | 0        |
| <b>Total</b>       | <b>29.82</b> | <b>1146.46</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 0.00         | 83.94          | 0        | 0        |
| Unit 4             | 3.82         | 96.10          | 215      | 147      |
| <b>Total</b>       | <b>3.82</b>  | <b>180.04</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 0.00         | 7.76           | 0        | 0        |
| Unit 2             | 0.00         | 35.70          | 0        | 0        |
| Unit 3             | 0.00         | 41.57          | 0        | 0        |
| Unit 4             | 0.00         | 42.26          | 0        | 0        |
| Unit 5             | 0.00         | 276.76         | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>404.04</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 0.00         | 14.10          | 0        | 0        |
| Unit 5             | 3.17         | 87.14          | 156      | 125      |
| <b>Total</b>       | <b>3.17</b>  | <b>101.24</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 6.29         | 144.97         | 274      | 253      |
| <b>Total</b>       | <b>6.29</b>  | <b>144.97</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.06         | 4.67           | 23       | 0        |
| <b>Total</b>       | <b>0.06</b>  | <b>4.67</b>    |          |          |
| <b>Koyna</b>       |              |                |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 0.98          | 67.60          | 50       | 35       |
| Stage 4         | 0.00          | 64.70          | 0        | 0        |
| Stage 3         | 0.63          | 56.56          | 80       | 0        |
| <b>Total</b>    | <b>1.61</b>   | <b>188.86</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.84          | 4.24           | 35       | 35       |
| VTRNA           | 0.00          | 1.88           | 0        | 0        |
| TILLARI         | 0.00          | 9.21           | 0        | 0        |
| BHIRA T.R.      | 0.45          | 12.92          | 40       | 0        |
| SMLHY_PTN       | 5.72          | 150.29         | 251      | 224      |
| GHATGHAR        | 0.12          | 5.80           | 85       | 0        |
| <b>Total</b>    | <b>7.12</b>   | <b>184.34</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 65.03         | 1189.50        | 0        | 0        |
| <b>Total</b>    | <b>65.03</b>  | <b>1189.50</b> |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 60.22         | 1877.82        | 0        | 0        |
| JSWEL(Mus)      | 20.85         | 554.93         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 17.43         | 650.78         | 0        | 0        |
| SWPGPL-Mus      | 2.76          | 140.33         | 0        | 0        |
| Other(Mus)      | 5.19          | 194.72         | 0        | 0        |
| <b>Total</b>    | <b>106.44</b> | <b>3418.58</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 3.47          | 164.07         | 0        | 0        |
| <b>Total</b>    | <b>3.47</b>   | <b>164.07</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 6.66          | 248.90         | 284      | 269      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 1.47          | 42.10          | 63       | 60       |
| Trombay 7B      | 1.17          | 33.38          | 50       | 48       |
| Trombay 8       | 3.35          | 84.20          | 158      | 137      |
| TATA Hydro      | 4.76          | 139.48         | 355      | 6        |
| <b>Total</b>    | <b>17.40</b>  | <b>548.07</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 6.85          | 205.10         | 287      | 284      |
| <b>Total</b>    | <b>6.85</b>   | <b>205.10</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 72.78       | 2945.98       | MSPGCL Total        | 87.80       | 3464.14       |
|                |             |         | MSPGCL Thml+Gas | 79.07       | 3090.94       | Koyna 1,2 & 4 Total | 0.98        | 132.30        |
|                |             |         | MSPGCL Hydro    | 8.73        | 373.20        | State Total         | 287.00      | 8989.47       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 30/Jul/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|-------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |       |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 2560        | 314  | 254  | 3128  | 2736  | 4229      | 0    | 0     | 5085        | 5032        | -1204                | 13921                 | 0                    | 13921                     | 2065             | 15986           | 50.02         |
| 2                  | 2660        | 308  | 263  | 3231  | 2501  | 4085      | 0    | 0     | 5015        | 4966        | -1077                | 13706                 | 0                    | 13706                     | 1919             | 15625           | 49.99         |
| 3                  | 2761        | 319  | 274  | 3354  | 2548  | 3985      | 0    | 0     | 4971        | 4967        | -1027                | 13827                 | 0                    | 13827                     | 1843             | 15670           | 49.99         |
| 4                  | 2920        | 306  | 264  | 3490  | 2460  | 4123      | 0    | 0     | 4939        | 4974        | -960                 | 14087                 | 0                    | 14087                     | 1770             | 15857           | 50.02         |
| 5                  | 3031        | 309  | 263  | 3603  | 2402  | 4294      | 0    | 0     | 4991        | 4877        | -931                 | 14245                 | 0                    | 14245                     | 1742             | 15987           | 50.00         |
| 6                  | 3070        | 294  | 264  | 3628  | 2534  | 4567      | 0    | 0     | 5439        | 5580        | -1004                | 15305                 | 0                    | 15305                     | 1816             | 17121           | 50.02         |
| 7                  | 3104        | 309  | 263  | 3676  | 2299  | 4690      | 0    | 21    | 6687        | 6703        | -1011                | 16378                 | 0                    | 16378                     | 1870             | 18248           | 49.98         |
| 8                  | 3178        | 360  | 253  | 3791  | 2303  | 4834      | 0    | 115   | 7160        | 7095        | -1159                | 16979                 | 0                    | 16979                     | 2057             | 19036           | 50.01         |
| 9                  | 3300        | 425  | 264  | 3989  | 2651  | 4966      | 0    | 264   | 6821        | 6854        | -1315                | 17409                 | 0                    | 17409                     | 2336             | 19745           | 50.03         |
| 10                 | 3363        | 438  | 254  | 4055  | 2870  | 4935      | 0    | 372   | 6653        | 6477        | -1496                | 17213                 | 0                    | 17213                     | 2620             | 19833           | 49.99         |
| 11                 | 3255        | 422  | 263  | 3940  | 2851  | 4870      | 0    | 422   | 6273        | 6012        | -1635                | 16460                 | 0                    | 16460                     | 2808             | 19268           | 50.00         |
| 12                 | 3205        | 428  | 263  | 3896  | 2946  | 4523      | 0    | 451   | 6222        | 6177        | -1684                | 16309                 | 0                    | 16309                     | 2843             | 19152           | 50.01         |
| 13                 | 3187        | 431  | 264  | 3882  | 2944  | 4220      | 0    | 410   | 6189        | 6094        | -1673                | 15877                 | 0                    | 15877                     | 2807             | 18684           | 50.07         |
| 14                 | 3043        | 376  | 264  | 3683  | 2755  | 3994      | 0    | 462   | 5877        | 5956        | -1583                | 15267                 | 0                    | 15267                     | 2678             | 17945           | 50.07         |
| 15                 | 3105        | 364  | 262  | 3731  | 2824  | 4012      | 0    | 391   | 5988        | 5891        | -1575                | 15274                 | 0                    | 15274                     | 2678             | 17952           | 50.00         |
| 16                 | 3219        | 356  | 262  | 3837  | 2836  | 4096      | 0    | 237   | 5951        | 5596        | -1546                | 15056                 | 0                    | 15056                     | 2670             | 17726           | 50.03         |
| 17                 | 3018        | 331  | 262  | 3611  | 2865  | 4028      | 0    | 218   | 5745        | 5838        | -1484                | 15076                 | 0                    | 15076                     | 2608             | 17684           | 49.99         |
| 18                 | 2941        | 330  | 263  | 3534  | 2660  | 4332      | 0    | 92    | 5560        | 5680        | -1369                | 14929                 | 0                    | 14929                     | 2523             | 17452           | 49.95         |
| 19                 | 3194        | 345  | 253  | 3792  | 2742  | 4828      | 0    | 17    | 5382        | 5379        | -1328                | 15430                 | 0                    | 15430                     | 2436             | 17866           | 49.98         |
| 20                 | 3344        | 436  | 263  | 4043  | 2841  | 5127      | 0    | 0     | 5488        | 5021        | -1292                | 15740                 | 0                    | 15740                     | 2414             | 18154           | 50.00         |
| 21                 | 2905        | 352  | 264  | 3521  | 3006  | 4842      | 0    | 0     | 5152        | 4869        | -1231                | 15007                 | 0                    | 15007                     | 2344             | 17351           | 50.01         |
| 22                 | 2830        | 376  | 263  | 3469  | 2878  | 4640      | 0    | 0     | 4795        | 4614        | -1199                | 14402                 | 0                    | 14402                     | 2255             | 16657           | 50.01         |
| 23                 | 2863        | 399  | 264  | 3526  | 2845  | 4215      | 0    | 0     | 4973        | 4778        | -1208                | 14156                 | 0                    | 14156                     | 2208             | 16364           | 49.99         |
| 24                 | 2727        | 401  | 264  | 3392  | 2732  | 4009      | 0    | 0     | 4935        | 4655        | -1231                | 13557                 | 0                    | 13557                     | 2163             | 15720           | 50.01         |
| MUs                | 72.78       | 8.73 | 6.29 | 87.80 | 65.03 | 106.44    | 0.00 | 3.47  | 136.29      | 134.08      | -31.22               | 365.61                | 0.00                 | 365.61                    | 55.47            | 421.08          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 30/Jul/2021**

**Position as on 6.30 Hrs of 31/Jul/2021**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                 | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                  |               |
| IPP                   | RPL(AMT) U-3            | 270      | 15/07/2021   | 00.00        |            | Continued. | Annual Overhaul                                                                  |               |
| MSPGCL                | Chandrapur Unit 9       | 500      | 15/07/2021   | 02.00        |            | Continued. | Annual Overhaul                                                                  |               |
| MSPGCL                | Paras Unit 3            | 250      | 20/07/2021   | 00.35        |            | Continued. | Annual Overhaul                                                                  |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                  |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                          |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                             |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                             |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                           |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                          |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                           |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                            |               |
| MSPGCL                | Nasik Unit 3            | 210      | 03/12/2020   | 06.45        |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).              |               |
| MSPGCL                | Koradi Unit 6           | 210      | 27/04/2021   | 19.59        |            | Continued. | Zero Schedule.                                                                   |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Zero Schedule.                                                                   |               |
| MSPGCL                | Parli Unit 6            | 250      | 04/05/2021   | 20.00        |            | Continued. | Zero Schedule By MSEDCL                                                          |               |
| MSPGCL                | Parli Unit 7            | 250      | 05/05/2021   | 19.00        |            | Continued. | Zero Schedule.                                                                   |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 08/06/2021   | 00.34        |            | Continued. | Zero Schedule.                                                                   |               |
| MSPGCL                | Uran Unit 6             | 108      | 29/06/2021   | 22.18        |            | Continued. | Gas shortage                                                                     |               |
| MSPGCL                | Nasik Unit 4            | 210      | 04/07/2021   | 11.03        |            | Continued. | Boiler Tube Leakage(Converted into to Zero Schedule from 20.00Hrs DT.06-07-2021) |               |
| MSPGCL                | Parli Unit 8            | 250      | 12/07/2021   | 18.00        |            | Continued. | Zero Schedule.                                                                   |               |
| MSPGCL                | Khaparkhedha Unit 1     | 210      | 15/07/2021   | 23.57        |            | Continued. | Zero schedule                                                                    |               |
| MSPGCL                | Khaparkhedha Unit 2     | 210      | 16/07/2021   | 00.12        |            | Continued. | Zero schedule                                                                    |               |
| MSPGCL                | Khaparkhedha Unit 3     | 210      | 16/07/2021   | 00.29        |            | Continued. | Zero schedule                                                                    |               |
| MSPGCL                | Khaparkhedha Unit 4     | 210      | 16/07/2021   | 02.00        |            | Continued. | Zero schedule                                                                    |               |
| IPP                   | JSW (J) U4              | 300      | 16/07/2021   | 17.44        |            | Continued. | Air Preheater problem.                                                           |               |
| IPP                   | SWPGPL U-4              | 135      | 19/07/2021   | 23.45        |            | Continued. | Zero schedule.                                                                   |               |
| MSPGCL                | Bhusawal Unit 4         | 500      | 26/07/2021   | 21.49        | 30/07/2021 | 03.14      | Zero schedule.                                                                   |               |
| MSPGCL                | Khaparkhedha Unit 5     | 500      | 29/07/2021   | 09.04        |            | Continued. | Boiler Tube Leakage                                                              |               |
| IPP                   | SWPGPL U-3              | 135      | 29/07/2021   | 09.11        |            | Continued. | PA fan bearing issue.(ready & under zero sch. from 12.30 hrs of 30.07.2021)      |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 30/07/2021   | 00.00        |            | Continued. | Zero Schedule.                                                                   |               |
| MSPGCL                | Koradi Unit-8           | 660      | 30/07/2021   | 16.31        |            | Continued. | Boiler Tube Leakage                                                              |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 30/Jul/2021**

**Position as on 6.30 Hrs of 31/Jul/2021**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage      | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------|---------------|
| MSPGCL             | Paras Unit 4            | 250      | 31/07/2021   | 19.49        | 31/07/2021 | 23.45      | Furnace Pressure High |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Tripping for 30/Jul/2021**

**Statement-VII**

**Position as on 6.30 Hrs of 31/Jul/2021**

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                               |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Tripping</b>               |                           |              |              |            |            |             |                                                                                |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                       |
| Chandrapur Bhadravati II                          | InterState                | 26/07/2021   | 15.36        |            | Continued. | PO          | Maintenance work.                                                              |
| Akola Aurangabad(PG) II                           | InterState                | 29/07/2021   | 13.10        | 30/07/2021 | 06.07      | HT          | Over Voltage                                                                   |
| Dhule Sar'Sarovar I                               | InterState                | 31/07/2021   | 13.32        |            | Continued. | HT          | Over Voltage                                                                   |
| Akola Aurangabad(PG) II                           | InterState                | 31/07/2021   | 17.39        |            | Continued. | T           | Reactor Protection                                                             |
| Main Bus I @ Akola                                | IntraState                | 29/07/2021   | 09.56        | 30/07/2021 | 05.18      | PO          | Routine Maintenance Work                                                       |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 29/07/2021   | 22.18        | 30/07/2021 | 10.27      | HT          | Over Voltage                                                                   |
| Jaigad-Karad Ckt-I                                | IntraState                | 30/07/2021   | 00.14        | 30/07/2021 | 09.25      | HT          | Over Voltage                                                                   |
| Deepnagar - Aurangabad                            | IntraState                | 30/07/2021   | 10.47        |            | Continued. | PO          | Insulator string replacement. (REC.16:29)                                      |
| Koradi-Khaperkheda li                             | IntraState                | 30/07/2021   | 23.59        |            | Continued. | HT          | Over Voltage                                                                   |
| Jejuri- Koynastage-IV                             | IntraState                | 31/07/2021   | 15.19        |            | Continued. | T           | Distance Protection                                                            |
| <b>400 KV ICT Outages/Tripping</b>                |                           |              |              |            |            |             |                                                                                |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/08/2020   | 09.58        |            | Continued. | PO          | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.                          |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe               | IntraState                | 30/07/2021   | 17.07        | 30/07/2021 | 19.17      | EO          | Attending RPRR indication of NIFPS (CTR Make) system of R-ph unit.             |
| <b>220 KV LINE Outages/Tripping</b>               |                           |              |              |            |            |             |                                                                                |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                    |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                         |
| Wadkhal(GIS)-JSW(GIS) I                           | IntraState                | 16/07/2021   | 17.50        | 31/07/2021 | 16.33      | PO          | For replacement of existing 1200/1A GIS metering CTs with new 1600/1A GIS CTs. |
| Balapur-Akola I                                   | IntraState                | 22/07/2021   | 07.48        |            | Continued. | T           | Distance Protection(tower collapse At LOC. No.15.)                             |
| Balapur-Akola li                                  | IntraState                | 22/07/2021   | 07.48        |            | Continued. | T           | Distance Protection(tower collapse At LOC. No.15.)                             |
| Mahad-Kandalgaon                                  | IntraState                | 22/07/2021   | 19.35        |            | Continued. | T           | Distance Protection                                                            |
| Mahad - Pedambe                                   | IntraState                | 22/07/2021   | 19.35        |            | Continued. | T           | Distance Protection                                                            |
| Kandalgaon - Pirangut                             | IntraState                | 22/07/2021   | 19.37        |            | Continued. | T           | Distance Protection                                                            |
| Kharghar-Borivali ckt II                          | IntraState                | 23/07/2021   | 08.43        |            | Continued. | PO          | To Carry out bunching work.                                                    |
| Kalwa-TIFIL                                       | IntraState                | 23/07/2021   | 11.12        |            | Continued. | PO          | For Complete Tower erection work at loc no. 75A & 76 (behind M/s Siemens).     |
| Kharghar-Borivali ckt I                           | IntraState                | 24/07/2021   | 08.46        |            | Continued. | PO          | Tower Erection & Bunching work                                                 |
| Kalwa - Siemens                                   | IntraState                | 24/07/2021   | 18.16        |            | Continued. | PO          | Tower Erection & Bunching work                                                 |
| Miraj - ICHALKARANJJI - II (TILWANI)              | IntraState                | 28/07/2021   | 08.19        |            | Continued. | T           | Tower collapsed at loc no.27.                                                  |
| Chikhli-Jalna-II                                  | IntraState                | 29/07/2021   | 20.00        | 30/07/2021 | 15.37      | HT          | for safety perpose.                                                            |
| Balapur-Akola I                                   | IntraState                | 30/07/2021   | 01.15        | 30/07/2021 | 02.04      | T           | 132kv BB2 operated.                                                            |
| Chikhli-Jalna-II                                  | IntraState                | 30/07/2021   | 15.37        |            | Continued. | HT          | To control ICT loading                                                         |
| 220KV Chalisagaon-Kopergaon                       | IntraState                | 30/07/2021   | 18.28        | 30/07/2021 | 19.51      | EO          | Attending Hot Spot                                                             |
| Pandarpur-Khanapur                                | IntraState                | 30/07/2021   | 23.20        | 31/07/2021 | 09.25      | HT          | Due to heavy sparking at wave trap.                                            |
| Eklahara(Gcr)(Nasik)- Bableswhar-I                | IntraState                | 31/07/2021   | 08.16        | 31/07/2021 | 19.09      | PO          | Testing Work                                                                   |
| Eklahara(Gcr)(Nasik)- Bableswhar 2                | IntraState                | 31/07/2021   | 08.20        | 31/07/2021 | 15.57      | PO          | Replacement work                                                               |
| Bableswhar -Bhenda                                | IntraState                | 31/07/2021   | 10.25        | 31/07/2021 | 13.30      | PO          | Quarterly Maintenance Work                                                     |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 30/Jul/2021**

**Statement-VII**

Position as on 6.30 Hrs of 31/Jul/2021

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                            |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------|
| Aurangabad (Waluj)-Bhenda              | IntraState                | 31/07/2021   | 14.45        | 31/07/2021 | 17.22      | PO          | Quarterly Maintenance Work                                  |
| Kolshet-Roma                           | IntraState                | 31/07/2021   | 15.35        | 31/07/2021 | 15.49      | PO          | Bus Section outage due to Heavy chattering due to crow nest |
| Chikhli-Jalna-I                        | IntraState                | 31/07/2021   | 21.54        |            | Continued. | HT          | To control Akola ICT loading.                               |
| <b>220 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                             |
| 220/132Kv 200MVA ICT-I @ Akola         | IntraState                | 30/07/2021   | 01.15        | 30/07/2021 | 02.30      | T           | 132kv BB2 operated.                                         |
| 220/132 Kv 200 Mva Bbl lct 4 @Padegaon | IntraState                | 30/07/2021   | 21.12        |            | Continued. | HT          | Over Voltage                                                |
| 220/132 KV ICT-2 @Nagar                | IntraState                | 31/07/2021   | 09.30        | 31/07/2021 | 18.33      | PO          | Attending Oil Leakage                                       |
| 220/100 Kv 200 MVA ICT I @Kolshet      | IntraState                | 31/07/2021   | 15.37        | 31/07/2021 | 15.50      | HT          | Clearing Crow Nest                                          |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage