

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 30/Jul/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	111.960	3363.428	1) Gujrat	11.007	-107.227
2) Hydro	16.620	409.060	2) Madhya Pradesh	10.813	206.051
3) Gas	3.190	109.832	3) Chattisgarh	3.050	113.130
Total MSPGCL	131.770	3882.320	4) Maharashtra	173.956	4360.141
B) 1) APML	55.976	1516.605	5) Goa (Amona)	-1.375	-43.578
2) JSWEL	13.090	415.249	Total	197.451	4528.517
3) VIPL	0.000	0.000	a) Mumbai Schedule	37.583	1020.397
4) RPL(AMT)	18.700	605.154	b) Mumbai Drawl	40.921	1097.737
5) SWPGPL	5.363	198.704	c) MSEDCL Bilateral *	50.785	2125.001
6) Other IPP	6.551	180.818	Include PX	0.000	2.872
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	37.583	1018.184
C) 1) TPCL Thermal	9.770	306.455	Include PX	0.000	0.000
2) TPCL Hydro	6.726	171.862	Standby	0.000	2.213
3) TPCL Gas	0.430	6.819	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.004	198.384	1) MSEDCL	396.946	11383.341
D) STATE			2) Mumbai Discoms	62.851	1781.260
1) Thermal	226.414	6784.797	3) Other Discoms	8.683	262.018
(A1+C1+C4+(B1-B6))			TOTAL STATE	468.480	13426.619
2) Hydro (A2+C2)	23.346	580.922			
3) Gas (A3+B7+C3)	3.620	116.651			
4) Wind	8.122	1221.851			
6) SOLAR	9.527	193.878			
TOTAL STATE	271.029	8898.099			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4710	4729	4738	4465
MSPGCL Hydro	364	413	1740	323
MSPGCL Gas	131	130	132	134
MSPGCL Total Generation	5205	5272	6610	4922
Central Sector Receipt	9411	9021	8327	7109
WIND	243	319	379	239
CPP / IPP Thermal	3686	3748	4412	4340
CPP / IPP Gas	0	0	0	0
SOLAR	1325	1243	0	0
Exchange with Mumbai	-2284	-2264	-1715	-1226
MSEDCL DEMAND MET	17199	16962	17598	15105
Load Shedding	0	0	0	0
MSEDCL DEMAND	17199	16962	17598	15105
TPCL GENERATION	608	598	885	621
AEML GENERATION	217	203	229	170
MUMBAI DEMAND	3109	3065	2829	2017
OTHER DISCOM DEMAND	387	377	415	279
STATE DEMAND MET	20695	20404	20842	17401
STATE DEMAND	20695	20404	20842	17401
Frequency (Hz)	50.02	50.01	49.95	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 13:05 Hrs	49.8 Hz at 20:11 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 30/Jul/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.86	72.06	140	100
Unit 7	0.00	0.00	0	0
Unit 8	0.00	43.27	0	0
Unit 9	9.19	221.01	406	374
Unit 10	10.40	313.62	455	406
Total	22.45	649.96		
Bhusawal				
Unit 3	0.00	44.11	0	0
Unit 4	8.03	235.78	410	250
Unit 5	7.11	214.32	330	270
Total	15.14	494.21		
Parli				
Unit 6	4.10	130.63	187	150
Unit 7	3.97	109.74	187	140
Unit 8	3.81	69.88	175	123
Total	11.88	310.26		
Chandrapur				
Unit 3	1.72	22.69	105	14
Unit 4	1.84	66.77	85	62
Unit 5	3.96	183.20	191	120
Unit 6	5.43	160.17	245	200
Unit 7	0.00	0.00	0	0
Unit 8	9.66	269.70	420	353
Unit 9	9.98	277.08	451	355
Total	32.59	979.60		
Paras				
Unit 3	3.85	97.65	182	145
Unit 4	3.81	105.91	178	140
Total	7.66	203.57		
Khaparkheda				
Unit 1	2.85	78.00	145	100
Unit 2	2.40	85.41	130	85
Unit 3	2.94	98.66	145	93
Unit 4	3.21	52.45	151	115
Unit 5	7.97	253.92	350	296
Total	19.36	568.45		
Nasik				
Unit 3	2.88	86.10	133	106
Unit 4	0.00	39.36	0	0
Unit 5	0.00	31.92	0	0
Total	2.88	157.38		
Uran				
All Units	3.19	109.83	144	128
Total	3.19	109.83		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.61	10.76	26	25
Total	0.61	10.76		
Koyana				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.88	71.70	500	40
Stage 4	4.26	62.59	946	0
Stage 3	2.26	46.19	240	0
Total	9.39	180.47		
Hydro				
KDPH	0.00	11.87	0	0
VTRNA	0.00	19.24	0	0
TILLARI	0.46	14.42	58	0
BHIRA T.R.	0.46	12.39	70	0
SMLHY_PTN	5.70	156.96	246	231
GHATGHAR	0.00	2.95	0	0
Total	6.62	217.83		
Wind				
Total	8.12	1221.85	0	0
Total	8.12	1221.85		
CPP				
APML(Mus)	55.98	1516.60	0	0
JSWEL(Mus)	13.09	415.25	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.70	605.15	0	0
SWPGPL-Mus	5.36	198.70	0	0
Other(Mus)	6.55	180.82	0	0
Total	99.68	2916.53		
SOLAR				
Total	9.53	193.88	0	0
Total	9.53	193.88		
Tata				
Trombay 5	6.58	193.44	311	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.43	4.25	115	0
Trombay 7B	0.00	2.57	0	0
TATA Hydro	6.73	171.86	379	198
Trombay 8	3.19	113.01	135	130
Total	16.93	485.14		
AEML				
DTPS U-1&2	5.00	198.38	245	165
Total	5.00	198.38		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	111.96	3363.43	MSPGCL Total	131.77	3882.32
			MSPGCL Thml+Gas	115.15	3473.26	Koyna 1,2 & 4 Total	7.13	134.28
			MSPGCL Hydro	16.62	409.06	State Total	271.03	8898.10

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 30/Jul/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4371	949	133	5453	260	4366	0	0	6830	7239	-1426	15559	0	15559	2410	333	18302	50.05
2	4383	474	133	4990	349	4330	0	0	7113	7124	-1346	15134	0	15134	2244	313	17691	50.04
3	4436	385	144	4965	302	4345	0	0	7011	7029	-1263	15092	0	15092	2104	286	17482	50.04
4	4465	323	134	4922	239	4340	0	0	6792	7109	-1226	15105	0	15105	2017	279	17401	50.04
5	4469	418	133	5020	264	4335	0	0	7113	7470	-1211	15579	0	15579	1995	299	17873	50.03
6	4578	596	133	5307	291	4347	0	0	7792	8236	-1165	16699	0	16699	2072	317	19088	50.04
7	4633	907	134	5674	230	4379	0	74	8303	8287	-1204	17099	0	17099	2153	341	19593	50.01
8	4811	605	134	5550	134	4401	0	402	8929	8855	-1375	17596	0	17596	2264	371	20231	50.02
9	4848	489	133	5470	244	4207	0	734	9154	9006	-1745	17524	0	17524	2546	392	20462	50.04
10	4794	431	132	5357	293	4016	0	1113	9139	9110	-2051	17434	0	17434	2850	404	20688	50.06
11	4810	429	131	5370	236	4070	0	1257	8856	8777	-2222	17091	0	17091	3057	397	20545	50.02
12	4710	364	131	5205	243	3686	0	1325	9405	9411	-2284	17199	0	17199	3109	387	20695	50.02
13	4729	413	130	5272	319	3748	0	1243	8963	9021	-2264	16962	0	16962	3065	377	20404	50.01
14	4582	358	130	5070	374	3636	0	1174	8800	8537	-2115	16342	0	16342	2937	334	19613	50.04
15	4623	356	131	5110	588	3645	0	884	9088	8935	-2123	16700	0	16700	2963	339	20002	50.00
16	4870	402	128	5400	781	3830	0	691	8762	8504	-2092	16728	0	16728	2990	386	20104	50.03
17	4759	337	130	5226	639	3806	0	429	8714	8655	-2003	16371	0	16371	2948	381	19700	50.00
18	4765	366	130	5261	640	3906	0	172	8986	8969	-1960	16596	0	16596	2870	392	19858	50.02
19	4786	727	131	5644	506	4262	0	29	8776	8439	-1864	16601	0	16601	2823	415	19839	50.07
20	4738	1740	132	6610	379	4412	0	0	8256	8327	-1715	17598	0	17598	2829	415	20842	49.95
21	4723	1523	132	6378	286	4386	0	0	8356	8225	-1696	17184	0	17184	2781	395	20360	49.97
22	4721	1449	143	6313	193	4394	0	0	7753	7772	-1583	16705	0	16705	2671	384	19760	50.04
23	4674	1579	134	6387	176	4404	0	0	7072	7155	-1515	16209	0	16209	2602	398	19209	50.02
24	4682	1000	134	5816	156	4429	0	0	7312	7259	-1473	15839	0	15839	2551	348	18738	50.02
MUs	111.96	16.62	3.19	131.77	8.12	99.68	0.00	9.53	197.28	197.45	-40.92	396.95	0.00	396.95	62.85	8.68	468.48	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 30/Jul/2022

Position as on 6.30 Hrs of 31/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Annual Overhaul	31/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koradi Unit 8	660	04/07/2022	21:55		Continued.	Annual Overhaul	10/08/2022
IPP	Adani U-3	660	27/07/2022	00:05		Continued.	Annual Overhaul	17/08/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/08/2022
MSPGCL	Uran Unit B0	120	24/06/2022	06:28		Continued.	Excitation channel fault(Converted to Gas Shortage from 26-06-22)	
MSPGCL	Uran Unit 8	108	24/06/2022	15:33		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vibration high	24/08/2022
TPC-G	Trombay 7A	120	07/07/2022	01:09	30/07/2022	18:55	Gas shortage	
TPC-G	Trombay 7B	60	07/07/2022	01:21	31/07/2022	01:37	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	09/07/2022	11:58	30/07/2022	00:07	Furnace Pressure High	31/07/2022
MSPGCL	Nasik Unit 5	210	11/07/2022	17:00	31/07/2022	16:00	WET COAL	
AEML	AEML Unit 2	250	13/07/2022	00:38		Continued.	Coal Shortage	
IPP	SWPGPL U-3	135	14/07/2022	14:58		Continued.	FD Fan Problem(converted to coal shortage from 19-7-2022)	
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
MSPGCL	Bhusawal Unit 3	210	16/07/2022	06:30		Continued.	Critical coal stock	
IPP	SWPGPL U-2	135	20/07/2022	01:00		Continued.	Coal Shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 30/Jul/2022

Position as on 6.30 Hrs of 31/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	RPL(AMT) U-5	270	20/07/2022	10:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 5	108	24/07/2022	13:14		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	28/07/2022	21:00	30/07/2022	21:00	C.W PUMP PROBLEM	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 30/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 31/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400KV 1500 MVA ICT-1 @ EKTUNI	IntraState	31/07/2022	11:50	31/07/2022	20:28	PO	Diagnostic Testing & Routine Maintenance
500 KV TBC Outages/Trippings							
POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	29/07/2022	22:36	30/07/2022	04:17	EO	For attending hotspot having temprature 189 deg(1 Nos), in between 100deg to 150 deg(5 Nos). Also to replace degraded capacitor jumpers.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	26/07/2022	11:09			HT	H/T FOR 400KV TALEGAON PG-CHAKAN LINE LOADING
KHADKA-AURANGABAD (WALUJ)	IntraState	29/07/2022	20:19		Continued.	HT	H/T DUE TO O/V
JAIGAD - KARAD CKT - 1	IntraState	30/07/2022	00:45	30/07/2022	08:57	HT	H/T on OV
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	IntraState	30/07/2022	11:32	31/07/2022	02:37	PO	Retrofitting of M- I relay of GCR ckty II
JAIGAD - KARAD CKT - 2	IntraState	30/07/2022	21:10		Continued.	HT	H/T DUE TO O/V
KALWA - KHARGHAR	IntraState	31/07/2022	18:53	31/07/2022	20:10	EO	To attend Hotspot on R-Phase Bus side CB palm @259 Deg. Celsius
400 KV ICT Outages/Trippings							
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	30/07/2022	09:41	30/07/2022	13:33	EO	Attending Hot Spot on "Y" Phase HV Bushing temp- 104 deg
220 KV LINE Outages/Trippings							
BALE - SOLAPUR (PG)	InterState	30/07/2022	16:53	31/07/2022	13:22	T	TRIPPED ON DISTANCE PROTECTION
BORIVALI - BOISAR (PG)	IntraState	18/07/2022	16:18			EO	Shifting of Line on TBC due to damaged B-Ph jumper (Twin) between Main Bus & Bus Isolator.
EKLAHARE (OCR) - PADGHE	IntraState	26/07/2022	10:04		Continued.	HT	H/T DUE TO 220KV BBSLR-NASIK LINE LOADING
PEDHAMBE ONI LINE	IntraState	30/07/2022	08:28	30/07/2022	14:50	PO	Bay R/M work
HINJAWADI I- CHINCHWAD	IntraState	30/07/2022	08:35			PO	Box cross arm & aux cross arm erection & dismantling of chinch-Hinj I line-2 Nos spans & restringing of 2 nos span of line on MDN +3 tower charging of Line. CB overhauling work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 31/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
JEJURI-PHURSUNGI 2	IntraState	30/07/2022	10:08	30/07/2022	19:14	PO	1 to 20 1) L .N -6 - B Phase pilot SSN Nutbolt Missing & Replacement of SSN clamp 2) L.N.-10-R Phase- Quarter D shackle -Quarter Nutbolt fixing 3)L.N.-13- B Phase Jump Nutbolt & Double Jumpering 4) L.N.-18 B Phase Polymer Replacement STN R & Y Phase Jump Nutbolt & Double Jumpering 5) L.N.-20-R Phase- Quarter D shackle -Quarter Nutbolt fixing Y Phase Jump Nutbolt & Double Jumpering 1 to 98 1) L.N.-43-B Phase- Quarter D shackle -Quarter Nutbolt fixing 2)L.N.-53,Y Phase Jump Nutbolt & Double Jumpering 3) L.N.-66,Y & B Phase Jump Nutbolt & Double Jumpering 4) L.N.-67,Y Phase Jump Nutbolt & Double Jumpering 5) L.N.-20 - B Phase-Double Jumpering & Nutbolt Tightening.
KHARGHAR - BORIVALI CKT - 2	IntraState	30/07/2022	12:20	30/07/2022	19:00	EO	Replacement of damaged Y-phase drop jumper twin between stub bus & CT.
AURANGABAD (WALUJ)-BHENDA	IntraState	30/07/2022	14:17	30/07/2022	16:38	PO	For bay quarterly maintenance work at 220 KV Bhenda S/stn end.
NEW KOYNA - PEDAMBE	IntraState	30/07/2022	15:03	30/07/2022	17:47	EO	Back Up relay is in hang condition and needs to be replaced.
KARAD -MUDSHINGI CKT 2-TAK	IntraState	30/07/2022	15:27	30/07/2022	19:12	T	TRIPPED ON DISTANCE PROTECTION
BABLESHWAR -BHENDA	IntraState	30/07/2022	16:49	30/07/2022	18:51	PO	For bay quarterly maintenance work at 220 KV Bhenda S/stn end.
TALOJA - PANCHANAND	IntraState	30/07/2022	19:07	30/07/2022	20:48	EO	220KV Panchanand Taloja line emergency outage required for attending Hot spot at LILO loc no.1 Y-Ph
KALWA SALSETTE - 3	IntraState	31/07/2022	06:44	31/07/2022	13:03	PO	For replacing A Phase LA at Salsette.
KALWA SALSETTE - 3	IntraState	31/07/2022	06:44	31/07/2022	13:23	PO	For replacing A Phase LA at Salsette.
KHARGHAR - CTRLS CKT	IntraState	31/07/2022	08:28		Continued.	PO	For carrying out the work of Charging of 220 KV Net magic S/S as a radial feeder at Loc. No 46.
KALWA - TFIPL	IntraState	31/07/2022	08:34		Continued.	PO	Outage required for safety purpose for For carrying out the work of Charging of 220 KV Net magic S/S as a radial feeder at Loc. No 46 of 220KV Kharghar-CTRLS Line (M/C Line)
TEMBHURNI - JEUR	IntraState	31/07/2022	11:59	31/07/2022	15:05	PO	Outage is required for To attend hot spot by replacing jumper of R-phase CT
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 31/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage