

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 30/Aug/2018 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 85.331         | 2970.407        | 1) Gujrat                      | -0.569         | -60.188          |
| 2) Hydro            | 7.304          | 222.604         | 2) Madhya Pradesh              | 10.975         | 248.843          |
| 3) Gas              | 2.934          | 175.857         | 3) Chattisgarh                 | 4.990          | 142.950          |
| <b>Total MSPGCL</b> | <b>95.569</b>  | <b>3368.868</b> | 4) Maharashtra Net             | 115.513        | 3092.427         |
| B) 1) APML          | 64.511         | 1687.488        | 5) Goa (Amona)                 | -0.418         | -18.700          |
| 2) JSWEL            | 17.560         | 471.616         | <b>Total</b>                   | <b>130.491</b> | <b>3405.332</b>  |
| 3) VIPL             | 7.329          | 157.421         | a) Mumbai Schedule             | 24.399         | 668.070          |
| 4) RPL(AMT)         | 26.151         | 607.515         | b) Mumbai Drawl                | 27.400         | 782.148          |
| 5) WPCL             | 4.478          | 115.139         | c) MSEDCL Bilateral *          | 22.918         | 603.345          |
| 6) PGPL             | 0.000          | 0.000           | Include PX                     | 6.133          | 28.459           |
| 7) Other IPP        | 3.432          | 136.340         | d) Mumbai Bilateral *          | 24.399         | 668.070          |
| C) 1) TPCL Thermal  | 14.124         | 405.845         | Include PX                     | 5.760          | 206.344          |
| 2) TPCL Hydro       | 4.855          | 140.352         | Include Standby                | 0.000          | 0.000            |
| 3) TPCL Gas         | 3.719          | 109.500         | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) R-INFRA Thermal  | 10.049         | 286.860         | 1) MSEDCL                      | 357.823        | 10685.661        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 60.147         | 1724.705         |
| 1) Thermal          | 232.965        | 6838.631        | <b>TOTAL STATE</b>             | <b>417.970</b> | <b>12410.366</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro            | 12.159         | 362.956         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 6.653          | 285.357         |                                |                |                  |
| (A3+B6+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 31.922         | 1409.553        |                                |                |                  |
| 6) SOLAR            | 3.780          | 108.537         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>287.479</b> | <b>9005.034</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 10 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 3574                      | 3457                  | 3702                      | 3518                      |
| MSPGCL Hydro             | 288                       | 248                   | 1245                      | 125                       |
| MSPGCL Gas               | 123                       | 129                   | 130                       | 121                       |
| MSPGCL Total Generation  | 3985                      | 3834                  | 5077                      | 3764                      |
| Central Sector Receipt   | 6246                      | 5956                  | 4795                      | 4466                      |
| WIND                     | 1577                      | 1702                  | 1408                      | 1183                      |
| CPP / IPP Thermal        | 5313                      | 5182                  | 5557                      | 4453                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 400                       | 353                   | 0                         | 0                         |
| Exchange with Mumbai     | -1474                     | -1517                 | -959                      | -824                      |
| <b>MSEDCL DEMAND MET</b> | <b>16047</b>              | <b>15510</b>          | <b>15878</b>              | <b>13042</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 16047                     | 15510                 | 15878                     | 13042                     |
| TPCL GENERATION          | 1013                      | 1051                  | 1361                      | 606                       |
| R-INFRA GENERATION       | 383                       | 376                   | 497                       | 377                       |
| <b>MUMBAI DEMAND</b>     | <b>2870</b>               | <b>2944</b>           | <b>2817</b>               | <b>1807</b>               |
| STATE DEMAND MET         | 18917                     | 18454                 | 18695                     | 14849                     |
| <b>STATE DEMAND</b>      | <b>18917</b>              | <b>18454</b>          | <b>18695</b>              | <b>14849</b>              |
| Frequency (Hz)           | 50.01                     | 49.97                 | 49.89                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.01 Hz at 16:01 Hrs | 49.72 Hz at 18:24 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 30/Aug/2018

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 0.00         | 0.99           | 0        | 0        |
| Unit 7             | 0.00         | 3.92           | 0        | 0        |
| Unit 8             | 0.00         | 177.30         | 0        | 0        |
| Unit 9             | 8.32         | 240.87         | 413      | 320      |
| Unit 10            | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>8.32</b>  | <b>423.08</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 0.00         | 85.26          | 0        | 0        |
| Unit 5             | 9.04         | 286.26         | 425      | 300      |
| <b>Total</b>       | <b>9.04</b>  | <b>371.52</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 5.86         | 140.70         | 252      | 234      |
| Unit 8             | 5.64         | 156.78         | 248      | 202      |
| <b>Total</b>       | <b>11.50</b> | <b>297.48</b>  |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 3.42         | 5.82           | 171      | 115      |
| Unit 4             | 3.91         | 102.23         | 181      | 143      |
| Unit 5             | 8.02         | 235.88         | 350      | 315      |
| Unit 6             | 7.23         | 167.82         | 340      | 150      |
| Unit 7             | 0.00         | 202.42         | 0        | 0        |
| Unit 8             | 0.00         | 168.88         | 0        | 0        |
| Unit 9             | 8.38         | 154.39         | 394      | 300      |
| <b>Total</b>       | <b>30.96</b> | <b>1037.45</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 4.45         | 143.32         | 230      | 146      |
| Unit 4             | 4.15         | 139.18         | 195      | 115      |
| <b>Total</b>       | <b>8.60</b>  | <b>282.49</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 0.00         | 33.37          | 0        | 0        |
| Unit 2             | 1.58         | 65.64          | 115      | 0        |
| Unit 3             | 3.74         | 62.72          | 187      | 137      |
| Unit 4             | 0.00         | 100.67         | 0        | 0        |
| Unit 5             | 7.56         | 176.11         | 450      | 180      |
| <b>Total</b>       | <b>12.88</b> | <b>438.50</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 4.02         | 92.99          | 184      | 155      |
| Unit 4             | 0.00         | 26.91          | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>4.02</b>  | <b>119.90</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 2.93         | 175.86         | 130      | 119      |
| <b>Total</b>       | <b>2.93</b>  | <b>175.86</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.00         | 1.84           | 0        | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.00</b>   | <b>1.84</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 1.83          | 53.47          | 390      | 40       |
| Stage 4         | 0.63          | 25.70          | 413      | 0        |
| Stage 3         | 0.94          | 35.46          | 160      | 0        |
| <b>Total</b>    | <b>3.40</b>   | <b>114.63</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.86          | 21.52          | 36       | 36       |
| VTRNA           | 0.69          | 16.45          | 61       | 0        |
| TILLARI         | 0.75          | 21.91          | 60       | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.42          | 12.72          | 80       | 0        |
| RNGR+BHTSA      | 0.39          | 5.82           | 17       | 16       |
| BHANDARDRA      | 0.34          | 10.24          | 15       | 14       |
| ELDARY          | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.44          | 14.62          | 27       | 16       |
| GHATGHAR        | 0.00          | 4.69           | 0        | 0        |
| <b>Total</b>    | <b>3.90</b>   | <b>107.97</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 31.92         | 1409.55        | 0        | 0        |
| <b>Total</b>    | <b>31.92</b>  | <b>1409.55</b> |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 64.51         | 1687.49        | 0        | 0        |
| JSWEL(Mus)      | 17.56         | 471.62         | 0        | 0        |
| VIPL(Mus)       | 7.33          | 157.42         | 0        | 0        |
| RPLAMT(Mus)     | 26.15         | 607.52         | 0        | 0        |
| WPCL(Mus)       | 4.48          | 115.14         | 0        | 0        |
| Other(Mus)      | 3.43          | 136.34         | 0        | 0        |
| <b>Total</b>    | <b>123.46</b> | <b>3175.52</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 3.78          | 108.54         | 0        | 0        |
| <b>Total</b>    | <b>3.78</b>   | <b>108.54</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 8.87          | 249.67         | 480      | 290      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.27          | 67.66          | 117      | 63       |
| Trombay 7B      | 1.45          | 41.84          | 68       | 50       |
| Trombay 8       | 5.25          | 156.18         | 241      | 200      |
| TATA Hydro      | 4.86          | 140.35         | 462      | 0        |
| <b>Total</b>    | <b>22.70</b>  | <b>655.70</b>  |          |          |
| <b>R-INFRA</b>  |               |                |          |          |
| DTPS U-1&2      | 10.05         | 286.86         | 501      | 374      |
| <b>Total</b>    | <b>10.05</b>  | <b>286.86</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 85.33       | 2970.41       | MSPGCL Total        | 95.57       | 3368.87       |
|                |             |         | MSPGCL Thml+Gas | 88.26       | 3146.26       | Koyna 1,2 & 4 Total | 2.46        | 79.17         |
|                |             |         | MSPGCL Hydro    | 7.30        | 222.60        | State Total         | 287.48      | 9005.03       |

**State Load Despatch Center,Airoli (MSETCL)**  
**Hourly Load Data As on 30/Aug/2018**

**Annexure-2**

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|-------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |       |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 3384        | 184  | 130  | 3698  | 1085  | 4620      | 0    | 0     | 4903        | 5002        | -946                 | 13459                 | 0                    | 13459                     | 2104             | 15563           | 49.96         |
| 2                  | 3471        | 135  | 120  | 3726  | 1223  | 4497      | 0    | 0     | 4843        | 4828        | -931                 | 13343                 | 0                    | 13343                     | 1919             | 15262           | 49.98         |
| 3                  | 3518        | 125  | 121  | 3764  | 1183  | 4453      | 0    | 0     | 4704        | 4466        | -824                 | 13042                 | 0                    | 13042                     | 1807             | 14849           | 50.00         |
| 4                  | 3557        | 123  | 120  | 3800  | 1253  | 4699      | 0    | 0     | 4490        | 4476        | -762                 | 13466                 | 0                    | 13466                     | 1743             | 15209           | 50.00         |
| 5                  | 3519        | 153  | 120  | 3792  | 1108  | 4812      | 0    | 0     | 4517        | 4544        | -759                 | 13497                 | 0                    | 13497                     | 1742             | 15239           | 49.94         |
| 6                  | 3569        | 208  | 121  | 3898  | 1039  | 5162      | 0    | 0     | 5074        | 5410        | -664                 | 14845                 | 0                    | 14845                     | 1863             | 16708           | 49.91         |
| 7                  | 3619        | 203  | 130  | 3952  | 1244  | 5226      | 0    | 16    | 6264        | 6376        | -730                 | 16084                 | 0                    | 16084                     | 2056             | 18140           | 49.92         |
| 8                  | 3611        | 211  | 120  | 3942  | 1136  | 5278      | 0    | 111   | 6783        | 6782        | -889                 | 16360                 | 0                    | 16360                     | 2264             | 18624           | 50.01         |
| 9                  | 3654        | 327  | 120  | 4101  | 1232  | 5372      | 0    | 253   | 6665        | 6434        | -1136                | 16256                 | 0                    | 16256                     | 2582             | 18838           | 50.05         |
| 10                 | 3574        | 288  | 123  | 3985  | 1577  | 5313      | 0    | 400   | 6498        | 6246        | -1474                | 16047                 | 0                    | 16047                     | 2870             | 18917           | 50.01         |
| 11                 | 3498        | 274  | 119  | 3891  | 1402  | 5245      | 0    | 480   | 6142        | 6086        | -1617                | 15487                 | 0                    | 15487                     | 3061             | 18548           | 50.01         |
| 12                 | 3495        | 203  | 130  | 3828  | 1504  | 5177      | 0    | 539   | 6217        | 6097        | -1631                | 15514                 | 0                    | 15514                     | 3090             | 18604           | 50.03         |
| 13                 | 3502        | 193  | 120  | 3815  | 1398  | 5182      | 0    | 435   | 6014        | 5814        | -1537                | 15107                 | 0                    | 15107                     | 2998             | 18105           | 49.98         |
| 14                 | 3499        | 218  | 121  | 3838  | 1511  | 5143      | 0    | 399   | 5723        | 5675        | -1447                | 15119                 | 0                    | 15119                     | 2889             | 18008           | 50.00         |
| 15                 | 3537        | 248  | 119  | 3904  | 1560  | 5177      | 0    | 395   | 5706        | 5741        | -1513                | 15264                 | 0                    | 15264                     | 2927             | 18191           | 49.99         |
| 16                 | 3457        | 248  | 129  | 3834  | 1702  | 5182      | 0    | 353   | 5833        | 5956        | -1517                | 15510                 | 0                    | 15510                     | 2944             | 18454           | 49.97         |
| 17                 | 3459        | 248  | 120  | 3827  | 1739  | 5186      | 0    | 267   | 5878        | 5808        | -1504                | 15323                 | 0                    | 15323                     | 2926             | 18249           | 49.98         |
| 18                 | 3546        | 248  | 120  | 3914  | 1374  | 5337      | 0    | 116   | 5783        | 5673        | -1415                | 14999                 | 0                    | 14999                     | 2868             | 17867           | 49.95         |
| 19                 | 3678        | 629  | 119  | 4426  | 1275  | 5465      | 0    | 16    | 5391        | 5214        | -1117                | 15279                 | 0                    | 15279                     | 2812             | 18091           | 49.89         |
| 20                 | 3702        | 1245 | 130  | 5077  | 1408  | 5557      | 0    | 0     | 4876        | 4795        | -959                 | 15878                 | 0                    | 15878                     | 2817             | 18695           | 49.89         |
| 21                 | 3662        | 724  | 121  | 4507  | 1418  | 5605      | 0    | 0     | 4603        | 4412        | -841                 | 15101                 | 0                    | 15101                     | 2686             | 17787           | 49.97         |
| 22                 | 3645        | 442  | 120  | 4207  | 1246  | 5498      | 0    | 0     | 4724        | 4658        | -802                 | 14807                 | 0                    | 14807                     | 2528             | 17335           | 49.97         |
| 23                 | 3595        | 240  | 120  | 3955  | 1293  | 5228      | 0    | 0     | 4951        | 4961        | -1172                | 14265                 | 0                    | 14265                     | 2398             | 16663           | 49.98         |
| 24                 | 3580        | 187  | 121  | 3888  | 1012  | 5046      | 0    | 0     | 4651        | 5037        | -1213                | 13770                 | 0                    | 13770                     | 2253             | 16023           | 50.01         |
| MUs                | 85.33       | 7.30 | 2.93 | 95.57 | 31.92 | 123.46    | 0.00 | 3.78  | 131.23      | 130.49      | -27.40               | 357.82                | 0.00                 | 357.82                    | 60.15            | 417.97          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center,Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 30/Aug/2018

Position as on 6.30 Hrs of 31/Aug/2018

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                               | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                |               |
| MSPGCL                | Parli Unit 6            | 250      | 23/07/2018   | 00:00        |            | Continued. | Capital Overhaul                               |               |
| MSPGCL                | Koradi Unit 10          | 660      | 28/07/2018   | 01.09        |            | Continued. | Annual Overhaul                                |               |
| IPP                   | JSW (J) U2              | 300      | 28/07/2018   | 13.48        |            | Continued. | Annual Overhaul                                |               |
| MSPGCL                | Bhusawal Unit 4         | 500      | 10/08/2018   | 01.02        |            | Continued. | Capital Overhaul                               |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown.<br>(NO PPA FROM 01.04.2018) |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                        |               |
| IPP                   | SWPGL U-2               | 135      | 29/02/2016   | 21.46        |            | Continued. | No PPA                                         |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                              |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                              |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                    |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                    |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 21/05/2018   | 18.46        |            | Continued. | IEPL Inter change                              |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 29/06/2018   | 01.12        |            | Continued. | Stator Earth Fault                             |               |
| MSPGCL                | Nasik Unit 5            | 210      | 12/07/2018   | 00.00        |            | Continued. | ZERO SCHEDULE.                                 |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |            | Continued. | Compressor & Turbine Blade Failure.            |               |
| IPP                   | VIPL U-2                | 300      | 27/07/2018   | 00.48        |            | Continued. | Coal Shortage                                  |               |
| MSPGCL                | Koradi Unit 7           | 210      | 03/08/2018   | 15.54        |            | Continued. | Poor Coal Receipt.                             |               |
| MSPGCL                | Nasik Unit 4            | 210      | 07/08/2018   | 15.35        |            | Continued. | Coal Swapping.                                 |               |
| MSPGCL                | Khaparkheda Unit 1      | 210      | 11/08/2018   | 23.57        |            | Continued. | Poor coal Receipt                              |               |
| IPP                   | RPL(AMT) U-3            | 270      | 20/08/2018   | 15:00        | 30/08/2018 | 06.03      | Zero Schedule by MSEDCL.                       |               |
| MSPGCL                | Khaparkheda Unit 2      | 210      | 21/08/2018   | 00.00        | 30/08/2018 | 03.11      | Wet coal.                                      |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 23/08/2018   | 08.37        |            | Continued. | poor coal receipt.                             |               |
| MSPGCL                | Koradi Unit-8           | 660      | 23/08/2018   | 14.49        |            | Continued. | Master Fuel Trip                               |               |
| IPP                   | Dhariwal                | 300      | 24/08/2018   | 14.01        |            | Continued. | POOR COAL RECEIPT.                             |               |
| IPP                   | RPL(AMT) U-5            | 270      | 24/08/2018   | 18.05        |            | Continued. | MASTER FUEL TRIPPED.                           |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 25/08/2018   | 20:10        |            | Continued. | Poor Coal Receipt.                             |               |
| MSPGCL                | Uran Unit 6             | 108      | 27/08/2018   | 02:06        |            | Continued. | Generator protection                           |               |
| MSPGCL                | Uran Unit A0            | 120      | 27/08/2018   | 02:06        |            | Continued. | Generator protection                           |               |
| MSPGCL                | Uran Unit 5             | 108      | 27/08/2018   | 03.31        |            | Continued. | Due to A0 Trip.                                |               |
| MSPGCL                | Koradi Unit 6           | 210      | 28/08/2018   | 06.14        |            | Continued. | Main Steam Temp. Low.                          |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | Coal Shortage                                  |               |
| MSPGCL                | Khaparkheda Unit 4      | 210      | 29/08/2018   | 17.44        |            | Continued. | Boiler Tube Leakage                            |               |
| IPP                   | Adani U-1               | 660      | 31/08/2018   | 00.51        |            | Continued. | HOT PA BELLOW                                  |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 30/Aug/2018**

Position as on 6.30 Hrs of 31/Aug/2018

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|-----------|------------|------------------|---------------|
|                    |                         |          |              |              |           |            | LEAKAGE.         |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 30/Aug/2018**

**Statement-VII**

**Position as on 6.30 Hrs of 31/Aug/2018**

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                            |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                             |
| Chandrapur - Padghe Hvdc Pole 1        | IntraState                | 30/08/2018   | 23.46        | 31/08/2018 | 05.43      | EO          | Replacement Of Y- PH Filter Breaker And Bus Side Isolator Of Pole-1 And attending Of Filter Bus Protection Relay Of Pole-2. |
| Chandrapur - Padghe Hvdc Pole 2        | IntraState                | 30/08/2018   | 23.46        | 31/08/2018 | 05.43      | EO          | Replacement Of Y- PH Filter Breaker And Bus Side Isolator Of Pole-1 And attending Of Filter Bus Protection Relay Of Pole-2. |
| <b>400 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                             |
| Karad Solapur (PG)                     | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line converted as 220 kV Solapur (PG)- Jeur from LOC 403                                                                    |
| Dhule Sar'Sarovar I                    | InterState                | 16/08/2018   | 03.38        | 30/08/2018 | 09.31      | T           | Distance Protection                                                                                                         |
| Dhule Sar'Sarovar I                    | InterState                | 30/08/2018   | 11.09        |            | Continued. | HT          | ATTENDING VT FUSE FAIL INDICATION ETC.(RFC DT 31-08-2018 TIME 00.25, CODE 2641).                                            |
| Dhule- Bableshtar - I                  | IntraState                | 01/06/2018   | 16.42        |            | Continued. | T           | Distance Protection Y-PH (Tower Collapsed)                                                                                  |
| Dhule - Bableshtar - li                | IntraState                | 01/06/2018   | 16.42        |            | Continued. | T           | Distance Protection Y-PH (Tower Collapsed)                                                                                  |
| Bus Coupler @ Parly(Girwali)           | IntraState                | 25/08/2018   | 12.25        | 30/08/2018 | 19:46      | HT          | Bus Bar Protection Out Of Service.                                                                                          |
| Karad - Jaigad - II                    | IntraState                | 29/08/2018   | 20.19        |            | Continued. | HT          | Over Voltage                                                                                                                |
| Khadka-Aurangabad (Waluj)              | IntraState                | 29/08/2018   | 22.53        | 30/08/2018 | 06.21      | HT          | Over Voltage                                                                                                                |
| Chandrapur II - Chandrapur ckt 2       | IntraState                | 30/08/2018   | 09.41        | 30/08/2018 | 20.34      | PO          | PMU Commissioning Work Under URTDSM Project Work & Diagnostic ETc, Maintenance Work.                                        |
| Koradi-Khaparkheda I                   | IntraState                | 30/08/2018   | 09.58        | 30/08/2018 | 16.52      | PO          | RELAY TESTING WORK OF LINE MEASUREMENT OF TAN DELTA OF CT.                                                                  |
| Deepnagar - Aurangabad                 | IntraState                | 30/08/2018   | 12.12        | 30/08/2018 | 15.46      | EO          | Taken on TBC at 400KV Waluj s/s To Attend Own CB SF6 Gas Work.                                                              |
| Khadka-Aurangabad (Waluj)              | IntraState                | 30/08/2018   | 17.22        |            | Continued. | HT          | Over Voltage                                                                                                                |
| <b>400 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                             |
| 400/220/33 Kv 315 Mva Ict 2 @Dhule     | IntraState                | 28/08/2018   | 01.05        | 30/08/2018 | 17.17      | T           | on ndr trial failed at 02.16 hrs.                                                                                           |
| 400/220/33kv 315mva Ict3 @Lonikand     | IntraState                | 29/08/2018   | 11.02        | 30/08/2018 | 16.26      | PO          | SHIFTED ON TBC.                                                                                                             |
| 400/220kv 315 Mva ICT I @Karad         | IntraState                | 30/08/2018   | 07.20        |            | Continued. | PO          | Dismantling Of B Phase Unit For Overhauling.                                                                                |
| 400/220/33 Kv 500 Mva Ict-3 @Nagothane | IntraState                | 30/08/2018   | 11.20        | 30/08/2018 | 12.42      | EO          | Attending Oil Leakage                                                                                                       |
| 400/220 Kv 315 MVA ICT -I @New Koyana  | IntraState                | 30/08/2018   | 12.00        | 30/08/2018 | 14.53      | EO          | Attending Hot Spot                                                                                                          |
| <b>220 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                             |
| Talandage - Chikodi                    | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | NO SCHEDULE.                                                                                                                |
| Mudshingi - Chikodi                    | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                                |
| Chandrapur GCR - Warora - I            | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.        |
| Chandrapur GCR - Wani                  | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.        |
| Vita - Miraj                           | IntraState                | 16/06/2018   | 14.15        |            | Continued. | PO          | Construction Work.                                                                                                          |
| Vita - Mhaishal                        | IntraState                | 16/06/2018   | 15.10        |            | Continued. | PO          | Construction Work.                                                                                                          |
| BOISAR BORIVALI                        | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To control line loading for availing outage on PG ckt 3.                                                                    |
| Sonkhar - Trombay                      | IntraState                | 10/08/2018   | 08.49        | 31/08/2018 | 00.59      | PO          | Conductor Replacement Work.                                                                                                 |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 30/Aug/2018**

**Statement-VII**

Position as on 6.30 Hrs of 31/Aug/2018

| Name of Line                                     | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                    |
|--------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------|
| JATH SHEDYAL                                     | IntraState                | 27/08/2018   | 21.13        |            | Continued. | HT          | Over Voltage                                        |
| Dahanu-Viraj                                     | IntraState                | 30/08/2018   | 07.03        | 30/08/2018 | 19.56      | PO          | Half Yearly Maintenance Of CB & Line Side Isolator. |
| Lonikand-VSNL                                    | IntraState                | 30/08/2018   | 08.23        | 30/08/2018 | 16.09      | PO          | Replacement Of Faulty Disc Insulator Of Line.       |
| Lonikand - Bhosari                               | IntraState                | 30/08/2018   | 14.36        | 30/08/2018 | 23.04      | T           | Distance Protection                                 |
| Chakan-Bhosari                                   | IntraState                | 30/08/2018   | 14.36        | 30/08/2018 | 14.50      | T           | TRIPPED FROM CHAKAN END ONLY.                       |
| Chinchwad-Hinjewadi I                            | IntraState                | 30/08/2018   | 14.47        | 30/08/2018 | 18.37      | HT          | CONTROL OVERLOADING.                                |
| Nerul-Trombay                                    | IntraState                | 30/08/2018   | 22.30        | 31/08/2018 | 01.35      | PO          | CONDUCTOR REPLACEMENT.                              |
| Oni Kharepatan Line                              | IntraState                | 31/08/2018   | 02.40        |            | Continued. | T           | Distance Protection                                 |
| Kharepatan -Pawas Line                           | IntraState                | 31/08/2018   | 02.40        | 31/08/2018 | 03.42      | T           | Distance Protection                                 |
| Kharghar - Nerul                                 | IntraState                | 31/08/2018   | 06.09        |            | Continued. | PO          | BROKEN STAND-OFF Y-PHASE CONDUCTOR.                 |
| <b>220 KV ICT Outages/Trippings</b>              |                           |              |              |            |            |             |                                                     |
| 220/132 Kv 200 Mva Emco Ict 2 @Raymond (Nasik 2) | IntraState                | 18/08/2018   | 22.50        |            | Continued. | HT          | due to sparking on R-PH HV bushing.                 |
| 220/132kv 150MVA ICT-II @ Bhenda                 | IntraState                | 30/08/2018   | 17.25        | 30/08/2018 | 19.35      | PO          | OLTC OIL TOP UP & QUARTERLY MAINTENANCE WORK.       |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage