

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 30/Sep/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	131.436	3458.843	1) Gujrat	14.498	305.979
2) Hydro	5.449	330.171	2) Madhya Pradesh	2.234	138.089
3) Gas	1.981	75.813	3) Chattisgarh	4.900	112.540
Total MSPGCL	138.866	3864.827	4) Maharashtra	157.843	4526.056
B) 1) APLM	61.051	1881.649	5) Goa (Amona)	-1.011	-35.059
2) JSWEL	17.650	541.202	Total	178.464	5047.605
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.015	971.173
4) RPL(AMT)	24.331	532.239	b) Mumbai Drawl	39.277	1073.897
5) SWPGPL	7.356	153.404	c) MSEDCL Bilateral *	62.144	1749.835
6) Other IPP	4.608	163.028	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.015	970.958
C) 1) TPCL Thermal	10.405	333.417	Include PX	0.000	0.000
2) TPCL Hydro	4.138	149.793	Standby	0.000	0.215
3) TPCL Gas	2.345	27.234	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.826	269.730	1) MSEDCL	405.980	11709.749
D) STATE			2) Mumbai Discoms	65.991	1854.072
1) Thermal	266.663	7333.512	3) Other Discoms	9.469	271.083
(A1+C1+C4+(B1-B6))			TOTAL STATE	481.440	13834.904
2) Hydro	9.587	479.964			
(A2+C2)					
3) Gas	4.326	103.047			
(A3+B7+C3)					
4) Wind	11.151	599.310			
6) SOLAR	11.249	271.465			
TOTAL STATE	302.976	8787.298			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	5161	5024	5807	5569
MSPGCL Hydro	246	157	884	145
MSPGCL Gas	83	83	83	85
MSPGCL Total Generation	5490	5264	6774	5799
Central Sector Receipt	8824	8357	6896	5915
WIND	144	152	800	425
CPP / IPP Thermal	4145	4499	5643	4768
CPP / IPP Gas	0	0	0	0
SOLAR	1575	1542	1	0
Exchange with Mumbai	-2145	-2126	-1735	-1164
MSEDCL DEMAND MET	17598	17267	17949	15412
Load Shedding	0	0	0	0
MSEDCL DEMAND	17598	17267	17949	15412
TPCL GENERATION	726	719	885	632
AEML GENERATION	485	464	458	361
MUMBAI DEMAND	3356	3309	3078	2157
OTHER DISCOM DEMAND	435	421	430	331
STATE DEMAND MET	21389	20997	21457	17900
STATE DEMAND	21389	20997	21457	17900
Frequency (Hz)	50.01	49.99	50.00	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.11 Hz at 14.00 Hrs	49.89 Hz at 13.43 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation, Maximum, Minimum for 30/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	39.35	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.44	294.76	470	370
Unit 9	9.49	87.39	443	340
Unit 10	10.46	299.46	462	376
Total	30.39	720.97		
Bhusawal				
Unit 3	2.48	60.29	120	55
Unit 4	7.30	243.36	355	230
Unit 5	8.65	99.52	405	280
Total	18.43	403.17		
Parli				
Unit 6	4.63	131.04	218	140
Unit 7	4.71	109.99	234	140
Unit 8	3.47	108.75	190	122
Total	12.81	349.77		
Chandrapur				
Unit 3	3.19	89.14	170	73
Unit 4	2.88	90.18	150	0
Unit 5	7.05	163.20	325	260
Unit 6	7.61	178.47	395	270
Unit 7	8.01	174.22	342	302
Unit 8	0.00	49.00	0	0
Unit 9	9.01	277.35	444	283
Total	37.75	1021.57		
Paras				
Unit 3	4.88	135.15	227	156
Unit 4	0.00	86.15	0	0
Total	4.88	221.30		
Khaparkheda				
Unit 1	2.94	80.52	135	110
Unit 2	2.85	49.25	150	105
Unit 3	3.28	95.65	165	115
Unit 4	3.30	91.29	173	124
Unit 5	8.74	243.58	450	270
Total	21.12	560.29		
Nasik				
Unit 3	3.11	37.61	146	118
Unit 4	2.96	62.66	141	102
Unit 5	0.00	81.51	0	0
Total	6.07	181.77		
Uran				
All Units	1.98	75.81	86	67
Total	1.98	75.81		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	15.69	26	24
Total	0.60	15.69		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.50	65.54	320	35
Stage 4	0.50	54.14	280	0
Stage 3	0.44	31.06	160	0
Total	2.43	150.74		
Hydro				
KDPH	0.00	7.61	0	0
VTRNA	0.00	19.47	0	0
TILLARI	0.00	12.89	0	0
BHIRA T.R.	0.28	11.41	77	0
SMLHY_PTN	2.01	106.22	93	73
GHATGHAR	0.13	6.13	76	0
Total	2.42	163.74		
Wind				
Total	11.15	599.31	0	0
Total	11.15	599.31		
CPP				
APML(Mus)	61.05	1881.65	0	0
JSWEL(Mus)	17.65	541.20	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.33	532.24	0	0
SWPGPL-Mus	7.36	153.40	0	0
Other(Mus)	4.61	163.03	0	0
Total	115.00	3271.52		
SOLAR				
Total	11.25	271.46	0	0
Total	11.25	271.46		
Tata				
Trombay 5	6.99	224.22	421	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.30	16.85	74	41
Trombay 7B	1.05	10.38	54	36
TATA Hydro	4.14	149.79	413	29
Trombay 8	3.42	109.20	203	131
Total	16.89	510.44		
AEML				
DTPS U-1&2	9.83	269.73	486	290
Total	9.83	269.73		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	131.44	3458.84	MSPGCL Total	138.87	3864.83
			MSPGCL Thml+Gas	133.42	3534.66	Koyna 1,2 & 4 Total	1.99	119.68
			MSPGCL Hydro	5.45	330.17	State Total	302.98	8787.30

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 30/Sep/2022

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5491	191	85	5767	349	4902	0	0	6320	6611	-1201	16081	0	16081	2338	347	18766	49.98
2	5569	145	85	5799	425	4768	0	0	6317	5915	-1164	15412	0	15412	2157	331	17900	49.99
3	5701	145	85	5931	449	4660	0	0	6357	6025	-1102	15644	0	15644	2016	319	17979	50.00
4	5719	145	85	5949	452	4592	0	0	6625	6250	-1068	15873	0	15873	1924	302	18099	50.03
5	5776	157	85	6018	443	4607	0	0	6713	6569	-1080	16225	0	16225	1928	332	18485	50.01
6	5824	148	85	6057	446	4994	0	0	7034	7273	-1059	17362	0	17362	2038	349	19749	50.01
7	5894	139	86	6119	460	5375	0	61	8008	7887	-1141	18388	0	18388	2204	373	20965	50.00
8	5854	146	85	6085	384	5143	0	410	8860	8414	-1481	18552	0	18552	2410	403	21365	50.04
9	5804	187	86	6077	324	4689	0	869	8495	8367	-1902	17987	0	17987	2759	437	21183	50.03
10	5458	186	85	5729	215	4550	0	1328	8690	8428	-2082	17741	0	17741	3075	427	21243	50.01
11	4996	212	84	5292	127	4345	0	1525	8897	8779	-2122	17509	0	17509	3293	437	21239	50.01
12	5161	246	83	5490	144	4145	0	1575	8526	8824	-2145	17598	0	17598	3356	435	21389	50.01
13	5024	157	83	5264	152	4499	0	1542	8429	8357	-2126	17267	0	17267	3309	421	20997	49.99
14	4950	139	82	5171	457	4425	0	1301	8436	8318	-2170	17091	0	17091	3173	411	20675	50.00
15	4902	144	80	5126	362	4525	0	1073	8580	8461	-2246	16877	0	16877	3237	424	20538	50.01
16	4879	133	74	5086	266	4552	0	903	8440	8529	-2180	16738	0	16738	3256	418	20412	50.01
17	5275	141	67	5483	395	4677	0	547	8109	7979	-2035	16622	0	16622	3217	424	20263	50.02
18	5693	142	68	5903	441	4953	0	114	7644	7494	-1827	16642	0	16642	3141	436	20219	50.02
19	5807	884	83	6774	800	5643	0	1	6896	6896	-1735	17949	0	17949	3078	430	21457	50.00
20	5855	642	83	6580	966	5736	0	0	6577	6349	-1498	17718	0	17718	3073	415	21206	50.04
21	5613	250	85	5948	853	5208	0	0	6808	6858	-1568	16887	0	16887	2947	412	20246	50.03
22	5489	313	85	5887	856	4681	0	0	6623	6749	-1580	16172	0	16172	2814	421	19407	50.00
23	5428	214	86	5728	747	4690	0	0	6504	6520	-1436	15852	0	15852	2669	397	18918	50.01
24	5274	243	86	5603	638	4637	0	0	6383	6612	-1329	15791	0	15791	2579	370	18740	50.00
MUs	131.44	5.45	1.98	138.87	11.15	115.00	0.00	11.25	180.27	178.46	-39.28	405.98	0.00	405.98	65.99	9.47	481.44	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 30/Sep/2022

Position as on 6.30 Hrs of 01/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	01/10/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	02/10/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	10/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35		Continued.	Tripped on Furnace Pressure High(converted to Overhaul)	03/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/10/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-2	270	18/09/2022	13:44		Continued.	Bottom Ash Evacuation problem.	03/10/2022
MSPGCL	Uran Unit 5	108	27/09/2022	17:11		Continued.	Gas shortage	
MSPGCL	Nasik Unit 5	210	29/09/2022	21:00		Continued.	Seal Trough Leakage(converted to Critical Coal Stock w.e.f.21.00 Hrs Dt.30-09-	
MSPGCL	Chandrapur Unit 4	210	29/09/2022	22:09	30/09/2022	01:19	System problem	
IPP	SWPGPL U-4	135	30/09/2022	10:35	30/09/2022	13:01	Turbine Oil Pressure Low.	
IPP	Adani U-5	660	01/10/2022	14:38		Continued.	APH-A hot PA below Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 01/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	30/09/2022	01:37	30/09/2022	09:21	EO	To attend the Hotspot on Pole-2 Earth rod, P2 B phTF A , P2 Y ph TF 2B
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (403) OF FUTURE LINE @ KUDUS	IntraState	30/09/2022	11:13	30/09/2022	15:47	EO	For attending alignment issue of 402-89B,as currently 402 bay (Tie bay of Kala-2) is already out off service due B-phase isolator blade issue
400 KV LINE Outages/Trippings							
LONIKAND I - TALEGAON (PGCIL)	InterState	30/09/2022	16:58	30/09/2022	21:09	PO	Replacement of PID suspected string at loc. no. 37 R phase for which 5 nos of discs shown weak.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	27/09/2022	10:25			HT	for load management
PADGHE - NAGOTHANE CKT - 2	IntraState	29/09/2022	18:52	30/09/2022	18:44	T	Tripped on DP
KHADKA-AURANGABAD (WALUJ)	IntraState	30/09/2022	22:11	01/10/2022	09:30	HT	To control Overvoltage
PADGHE - KALWA CKT - 2	IntraState	01/10/2022	06:04	01/10/2022	14:32	PO	For Temporary diversion of the 400KV Kalwa-Padgha-II line between loc no. 3 to 46 on Dead Ckt of 400KV Padgha-Kharghar Line between loc no. 88 to 132 using ERS for the Work of replacement of existing 0.5 ACSR Twin Moose Conductor by HTLS conductor of Kalwa-Padgha-II line.
400 KV ICT Outages/Trippings							
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	26/09/2022	11:32				Oil filtration, Oil leakage attending, Electrical Testing and painting of Station Transformer -8A Station Transformer -8A Bus duct servicing, maintenance and below replacement
400 KV BR Outages/Trippings							
125 MVAR BUS REACTOR @ 400KV KHAPARKHEDA S/S	InterState	30/09/2022	10:44	30/09/2022	13:07	PO	Diagnostic Testing of 400 kv 125 MVAR Shunt Bus Reactor
125MVAR BUS REACTOR @ WARORA	IntraState	01/10/2022	10:37	01/10/2022	16:12	PO	Bushing Tan delta ,Diagnostic testing work
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	26/09/2022	07:44			HT	for load management on Nashik BBLR
EKLAHARE (OCR) - PADGHE	IntraState	29/09/2022	10:33	01/10/2022	19:24	PO	CB overhauling work
TROMBAY - DHARAVI 9	IntraState	29/09/2022	17:43	30/09/2022	04:05	HT	For Emergency outage of Main bus section 2 @ Trombay tata
TROMBAY MSETCL TIE - 2	IntraState	29/09/2022	17:47	30/09/2022	03:57	HT	For Emergency outage of Main bus section 2 @ Trombay tata
TROMBAY MSETCL TIE - 1	IntraState	29/09/2022	17:48	30/09/2022	03:53	HT	For Emergency outage of Main bus section 2 @ Trombay tata
BUS - 2 @ TROMBAY	IntraState	29/09/2022	17:48	30/09/2022	03:53	EO	Main Bus 2 outage will be required as Tie line 1 traverses above Main Bus 2 and during attending Tie 1 Gantry string insulator
KARAD - VITA CKT- 2	IntraState	30/09/2022	08:03	30/09/2022	20:00	PO	For wiring,commissioning & charging of new 220 kv CGL make CB (200SFM50AA Sr No-58661C & taking load on own bay after charging of 220 kv CB

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 01/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GOREGAON - AAREY CKT - 1	IntraState	30/09/2022	09:57	30/09/2022	16:25	PO	Under MMRC Line Diversion scheme for Metro-3 project Tightening of loose jumper connection observed during routine inspection.
FLAGSHIP-CHINCHWAD	IntraState	30/09/2022	11:22	30/09/2022	17:21	PO	Annual Relay Testing and Maintenance work
BORIVALI - TARAPUR	IntraState	30/09/2022	12:34	30/09/2022	18:34	PO	Work of replacement of rusted hardware in balance span at location 28-50.
PADGHE - WADA	IntraState	30/09/2022	14:44	30/09/2022	23:19	PO	Work to be carried out :- 1. Retrofitting of 86Relay under MTAMC Work 2. modification of 220kV Earth Isolators & attending closing/opening problem of Line isolators. 3. Diagnostic testing work of CT, CB & LA
RANJANGAON-LONIKAND	IntraState	30/09/2022	15:22	30/09/2022	16:25	EO	To carryout the Work of emergency teak wood tree & coconut tree trimming between Loc No 345-346 in ROW Issue.
PARGAON(KATHAPUR)-LONIKAND	IntraState	30/09/2022	16:51	30/09/2022	21:47	EO	To carryout the Work of emergency teak wood tree & coconut tree trimming between Loc No 345-346 in ROW Issue.
BORIVALI - TARAPUR	IntraState	30/09/2022	18:29	01/10/2022	18:34	T	TRIPPED ON SOTF WHILE CHARGING AFTER COMPLITION OF OUTAGE
KARAD - NERLE	IntraState	01/10/2022	05:52	01/10/2022	07:54	T	Tripped on DP
NERLE- POPHALI	IntraState	01/10/2022	05:55	01/10/2022	08:45	T	Tripped from Popoali end only
NERLE - DASGAON	IntraState	01/10/2022	05:56	01/10/2022	08:11	T	Tripped from Dasgaon end
TROMBAY - ANTOP HILL CKT - 2	IntraState	01/10/2022	06:16	01/10/2022	07:44	PO	Bird nest removal at Trombay
TAMBATI - ADLABS	IntraState	01/10/2022	07:05	01/10/2022	08:40	EO	Attending hotspot at Loc no. 528 (LILO tower) top phase.
PIRANGUT - HINJAWADI 2	IntraState	01/10/2022	09:28	01/10/2022	13:05	PO	Removal of earth wire & OPGW on Tower no 1
MAHALAXMI - BACKBAY	IntraState	01/10/2022	09:39		Continued.	PO	Cable shifting work at Marine drive for Coastal road project work by BMC
BORIVALI - TARAPUR	IntraState	01/10/2022	11:50	01/10/2022	18:34	PO	Work of replacement of rusted hardware in balance span at location 28-50.
KURKUMBH - SHIRSHUPHAL CKT	IntraState	01/10/2022	14:20	01/10/2022	15:55	PO	ISOLATION OF LINE ISOLATOR BY REMOVING JUMPERS TO REPLACE ISOLATOR.
BOISAR - VERSOVA	IntraState	01/10/2022	18:51	01/10/2022	21:58	HT	HT for load management
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
250 MVA ICT-5 @ TROMBAY	IntraState	29/09/2022	17:42	30/09/2022	05:00	HT	For Emergency outage of Main bus section 2 @ Trombay tata
220/33 KV 50MVA PTR NO 1 @ ALEPHATA	IntraState	30/09/2022	08:49	30/09/2022	11:36	PO	For CB timing and general maintenance work.
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	30/09/2022	10:19	30/09/2022	11:46	PO	For attending hot spots
220/22 KV 50 MVA PTR 1 @ PADGHE	IntraState	30/09/2022	10:27	30/09/2022	20:26		Replacement of 70kN Disc Insulator by 120kN Disc Insulator suspension type
220/132KV 100MVA ICT-2 @ WALCHANDNAGAR	IntraState	30/09/2022	10:40	30/09/2022	14:05	PO	CTR fire fighting system overhauling

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 01/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA	IntraState	30/09/2022	11:50	30/09/2022	14:56	PO	For CB timing and general maintenance work.
220/22-22 KV 50 MVA PTR 3 @ ANANDNAGAR	IntraState	30/09/2022	13:20	30/09/2022	14:28	PO	For attending hot spots
220/33 KV 50 MVA PTR NO 3 @ ALEPHATA	IntraState	30/09/2022	15:05	30/09/2022	18:33	PO	For CB timing and general maintenance work.
220/33kv 50MVA TF-1 @ KOPARGAON	IntraState	01/10/2022	11:00	01/10/2022	14:01	PO	For Diagnostic of 220/33 KV Trafo -1 and its associated equipment (Tan Delta, CRM, CBT) and Attending Hotspot at R Ph LV Bushing
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	01/10/2022	11:06	01/10/2022	13:58	PO	RECONNECTION OF TBC ISOLATOR OF ICT BAY.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
KHOPOLI - BHIVPURI CKT - 2	IntraState	30/09/2022	09:32	30/09/2022	13:37	PO	attending hot spot on c ph vertical dropper at Khopoli
BMC KOLSHET	IntraState	30/09/2022	12:03	30/09/2022	19:21	EO	replacement of damaged arm of 110kV Kolshet-BMC Line GOD at BMC.
WAGHIVALI - CHEMBUR	IntraState	30/09/2022	14:26	30/09/2022	16:25	EO	PROJECT WORK- Loc No:56 (Erection with Crane near close proximity of 110KV line for 400KV Tower Erection work in Mandala)

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage