

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 30/Oct/2021 SATURDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 143.817        | 3738.855        | 1) Gujrat                      | -4.465         | -219.527         |
| 2) Hydro            | 11.373         | 642.781         | 2) Madhya Pradesh              | 9.313          | 283.687          |
| 3) Gas              | 5.784          | 151.488         | 3) Chattisgarh                 | 6.150          | 162.270          |
| <b>Total MSPGCL</b> | <b>160.974</b> | <b>4533.124</b> | 4) Maharashtra                 | 147.845        | 4436.283         |
| B) 1) APML          | 58.986         | 1747.747        | 5) Goa (Amona)                 | -1.572         | -34.481          |
| 2) JSWEL            | 14.255         | 510.437         | <b>Total</b>                   | <b>157.271</b> | <b>4628.232</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 27.901         | 812.459          |
| 4) RPL(AMT)         | 16.626         | 494.923         | b) Mumbai Drawl                | 26.943         | 841.267          |
| 5) SWPGPL           | 5.599          | 163.004         | c) MSEDCL Bilateral *          | 37.462         | 1211.535         |
| 6) Other IPP        | 19.187         | 242.909         | Include PX                     | 2.216          | 244.531          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 27.901         | 812.345          |
| C) 1) TPCL Thermal  | 12.318         | 439.400         | Include PX                     | 6.869          | 132.991          |
| 2) TPCL Hydro       | 3.325          | 128.331         | Standby                        | 0.000          | 0.114            |
| 3) TPCL Gas         | 4.288          | 102.292         | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 9.361          | 308.445         | 1) MSEDCL                      | 432.130        | 11960.251        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 56.235         | 1819.740         |
| 1) Thermal          | 280.149        | 7645.720        | <b>TOTAL STATE</b>             | <b>488.365</b> | <b>13779.991</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro            | 14.698         | 771.112         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 10.072         | 253.780         |                                |                |                  |
| (A3+B7+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 18.094         | 255.373         |                                |                |                  |
| 6) SOLAR            | 8.081          | 225.769         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>331.094</b> | <b>9151.754</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 2 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 6364                      | 6387                  | 6540                      | 4831                      |
| MSPGCL Hydro             | 907                       | 400                   | 1148                      | 277                       |
| MSPGCL Gas               | 232                       | 227                   | 251                       | 248                       |
| MSPGCL Total Generation  | 7503                      | 7014                  | 7939                      | 5356                      |
| Central Sector Receipt   | 7284                      | 7684                  | 6350                      | 5758                      |
| WIND                     | 768                       | 233                   | 224                       | 1458                      |
| CPP / IPP Thermal        | 5087                      | 5176                  | 5086                      | 4282                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 1069                      | 886                   | 0                         | 0                         |
| Exchange with Mumbai     | -1586                     | -1106                 | -1063                     | -1099                     |
| <b>MSEDCL DEMAND MET</b> | <b>20125</b>              | <b>19887</b>          | <b>18536</b>              | <b>15755</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 20125                     | 19887                 | 18536                     | 15755                     |
| TPCL GENERATION          | 711                       | 1039                  | 1147                      | 604                       |
| AEML GENERATION          | 341                       | 499                   | 500                       | 287                       |
| <b>MUMBAI DEMAND</b>     | <b>2638</b>               | <b>2644</b>           | <b>2710</b>               | <b>1990</b>               |
| STATE DEMAND MET         | 22763                     | 22531                 | 21246                     | 17745                     |
| <b>STATE DEMAND</b>      | <b>22763</b>              | <b>22531</b>          | <b>21246</b>              | <b>17745</b>              |
| Frequency (Hz)           | 50.01                     | 49.92                 | 49.96                     | 50.01                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.28 Hz at 13.03 Hrs | 49.64 Hz at 16.51 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 30/Oct/2021

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 3.57         | 86.06          | 185      | 120      |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 13.67        | 357.63         | 620      | 398      |
| Unit 9             | 13.73        | 282.69         | 617      | 390      |
| Unit 10            | 13.67        | 270.29         | 603      | 434      |
| <b>Total</b>       | <b>44.64</b> | <b>996.68</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 8.78         | 249.80         | 405      | 280      |
| Unit 5             | 8.71         | 194.10         | 400      | 275      |
| <b>Total</b>       | <b>17.48</b> | <b>443.90</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 6             | 4.30         | 36.55          | 221      | 147      |
| Unit 7             | 4.15         | 129.54         | 223      | 151      |
| Unit 8             | 4.06         | 124.28         | 207      | 150      |
| <b>Total</b>       | <b>12.52</b> | <b>290.36</b>  |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 3.34         | 74.73          | 156      | 125      |
| Unit 5             | 9.08         | 183.87         | 420      | 295      |
| Unit 6             | 0.00         | 98.28          | 0        | 0        |
| Unit 7             | 7.75         | 230.04         | 356      | 288      |
| Unit 8             | 9.21         | 274.33         | 425      | 280      |
| Unit 9             | 9.93         | 272.01         | 474      | 287      |
| <b>Total</b>       | <b>39.31</b> | <b>1133.26</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 0.00         | 101.07         | 0        | 0        |
| Unit 4             | 4.12         | 70.92          | 213      | 141      |
| <b>Total</b>       | <b>4.12</b>  | <b>171.98</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 2.65         | 48.84          | 125      | 90       |
| Unit 2             | 3.24         | 94.50          | 170      | 120      |
| Unit 3             | 3.48         | 103.74         | 177      | 120      |
| Unit 4             | 3.22         | 105.26         | 153      | 124      |
| Unit 5             | 9.84         | 244.49         | 480      | 275      |
| <b>Total</b>       | <b>22.43</b> | <b>596.84</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 3.32         | 105.84         | 188      | 114      |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>3.32</b>  | <b>105.84</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 5.78         | 151.49         | 259      | 227      |
| <b>Total</b>       | <b>5.78</b>  | <b>151.49</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.58         | 15.68          | 25       | 24       |
| <b>Total</b>       | <b>0.58</b>  | <b>15.68</b>   |          |          |
| <b>Koyna</b>       |              |                |          |          |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 3.10          | 138.84         | 430      | 40       |
| Stage 4         | 0.91          | 232.58         | 268      | 0        |
| Stage 3         | 0.87          | 80.15          | 160      | 0        |
| <b>Total</b>    | <b>4.87</b>   | <b>451.58</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.43          | 4.10           | 18       | 18       |
| VTRNA           | 0.00          | 4.15           | 0        | 0        |
| TILLARI         | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.24          | 8.65           | 80       | 0        |
| SMLHY_PTN       | 5.40          | 160.02         | 238      | 205      |
| GHATGHAR        | 0.43          | 14.27          | 220      | 0        |
| <b>Total</b>    | <b>6.50</b>   | <b>191.20</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 18.09         | 255.37         | 0        | 0        |
| <b>Total</b>    | <b>18.09</b>  | <b>255.37</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 58.99         | 1747.75        | 0        | 0        |
| JSWEL(Mus)      | 14.26         | 510.44         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 16.63         | 494.92         | 0        | 0        |
| SWPGPL-Mus      | 5.60          | 163.00         | 0        | 0        |
| Other(Mus)      | 19.19         | 242.91         | 0        | 0        |
| <b>Total</b>    | <b>114.65</b> | <b>3159.02</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 8.08          | 225.77         | 0        | 0        |
| <b>Total</b>    | <b>8.08</b>   | <b>225.77</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 7.98          | 291.58         | 478      | 268      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.71          | 61.87          | 113      | 112      |
| Trombay 7B      | 1.58          | 40.42          | 66       | 65       |
| Trombay 8       | 4.33          | 147.82         | 220      | 141      |
| TATA Hydro      | 3.32          | 128.33         | 378      | 2        |
| <b>Total</b>    | <b>19.93</b>  | <b>670.02</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 9.36          | 308.44         | 502      | 287      |
| <b>Total</b>    | <b>9.36</b>   | <b>308.44</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 143.82      | 3738.86       | MSPGCL Total        | 160.97      | 4533.12       |
|                |             |         | MSPGCL Thml+Gas | 149.60      | 3890.34       | Koyna 1,2 & 4 Total | 4.00        | 371.42        |
|                |             |         | MSPGCL Hydro    | 11.37       | 642.78        | State Total         | 331.09      | 9151.75       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 30/Oct/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4764        | 282   | 248  | 5294   | 1379  | 4191      | 0    | 0     | 6204        | 6154        | -1196                | 15822                 | 0                    | 15822                     | 2121             | 17943           | 50.03         |
| 2                  | 4831        | 277   | 248  | 5356   | 1458  | 4282      | 0    | 0     | 5866        | 5758        | -1099                | 15755                 | 0                    | 15755                     | 1990             | 17745           | 50.01         |
| 3                  | 5044        | 263   | 249  | 5556   | 1412  | 4289      | 0    | 0     | 5780        | 5612        | -970                 | 15899                 | 0                    | 15899                     | 1877             | 17776           | 50.01         |
| 4                  | 5084        | 275   | 248  | 5607   | 1342  | 4304      | 0    | 0     | 5814        | 5759        | -900                 | 16112                 | 0                    | 16112                     | 1801             | 17913           | 49.99         |
| 5                  | 5666        | 276   | 259  | 6201   | 1240  | 4385      | 0    | 0     | 5750        | 5854        | -872                 | 16808                 | 0                    | 16808                     | 1781             | 18589           | 50.01         |
| 6                  | 5976        | 322   | 249  | 6547   | 1259  | 4640      | 0    | 0     | 6213        | 6229        | -859                 | 17816                 | 0                    | 17816                     | 1831             | 19647           | 49.99         |
| 7                  | 6275        | 385   | 239  | 6899   | 1303  | 4996      | 0    | 26    | 6176        | 6119        | -786                 | 18557                 | 0                    | 18557                     | 1873             | 20430           | 50.02         |
| 8                  | 6412        | 526   | 249  | 7187   | 1132  | 5169      | 0    | 206   | 5998        | 6181        | -880                 | 18995                 | 0                    | 18995                     | 1972             | 20967           | 50.04         |
| 9                  | 6227        | 372   | 237  | 6836   | 1046  | 5011      | 0    | 572   | 6441        | 6711        | -1151                | 19025                 | 0                    | 19025                     | 2186             | 21211           | 50.06         |
| 10                 | 6208        | 477   | 244  | 6929   | 916   | 4830      | 0    | 864   | 7028        | 7185        | -1415                | 19309                 | 0                    | 19309                     | 2442             | 21751           | 50.01         |
| 11                 | 6364        | 907   | 232  | 7503   | 768   | 5087      | 0    | 1069  | 7381        | 7284        | -1586                | 20125                 | 0                    | 20125                     | 2638             | 22763           | 50.01         |
| 12                 | 6398        | 411   | 230  | 7039   | 584   | 5148      | 0    | 1210  | 7837        | 7360        | -1486                | 19855                 | 0                    | 19855                     | 2712             | 22567           | 50.05         |
| 13                 | 6132        | 279   | 239  | 6650   | 460   | 4751      | 0    | 1201  | 8073        | 7660        | -1285                | 19437                 | 0                    | 19437                     | 2728             | 22165           | 50.05         |
| 14                 | 6221        | 291   | 229  | 6741   | 278   | 4838      | 0    | 1051  | 7638        | 7217        | -1147                | 18978                 | 0                    | 18978                     | 2617             | 21595           | 50.11         |
| 15                 | 6387        | 400   | 227  | 7014   | 233   | 5176      | 0    | 886   | 7573        | 7684        | -1106                | 19887                 | 0                    | 19887                     | 2644             | 22531           | 49.92         |
| 16                 | 6434        | 614   | 227  | 7275   | 149   | 5181      | 0    | 667   | 7510        | 7281        | -1057                | 19496                 | 0                    | 19496                     | 2684             | 22180           | 49.97         |
| 17                 | 6427        | 662   | 228  | 7317   | 116   | 5061      | 0    | 288   | 7329        | 7232        | -994                 | 19020                 | 0                    | 19020                     | 2669             | 21689           | 49.90         |
| 18                 | 6453        | 648   | 230  | 7331   | 156   | 5092      | 0    | 41    | 6775        | 6910        | -1003                | 18527                 | 0                    | 18527                     | 2652             | 21179           | 49.99         |
| 19                 | 6540        | 1148  | 251  | 7939   | 224   | 5086      | 0    | 0     | 6671        | 6350        | -1063                | 18536                 | 0                    | 18536                     | 2710             | 21246           | 49.96         |
| 20                 | 6575        | 720   | 242  | 7537   | 365   | 5164      | 0    | 0     | 6611        | 6236        | -1056                | 18246                 | 0                    | 18246                     | 2665             | 20911           | 49.99         |
| 21                 | 6270        | 452   | 234  | 6956   | 396   | 4925      | 0    | 0     | 6296        | 5912        | -1178                | 17011                 | 0                    | 17011                     | 2557             | 19568           | 50.01         |
| 22                 | 5622        | 552   | 244  | 6418   | 421   | 4383      | 0    | 0     | 6283        | 6270        | -1252                | 16240                 | 0                    | 16240                     | 2454             | 18694           | 49.98         |
| 23                 | 5659        | 523   | 256  | 6438   | 640   | 4276      | 0    | 0     | 6411        | 6332        | -1313                | 16373                 | 0                    | 16373                     | 2346             | 18719           | 50.01         |
| 24                 | 5848        | 311   | 245  | 6404   | 817   | 4388      | 0    | 0     | 6413        | 5981        | -1289                | 16301                 | 0                    | 16301                     | 2285             | 18586           | 49.97         |
| MUs                | 143.82      | 11.37 | 5.78 | 160.97 | 18.09 | 114.65    | 0.00 | 8.08  | 160.07      | 157.27      | -26.94               | 432.13                | 0.00                 | 432.13                    | 56.24            | 488.36          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 30/Oct/2021**

**Position as on 6.30 Hrs of 31/Oct/2021**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                       | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                        |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 04/09/2021   | 23.58        |            | Continued. | Annual Overhaul                                                                        |               |
| MSPGCL                | Chandrapur Unit 6       | 500      | 17/10/2021   | 18.40        |            | Continued. | Boiler Tripped On Total Air Flow less than 30%.(Converted to AOH 00:00 hrs 18.10.2021) |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                        |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                   |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                   |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                                 |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                 |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                  |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                                          |               |
| MSPGCL                | Nasik Unit 3            | 210      | 30/08/2021   | 22.51        |            | Continued. | Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021            |               |
| IPP                   | JSW (J) U1              | 300      | 02/09/2021   | 08.41        |            | Continued. | Turbine vibrations high.                                                               |               |
| MSPGCL                | Uran Unit A0            | 120      | 10/09/2021   | 01.54        |            | Continued. | Turbine bearing Vabration high                                                         |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 18/09/2021   | 03.30        | 31/10/2021 | 04.40      | Coal Shortage                                                                          |               |
| MSPGCL                | Nasik Unit 5            | 210      | 19/09/2021   | 20.50        |            | Continued. | Coal Shortage.                                                                         |               |
| IPP                   | RPL(AMT) U-2            | 270      | 29/09/2021   | 01.15        |            | Continued. | Coal Shortage                                                                          |               |
| IPP                   | RPL(AMT) U-1            | 270      | 05/10/2021   | 22.15        |            | Continued. | Coal Shortage                                                                          |               |
| MSPGCL                | Uran Unit 5             | 108      | 14/10/2021   | 22.04        | 31/10/2021 | 17.40      | Gas shortage                                                                           |               |
| IPP                   | JSW (J) U4              | 300      | 22/10/2021   | 21.45        |            | Continued. | Due to no schedule.                                                                    |               |
| MSPGCL                | Paras Unit 3            | 250      | 27/10/2021   | 19.05        |            | Continued. | Air heater problem                                                                     |               |
| IPP                   | SWPGPL U-4              | 135      | 28/10/2021   | 20.18        |            | Continued. | Bearing vibration high                                                                 |               |
| MSPGCL                | Khaparkheda Unit 5      | 500      | 31/10/2021   | 13.37        |            | Continued. | Boiler Tube Leakage                                                                    |               |
| MSPGCL                | Paras Unit 4            | 250      | 31/10/2021   | 13.45        |            | Continued. | Boiler Tube Leakage                                                                    |               |
| TPC-G                 | Trombay 7A              | 120      | 31/10/2021   | 17.19        | 31/10/2021 | 20.22      | Tripping Of Control Oil Pump.                                                          |               |
| TPC-G                 | Trombay 7B              | 60       | 31/10/2021   | 17.19        | 31/10/2021 | 21.41      | Tripping Of Control Oil Pump.                                                          |               |
| MSPGCL                | Uran Unit 8             | 108      | 31/10/2021   | 21.07        | 31/10/2021 | 23.46      | Gas Skid Fault.                                                                        |               |
| MSPGCL                | Uran Unit B0            | 120      | 31/10/2021   | 21.07        |            | Continued. | Gas Skid Fault.                                                                        |               |
| IPP                   | SWPGPL U-2              | 135      | 31/10/2021   | 23.47        |            | Continued. | ID Fan Vibration High.                                                                 |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 30/Oct/2021**

**Statement-VII**

**Position as on 6.30 Hrs of 31/Oct/2021**

| Name of Line                         | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                     |
|--------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                                                      |
| Chandrapur - Padghe Hvdc Pole 2      | IntraState                | 31/10/2021   | 00.48        | 31/10/2021 | 05.28      | T           | Tripped on reduce voltage mode.                                                                                                                      |
| <b>400 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                                                      |
| Karad Solapur (PG)                   | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                                             |
| Dhule Sar'Sarovar I                  | InterState                | 30/10/2021   | 12.15        | 30/10/2021 | 13.46      | T           | Distance Protection                                                                                                                                  |
| Khadka-Aurangabad (Waluj)            | IntraState                | 11/10/2021   | 12.33        |            | Continued. | PO          | Height raising/shifting work of S/C 400kV Waluj- Bhusawal line for Samruddhi Mahamarg. ie. 1) Dismantling of loc no. 125 (D+6), 126 (D+6).           |
| Padghe - Nagothane - II              | IntraState                | 30/10/2021   | 08.13        | 30/10/2021 | 16.58      | PO          | For Chemical Washing Work.                                                                                                                           |
| Koradi-RattanIndia                   | IntraState                | 30/10/2021   | 09.54        | 30/10/2021 | 14.50      | EO          | Flashover Observed on B PH String & hardware At loc.no.260.                                                                                          |
| Kharghar-Talegaon(PG)                | IntraState                | 31/10/2021   | 06.38        | 31/10/2021 | 10.20      | EO          | Emergency Outage for removing of traction machine which is been stuck on old rusted Earth wire between loc. no. 103-104 in hilly section of Mathran. |
| <b>400 KV ICT Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                                                      |
| 400/132 Kv 200 Mva Ict 2 @Khadka     | IntraState                | 30/10/2021   | 09.57        | 30/10/2021 | 17.17      | PO          | For Diagnostic Testing & Routine bay Maintenance Work.                                                                                               |
| 400/220 KV 300 MVA ICT- I @Koradi    | IntraState                | 30/10/2021   | 10.35        | 30/10/2021 | 22.22      | PO          | For Routine Diagnostic Testing Work bushing tan delta, winding tan delta.                                                                            |
| <b>220 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                                                      |
| Mudshingi Chikodi                    | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                                                          |
| Talandage - Chikodi                  | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                                                               |
| Borivali - Tarapur                   | InterState                | 27/10/2021   | 10.20        | 30/10/2021 | 22.06      | PO          | Tarapur work.                                                                                                                                        |
| Boiser(M)-Boiser(PG) -III            | InterState                | 30/10/2021   | 13.16        | 30/10/2021 | 20.03      | EO          | Oil Leakage Attending of 220kV B PH CT. Fumes are seen from 220kV B PH CT Stud.                                                                      |
| Padegaon-Sawangi                     | IntraState                | 29/10/2021   | 08.23        |            | Continued. | PO          | Height raising at 1st crossing form LOC no.38 to LOC no.41 & 2nd crossing form LOC no.22 to 23 for samruddhi mahamarg crossing (ORC) packing NME.    |
| Trombay Salsette 1 Backbay           | IntraState                | 29/10/2021   | 23.37        | 30/10/2021 | 07.37      | PO          | Metro Work.                                                                                                                                          |
| Trombay-Salsette II                  | IntraState                | 29/10/2021   | 23.51        | 30/10/2021 | 07.46      | PO          | Metro Work.                                                                                                                                          |
| Kalmeshwar-Kalmeshwar Rly Tss 2      | IntraState                | 30/10/2021   | 01.18        | 30/10/2021 | 02.45      | T           | Bus bar operated.                                                                                                                                    |
| Kalmeshwar-Kalmeshwar Rly Tss 1      | IntraState                | 30/10/2021   | 01.18        | 30/10/2021 | 01.54      | T           | Bus bar operated.                                                                                                                                    |
| Khaparkheda-Kalmeshwar               | IntraState                | 30/10/2021   | 01.18        | 30/10/2021 | 16.48      | T           | Due To Bursting of B-PH CT Bus Bar Protection Operated.                                                                                              |
| Kalmeshwar-Pandhurna                 | IntraState                | 30/10/2021   | 01.18        | 30/10/2021 | 02.15      | T           | Bus bar operated.                                                                                                                                    |
| Ambazari-Kalmeshwar                  | IntraState                | 30/10/2021   | 01.18        | 30/10/2021 | 01.44      | T           | Bus bar operated.                                                                                                                                    |
| Kalmeshwar-Kalmeshwar Rly Tss 1      | IntraState                | 30/10/2021   | 08.33        | 30/10/2021 | 10.05      | PO          | To Remove CT For Replacing B-PH CT of Khaperkheda ckt.                                                                                               |
| MAHAPE - RELIANCE GIS                | IntraState                | 30/10/2021   | 09.08        | 30/10/2021 | 16.40      | PO          | Bay maintenance & Diagnostic Testing work.                                                                                                           |
| karad - Dasgaon                      | IntraState                | 30/10/2021   | 09.35        | 30/10/2021 | 18.32      | PO          | 220kV line bay maintenance & SF6 Breaker hardware Replacement.                                                                                       |
| Kadegaon-Miraj                       | IntraState                | 30/10/2021   | 10.11        | 30/10/2021 | 17.30      | PO          | outage For Cold line Washing & String Replacement Work.                                                                                              |
| Chinchwad-Hinjewadi I                | IntraState                | 30/10/2021   | 10.24        | 30/10/2021 | 18.06      | PO          | Half yearly maintenance work, DT & Relay Testing.                                                                                                    |
| Bableshwar -Ahamadnagar-I            | IntraState                | 30/10/2021   | 10.48        | 30/10/2021 | 17.55      | PO          | For Replacement of 220kV CTs..                                                                                                                       |
| Parli 3 (Old Gcr)-Girwali Ckt 2      | IntraState                | 30/10/2021   | 11.02        | 30/10/2021 | 13.33      | EO          | Attending Hot Spot on R PH CT                                                                                                                        |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 30/Oct/2021**

**Statement-VII**

Position as on 6.30 Hrs of 31/Oct/2021

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                               |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------|
|                                          |                           |              |              |            |            |             | line side Pad at 220kV Girwali S/S.                                                            |
| Nanded-Nanded(Waghale) I                 | IntraState                | 30/10/2021   | 11.43        | 30/10/2021 | 18.43      | PO          | B PH CT P1 Side Stud Oil Leakage Attending & P1 Side CU Stud Replacement Work By Agency.       |
| Paras Ext. - Balapur                     | IntraState                | 30/10/2021   | 11.58        | 30/10/2021 | 14.14      | PO          | Diagnostic Testing & Routine Maintenance Work                                                  |
| Theur-Phursungi                          | IntraState                | 30/10/2021   | 15.55        | 30/10/2021 | 17.17      | EO          | Replacement of Flash over string at L.N.18 R PH.                                               |
| Bableshwar Ahamadnagar-li                | IntraState                | 30/10/2021   | 18.02        | 30/10/2021 | 21.53      | PO          | For Replacement of 220kV CTs.                                                                  |
| karad - Dasgaon                          | IntraState                | 31/10/2021   | 09.29        | 31/10/2021 | 15.17      | PO          | 220kV line bay maintenance and SF6 breaker bottom pad hardware replacement.                    |
| Mahad-Kandalgaon                         | IntraState                | 31/10/2021   | 11.50        | 31/10/2021 | 17.45      | PO          | Replacement of Damaged nut & bolts of Jumper at Loc.No.10 & 16 and etc. Line maintenance work. |
| Nalasopara-Boisar                        | IntraState                | 31/10/2021   | 12.10        | 31/10/2021 | 20.55      | PO          | PID Faulty Insulator String Replacement.                                                       |
| Khaparkheda-Kalmeshwar                   | IntraState                | 31/10/2021   | 12.13        | 31/10/2021 | 12.56      | T           | Shifting To Main Bus 1 Ckt.                                                                    |
| <b>220 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                |
| 220/132 Kv 200 Mva Bbl Ict 1 @Kalmeshwar | IntraState                | 30/10/2021   | 01.18        | 30/10/2021 | 03.02      | T           | Bus bar operated.                                                                              |
| 220/132 Kv 200 MVA ICT II @Kalmeshwar    | IntraState                | 30/10/2021   | 01.18        | 30/10/2021 | 02.10      | T           | Bus Bar protection Operated.                                                                   |
| Dharavi : 220 / 105 / 23 250 MVA ICT 7   | IntraState                | 31/10/2021   | 09.19        | 31/10/2021 | 14.47      | PO          | For Guard wire Removal(GIS Project Work).                                                      |
| 220/100 Kv 200 MVA ICT II @Kolshet       | IntraState                | 31/10/2021   | 14.30        | 31/10/2021 | 20.50      | T           | Differential protection                                                                        |
| Dharavi : 220 / 110 / 33 250 MVA ICT 9   | IntraState                | 31/10/2021   | 15.21        | 31/10/2021 | 17.54      | PO          | For Disconnection Of TBS GOD (GIS Project Work).                                               |
| Dharavi : 220 / 110 / 33 250 MVA ICT 8   | IntraState                | 31/10/2021   | 18.30        | 31/10/2021 | 19.49      | PO          | For Disconnection of TBS GOD Connection (GIS Project Work).                                    |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage