

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 30/Dec/2018 SUNDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 131.576        | 4049.527        | 1) Gujrat                      | 0.152          | 37.760           |
| 2) Hydro            | 3.968          | 156.760         | 2) Madhya Pradesh              | 4.595          | 243.826          |
| 3) Gas              | 7.297          | 209.327         | 3) Chattisgarh                 | 4.100          | 164.040          |
| <b>Total MSPGCL</b> | <b>142.841</b> | <b>4415.614</b> | 4) Maharashtra Net             | 82.817         | 2711.740         |
| B) 1) APML          | 62.993         | 2039.135        | 5) Goa (Amona)                 | -0.198         | -9.240           |
| 2) JSWEL            | 19.621         | 558.506         | <b>Total</b>                   | <b>91.466</b>  | <b>3148.126</b>  |
| 3) VIPL             | 5.074          | 273.807         | a) Mumbai Schedule             | 14.809         | 550.167          |
| 4) RPL(AMT)         | 0.000          | 270.357         | b) Mumbai Drawl                | 18.954         | 656.276          |
| 5) WPCL             | 0.000          | 27.408          | c) MSEDCL Bilateral *          | 19.612         | 584.216          |
| 6) PGPL             | 0.000          | 0.000           | Include PX                     | -7.276         | -179.082         |
| 7) Other IPP        | 15.367         | 458.832         | d) Mumbai Bilateral *          | 14.809         | 543.752          |
| C) 1) TPCL Thermal  | 11.716         | 380.792         | Include PX                     | 1.541          | 35.695           |
| 2) TPCL Hydro       | 0.221          | 100.565         | Include Standby                | 0.000          | 6.415            |
| 3) TPCL Gas         | 3.419          | 125.791         | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) R-INFRA Thermal  | 4.571          | 226.011         | 1) MSEDCL                      | 339.506        | 10986.501        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 38.881         | 1489.428         |
| 1) Thermal          | 250.918        | 8284.375        | <b>TOTAL STATE</b>             | <b>378.387</b> | <b>12475.929</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro (A2+C2)    | 4.189          | 257.325         |                                |                |                  |
| 3) Gas (A3+B6+C3)   | 10.716         | 335.118         |                                |                |                  |
| 4) Wind             | 15.071         | 293.855         |                                |                |                  |
| 6) SOLAR            | 6.027          | 157.137         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>286.921</b> | <b>9327.810</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 24 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|----------------------------|
| MSPGCL Thermal           | 6306                      | 6121                  | 5230                      | 5152                       |
| MSPGCL Hydro             | 439                       | 262                   | 244                       | 71                         |
| MSPGCL Gas               | 291                       | 289                   | 296                       | 317                        |
| MSPGCL Total Generation  | 7036                      | 6672                  | 5770                      | 5540                       |
| Central Sector Receipt   | 5291                      | 4697                  | 4731                      | 2014                       |
| WIND                     | 390                       | 401                   | 448                       | 417                        |
| CPP / IPP Thermal        | 5070                      | 4909                  | 4375                      | 3862                       |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                          |
| SOLAR                    | 830                       | 889                   | 5                         | 0                          |
| Exchange with Mumbai     | -1058                     | -1026                 | -1033                     | -737                       |
| <b>MSEDCL DEMAND MET</b> | <b>17559</b>              | <b>16542</b>          | <b>14296</b>              | <b>11096</b>               |
| Load Shedding            | 0                         | 0                     | 0                         | 0                          |
| MSEDCL DEMAND            | 17559                     | 16542                 | 14296                     | 11096                      |
| TPCL GENERATION          | 631                       | 631                   | 668                       | 627                        |
| R-INFRA GENERATION       | 190                       | 190                   | 191                       | 191                        |
| <b>MUMBAI DEMAND</b>     | <b>1879</b>               | <b>1847</b>           | <b>1892</b>               | <b>1555</b>                |
| STATE DEMAND MET         | 19438                     | 18389                 | 16188                     | 12651                      |
| <b>STATE DEMAND</b>      | <b>19438</b>              | <b>18389</b>          | <b>16188</b>              | <b>12651</b>               |
| Frequency (Hz)           | 49.95                     | 49.94                 | 49.99                     | 50.06                      |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.16 Hz at 18.00 Hrs | 49.67 Hz at 07.53 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 30/Dec/2018

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 0.00         | 20.06          | 0        | 0        |
| Unit 7             | 3.34         | 39.72          | 155      | 110      |
| Unit 8             | 0.00         | 220.94         | 0        | 0        |
| Unit 9             | 8.15         | 126.94         | 408      | 299      |
| Unit 10            | 8.07         | 227.05         | 401      | 295      |
| <b>Total</b>       | <b>19.56</b> | <b>634.72</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 10.78          | 0        | 0        |
| Unit 4             | 9.08         | 233.01         | 500      | 350      |
| Unit 5             | 9.16         | 287.10         | 500      | 350      |
| <b>Total</b>       | <b>18.24</b> | <b>530.90</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 11.08          | 0        | 0        |
| Unit 7             | 0.00         | 37.54          | 0        | 0        |
| Unit 8             | 4.92         | 145.36         | 216      | 197      |
| <b>Total</b>       | <b>4.92</b>  | <b>193.98</b>  |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 4.17         | 126.00         | 193      | 162      |
| Unit 4             | 4.10         | 124.88         | 187      | 160      |
| Unit 5             | 8.92         | 276.44         | 410      | 358      |
| Unit 6             | 9.42         | 252.60         | 445      | 365      |
| Unit 7             | 9.34         | 271.99         | 428      | 366      |
| Unit 8             | 9.50         | 299.76         | 470      | 360      |
| Unit 9             | 9.45         | 299.44         | 460      | 360      |
| <b>Total</b>       | <b>54.89</b> | <b>1651.11</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 5.06         | 157.84         | 255      | 196      |
| <b>Total</b>       | <b>5.06</b>  | <b>157.84</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 3.93         | 48.22          | 195      | 150      |
| Unit 2             | 3.96         | 118.24         | 190      | 155      |
| Unit 3             | 3.94         | 118.89         | 190      | 155      |
| Unit 4             | 3.87         | 113.63         | 185      | 155      |
| Unit 5             | 9.22         | 270.04         | 440      | 370      |
| <b>Total</b>       | <b>24.92</b> | <b>669.02</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 0.00         | 108.96         | 0        | 0        |
| Unit 4             | 4.00         | 103.00         | 190      | 159      |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>4.00</b>  | <b>211.97</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 7.30         | 209.33         | 320      | 276      |
| <b>Total</b>       | <b>7.30</b>  | <b>209.33</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.07         | 2.14           | 32       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.07</b>   | <b>2.14</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 1.22          | 44.80          | 190      | 40       |
| Stage 4         | 0.00          | 12.50          | 0        | 0        |
| Stage 3         | 0.20          | 12.61          | 114      | 0        |
| <b>Total</b>    | <b>1.42</b>   | <b>69.91</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 11.72          | 0        | 0        |
| VTRNA           | 0.52          | 10.77          | 60       | 0        |
| TILLARI         | 0.00          | 6.42           | 0        | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.12          | 4.94           | 63       | 0        |
| RNGR+BHTSA      | 0.27          | 9.53           | 15       | 0        |
| BHANDARDRA      | 0.00          | 0.01           | 0        | 0        |
| ELDARY          | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.37          | 13.55          | 23       | 13       |
| GHATGHAR        | 1.26          | 29.90          | 125      | 0        |
| <b>Total</b>    | <b>2.55</b>   | <b>86.85</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 15.07         | 293.86         | 0        | 0        |
| <b>Total</b>    | <b>15.07</b>  | <b>293.86</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 62.99         | 2039.14        | 0        | 0        |
| JSWEL(Mus)      | 19.62         | 558.51         | 0        | 0        |
| VIPL(Mus)       | 5.07          | 273.81         | 0        | 0        |
| RPLAMT(Mus)     | 0.00          | 270.36         | 0        | 0        |
| WPCL(Mus)       | 0.00          | 27.41          | 0        | 0        |
| Other(Mus)      | 15.37         | 458.83         | 0        | 0        |
| <b>Total</b>    | <b>103.06</b> | <b>3628.04</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 6.03          | 157.14         | 0        | 0        |
| <b>Total</b>    | <b>6.03</b>   | <b>157.14</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 6.82          | 233.84         | 306      | 278      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.04          | 79.32          | 114      | 65       |
| Trombay 7B      | 1.38          | 46.47          | 67       | 50       |
| Trombay 8       | 4.89          | 146.95         | 205      | 202      |
| TATA Hydro      | 0.22          | 100.56         | 65       | 0        |
| <b>Total</b>    | <b>15.36</b>  | <b>607.15</b>  |          |          |
| <b>R-INFRA</b>  |               |                |          |          |
| DTPS U-1&2      | 4.57          | 226.01         | 192      | 190      |
| <b>Total</b>    | <b>4.57</b>   | <b>226.01</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 131.58      | 4049.53       | MSPGCL Total        | 142.84      | 4415.61       |
|                |             |         | MSPGCL Thml+Gas | 138.87      | 4258.85       | Koyna 1,2 & 4 Total | 1.22        | 57.30         |
|                |             |         | MSPGCL Hydro    | 3.97        | 156.76        | State Total         | 286.92      | 9327.81       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 30/Dec/2018

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5240        | 94   | 318  | 5652   | 890   | 3889      | 0    | 0     | 1943        | 1909        | -612                 | 11728                 | 0                    | 11728                     | 1447             | 13175           | 50.01         |
| 2                  | 5240        | 84   | 318  | 5642   | 904   | 3895      | 0    | 0     | 2027        | 1980        | -522                 | 11899                 | 0                    | 11899                     | 1332             | 13231           | 49.96         |
| 3                  | 5274        | 69   | 319  | 5662   | 995   | 3898      | 0    | 0     | 1791        | 1905        | -468                 | 11992                 | 0                    | 11992                     | 1258             | 13250           | 49.98         |
| 4                  | 5240        | 54   | 319  | 5613   | 1032  | 3879      | 0    | 0     | 1924        | 2085        | -432                 | 12177                 | 0                    | 12177                     | 1223             | 13400           | 49.98         |
| 5                  | 5232        | 54   | 319  | 5605   | 1066  | 3889      | 0    | 0     | 2406        | 2376        | -444                 | 12492                 | 0                    | 12492                     | 1234             | 13726           | 49.95         |
| 6                  | 5209        | 54   | 309  | 5572   | 1101  | 3901      | 0    | 0     | 3027        | 3119        | -531                 | 13162                 | 0                    | 13162                     | 1321             | 14483           | 50.00         |
| 7                  | 5279        | 53   | 320  | 5652   | 1146  | 3921      | 0    | 4     | 3978        | 4195        | -602                 | 14316                 | 0                    | 14316                     | 1395             | 15711           | 50.00         |
| 8                  | 5644        | 293  | 317  | 6254   | 936   | 4146      | 0    | 70    | 4559        | 4740        | -680                 | 15466                 | 0                    | 15466                     | 1469             | 16935           | 49.85         |
| 9                  | 6072        | 161  | 317  | 6550   | 750   | 4797      | 0    | 296   | 4677        | 4621        | -777                 | 16237                 | 0                    | 16237                     | 1618             | 17855           | 49.99         |
| 10                 | 6248        | 143  | 301  | 6692   | 759   | 5033      | 0    | 534   | 4829        | 5073        | -895                 | 17196                 | 0                    | 17196                     | 1752             | 18948           | 49.96         |
| 11                 | 6299        | 390  | 294  | 6983   | 564   | 5088      | 0    | 724   | 5106        | 5022        | -1043                | 17338                 | 0                    | 17338                     | 1857             | 19195           | 49.96         |
| 12                 | 6306        | 439  | 291  | 7036   | 390   | 5070      | 0    | 830   | 5151        | 5291        | -1058                | 17559                 | 0                    | 17559                     | 1879             | 19438           | 49.95         |
| 13                 | 6121        | 262  | 289  | 6672   | 401   | 4909      | 0    | 889   | 5019        | 4697        | -1026                | 16542                 | 0                    | 16542                     | 1847             | 18389           | 49.94         |
| 14                 | 5680        | 202  | 287  | 6169   | 268   | 4742      | 0    | 857   | 4910        | 4959        | -940                 | 16055                 | 0                    | 16055                     | 1762             | 17817           | 49.97         |
| 15                 | 5568        | 202  | 286  | 6056   | 299   | 4462      | 0    | 776   | 4891        | 4895        | -875                 | 15613                 | 0                    | 15613                     | 1695             | 17308           | 50.01         |
| 16                 | 5261        | 192  | 276  | 5729   | 246   | 4298      | 0    | 610   | 4911        | 4935        | -840                 | 14978                 | 0                    | 14978                     | 1667             | 16645           | 49.99         |
| 17                 | 5228        | 192  | 287  | 5707   | 237   | 4283      | 0    | 330   | 4855        | 4905        | -846                 | 14616                 | 0                    | 14616                     | 1673             | 16289           | 49.99         |
| 18                 | 5220        | 192  | 289  | 5701   | 270   | 4310      | 0    | 102   | 4484        | 4782        | -885                 | 14280                 | 0                    | 14280                     | 1711             | 15991           | 50.00         |
| 19                 | 5230        | 244  | 296  | 5770   | 448   | 4375      | 0    | 5     | 4649        | 4731        | -1033                | 14296                 | 0                    | 14296                     | 1892             | 16188           | 49.99         |
| 20                 | 5235        | 142  | 297  | 5674   | 547   | 4391      | 0    | 0     | 4455        | 4289        | -1002                | 13899                 | 0                    | 13899                     | 1920             | 15819           | 49.97         |
| 21                 | 5202        | 127  | 310  | 5639   | 486   | 4157      | 0    | 0     | 3599        | 3546        | -961                 | 12867                 | 0                    | 12867                     | 1879             | 14746           | 50.00         |
| 22                 | 5204        | 127  | 305  | 5636   | 481   | 3950      | 0    | 0     | 2979        | 2954        | -898                 | 12123                 | 0                    | 12123                     | 1810             | 13933           | 50.01         |
| 23                 | 5192        | 127  | 316  | 5635   | 438   | 3911      | 0    | 0     | 2271        | 2443        | -847                 | 11580                 | 0                    | 11580                     | 1685             | 13265           | 50.03         |
| 24                 | 5152        | 71   | 317  | 5540   | 417   | 3862      | 0    | 0     | 1945        | 2014        | -737                 | 11096                 | 0                    | 11096                     | 1555             | 12651           | 50.06         |
| MUs                | 131.58      | 3.97 | 7.30 | 142.84 | 15.07 | 103.05    | 0.00 | 6.03  | 90.39       | 91.47       | -18.95               | 339.51                | 0.00                 | 339.51                    | 38.88            | 378.39          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 30/Dec/2018**

**Position as on 6.30 Hrs of 31/Dec/2018**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                                                                                         |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |           | Continued. | Annual Overhaul                                                                                                                                         |               |
| MSPGCL                | Nasik Unit 5            | 210      | 22/11/2018   | 03.50        |           | Continued. | Boiler Tube Leakage work completed on 24/11/2018. Available against case 4 from 25/11/2018. Converted to COH from 00:00 Hrs of 05/12/2018 (for 40 Days) |               |
| RINFRA-G              | REL Unit 1              | 250      | 23/12/2018   | 06.06        |           | Continued. | For COH.                                                                                                                                                |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                                                                                         |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |           | Continued. | Economic shutdown                                                                                                                                       |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                                                                                 |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                                                       |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                                                       |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                                                                             |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                                                                             |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |           | Continued. | Compressor & Turbine Blade Failure.                                                                                                                     |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | Poor Coal Receipt                                                                                                                                       |               |
| MSPGCL                | Uran Unit 8             | 108      | 08/09/2018   | 22.08        |           | Continued. | Withdrawn due to B0 & U-7                                                                                                                               |               |
| MSPGCL                | Paras Unit 3            | 250      | 15/09/2018   | 00.55        |           | Continued. | Stator Earth Fault                                                                                                                                      |               |
| IPP                   | RPL(AMT) U-4            | 270      | 20/09/2018   | 00.01        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| MSPGCL                | Koyana Unit 4           | 70       | 03/11/2018   | 09.02        |           | Continued. | Stator Earth Fault                                                                                                                                      |               |
| MSPGCL                | Koyana Unit 1           | 70       | 26/11/2018   | 00.00        |           | Continued. | Oil Cooler Leakage.                                                                                                                                     |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |           | Continued. | No Schedule.                                                                                                                                            |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |           | Continued. | ZERO SCHEDULE.                                                                                                                                          |               |
| MSPGCL                | Parli Unit 7            | 250      | 12/12/2018   | 00.00        |           | Continued. | ZERO SCHEDULE.                                                                                                                                          |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 14/12/2018   | 03.00        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| IPP                   | RPL(AMT) U-1            | 270      | 14/12/2018   | 16.00        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| IPP                   | RPL(AMT) U-3            | 270      | 14/12/2018   | 16.30        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |           | Continued. | No Schedule                                                                                                                                             |               |
| MSPGCL                | Koradi Unit 6           | 210      | 22/12/2018   | 01.18        |           | Continued. | Bearing Temperature high                                                                                                                                |               |
| IPP                   | RPL(AMT) U-2            | 270      | 27/12/2018   | 19.30        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| IPP                   | RPL(AMT) U-5            | 270      | 28/12/2018   | 19.30        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| MSPGCL                | Nasik Unit 3            | 210      | 28/12/2018   | 22.05        |           | Continued. | Zero Schedule.                                                                                                                                          |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                                                                                                                                           |               |
| IPP                   | RPL(AMT) U-5            | 270      | 29/12/2018   | 19.30        |           | Continued. | Due To Zero Schedule.                                                                                                                                   |               |
| MSPGCL                | Koradi Unit-8           | 660      | 29/12/2018   | 23.01        |           | Continued. | FOR BOILER VALIDITY EXTENSION PCR.                                                                                                                      |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 30/Dec/2018**

**Statement-VII**

**Position as on 6.30 Hrs of 31/Dec/2018**

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                       |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                        |
| Chandrapur - Padghe Hvdc Pole 2          | IntraState                | 30/12/2018   | 23.22        | 31/12/2018 | 01.38      | PO          | Attend alarm of TC1 & TC2 reliefvent.                                                                                                  |
| <b>400 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                        |
| Karad Solapur (PG)                       | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line converted as 220 kV Solapur (PG)- Jeur from LOC 403                                                                               |
| Dhule Sar'Sarovar II                     | InterState                | 24/12/2018   | 18.09        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Padgha Tarapur II                        | InterState                | 28/12/2018   | 04.48        | 30/12/2018 | 09.57      | T           | Y Phase CT Burst. 30/12/2018 (RFC 12.50).                                                                                              |
| Dhule Sar'Sarovar II                     | InterState                | 29/12/2018   | 10.30        |            | Continued. | PO          | Already out - Maintenance Work. 29/Dec/2018 (RFC 19.30).                                                                               |
| Karad-Jaigad - I                         | IntraState                | 29/12/2018   | 17.31        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Khadka-Aurangabad (Waluj)                | IntraState                | 29/12/2018   | 18.06        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Lonikand I - Koyna stage-IV              | IntraState                | 29/12/2018   | 21.08        | 30/12/2018 | 09.53      | HT          | Over Voltage                                                                                                                           |
| Lonikand I - Koyna stage-IV              | IntraState                | 30/12/2018   | 20.17        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Padghe - Kalwa- I                        | IntraState                | 31/12/2018   | 03.01        |            | Continued. | T           | Over Voltage                                                                                                                           |
| <b>400 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                        |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe      | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential protection, Declared Faulty.                                                                                              |
| 400/220kv 315MVA ICT-I@Parly             | IntraState                | 24/12/2018   | 15.40        |            | Continued. | PO          | Replacement Of B-PH Unit By Re paired One.                                                                                             |
| 400/220/33kv 500MVA ICT 5 @ Padghe       | IntraState                | 30/12/2018   | 16.14        | 30/12/2018 | 18.21      | HT          | NDR alarm charged from HV side.                                                                                                        |
| <b>220 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                        |
| Talandage - Chikodi                      | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                                                                                            |
| Mudshingi - Chikodi                      | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                                           |
| Chandrapur GCR - Warora - I              | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.                   |
| Chandrapur GCR - Wani                    | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | For Bunching Of Conductor at Loc No.86 Disconnecting Of jumper at Loc No.86 to 107 And Deenergising The Line Between Loc No.86 To 107. |
| BOISAR BORIVALI                          | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To control line loading.                                                                                                               |
| Kalwa-TIFIL                              | IntraState                | 27/11/2018   | 06.06        |            | Continued. | EO          | Tapping Of Tifil Substation On 220KV Kharghar-Borivali Line                                                                            |
| Padgha-Temghar-II                        | IntraState                | 03/12/2018   | 08.15        |            | Continued. | EO          | To control load on Padgha ICTs.                                                                                                        |
| Padgha - Temghar I                       | IntraState                | 03/12/2018   | 08.15        |            | Continued. | EO          | To control load on Padgha ICTs.                                                                                                        |
| Bhira Dharavi 7                          | IntraState                | 22/12/2018   | 09.00        |            | Continued. | PO          | Errection Of Tower At LOC.124                                                                                                          |
| Trombay - Kalwa                          | IntraState                | 24/12/2018   | 14.50        |            | Continued. | PO          | For Replacement Of Rusted Tower.                                                                                                       |
| Trombay - Mulund                         | IntraState                | 24/12/2018   | 15.14        |            | Continued. | PO          | For Replacement Of Rusted Tower.                                                                                                       |
| Wpcl-Warora 1                            | IntraState                | 27/12/2018   | 10.16        |            | Continued. | PO          | Routine Maintenance Work                                                                                                               |
| Pophali - Kdph                           | IntraState                | 30/12/2018   | 10.45        | 30/12/2018 | 17.05      | PO          | Routine Maintenance Work                                                                                                               |
| Chakan I - Chakan II (tap to Volkswagen) | IntraState                | 30/12/2018   | 14.19        | 30/12/2018 | 15.23      | PO          | Meter replacement work at volksagan end.                                                                                               |
| Kandalgaon - ONGC Panvel                 | IntraState                | 30/12/2018   | 15.01        | 30/12/2018 | 15.45      | T           | ONGC end only Y PH E/F Z2.                                                                                                             |
| <b>220 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                        |
| 220/100 Kv 200 Mva Vijai Ict 3 @Trombay  | IntraState                | 30/12/2018   | 13.14        | 30/12/2018 | 13.42      | EO          | Removing of hanging cloth on LV side R PH bus tube.                                                                                    |
| 220/100 Kv 200 MVA ICT I @Kolshet        | IntraState                | 30/12/2018   | 13.20        | 30/12/2018 | 16.00      | PO          | LV side R PH bushing oil leakage.                                                                                                      |
| <b>132 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                        |
| Beed - Raimoha                           | IntraState                | 31/12/2018   | 05.43        | 31/12/2018 | 06.28      | T           | Distance Protection load affected approximately 12MW of Raimoha                                                                        |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 30/Dec/2018**

**Statement-VII**

Position as on 6.30 Hrs of 31/Dec/2018

| Name of Line | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage |
|--------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|------------------|
|              |                              |                 |                 |            |               |                | S/s.             |