

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 30/Dec/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.496	4621.025	1) Gujrat	-3.649	-178.089
2) Hydro	12.858	360.777	2) Madhya Pradesh	5.284	54.847
3) Gas	3.256	122.833	3) Chattisgarh	6.400	161.150
Total MSPGCL	175.610	5104.635	4) Maharashtra	187.571	5236.504
B) 1) APML	37.717	1741.553	5) Goa (Amona)	-1.177	-38.623
2) JSWEL	20.445	400.137	Total	194.429	5235.789
3) VIPL	0.000	0.000	a) Mumbai Schedule	25.079	822.437
4) RPL(AMT)	25.479	832.162	b) Mumbai Drawl	29.109	955.442
5) SWPGPL	8.756	252.157	c) MSEDCL Bilateral *	79.664	2206.667
6) Other IPP	45.553	1325.911	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	25.079	821.932
C) 1) TPCL Thermal	11.175	333.657	Include PX	0.000	0.000
2) TPCL Hydro	3.947	113.673	Standby	0.000	0.504
3) TPCL Gas	1.775	46.411	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.116	291.796	1) MSEDCL	485.533	14261.434
D) STATE			2) Mumbai Discoms	54.122	1740.982
1) Thermal	316.737	9798.398	3) Other Discoms	9.777	282.932
(A1+C1+C4+(B1-B6))			TOTAL STATE	549.432	16285.348
2) Hydro	16.805	474.450			
(A2+C2)					
3) Gas	5.031	169.244			
(A3+B7+C3)					
4) Wind	3.937	267.118			
6) SOLAR	12.493	340.346			
TOTAL STATE	355.003	11049.556			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6754	6646	6767	5897
MSPGCL Hydro	1838	619	767	219
MSPGCL Gas	134	131	134	139
MSPGCL Total Generation	8726	7396	7668	6255
Central Sector Receipt	8793	9546	7429	7330
WIND	114	81	213	268
CPP / IPP Thermal	6377	6461	6305	5241
CPP / IPP Gas	0	0	0	0
SOLAR	1670	1829	3	0
Exchange with Mumbai	-1355	-1574	-1305	-1175
MSEDCL DEMAND MET	23874	23307	19852	17511
Load Shedding	0	0	0	0
MSEDCL DEMAND	23874	23307	19852	17511
TPCL GENERATION	908	768	907	515
AEML GENERATION	500	460	454	291
MUMBAI DEMAND	2763	2802	2666	1981
OTHER DISCOM DEMAND	451	432	461	408
STATE DEMAND MET	27088	26541	22979	19900
STATE DEMAND	27088	26541	22979	19900
Frequency (Hz)	50.03	50.03	50.05	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 14.09 Hrs	49.5 Hz at 09.19 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 30/Dec/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	5.10	149.80	215	205
Unit 7	0.00	0.00	0	0
Unit 8	13.78	390.13	623	551
Unit 9	12.78	387.30	549	515
Unit 10	13.08	375.33	570	510
Total	44.74	1302.57		
Bhusawal				
Unit 3	3.33	31.16	170	115
Unit 4	10.74	306.66	495	325
Unit 5	9.74	305.37	465	285
Total	23.80	643.19		
Parli				
Unit 6	4.74	133.36	235	148
Unit 7	4.49	135.95	245	147
Unit 8	3.58	102.34	160	144
Total	12.80	371.65		
Chandrapur				
Unit 3	3.59	99.28	171	126
Unit 4	3.07	92.80	145	110
Unit 5	7.10	197.37	315	275
Unit 6	8.75	232.18	425	147
Unit 7	0.00	0.00	0	0
Unit 8	11.68	270.16	498	461
Unit 9	3.64	307.51	500	0
Total	37.82	1199.29		
Paras				
Unit 3	4.62	133.92	218	118
Unit 4	4.66	140.03	233	0
Total	9.28	273.95		
Khaparkheda				
Unit 1	2.87	83.34	140	110
Unit 2	2.90	83.55	133	100
Unit 3	3.84	106.53	183	131
Unit 4	3.07	97.56	143	105
Unit 5	11.64	273.07	500	465
Total	24.33	644.04		
Nasik				
Unit 3	0.00	23.31	0	0
Unit 4	3.38	95.00	160	116
Unit 5	3.35	68.03	171	113
Total	6.72	186.34		
Uran				
All Units	3.26	122.83	141	130
Total	3.26	122.83		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.58	5.84	39	0
Total	0.58	5.84		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.46	109.34	560	40
Stage 4	4.18	110.92	742	0
Stage 3	1.70	47.59	304	0
Total	9.35	267.86		
Hydro				
KDPH	0.65	9.43	36	18
VTRNA	0.00	0.00	0	0
TILLARI	0.00	14.19	0	0
BHIRA T.R.	0.22	6.40	40	0
SMLHY_PTN	1.19	39.09	52	48
GHATGHAR	0.87	17.96	125	0
Total	2.93	87.07		
Wind				
Total	3.94	267.12	0	0
Total	3.94	267.12		
CPP				
APML(Mus)	37.72	1741.55	0	0
JSWEL(Mus)	20.44	400.14	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.48	832.16	0	0
SWPGPL-Mus	8.76	252.16	0	0
Other(Mus)	45.55	1325.91	0	0
Total	137.95	4551.92		
SOLAR				
Total	12.49	340.35	0	0
Total	12.49	340.35		
Tata				
Trombay 5	7.25	219.06	439	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.95	25.99	43	36
Trombay 7B	0.82	20.42	36	32
TATA Hydro	3.95	113.67	392	12
Trombay 8	3.93	114.60	236	132
Total	16.90	493.74		
AEMIL				
DTPS U-1&2	8.12	291.80	500	233
Total	8.12	291.80		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.50	4621.02	MSPGCL Total	175.61	5104.64
			MSPGCL Thml+Gas	162.75	4743.86	Koyna 1,2 & 4 Total	7.64	220.27
			MSPGCL Hydro	12.86	360.78	State Total	355.00	11049.56

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 30/Dec/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6493	109	138	6740	95	4706	0	0	7499	7685	-1013	17855	0	17855	1827	357	20040	49.99
2	6402	110	140	6652	125	4696	0	0	7846	7780	-914	18010	0	18010	1705	329	20044	50.01
3	6475	109	141	6725	117	4708	0	0	7956	7932	-833	18328	0	18328	1622	321	20271	50.02
4	6363	109	140	6612	103	4675	0	0	8129	8118	-784	18417	0	18417	1570	307	20294	50.02
5	6560	109	140	6809	120	4754	0	0	8294	8267	-793	18848	0	18848	1575	309	20732	49.98
6	7039	189	140	7368	196	5112	0	0	8218	8202	-876	19653	0	19653	1668	349	21670	49.97
7	7279	385	135	7799	177	5775	0	2	7864	7863	-887	20354	0	20354	1792	375	22521	49.98
8	7134	1554	136	8824	194	6228	0	167	7218	7240	-885	21361	0	21361	1992	407	23760	49.99
9	6936	1396	140	8472	166	6368	0	685	7522	7753	-961	22041	0	22041	2286	442	24769	49.94
10	6837	1343	134	8314	114	6402	0	1237	7805	7797	-1114	22298	0	22298	2553	452	25303	49.77
11	6754	1838	134	8726	114	6377	0	1670	8230	8793	-1355	23874	0	23874	2763	451	27088	50.03
12	6706	1346	133	8185	81	6350	0	1873	8593	8701	-1506	23240	0	23240	2831	444	26515	50.08
13	6646	619	131	7396	81	6461	0	1829	8997	9546	-1574	23307	0	23307	2802	432	26541	50.03
14	6655	150	130	6935	77	5932	0	1724	9593	9805	-1729	22317	0	22317	2618	427	25362	50.05
15	6716	161	133	7010	93	5850	0	1533	9862	10002	-1725	22335	0	22335	2618	427	25381	50.11
16	6730	162	132	7024	132	6062	0	1095	10101	9776	-1668	21979	0	21979	2637	442	25058	50.05
17	6762	561	134	7457	156	6238	0	574	8299	8127	-1498	20599	0	20599	2629	455	23683	50.00
18	6746	673	133	7552	145	6379	0	101	7642	7520	-1324	19924	0	19924	2607	449	22980	50.08
19	6767	767	134	7668	213	6305	0	3	7299	7429	-1305	19852	0	19852	2666	461	22979	50.05
20	6780	460	134	7374	334	6466	0	0	7078	6938	-1158	19494	0	19494	2588	459	22542	50.00
21	6526	163	136	6825	276	5939	0	0	7186	7234	-1352	18489	0	18489	2425	434	21347	49.97
22	6270	163	134	6567	304	5661	0	0	7031	7159	-1409	17847	0	17847	2263	435	20545	50.03
23	6023	163	135	6321	256	5267	0	0	7085	7432	-1271	17600	0	17600	2104	405	20109	50.02
24	5897	219	139	6255	268	5241	0	0	7149	7330	-1175	17511	0	17511	1981	408	19900	49.96
MUs	159.50	12.86	3.26	175.61	3.94	137.95	0.00	12.49	192.50	194.43	-29.11	485.53	0.00	485.53	54.12	9.78	549.43	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 30/Dec/2022

Position as on 6.30 Hrs of 31/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
IPP	Adani U-5	660	10/12/2022	23:56		Continued.	COH activities.	10/01/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/01/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	03/01/2023
MSPGCL	Nasik Unit 3	210	07/12/2022	21:25		Continued.	Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022	
MSPGCL	Uran Unit 6	108	20/12/2022	17:00		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	25/12/2022	17:45		Continued.	Bottom Ash evacuation problem	02/01/2023
IPP	Adani U-3	660	27/12/2022	13:57	30/12/2022	04:21	APH-A Hot PA bellow leakage.	30/12/2022
IPP	SWPGPL U-4	135	28/12/2022	00:00		Continued.	BOTTOM ASH EVACUATION PROBLEM	03/01/2023
IPP	Adani U-4	660	28/12/2022	12:46		Continued.	APH-B gear box abnormal sound.	01/01/2023
MSPGCL	Chandrapur Unit 9	500	30/12/2022	07:51	31/12/2022	04:30	Heavy steam leakage at turbine side	
AEML	AEML Unit 1	250	30/12/2022	12:50	30/12/2022	17:17	Generator 01 PT Failure.	
MSPGCL	Paras Unit 4	250	30/12/2022	22:09		Continued.	Boiler Tube Leakage	02/01/2023
MSPGCL	Chandrapur Unit 6	500	30/12/2022	23:31	31/12/2022	17:35	Flame Failure	01/01/2023
MSPGCL	Bhusawal Unit 3	210	31/12/2022	09:43		Continued.	Boiler Tube Leakage	03/01/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 30/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 31/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LR Outages/Trippings							
LR (707) OF KORADI CKT - 1@ TIRODA	IntraState	28/12/2022	09:10	30/12/2022	17:21	PO	for attending SF6 gas leakage.
765 KV LINE Outages/Trippings							
BUS - 1 @ TIRODA	IntraState	30/12/2022	11:38	31/12/2022	00:56	PO	Tan delta measurement of Bus CVT & Bus isolator maintenance work
765 KV ICT Outages/Trippings							
765/400kV 1500MVA ICT @ AKOLA 2	IntraState	30/12/2022	11:14	30/12/2022	18:46	PO	Taking Spare ICT in Service in place of B-ph ICT as per CEA guideline
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
BUSBAR PROTECTION SCHEME @ DEEPNAGAR	IntraState	28/12/2022	17:04	30/12/2022	19:35	PO	For cable termination, wiring, testing & configuration of new Station TF (STN-6B) in existing 400 KV Busbar Panel in r/o 660 MW Unit.
400 KV LINE Outages/Trippings							
KOLHAPUR - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
PARLI(MS) - PARLI (PG) CKT -1	InterState	30/12/2022	06:23	30/12/2022	20:35	PO	POST OCC: BYPASSING OF 400KV PARLI(PG)-PARLI(M) 400KV D/C AND 400KV PARLI(PG)-PARLI (NEW) D/C QUAD LINE AT THE OUT SKIRT OF PARLI(PG) S/S SO AS TO FORM PARLI(M)-PARLI(NEW) 400KV D/C LINE
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
LONIKAND I - CHAKAN	IntraState	28/12/2022	09:47	30/12/2022	04:00	PO	O/H & Serviceing of 29A PG Isolator & Replacement of PGI mechanism box.
AKOLA - KHADKA (BHUSAWAL)	IntraState	30/12/2022	08:30	30/12/2022	17:31	PO	for breaker pneumatic system & breaker compressor overhauling work by agency line will be in service through TBC A/R required in non auto mode at both end
LONIKAND I - KOYNA STAGE-IV	IntraState	30/12/2022	11:55	30/12/2022	18:10	PO	PID Faulty disc insulator replacement work & Cold line washing work
JAIGAD - KARAD CKT - 2	IntraState	31/12/2022	22:13		Continued.	HT	H/T to Control Over Voltage.
400 KV ICT Outages/Trippings							
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	30/12/2022	11:41	30/12/2022	18:33	EO	To attend Hotspot at B-ph 29B Isolator Jaw by opening jumper by Hotline unit
400/220/33 KV 315MVA ICT - 3 @ KHADKA	IntraState	31/12/2022	09:26	31/12/2022	16:39	PO	For 400KV Breaker pneumatic system & compressor overhauling work by agency
400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	IntraState	31/12/2022	13:09	31/12/2022	15:18	T	Tripped on Yph OSR
220 KV MAINBAY Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 31/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV SHIVAJINAGAR - MALEGAON	IntraState	30/12/2022	18:23	30/12/2022	22:33	PO	For replacement of PID detected critical strings
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
EKLAHARE (OCR) - PADGHE	IntraState	19/12/2022	18:12			HT	HT for Load Management
LAMBOTI - KARKAMB	IntraState	29/12/2022	12:26			PO	Outage is required For replacement of old Tower at Loc no. 432 & 436 by new B+6 type tower due to low ground clearance along with necessary stringing work.
LAMBOTI - PANDHARPUR	IntraState	29/12/2022	12:42			PO	Outage is required for replacement of old Tower at Loc no. 432 & 436 by new B+6 type tower due to low ground clearance along with necessary stringing work.
ONI KHAREPATAN LINE	IntraState	30/12/2022	09:14	30/12/2022	18:51	PO	Cold washing of Line insulators.
JAMBHUL - ANANDNAGAR	IntraState	30/12/2022	10:00	30/12/2022	17:26	PO	Works to be carried out 1) Replacement of 198kV LAs by Agency 2) Routine Maintenance Work
NAGOTHANE - SPCL	IntraState	30/12/2022	10:06	30/12/2022	16:53	PO	ISOLATOR OVERHAULING AND BAY MAINTENANCE WORK AT SPCL END.
URAN - APTA 3	IntraState	30/12/2022	11:09	30/12/2022	14:25	PO	CT Tan delta and diagnostic testing work at Apta end.
PADGHE - KAMBA 2	IntraState	30/12/2022	11:30	30/12/2022	18:36		1. Diagnostic testing work 2. Bay maintenance work 3. Isolator maintenance work 4. Attending hotspot (if any) 5. Pending MTAMC work
ADLABS - PEDAMBE	IntraState	30/12/2022	11:40	30/12/2022	19:53	PO	Damaged jumper nut bolt replacement, Cold washing of insulator strings and Outage tree cutting work and other line maintenance work.
TROMBAY - SALSETTE CKT - 1	IntraState	30/12/2022	23:38	31/12/2022	07:24	PO	For KVPTL project work.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	31/12/2022	03:36	31/12/2022	08:55	HT	For outage of Nasik-BBLR ckt1
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	31/12/2022	03:40	31/12/2022	08:48	PO	1. To attend the damaged jump at loc.no.13 R-phase. 2. conversion of single jump to twin jump at loc.no.13& 54.
GHODBUNDER - MSETCL BOISAR	IntraState	31/12/2022	08:58	31/12/2022	17:37	EO	For safety purpose during attending damaged conductor of 220KV Boisar-Borivali Line as both are on same M/C tower.
ONI KHAREPATAN LINE	IntraState	31/12/2022	09:03	31/12/2022	16:23	PO	Cold washing of Line insulators.
BORIVALI - BOISAR II LINE	IntraState	31/12/2022	09:07	31/12/2022	17:43	EO	To attend damaged conductor of R-Phase by fixing repair sleeve.
WAGHIVALI - DHARAVI 7	IntraState	31/12/2022	12:02	31/12/2022	12:43	EO	removing hanging object
BABHALESHWAR - UTECH SUGAR	IntraState	31/12/2022	13:09	31/12/2022	13:38	T	LTS stage 1 operated at 400 KV Babhleshwar
BABLESHWAR- ALEPHATA CKT - 1	IntraState	31/12/2022	13:09	31/12/2022	15:27	T	LTS stage 1 operated at 400 KV Babhleshwar
URAN - APTA 2	IntraState	31/12/2022	13:11	31/12/2022	14:58	EO	Secondary CT Oil leakage arresting work
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 30/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 31/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 200MVA PTR NO 3 @ CHINCHWAD	IntraState	30/12/2022	10:04	30/12/2022	17:09	PO	132KV ITC make L.V (R,Y,B) phase C.T replacement work
220/100 KV 100 MVA ICT 2 @ VASAI II	IntraState	30/12/2022	10:52	30/12/2022	14:27	PO	For CTR overhauling and N2 Cylinder replacement by Agency
220/22 KV 25 MVA PTR 1 @ WASHALA	IntraState	31/12/2022	10:40	31/12/2022	17:20	PO	198 KV LA Replacement work & LV Bus Bar Epoxy coating work.
220 KV BUSBAR Outages/Trippings							
GIS BUS - 2 @ SALSETTE	IntraState	30/12/2022	21:14	30/12/2022	22:04	PO	FOR TEST CHARGING 125 MAVR REACTOR BAY AND REACTOR
110 KV LINE Outages/Trippings							
AMBERNATH - KALYAN CKT - 2	IntraState	30/12/2022	20:48	30/12/2022	22:39	PO	FOR RECONNECTION OF NORTH OFA TAP JUMPER

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage