

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 31/May/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	149.141	5030.131	1) Gujrat	-2.005	-94.531
2) Hydro	35.858	736.527	2) Madhya Pradesh	11.160	230.684
3) Gas	5.622	163.051	3) Chattisgarh	5.230	160.900
Total MSPGCL	190.621	5929.709	4) Maharashtra	212.112	6256.380
B) 1) APLM	72.679	1860.617	5) Goa (Amona)	-1.539	-39.650
2) JSWEL	24.776	676.888	Total	224.958	6513.783
3) VIPL	0.000	0.000	a) Mumbai Schedule	45.699	1224.386
4) RPL(AMT)	30.964	779.366	b) Mumbai Drawl	48.656	1343.671
5) SWPGPL	8.984	309.736	c) MSEDCL Bilateral *	103.939	3013.432
6) Other IPP	3.071	265.649	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	45.699	1224.293
C) 1) TPCL Thermal	13.318	362.709	Include PX	0.000	0.000
2) TPCL Hydro	6.318	152.842	Standby	0.000	0.094
3) TPCL Gas	2.698	68.786	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.932	310.017	1) MSEDCL	531.129	15777.627
D) STATE			2) Mumbai Discoms	78.922	2238.025
1) Thermal	310.865	9595.113	3) Other Discoms	10.585	320.353
(A1+C1+C4+(B1-B6))			TOTAL STATE	620.636	18336.005
2) Hydro (A2+C2)	42.176	889.369			
3) Gas (A3+B7+C3)	8.320	231.837			
4) Wind	17.647	608.786			
6) SOLAR	16.670	497.117			
TOTAL STATE	395.678	11822.222			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6112	6311	6311	6184
MSPGCL Hydro	878	1398	1444	1422
MSPGCL Gas	197	193	277	224
MSPGCL Total Generation	7186	7902	8032	7830
Central Sector Receipt	10527	10482	9358	8553
WIND	558	474	1151	820
CPP / IPP Thermal	5507	5569	6035	5792
CPP / IPP Gas	0	0	0	0
SOLAR	2127	1857	0	633
Exchange with Mumbai	-2691	-2516	-1940	-1804
MSEDCL DEMAND MET	22731	23285	22171	21383
Load Shedding	0	0	0	0
MSEDCL DEMAND	22731	23285	22171	21383
TPCL GENERATION	804	992	1057	581
AEML GENERATION	292	382	296	293
MUMBAI DEMAND	3787	3890	3293	2678
OTHER DISCOM DEMAND	483	482	466	442
STATE DEMAND MET	27001	27657	25930	24503
STATE DEMAND	27001	27657	25930	24503
Frequency (Hz)	50.04	50.01	49.99	50.06

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.28 Hz at 18:03 Hrs	49.83 Hz at 09:56 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 31/May/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.13	118.52	200	150
Unit 8	0.00	326.28	0	0
Unit 9	0.00	366.34	0	0
Unit 10	12.96	312.84	600	490
Total	17.09	1123.99		
Bhusawal				
Unit 3	3.54	105.96	150	135
Unit 4	9.82	264.52	440	350
Unit 5	10.58	278.40	475	310
Total	23.94	648.88		
Parli				
Unit 6	5.58	110.32	250	147
Unit 7	5.19	127.82	245	169
Unit 8	4.13	139.49	181	148
Total	14.89	377.63		
Chandrapur				
Unit 3	3.25	110.88	150	114
Unit 4	3.56	102.41	152	145
Unit 5	0.00	170.06	0	0
Unit 6	9.34	286.72	400	337
Unit 7	9.70	292.02	416	386
Unit 8	11.69	311.03	494	474
Unit 9	11.83	342.37	500	484
Total	49.36	1615.48		
Paras				
Unit 3	5.13	148.58	235	185
Unit 4	5.38	156.27	239	207
Total	10.50	304.84		
Khaparkheda				
Unit 1	2.77	92.94	125	105
Unit 2	3.02	89.03	135	115
Unit 3	4.08	125.55	182	157
Unit 4	4.32	119.64	187	172
Unit 5	11.18	290.52	472	443
Total	25.36	717.68		
Nasik				
Unit 3	0.00	25.27	0	0
Unit 4	4.06	124.72	178	155
Unit 5	3.94	91.64	174	157
Total	8.00	241.64		
Uran				
All Units	5.62	163.05	312	193
Total	5.62	163.05		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.06	1.12	37	0
Total	0.06	1.12		
Koyna				
Stage 1-2	7.44	154.96	515	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	18.65	342.05	1022	400
Stage 3	5.34	109.90	312	80
Total	31.44	606.91		
Hydro				
KDPH	0.49	19.84	21	21
VTRNA	1.15	32.63	61	0
TILLARI	0.45	4.44	58	0
BHIRA T.R.	0.46	9.10	80	0
SMLHY_PTN	1.81	61.58	86	68
GHATGHAR	0.00	0.91	0	0
Total	4.36	128.49		
Wind				
Total	17.65	608.79	0	0
Total	17.65	608.79		
CPP				
APML(Mus)	72.68	1860.62	0	0
JSWEL(Mus)	24.78	676.89	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.96	779.37	0	0
SWPGPL-Mus	8.98	309.74	0	0
Dhariwal	0.00	16.14	0	0
IEPL	0.00	116.69	0	0
Other(Mus)	3.07	132.82	0	0
Total	140.47	3892.26		
SOLAR				
Total	16.67	497.12	0	0
Total	16.67	497.12		
Tata				
Trombay 5	8.72	236.96	429	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.57	40.05	108	38
Trombay 7B	1.12	28.74	64	35
TATA Hydro	6.32	152.84	430	87
Trombay 8	4.60	125.75	232	131
Total	22.33	584.34		
AEML				
DTPS U-1&2	7.93	310.02	495	286
Total	7.93	310.02		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	149.14	5030.13	MSPGCL Total	190.62	5929.71
			MSPGCL Thml+Gas	154.76	5193.18	Koyna 1,2 & 4 Total	26.09	497.01
			MSPGCL Hydro	35.86	736.53	State Total	395.68	11822.22

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 31/May/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6292	1968	225	8484	529	6209	0	0	8620	8880	-1584	22121	591	0	22712	3280	397	26389	50.01
2	6295	1990	225	8510	568	6192	0	0	8756	8655	-1451	22117	363	0	22480	3098	357	25936	50.04
3	6265	1904	225	8394	622	6191	0	0	8966	8871	-1579	22175	0	0	22175	2865	324	25364	50.04
4	6296	1716	225	8238	656	6140	0	0	8867	8733	-1639	21791	0	0	21791	2742	336	24869	50.01
5	6311	1520	226	8058	680	6075	0	0	8907	8939	-1570	21839	0	0	21839	2659	342	24840	49.98
6	6313	1814	228	8356	826	6086	0	2	8860	8717	-1524	22071	0	0	22071	2615	391	25077	49.97
7	6205	1530	230	7966	900	6020	0	163	8524	8576	-1676	21522	0	0	21522	2556	426	24504	50.05
8	6184	1422	224	7830	820	5792	0	633	8411	8553	-1804	21383	0	0	21383	2678	442	24503	50.06
9	6097	944	218	7258	847	5644	0	1181	9026	9195	-2076	21586	0	0	21586	3003	464	25053	50.06
10	6028	912	214	7154	894	5588	0	1601	9687	9507	-2325	21942	0	31	21942	3344	477	25764	49.97
11	6041	838	205	7084	751	5227	0	2048	10354	10384	-2594	22402	0	75	22402	3624	499	26525	49.98
12	6112	878	197	7186	558	5507	0	2127	10465	10527	-2691	22731	0	164	22731	3787	483	27001	50.04
13	6148	964	196	7308	421	5580	0	2173	10542	10419	-2517	22911	0	176	22911	3823	473	27207	50.01
14	6187	1118	195	7500	350	5281	0	2051	10471	10820	-2466	23063	0	30	23063	3760	473	27296	50.03
15	6311	1398	193	7902	474	5569	0	1857	10615	10482	-2516	23285	0	141	23285	3890	482	27657	50.01
16	6272	1534	195	8000	585	5588	0	1452	10677	10303	-2511	22928	0	182	22928	3945	489	27363	50.03
17	6260	1574	193	8028	607	5825	0	931	10078	10172	-2442	22633	0	123	22633	3862	488	26983	50.08
18	6232	1692	230	8154	763	5862	0	394	9757	9692	-2308	22071	0	0	22071	3673	486	26231	50.09
19	6282	1466	278	8026	936	5884	0	57	9307	9014	-2151	21268	0	0	21268	3405	498	25170	50.05
20	6311	1444	277	8032	1151	6035	0	0	9379	9358	-1940	22171	0	0	22171	3293	466	25930	49.99
21	6318	1496	297	8110	1071	5992	0	0	8660	8608	-1901	21424	0	0	21424	3235	457	25116	49.95
22	6307	1974	309	8590	942	6060	0	0	7947	8237	-1779	21591	0	0	21591	3208	459	25257	49.98
23	6123	1826	305	8254	845	6043	0	0	8960	8880	-1744	21830	0	0	21830	3242	448	25521	49.98
24	5951	1934	312	8198	851	6083	0	0	9351	9436	-1868	22273	0	0	22273	3335	427	26035	50.03
MUs	149.14	35.86	5.62	190.62	17.65	140.47	0.00	16.67	225.19	224.96	-48.66	531.13	0.95	0.92	532.08	78.92	10.58	621.59	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)132kv BBLR-Rahuri line overload.2)DLS was implemented due to overloading of 400kv Talegaon-Chakan line & To avoid LTS operation as the voltage dropped down to 372kv.3)LTS operated due to overloading of 400/220kv 315 MVA ICT1 at 400kv PGCIL(Boisar)S/s.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 31/May/2023

Position as on 6.30 Hrs of 01/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Uran Unit 6	108	10/05/2023	02:00	31/05/2023	17:00	Zero Schedule.	
MSPGCL	Nasik Unit 3	210	20/05/2023	08:45		Continued.	Boiler Tube Leakage(under tolling from 22.25Hrs DT. 20-5-2023)	
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
IPP	IEPL Unit 1	270	24/05/2023	20:10		Continued.	Clinker formation in furnace	04/06/2023
IPP	SWPGPL U-1	135	29/05/2023	03:57	01/06/2023	05:30	ID Fan Problem	01/06/2023
MSPGCL	Koradi Unit 8	660	29/05/2023	05:36		Continued.	Boiler Tube Leakage	02/06/2023
MSPGCL	Koradi Unit 9	660	30/05/2023	00:08		Continued.	Boiler Tube Leakage	01/06/2023
MSPGCL	Koyna STG-IV Unit-3	250	30/05/2023	23:25	31/05/2023	00:00	Generator oil vapour asperator control fault.	
MSPGCL	Uran Unit 6	108	01/06/2023	01:06		Continued.	No Schedule	
MSPGCL	Khaparkheda Unit 3	210	01/06/2023	07:43		Continued.	Boiler Tube Leakage	02/06/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 31/May/2023

Statement-VII

Position as on 6.30 Hrs of 01/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (403) OF KHADKA CKT - 2 @ DEEPNAGAR	IntraState	29/05/2023	11:43	31/05/2023	21:33	PO	For servicing & overhauling of 400 kV AREVA make Tie C.B.(403) Mechanism
400 KV MAINBAY Outages/Trippings							
MAIN BAY (401) OF TAPTITANDA CKT - 2 @ EKTUNI	IntraState	01/06/2023	10:48			PO	Diagnostic Testing of CB, CT & Routine Maintenance
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
DHULE - SSNNL CKT - 1	InterState	31/05/2023	09:45	31/05/2023	16:36	PO	For Replacement of Corona ring & tightening of Loose hardware.400 KV Dhule-SSNNL CKT 2 A/R switch will be kept on Non auto mode.
LAMBOTI - SOLAPUR (PG)	InterState	31/05/2023	16:36	01/06/2023	00:34	PO	Hardware tieghtning and washing
CHANDRAPUR GCR - CHANDRAPUR HVDC - 1	IntraState	20/05/2023	13:31			PO	1. Replacement of CB with new Siemens make Quad CB along with its commissioning and testing. "400KV HVDC CKT-1" will be in service via 400KV TBC-2.
DABHOL - NEW KOYNA CKT - 2	IntraState	22/05/2023	13:26			PO	Dismantling of exisging tilted old tower at location no 94 and erection of new tower (B+9ST) with foundation and stringing of conductor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	23/05/2023	09:46			HT	For load management
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
BABHALESHWAR - PADGHE CKT - 2	IntraState	31/05/2023	02:54	31/05/2023	05:41	EO	To replaced the broken Y-ph CVT clamp
CHANDRAPUR GCR - CHANDRAPUR HVDC - 1	IntraState	01/06/2023	03:33			EO	1. To attend the problem of low SF6 gas/N2/Oil alarm of 400kV BHEL make Quad CB of TBC-2 bay. 2. Protection trials newly erected Siemens Ltd. Make 420kV, 3150Amp. Quad Break Circuit Breaker of 400kV GCR Chandrapur-HVDC ckt. no-1 bay. 3. Charging of new 420kV, 3150Amp. Quad Break Circuit Breaker of 400kV GCR Chandrapur-HVDC ckt. no-1 bay.
JEJURI- KOYNA STAGE-IV	IntraState	01/06/2023	08:22			PO	PID Faulty disc replacement work & Hot Spot attending Work at Loc No 1
DHARIWAL- CHANDRAPUR 2 CKT I	IntraState	01/06/2023	10:17			PO	Work of MSEDCL/MSETCL energy meters disconnection work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
220 KV TBC Outages/Trippings							
TBC @ KADEGAON	IntraState	31/05/2023	10:57	31/05/2023	12:22	PO	220kV bus isolator (29B) alignment work by hot line method

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 31/May/2023

Statement-VII

Position as on 6.30 Hrs of 01/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AAREY - AEML SAKI CKT - 1	IntraState	28/05/2023	17:23			T	Tripped on Differential protection.
MAIN BUS - 1 @ AAREY	IntraState	30/05/2023	23:29	31/05/2023	01:23	PO	Charging of 220kV Aarey - Goregaon line 1 after shifting from AIS Bay 01 to NEW GIS Bay no 17. Line will be charged via 220kV Aarey- AEML Borivali Line. Work to be executed under MERC approved 220kV AIS to GIS Conversion Scheme.
VERSOVA - GHODBUNDER	IntraState	31/05/2023	01:13	31/05/2023	06:55	PO	Erection of U-Girder @ LOC P145 -146 LHS along metro line 9 near silver park, Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.
PALGHAR - PANCHALI TSS	IntraState	31/05/2023	01:52	31/05/2023	07:08	PO	Replacement of Old rusted disc insulator with porcelain long rod insulator at various locations.
BOISAR - VERSOVA	IntraState	31/05/2023	07:26	31/05/2023	09:37	PO	outage for safety purpose ,for NHRCL work
220 KV TADALI - MIDC CHANDRAPUR CKT	IntraState	31/05/2023	07:58	31/05/2023	13:30	HT	Diagnostic testing and allied bay maintenance work.
AMBAZARI - KARANJA CKT	IntraState	31/05/2023	08:47	31/05/2023	19:37	HT	Putting hv insulations tape between loc 2 & 3 and other allied works.
CHIKHALI-JALNA I	IntraState	31/05/2023	11:40	31/05/2023	22:45	HT	For replacement of damaged b-phase conductor span between loc.no. 140 to 145.
URAN - APTA 2	IntraState	31/05/2023	13:58	31/05/2023	17:03	T	TRIPPED ON DISTANCE PROTECTION.
SIEMENS - RELIANCE GIS	IntraState	31/05/2023	15:35	31/05/2023	18:47	EO	for attending Hot Spot at B-ph GIS Bushing clamp
MAIN BUS - 1 @ AAREY	IntraState	31/05/2023	17:52	31/05/2023	18:33	T	Tripped. Reason awaited
MAIN BUS - 2 @ AAREY	IntraState	31/05/2023	17:52	31/05/2023	18:31	T	tripped. reason awaited
URSE-CHINCHWAD	IntraState	31/05/2023	17:56	01/06/2023	02:55	T	Tripped on distance protection
VERSOVA - GHODBUNDER	IntraState	01/06/2023	00:57	01/06/2023	07:14	PO	Erection of U-Girder at LOC P146-147 RHS along metro 9 near silver park - Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.
PALGHAR - PANCHALI TSS	IntraState	01/06/2023	02:27	01/06/2023	08:06	PO	Replacement of Old rusted disc insulator with porcelain long rod insulator at various locations.
WAGHIVALI - DHARAVI 8	IntraState	01/06/2023	04:57	01/06/2023	07:36	PO	Installation of Split Core CT at Chunabhatti, Differential CT wiring at Dharavi
PANDHARPUR - KHANAPUR	IntraState	01/06/2023	07:51	01/06/2023	10:58	PO	Cold line washing work from Loc No.219-20
PETH- MUDSHINGI 1 LINE	IntraState	01/06/2023	10:18			PO	Structure Painting Work
KANDALGAON - ONGC PANVEL	IntraState	01/06/2023	10:31			PO	Routine maintenance & emergency tree cutting work & cold line cleaning of disc & polymer insulator
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 31/May/2023

Statement-VII

Position as on 6.30 Hrs of 01/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 200 MVA ICT 2	IntraState	31/05/2023	07:57	31/05/2023	16:50	HT	Alignment work of 132kv bus2 isolator(iso bus side jumper remerging and connecting work will be carried out by hlu nagpur; premonsoon maintenance work; dignostic testing.
220/132 KV 200 MVA ICT 2	IntraState	31/05/2023	08:07	31/05/2023	10:42	HT	Pre- monsoon maintenance.
220/132 KV 200 MVA ICT 2	IntraState	31/05/2023	08:13	31/05/2023	13:45	HT	For pre-monsoon maintenance work and bay maint work.
220/132-110 KV 100 MVA ICT 2	IntraState	31/05/2023	08:19	31/05/2023	18:36	PO	OLTC overhauling & Q.M work
220/132 KV 100 MVA ICT 2	IntraState	31/05/2023	08:23	31/05/2023	14:45	HT	IR measurement of lv bay r ph la and pre monsoon maintenace work.
220/132KV 200MVA ICT 6 @ EKLAHARE (GCR)	IntraState	31/05/2023	08:43	31/05/2023	12:33	PO	Premonsoon maintenance work
220/132 KV 200 MVA ICT 2 @ BEED	IntraState	31/05/2023	09:57	31/05/2023	11:21	HT	For premansoon maint. work & grtly. maint. work.
100 MVA 220/132 KV ICT - II	IntraState	31/05/2023	10:00	31/05/2023	12:55	HT	Pre-mansoon maintenance work 2. replacement of damaged control cable from elay panel to m.b.
220/132KV 200MVA PTR 1 @ LONAND	IntraState	31/05/2023	10:05	31/05/2023	17:24	PO	Premonsoon and quarterly maintenance work
220/132 KV 200 MVA ICT 2@ BALE(SOLAPUR)	IntraState	31/05/2023	11:55	31/05/2023	14:02	PO	Outage is required for Tan delta testing
220/132KV 100MVA ICT 1 @ BARAMATI	IntraState	31/05/2023	16:52	31/05/2023	18:35	EO	To attain oil leakage of R-ph HV Bushing
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	IntraState	01/06/2023	06:16			PO	For Rph LV Bushing replacement work
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	01/06/2023	08:33			PO	Removing Bird Nest at loc 66,67 and 68

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage