

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 31/May/2024 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	166.245	5228.658	1) Gujrat	2.630	6.738
2) Hydro	40.048	655.057	2) Madhya Pradesh	3.308	142.315
3) Gas	7.305	218.201	3) Chattisgarh	1.710	106.530
Total MSPGCL	213.598	6101.916	4) Maharashtra	185.412	5758.337
B) 1) APLM	62.896	1967.346	5) Goa (Amona)	-2.528	-63.567
2) JSWEL	28.400	839.082	Total	190.532	5950.353
3) VIPL	0.000	0.000	a) Mumbai Schedule	46.243	1369.848
4) RPL(AMT)	25.700	890.344	b) Mumbai Drawl	49.604	1421.472
5) SWPGPL	11.202	362.320	c) MSEDCL Bilateral *	88.419	2559.919
6) Other IPP	14.595	509.675	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	46.243	1369.848
C) 1) TPCL Thermal	13.058	395.850	Include PX	0.000	0.000
2) TPCL Hydro	5.460	147.169	Standby	0.000	0.000
3) TPCL Gas	4.128	120.585	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.087	313.883	1) MSEDCL	537.012	16048.932
D) STATE			2) Mumbai Discoms	83.337	2398.953
1) Thermal	333.183	10507.158	3) Other Discoms	12.090	361.297
(A1+C1+C4+(B1-B6))			TOTAL STATE	632.439	18809.182
2) Hydro	45.508	802.226			
(A2+C2)					
3) Gas	11.433	338.786			
(A3+B7+C3)					
4) Wind	33.152	688.149			
6) SOLAR	18.631	522.516			
TOTAL STATE	441.907	12858.835			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6116	7064	7484	6821
MSPGCL Hydro	1707	1655	1894	1924
MSPGCL Gas	277	278	372	286
MSPGCL Total Generation	8100	8997	9750	9031
Central Sector Receipt	9085	9045	6754	7849
WIND	788	962	1734	1224
CPP / IPP Thermal	5125	5710	6693	5119
CPP / IPP Gas	0	0	0	0
SOLAR	2390	1644	0	663
Exchange with Mumbai	-2609	-2554	-1782	-1763
MSEDCL DEMAND MET	22326	23261	22615	21623
Load Shedding	0	0	0	0
MSEDCL DEMAND	22326	23261	22615	21623
TPCL GENERATION	817	1088	1264	718
AEML GENERATION	489	504	464	370
MUMBAI DEMAND	3915	4146	3510	2851
OTHER DISCOM DEMAND	553	543	534	500
STATE DEMAND MET	26794	27950	26659	24974
STATE DEMAND	26794	27950	26659	24974
Frequency (Hz)	50.00	49.99	49.99	50.10

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 07.55 Hrs	49.84 Hz at 10.37 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 31/May/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.43	116.89	194	156
Unit 8	13.60	264.68	620	502
Unit 9	0.00	369.60	0	0
Unit 10	12.58	417.10	560	470
Total	30.61	1168.26		
Bhusawal				
Unit 3	0.00	79.18	0	0
Unit 4	8.72	284.60	480	0
Unit 5	10.10	294.56	470	310
Total	18.82	658.33		
Parli				
Unit 6	4.28	137.36	248	144
Unit 7	4.42	132.76	246	144
Unit 8	4.42	130.60	238	145
Total	13.13	400.72		
Chandrapur				
Unit 3	3.57	110.18	165	125
Unit 4	3.65	113.21	167	122
Unit 5	9.11	273.47	435	280
Unit 6	8.93	219.66	440	280
Unit 7	8.71	250.43	414	292
Unit 8	10.23	318.00	460	321
Unit 9	11.40	295.57	500	392
Total	55.62	1580.52		
Paras				
Unit 3	5.19	146.64	234	161
Unit 4	5.56	168.48	252	163
Total	10.75	315.13		
Khaparkheda				
Unit 1	3.90	109.90	175	145
Unit 2	4.62	133.06	206	148
Unit 3	2.96	120.81	160	0
Unit 4	4.36	123.10	190	149
Unit 5	11.41	316.91	485	455
Total	27.26	803.78		
Nasik				
Unit 3	3.47	96.83	165	122
Unit 4	3.24	107.16	144	125
Unit 5	3.36	97.93	167	119
Total	10.07	301.92		
Uran				
All Units	7.30	218.20	379	276
Total	7.30	218.20		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	5.19	0	0
Total	0.00	5.19		
Koyna				
Stage 1-2	8.16	150.05	520	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	22.43	296.79	1009	507
Stage 3	6.95	99.90	320	144
Total	37.53	546.74		
Hydro				
KDPH	0.50	18.85	21	21
VTRNA	0.41	24.32	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.54	57.46	66	62
GHATGHAR	0.07	7.69	69	0
Total	2.52	108.31		
Wind				
Total	33.15	688.15	0	0
Total	33.15	688.15		
CPP				
APML(Mus)	62.90	1967.35	0	0
JSWEL(Mus)	28.40	839.08	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.70	890.34	0	0
SWPGPL-Mus	11.20	362.32	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.14	163.79	242	195
Other(Mus)	5.58	205.65	0	0
JPL	3.87	140.24	204	134
Total	142.79	4568.77		
SOLAR				
Total	18.63	522.52	0	0
Total	18.63	522.52		
Tata				
Trombay 5	8.70	268.77	455	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	74.76	108	108
Trombay 7B	1.54	45.82	64	64
TATA Hydro	5.46	147.17	436	89
Trombay 8	4.36	127.08	225	129
Total	22.65	663.60		
AEML				
DTPS U-1&2	11.09	313.88	504	370
Total	11.09	313.88		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	166.24	5228.66	MSPGCL Total	213.60	6101.92
			MSPGCL Thml+Gas	173.55	5446.86	Koyna 1,2 & 4 Total	30.58	446.84
			MSPGCL Hydro	40.05	655.06	State Total	441.91	12858.84

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 31/May/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7301	1918	352	9571	2153	6590	0	0	7471	7142	-1944	23062	0	0	23062	3478	450	26990	50.01
2	7262	1587	295	9144	2066	6590	0	0	7628	7323	-1954	22747	0	0	22747	3223	422	26392	50.00
3	7106	1415	287	8808	1920	6574	0	0	7500	7046	-1775	22175	0	0	22175	3019	398	25592	49.99
4	6980	1866	287	9133	1718	5972	0	0	7503	7490	-1741	22181	0	0	22181	2888	391	25460	49.99
5	7267	1934	288	9489	1473	6276	0	0	7485	7256	-1609	22474	0	0	22474	2804	411	25689	49.96
6	7385	1893	288	9566	1423	6514	0	0	7539	7289	-1565	22781	0	0	22781	2777	446	26004	49.96
7	7201	1905	287	9393	1094	5922	0	155	7842	7677	-1572	22192	0	10	22192	2745	477	25414	50.01
8	6821	1924	286	9031	1224	5119	0	663	7806	7849	-1763	21623	0	10	21623	2851	500	24974	50.10
9	6641	917	286	7844	1180	5178	0	1334	8394	8170	-1981	21192	0	5	21192	3167	533	24892	50.05
10	5648	1650	284	7582	1106	5086	0	1831	8891	8811	-2389	21485	0	0	21485	3510	542	25537	49.93
11	5791	1678	279	7748	884	5062	0	2171	9111	8997	-2551	21761	0	0	21761	3808	550	26119	49.92
12	6116	1707	277	8100	788	5125	0	2390	9155	9085	-2609	22326	0	7	22326	3915	553	26794	50.00
13	6051	1727	277	8055	796	5048	0	2455	9200	9015	-2633	22191	0	13	22191	3950	545	26686	50.05
14	6089	1623	277	7989	892	5043	0	2340	9222	9051	-2627	22158	0	15	22158	3875	530	26563	50.05
15	6679	1702	276	8657	863	5196	0	2058	9391	9185	-2669	22763	0	13	22763	4056	527	27346	50.04
16	7064	1655	278	8997	962	5710	0	1644	9394	9045	-2554	23261	0	13	23261	4146	543	27950	49.99
17	7234	1394	281	8909	1172	6545	0	1035	8640	8266	-2396	22982	0	14	22982	4031	549	27562	50.00
18	7114	1253	281	8648	1463	6442	0	482	8776	8170	-2267	22375	0	6	22375	3842	563	26780	49.98
19	7049	1710	281	9040	1512	5670	0	73	8191	8067	-2028	21772	0	0	21772	3591	562	25925	50.01
20	7411	1706	356	9473	1621	6324	0	0	7866	7435	-1858	22447	0	0	22447	3546	548	26541	49.97
21	7484	1894	372	9750	1734	6693	0	0	7156	6754	-1782	22615	0	0	22615	3510	534	26659	49.99
22	7522	1506	373	9401	1667	6692	0	0	6875	6730	-1713	22254	0	0	22254	3481	523	26258	50.00
23	7539	1582	378	9499	1715	6687	0	0	7255	7200	-1768	22826	0	0	22826	3526	507	26859	50.01
24	7490	1902	379	9771	1726	6735	0	0	7526	7479	-1856	23372	0	0	23372	3598	483	27453	50.02
MUs	166.25	40.05	7.30	213.60	33.15	142.79	0.00	18.63	195.82	190.53	-49.60	537.01	0.00	0.11	537.01	83.34	12.09	632.44	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) 132 KV BBLR TO Rahuri line over Load Alarm 488 AMP/102.10 MW.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 31/May/2024

Position as on 6.30 Hrs of 01/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Koradi Unit 9	660	28/05/2024	22:12		Continued.	Boiler Tube Leakage	02/06/2024
MSPGCL	Bhusawal Unit 3	210	29/05/2024	02:31		Continued.	Boiler Tube Leakage	02/06/2024
MSPGCL	Khaparkheda Unit 3	210	30/05/2024	22:20	31/05/2024	04:02	Due to furnace draft high.	
MSPGCL	Bhusawal Unit 4	500	31/05/2024	09:09	31/05/2024	11:05	Flame Failure	02/06/2024
MSPGCL	Nasik Unit 3	210	01/06/2024	02:15	01/06/2024	05:30	Low furnace pressure	
MSPGCL	Paras Unit 4	250	01/06/2024	22:27		Continued.	Drum level low	04/06/2024
Total Capacity MSPGCL		2285						
IPP								
IPP	SWPGPL U-3	135	28/05/2024	10:14	31/05/2024	04:06	Boiler Tube Leakage	30/05/2024
IPP	RPL(AMT) U-4	270	28/05/2024	18:57		Continued.	Due to ID Fan tripped on high vibration..	28/06/2024
Total Capacity IPP		405						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		3010						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	19/05/2024	02:00		Continued.	As per MSEDCL zero schedule.	
MSPGCL	Uran Unit 6	108	31/05/2024	01:02	31/05/2024	19:00	Due to Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	01/06/2024	02:00		Continued.	Due to Zero Schedule given by MSEDCL.	
Total Capacity MSPGCL		324						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		324						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 31/May/2024

Position as on 6.30 Hrs of 01/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 31/May/2024

Statement-VII

Position as on 6.30 Hrs of 01/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	26/05/2024	18:11			T	Tripped on distance protection.(Due to tower
400 KV LINE Outages/Trippings							
LONIKAND I - TALEGAON (PGCIL)	InterState	30/05/2024	22:55	31/05/2024	05:47	PO	Cold line washing.
AKOLA - WARDHA(PG) CKT - 1	InterState	31/05/2024	16:40	31/05/2024	20:45	EO	FOR RECTIFICATION OF MELTED JUMPER PAD
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
220 KV PARLI (400 KV)- GIRWALI I/C -2	IntraState	26/05/2024	15:40			T	6 Nos. Tower collapsed (Loc no 36- 41) .
220 KV KHADKA (400 KV)- CHALISGAON CKT -1	IntraState	31/05/2024	08:09	31/05/2024	16:45	PO	FOR WORK OF RESTRINGING OF CONDUCTOR BETWEEN LOC NO. 299 TO 313
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/220kv 500MVA ICT-2 @ TAPTITANDA	IntraState	31/05/2024	08:29	31/05/2024	14:40	PO	Pre monsoon work, and testing work.
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	31/05/2024	10:52	31/05/2024	15:08	T	MAIN AND TIE BAY TRIPPED ON BUCHOLZ PROT OF STN TF 8A
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	31/05/2024	15:05	31/05/2024	15:57	T	220 kV Busbar operated
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	31/05/2024	15:05	31/05/2024	15:43	T	220 kV Busbar operated
400/220/33 KV 500 MVA ICT - 3 @ PARLI	IntraState	31/05/2024	15:05	31/05/2024	15:51	T	220 kV Busbar operated
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	01/06/2024	00:26	01/06/2024	06:25	HT	HT for Load Management
400 KV BR Outages/Trippings							
400KV 125 MVAR BUS REACTOR @ AKOLA	InterState	31/05/2024	08:28	31/05/2024	14:07	PO	routine maintenance & testing work
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220/132 KV 100MVA ICT 2	IntraState	31/05/2024	09:16	31/05/2024	16:27	PO	DIAGNOSTIC TESTING (TAN DELTA, TIMING TEST ,CRM TEST)
220 KV LINE Outages/Trippings							
HINJEWADI 2 - HINJEWADI 3 CKT - 1	IntraState	24/05/2024	12:34			PO	Attending SF6 Gas Leakage at G-9 Chamber of 'B' phase of 220kV Hinjawadi2 Line 1 bay

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 31/May/2024

Statement-VII

Position as on 6.30 Hrs of 01/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	25/05/2024	13:25			HT	For load management
132 KV GHATODI (220 KV) - DIGRAS CKT	IntraState	26/05/2024	15:36			T	6 Nos. Tower collapsed (Loc no 99-104).
132 kv GHATODI ARNI	IntraState	26/05/2024	15:36			T	6 Nos. Tower collapsed (Loc no 99-104) .
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	26/05/2024	15:40			T	6 Nos. Tower collapsed (Loc no 36- 41) .
LAMBOTI - PANDHARPUR	IntraState	26/05/2024	17:25			T	TOWER COLLAPSED AT LOC.414-419.
LAMBOTI - KARKAMB	IntraState	26/05/2024	17:25			T	TOWER COLLAPSED AT LOC.414-419.
GORAI -MSETCL BORIVALI CKT -1	IntraState	28/05/2024	17:59			T	Bus fault
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
GORAI -MSETCL BORIVALI CKT -2	IntraState	28/05/2024	17:59			T	Bus fault
KARAD -MUDSHINGI CKT 2-TAK	IntraState	30/05/2024	10:07	31/05/2024	1774	PO	Opening of Jump at Loc No.64 & 76 for replacement of bend/titled tower at Loc No.74
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
PALGHAR - NALASOPARA	IntraState	31/05/2024	04:46	31/05/2024	08:20	PO	Replacement of Insulator String Identified in PID.
GADCHANDUR - VIRUR-II	IntraState	31/05/2024	05:41	31/05/2024	17:33	PO	FOR HEIGH RAISING/SHIFTING OF LINE FOR CONSTRUCTION OF NH-353 FROM RAJURA- KORPANA- ADILABAD UP TO MS BORDER FROM EXT.
WARORA - HINGANGHAT	IntraState	31/05/2024	07:18	31/05/2024	10:17	PO	1) FOR DIAGNOSTIC TESTING (I.E. CRM,CB TIMING AND TAN DELTA OF CT OF 220 KV HINGANGHAT- WARORA LINE(BAY))
NERUL - SEAWOOD CABLE CKT - 1	IntraState	31/05/2024	09:09	31/05/2024	13:21	PO	Pre-Monsoon Maintenance and LA Meggering work
BUTIBORI-INOX	IntraState	31/05/2024	09:13	31/05/2024	00:04	PO	SF6 BREAKER MAINTENANCE & N2 SYSTEM INSTALLATION AT M/S. INOX (220KV INOX S/S.)
BOMBAY DYEING - SAHARA	IntraState	31/05/2024	12:48	31/05/2024	16:00	PO	Replacement of flashover string insulators at Loc No. 124.
220 KV GIRWALI (400 KV) -PARLI U -8 CKT	IntraState	31/05/2024	15:05	31/05/2024	15:59	T	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.
220KV KURUNDA -GIRWALI CKT	IntraState	31/05/2024	15:05	31/05/2024	15:33	T	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.
220 KV GIRWALI - MURUD CKT	IntraState	31/05/2024	15:05	31/05/2024	15:50	T	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 31/May/2024

Statement-VII

Position as on 6.30 Hrs of 01/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV PARLI (OLD GCR)-GIRWALI (400 KV) CKT 4	IntraState	31/05/2024	15:05	31/05/2024	15:31	T	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.
220 KV PARLI (OLD GCR)-GIRWALI (400 KV) CKT 3	IntraState	31/05/2024	15:05	31/05/2024	15:31	T	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.
MHAISAL - ALKUD	IntraState	31/05/2024	16:56	31/05/2024	21:55	PO	Wedge Connector Work
PALGHAR - NALASOPARA	IntraState	01/06/2024	06:25			PO	Replacement of Insulator String Identified in PID.
BUTIBORI-INOX	IntraState	01/06/2024	09:13	01/06/2024	00:04	PO	SF6 BREAKER MAINTENANCE & N2 SYSTEM INSTALLATION AT M/S. INOX (220KV INOX S/S.)
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132 KV 200 MVA ICT 2 @ AMALNER	IntraState	30/05/2024	17:50			HT	Testing work.
220/33 KV 50 MVA PTR 1 @ MALEGAON	IntraState	31/05/2024	07:15	31/05/2024	08:12	PO	For Pre-monsoon maintenance work
220/33 KV 50 MVA PTR 2 @ MALEGAON	IntraState	31/05/2024	08:17	31/05/2024	08:53	PO	For Pre-monsoon maintenance work
220/33 KV 50 MVA T/F 3 @ MALEGAON	IntraState	31/05/2024	09:50	31/05/2024	09:50	PO	For Pre-monsoon maintenance work
220/132 KV 200 MVA ICT 1 @ BOISAR-II	IntraState	31/05/2024	10:02	31/05/2024	11:59	PO	Pre Monsoon maintenance work
220/132 KV 200 MVA ICT 1 @ MALEGAON	IntraState	31/05/2024	10:04	31/05/2024	11:53	PO	For Pre-monsoon maintenance work
220/33 KV 50 MVA TF - 1@BELWANDI	IntraState	31/05/2024	10:12	31/05/2024	12:21	PO	Pre-monsoon maintenance work
220/100 KV 200 MVA ICT 4 @ APTA	IntraState	31/05/2024	11:40	31/05/2024	14:36	PO	100 kV BUS 2 Outage :- ICT-3 & 4 Premonsoon maintenance work
220/100 KV 200 MVA ICT 3 @ APTA	IntraState	31/05/2024	11:42	31/05/2024	14:35	PO	100 kV BUS 2 Outage :- ICT-3 & 4 Premonsoon maintenance work
220/132 KV 200 MVA ICT 2 @ MALEGAON	IntraState	31/05/2024	12:03	31/05/2024	12:45	PO	For Pre-monsoon maintenance work
220/33 KV 50 MVA TF - 2@BELWANDI	IntraState	31/05/2024	12:24	31/05/2024	13:20	PO	Pre-monsoon maintenance work
220/132 KV 200 MVA ICT 2 @ BOISAR-II	IntraState	31/05/2024	12:45	31/05/2024	16:01	PO	Annual maintenance work of NIFPS (CTR make) system.
220/100 KV 200 MVA ICT 2 @ KOLSHET	IntraState	31/05/2024	12:52	31/05/2024	22:08	PO	1) Replacement of Differential, HV Backup LV Backup relays, 2) Pre-monsoon maintenance work, bay R&M work.
200 MVA 220/132 KV ICT 1 @ GIRWALI	IntraState	31/05/2024	15:05	31/05/2024	15:48	T	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.
200 MVA 220/132 KV ICT 2 @ GIRWALI	IntraState	31/05/2024	15:05	31/05/2024	16:10	T	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 31/May/2024

Statement-VII

Position as on 6.30 Hrs of 01/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
200 MVA 220/132 KV ICT 3 @ GIRWALI	IntraState	31/05/2024	15:05	31/05/2024	15:58	T	220 KV BUS SECTIONALISER R PH CT BURST 220KV BUS BAR PROT OPTD.
220/100 KV 200 MVA ICT 3 @ TROMBAY	IntraState	01/06/2024	06:34			PO	For 1) Premonsoon maintenance work & 2) RM work.
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.
110 KV LINE Outages/Trippings							
KARANJADE - BHOKARPADA	IntraState	31/05/2024	08:02	31/05/2024	12:32	PO	For RM

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage