

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 31/Aug/2020 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	102.102	2990.607	1) Gujrat	12.622	62.501
2) Hydro	11.950	259.343	2) Madhya Pradesh	5.235	200.467
3) Gas	6.505	160.526	3) Chattisgarh	4.830	153.490
Total MSPGCL	120.557	3410.476	4) Maharashtra	114.031	3431.838
B) 1) APML	29.279	873.139	5) Goa (Amona)	-1.645	-50.924
2) JSWEL	19.273	497.385	Total	135.073	3797.372
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.139	747.142
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	23.115	739.335
5) WPCL	2.604	134.230	c) MSEDCL Bilateral *	24.252	962.132
6) Other IPP	9.078	250.533	Include PX	6.010	186.610
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.139	747.142
C) 1) TPCL Thermal	7.894	243.923	Include PX	11.627	434.706
2) TPCL Hydro	7.203	140.883	Standby	0.000	0.000
3) TPCL Gas	2.527	107.890	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.896	150.760	1) MSEDCL	331.162	9737.215
D) STATE			2) Mumbai Discoms	45.635	1382.789
1) Thermal	175.126	5140.577	TOTAL STATE	376.797	11120.004
(A1+C1+C4+(B1-B6))					
2) Hydro	19.153	400.226			
(A2+C2)					
3) Gas	9.032	268.416			
(A3+B7+C3)					
4) Wind	32.370	1374.801			
6) SOLAR	6.043	138.614			
TOTAL STATE	241.724	7322.634			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4461	4496	4425	3804
MSPGCL Hydro	282	481	1813	217
MSPGCL Gas	276	266	276	277
MSPGCL Total Generation	5019	5243	6514	4298
Central Sector Receipt	6547	6287	5457	4431
WIND	1544	1246	931	1698
CPP / IPP Thermal	2623	2677	2705	2056
CPP / IPP Gas	0	0	0	0
SOLAR	667	379	0	0
Exchange with Mumbai	-1243	-1142	-846	-749
MSEDCL DEMAND MET	15157	14690	14761	11734
Load Shedding	0	0	0	0
MSEDCL DEMAND	15157	14690	14761	11734
TPCL GENERATION	737	780	961	520
AEML GENERATION	189	189	250	189
MUMBAI DEMAND	2169	2111	2057	1458
STATE DEMAND MET	17326	16801	16818	13192
STATE DEMAND	17326	16801	16818	13192
Frequency (Hz)	50.00	50.00	49.81	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.15 Hz at 13.01 Hrs	49.6 Hz at 19.10 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 31/Aug/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	11.11	198.01	530	400
Unit 9	9.20	178.90	423	345
Unit 10	8.67	118.40	400	330
Total	28.98	495.31		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.46	147.28	465	350
Unit 5	9.60	245.34	470	355
Total	19.06	392.62		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	4.04	37.24	176	163
Unit 4	0.00	92.66	0	0
Unit 5	9.42	269.18	411	365
Unit 6	0.00	194.84	0	0
Unit 7	0.00	44.52	0	0
Unit 8	10.64	225.32	490	360
Unit 9	0.00	277.95	0	0
Total	24.09	1141.71		
Paras				
Unit 3	4.00	124.44	185	125
Unit 4	3.77	124.39	197	94
Total	7.78	248.83		
Khaparkheda				
Unit 1	2.50	98.66	120	90
Unit 2	2.99	98.20	150	120
Unit 3	3.22	103.41	150	125
Unit 4	3.14	115.60	145	120
Unit 5	10.34	296.26	490	365
Total	22.19	712.13		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.50	160.53	278	257
Total	6.50	160.53		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.25	32.05	52	52

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	1.25	32.05		
Koyna				
Stage 1-2	4.02	81.94	545	40
Stage 4	2.21	36.86	947	0
Stage 3	2.19	56.49	240	0
Total	8.43	175.29		
Hydro				
KDPH	0.89	10.22	37	37
VTRNA	0.00	0.61	0	0
TILLARI	0.38	19.87	58	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.43	12.28	40	0
RNGR+BHTSA	0.00	0.41	0	0
BHANDARDRA	0.34	8.40	15	14
ELDARY	0.54	8.61	23	22
SMLHY_PTN	0.94	23.63	40	39
GHATGHAR	0.00	0.03	0	0
Total	3.52	84.06		
Wind				
Total	32.37	1374.80	0	0
Total	32.37	1374.80		
CPP				
APML(Mus)	29.28	873.14	0	0
JSWEL(Mus)	19.27	497.38	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.60	134.23	0	0
Other(Mus)	9.08	250.53	0	0
Total	60.23	1755.29		
SOLAR				
Total	6.04	138.61	0	0
Total	6.04	138.61		
Tata				
Trombay 5	7.89	243.92	399	286
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.41	65.81	65	56
Trombay 7B	1.11	42.08	51	44
Trombay 8	0.00	0.00	0	0
TATA Hydro	7.20	140.88	459	118
Total	17.62	492.70		
AEML				
DTPS U-1&2	4.90	150.76	250	188
Total	4.90	150.76		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	102.10	2990.61	MSPGCL Total	120.56	3410.48
			MSPGCL Thml+Gas	108.61	3151.13	Koyna 1,2 & 4 Total	6.23	118.80
			MSPGCL Hydro	11.95	259.34	State Total	241.72	7322.63

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 31/Aug/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3914	217	268	4399	1756	2068	0	0	4785	4449	-778	11894	0	11894	1637	13531	50.00
2	3843	222	267	4332	1816	2030	0	0	4491	4257	-716	11719	0	11719	1551	13270	49.96
3	3815	227	276	4318	1742	2048	0	0	4199	4332	-721	11719	0	11719	1489	13208	49.96
4	3804	217	277	4298	1698	2056	0	0	4309	4431	-749	11734	0	11734	1458	13192	49.99
5	3785	217	267	4269	1700	2178	0	0	4806	4806	-714	12239	0	12239	1440	13679	50.01
6	4018	301	278	4597	1569	2468	0	0	5317	5319	-730	13223	0	13223	1483	14706	50.03
7	4209	302	277	4788	1391	2580	0	32	6411	6300	-768	14323	0	14323	1538	15861	50.01
8	4405	261	268	4934	1211	2633	0	226	6682	6883	-905	14982	0	14982	1698	16680	50.00
9	4531	272	266	5069	1313	2626	0	475	6762	6936	-1088	15331	0	15331	1919	17250	50.02
10	4461	282	276	5019	1544	2623	0	667	6945	6547	-1243	15157	0	15157	2169	17326	50.00
11	4164	198	265	4627	1458	2555	0	711	7385	6822	-1330	14843	0	14843	2280	17123	49.97
12	4089	283	277	4649	1514	2501	0	702	6553	6704	-1375	14695	0	14695	2334	17029	50.04
13	4071	483	257	4811	1318	2491	0	746	6326	6460	-1358	14468	0	14468	2320	16788	50.03
14	4146	337	276	4759	1349	2553	0	722	6052	6080	-1255	14208	0	14208	2209	16417	49.99
15	4335	438	276	5049	1397	2609	0	702	6049	6010	-1211	14556	0	14556	2172	16728	49.95
16	4429	743	266	5438	1268	2658	0	507	5877	5942	-1168	14645	0	14645	2137	16782	49.95
17	4496	481	266	5243	1246	2677	0	379	6213	6287	-1142	14690	0	14690	2111	16801	50.00
18	4507	431	276	5214	1224	2633	0	152	6280	5886	-1069	14040	0	14040	2063	16103	49.96
19	4429	1100	267	5796	940	2651	0	22	5983	5889	-929	14369	0	14369	2045	16414	49.84
20	4425	1813	276	6514	931	2705	0	0	5648	5457	-846	14761	0	14761	2057	16818	49.81
21	4563	1468	258	6289	960	2716	0	0	5235	5079	-782	14262	0	14262	1989	16251	49.86
22	4578	756	278	5612	1001	2724	0	0	5149	4703	-700	13340	0	13340	1907	15247	49.94
23	4586	503	278	5367	1038	2730	0	0	4728	4951	-743	13343	0	13343	1846	15189	50.00
24	4499	398	269	5166	986	2721	0	0	4550	4543	-795	12621	0	12621	1783	14404	49.99
MUs	102.10	11.95	6.51	120.56	32.37	60.23	0.00	6.04	136.73	135.07	-23.12	331.16	0.00	331.16	45.64	376.80	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 31/Aug/2020

Position as on 6.30 Hrs of 01/Sep/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U4	300	20/08/2020	15.57		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.(Converted zero schedule from 25.03.2020)	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 7	250	12/05/2020	19.34		Continued.	Zero Schedule.	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Parli Unit 8	250	01/06/2020	13.13		Continued.	Zero schedule By MSEDCL	
IPP	Adani U-1	660	03/06/2020	15.02		Continued.	Converted zero schedule from 03.06.2020	
IPP	Adani U-5	660	04/06/2020	12.29		Continued.	Zero Schedule.	
IPP	Adani U-4	660	12/06/2020	10.30		Continued.	Zero Schedule	
AEML	AEML Unit 1	250	27/06/2020	23.55		Continued.	Zero schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 31/Aug/2020

Position as on 6.30 Hrs of 01/Sep/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 7	500	06/08/2020	03.33		Continued.	Sparkling in generator R phase winding.	
CPP	SWPGL U-4	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	
CPP	SWPGL U-3	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Ghatghar Unit-1	125	27/08/2020	05.25		Continued.	Runner band Drainage valve Leakage	
MSPGCL	Chandrapur Unit 6	500	27/08/2020	10.55		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 4	210	27/08/2020	18.00		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 9	500	29/08/2020	15.30	01/09/2020	20.45	Boiler Tube Leakage	
IPP	Adani U-2	660	01/09/2020	19.41		Continued.	Air pre-heater PA Bellow leakage.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 31/Aug/2020

Statement-VII

Position as on 6.30 Hrs of 01/Sep/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Khandwa II	InterState	29/08/2020	19.15		Continued.	T	Due To Fire At 48 Volt DC Charger.
BABHALESHWAR - RPL(NASHIK) CKT - 1	IntraState	11/06/2020	10.40		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	07/08/2020	23.23		Continued.	HT	Over Voltage
Jaigad-Karad Ckt-II	IntraState	13/08/2020	10.59		Continued.	EO	To attend CB problem.(RFC 29-08-2020 At 17.05).
Dhule- Bableswhar - I	IntraState	23/08/2020	19.46	31/08/2020	08.39	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	25/08/2020	17.28		Continued.	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt I	IntraState	27/08/2020	21.57		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	29/08/2020	20.58	31/08/2020	08.31	HT	Over Voltage
Koradi-Khaperkheda I	IntraState	30/08/2020	04.32	01/09/2020	08.13	T	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	30/08/2020	19.47	31/08/2020	08.32	HT	Over Voltage
karad -kolhapur-II	IntraState	30/08/2020	19.50	01/09/2020	09.43	HT	Over Voltage
Babhaleshwar - Padghe-I	IntraState	30/08/2020	23.48	31/08/2020	11.22	HT	Over Voltage
Ektuni-Bableswhar ckt I	IntraState	31/08/2020	09.34	31/08/2020	18.45	PO	Quarterly Maintenance Work
Dhule- Bableswhar - I	IntraState	31/08/2020	17.26		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	31/08/2020	20.09	01/09/2020	09.44	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	31/08/2020	22.37		Continued.	HT	Over Voltage
Babhaleshwar - Padghe-I	IntraState	31/08/2020	22.51		Continued.	HT	Over Voltage
Switching Ckt I 401 CB @ Chandrapur	IntraState	01/09/2020	10.38	01/09/2020	14.49	PO	Confirmation of Healhtiness Of R-PH Line CVT.
Koradi-RattanIndia	IntraState	01/09/2020	13.10		Continued.	T	Distance Protection
Padghe - Kalwa- I	IntraState	01/09/2020	19.03		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	01/09/2020	19.45		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/08/2020	09.58		Continued.	PO	Replacement Of Existing 315 MVA ICT By 3*167 MVA ICT.
400/11.5 KV 90MVA Station T/F V @ Chandrapur	IntraState	28/08/2020	12.34	01/09/2020	17.28	PO	Routine Maintenance Work at GENCO End.
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	31/08/2020	00.29	31/08/2020	06.27	HT	Over Voltage
400/220 kv 500 MVA ICT III @ Jejuri	IntraState	31/08/2020	02.06	31/08/2020	06.28	HT	Over Voltage
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	01/09/2020	00.48	01/09/2020	07.00	HT	Over Voltage
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Kharghar-Borivali ckt II	IntraState	11/08/2020	08.45		Continued.	T	Cable Faulty
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage arrangement HTLS work.
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage arrangement HTLS work.
Lonikand1 (400 Kv)-Theur I	IntraState	14/08/2020	10.38		Continued.	PO	Replacement of Existing 0.4 DEER Conductor, hardware & Insulator to HTLS Conductor.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower due to Railway crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower due to Railway

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 31/Aug/2020

Statement-VII

Position as on 6.30 Hrs of 01/Sep/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							crossing
Talandge(400kv)- Ichalkaranji ckt-1	IntraState	31/08/2020	09.38	31/08/2020	13.27	PO	Quarterly Maintenance Work
Talandge-Mudshingi Ckt-I	IntraState	31/08/2020	10.11	31/08/2020	19.31	PO	Quarterly Maintenance Work
New Koyna - Loteparshuram	IntraState	31/08/2020	10.44	31/08/2020	15.36	EO	Replacement of Insulator String & Attending Hot Spot.
Chinchwad-Hinjewadi I	IntraState	31/08/2020	16.17	31/08/2020	20.20	EO	Attending Hot Spot
Ghatghar - Jindal	IntraState	01/09/2020	12.32	01/09/2020	16.46	EO	Attending Hot Spot
Bhugaon- Wardha	IntraState	01/09/2020	12.45	01/09/2020	20.37	T	Distance Protection
Ghatghar - Bapgaon	IntraState	01/09/2020	13.09	01/09/2020	17.06	EO	Attending Hot Spot
Koradi-Ambazari-I	IntraState	01/09/2020	13.10		Continued.	T	Distance Protection
Topworth - Kharghar	IntraState	01/09/2020	13.40	01/09/2020	15.02	T	Distance Protection
Chikhli-Jalna-II	IntraState	01/09/2020	21.30	01/09/2020	22.11	T	R-PH BUS P.T.Burst of 220KV BUS Section 1.
Chikhli-Jalna-I	IntraState	01/09/2020	21.30	01/09/2020	22.10	T	R-PH BUS P.T.Burst of 220KV BUS Section 1.
Taptitanda- Jalna ckt- I	IntraState	01/09/2020	21.30	01/09/2020	22.29	T	R-PH BUS P.T.Burst of 220KV BUS Section 1.
Taptitanda-Jalna ckt II	IntraState	01/09/2020	21.30	01/09/2020	22.30	T	R-PH BUS P.T.Burst of 220KV BUS Section 1.
220 KV ICT Outages/Trippings							
220/132-110kv 200mva Ptr 1 @Oglewadi	IntraState	31/08/2020	10.04	31/08/2020	16.20	PO	Quarterly Maintainance Work
220/100 kV 200 MVA ICT-II @Kalwa	IntraState	01/09/2020	11.53		Continued.	EO	CTR Panel Checking.
220/132 Kv 200 Mva Emco Ict 2 @Ambazari	IntraState	01/09/2020	14.48	01/09/2020	15.22	PO	Main Tank PRV Details.
220/132 Kv 200mva Vijay Ict 2 @Jalna	IntraState	01/09/2020	21.30	01/09/2020	22.35	T	R-PH BUS P.T.Burst of 220KV BUS Section 1.
220/132 Kv 200mva Alstom Ict 1 @Jalna	IntraState	01/09/2020	21.30	01/09/2020	22.12	T	R-PH BUS P.T.Burst of 220KV BUS Section 1.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage