

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 31/Oct/2020 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	139.794	4153.173	1) Gujrat	0.323	46.120
2) Hydro	4.598	175.054	2) Madhya Pradesh	6.456	194.447
3) Gas	6.655	180.963	3) Chattisgarh	5.880	179.270
Total MSPGCL	151.047	4509.190	4) Maharashtra	111.495	3522.598
B) 1) APML	67.297	1920.022	5) Goa (Amona)	-1.357	-42.072
2) JSWEL	24.143	728.720	Total	122.797	3900.363
3) VIPL	0.000	0.000	a) Mumbai Schedule	17.354	625.532
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	24.611	703.134
5) WPCL	7.815	197.795	c) MSEDCL Bilateral *	29.966	965.301
6) Other IPP	10.243	267.391	Include PX	0.745	63.812
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	17.354	623.954
C) 1) TPCL Thermal	14.746	384.953	Include PX	5.608	226.338
2) TPCL Hydro	1.814	129.923	Standby	0.000	1.578
3) TPCL Gas	3.862	133.184	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.760	307.261	1) MSEDCL	368.447	11245.316
D) STATE			2) Mumbai Discoms	52.793	1658.452
1) Thermal	271.798	7959.315	TOTAL STATE	421.240	12903.768
(A1+C1+C4+(B1-B6))					
2) Hydro	6.412	304.977			
(A2+C2)					
3) Gas	10.517	314.147			
(A3+B7+C3)					
4) Wind	3.436	256.180			
6) SOLAR	6.280	168.789			
TOTAL STATE	298.443	9003.408			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6033	6028	6046	5352
MSPGCL Hydro	267	195	845	74
MSPGCL Gas	269	257	270	292
MSPGCL Total Generation	6569	6480	7161	5718
Central Sector Receipt	5567	5598	5164	4587
WIND	99	64	131	118
CPP / IPP Thermal	4936	4961	5190	3857
CPP / IPP Gas	0	0	0	0
SOLAR	824	456	0	0
Exchange with Mumbai	-1245	-1228	-1016	-831
MSEDCL DEMAND MET	16750	16331	16630	13449
Load Shedding	0	0	0	0
MSEDCL DEMAND	16750	16331	16630	13449
TPCL GENERATION	915	886	1058	661
AEML GENERATION	283	365	399	281
MUMBAI DEMAND	2443	2479	2473	1773
STATE DEMAND MET	19193	18810	19103	15222
STATE DEMAND	19193	18810	19103	15222
Frequency (Hz)	50.00	49.97	50.01	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.2 Hz at 18:01 Hrs	49.8 Hz at 17:43 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 31/Oct/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	12.48	306.83	590	335
Unit 9	0.00	233.11	0	0
Unit 10	9.10	260.20	420	371
Total	21.59	800.14		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.42	302.59	500	280
Unit 5	10.67	302.42	500	280
Total	21.10	605.01		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	4.68	115.73	245	165
Unit 7	0.00	77.44	0	0
Unit 8	0.00	126.04	0	0
Total	4.68	319.22		
Chandrapur				
Unit 3	4.07	54.62	176	158
Unit 4	3.81	97.46	162	149
Unit 5	9.16	288.87	415	325
Unit 6	10.05	276.35	425	410
Unit 7	0.00	0.00	0	0
Unit 8	11.44	323.80	495	450
Unit 9	11.64	322.97	496	470
Total	50.17	1364.07		
Paras				
Unit 3	5.92	151.44	254	235
Unit 4	5.88	156.05	252	228
Total	11.80	307.49		
Khaparkheda				
Unit 1	3.74	106.05	165	140
Unit 2	3.96	120.80	180	140
Unit 3	4.05	115.47	180	135
Unit 4	4.21	122.80	185	140
Unit 5	11.22	236.74	500	375
Total	27.18	701.87		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.29	55.38	156	127
Unit 5	0.00	0.00	0	0
Total	3.29	55.38		
Uran				
All Units	6.66	180.96	296	256
Total	6.66	180.96		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.25	16.35	54	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.25	16.35		
Koyna				
Stage 1-2	2.18	71.69	360	40
Stage 4	0.42	26.79	250	0
Stage 3	0.71	24.74	80	0
Total	3.30	123.22		
Hydro				
KDPH	0.00	5.06	0	0
VTRNA	0.00	0.49	0	0
TILLARI	0.00	4.42	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.16	9.53	40	0
RNGR+BHTSA	0.36	6.38	15	14
BHANDARDRA	0.00	1.30	0	0
ELDARY	0.36	12.16	16	15
SMLHY_PTN	0.00	4.80	0	0
GHATGHAR	0.42	7.69	125	0
Total	1.30	51.83		
Wind				
Total	3.44	256.18	0	0
Total	3.44	256.18		
CPP				
APML(Mus)	67.30	1920.02	0	0
JSWEL(Mus)	24.14	728.72	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	7.82	197.80	0	0
Other(Mus)	10.24	267.39	0	0
Total	109.50	3113.93		
SOLAR				
Total	6.28	168.79	0	0
Total	6.28	168.79		
Tata				
Trombay 5	9.56	287.86	447	278
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.40	86.01	117	71
Trombay 7B	1.46	47.18	67	52
Trombay 8	5.19	97.09	234	139
TATA Hydro	1.81	129.92	260	3
Total	20.42	648.06		
AEML				
DTPS U-1&2	7.76	307.26	500	250
Total	7.76	307.26		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	139.79	4153.17	MSPGCL Total	151.05	4509.19
			MSPGCL Thml+Gas	146.45	4334.14	Koyna 1,2 & 4 Total	2.59	98.48
			MSPGCL Hydro	4.60	175.05	State Total	298.44	9003.41

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 31/Oct/2020

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5385	79	271	5735	229	3855	0	0	4767	4766	-988	13597	0	13597	2138	15735	50.00
2	5297	69	292	5658	198	3858	0	0	4676	4603	-883	13434	0	13434	1997	15431	49.99
3	5360	79	282	5721	152	3868	0	0	4589	4607	-796	13552	0	13552	1874	15426	50.00
4	5352	74	292	5718	118	3857	0	0	4532	4587	-831	13449	0	13449	1773	15222	49.99
5	5670	131	282	6083	127	4039	0	0	4547	4666	-849	14066	0	14066	1734	15800	49.96
6	5953	75	293	6321	201	4551	0	0	4913	4811	-857	15027	0	15027	1744	16771	49.89
7	6022	85	283	6390	238	4971	0	12	5348	5109	-761	15959	0	15959	1782	17741	49.97
8	6031	85	283	6399	219	5162	0	178	5330	5414	-555	16817	0	16817	1852	18669	50.01
9	6053	126	292	6471	103	5157	0	440	5354	5365	-733	16803	0	16803	2031	18834	50.01
10	5943	155	280	6378	98	4982	0	711	5555	5285	-1101	16353	0	16353	2259	18612	50.01
11	6033	267	269	6569	99	4936	0	824	5511	5567	-1245	16750	0	16750	2443	19193	50.00
12	6031	130	267	6428	106	4772	0	951	5793	5688	-1323	16622	0	16622	2526	19148	50.00
13	6028	110	267	6405	80	4363	0	967	5795	5601	-1296	16120	0	16120	2501	18621	49.99
14	6032	170	256	6458	59	4062	0	827	5591	5767	-1240	15933	0	15933	2435	18368	49.99
15	6035	250	265	6550	46	4443	0	704	5687	5668	-1304	16107	0	16107	2455	18562	49.95
16	6028	195	257	6480	64	4961	0	456	5591	5598	-1228	16331	0	16331	2479	18810	49.97
17	6044	221	267	6532	79	5124	0	180	5235	5308	-1017	16206	0	16206	2470	18676	49.99
18	6042	372	279	6693	117	5186	0	30	5126	4852	-916	15962	0	15962	2419	18381	49.97
19	6046	845	270	7161	131	5190	0	0	5095	5164	-1016	16630	0	16630	2473	19103	50.01
20	5999	497	270	6766	160	5195	0	0	5354	4953	-1149	15925	0	15925	2457	18382	50.02
21	5877	150	283	6310	115	4627	0	0	5077	4897	-1215	14734	0	14734	2368	17102	50.02
22	5771	160	285	6216	167	4414	0	0	5134	4759	-1157	14399	0	14399	2254	16653	50.03
23	5641	165	274	6080	236	4034	0	0	5021	4856	-1089	14117	0	14117	2180	16297	50.02
24	5121	108	296	5525	294	3891	0	0	5049	4906	-1062	13554	0	13554	2149	15703	50.01
MUs	139.79	4.60	6.65	151.05	3.44	109.50	0.00	6.28	124.67	122.80	-24.61	368.45	0.00	368.45	52.79	421.24	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 31/Oct/2020

Position as on 6.30 Hrs of 01/Nov/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Chandrapur Unit 7	500	29/09/2020	01.58		Continued.	Tripped On Generator Protection.	
MSPGCL	Ghatghar Unit-1	125	30/09/2020	18.05		Continued.	Turbine Guide Bearing problem	
MSPGCL	Parli Unit 7	250	22/10/2020	20.00		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Koradi Unit 9	660	29/10/2020	02.15		Continued.	Boiler Tube Leakage	
MSPGCL	Parli Unit 8	250	30/10/2020	21.55		Continued.	Boiler Tube Leakage	
AEML	AEML Unit 2	250	31/10/2020	18.47		Continued.	Milling system problems	
IPP	JSW (J) U2	300	01/11/2020	04.44		Continued.	No Schedule	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 31/Oct/2020

Statement-VII

Position as on 6.30 Hrs of 01/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	19/10/2020	23.01		Continued.	PO	Abnormal sound from main tank of smoothing reactor.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	30/10/2020	10.12	31/10/2020	10.40	PO	Replacement of earth wire (RFC 15:40hrs Over voltage)
Dhule Sar'Sarovar I	InterState	31/10/2020	18.09		Continued.	HT	Over Voltage
Waluj Aurangabad(PG) II	InterState	01/11/2020	23.12		Continued.	EO	Safety purpose.
Karad - Jaigad - II	IntraState	16/09/2020	23.34		Continued.	HT	Over Voltage (Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Jaigad-Karad Ckt-I	IntraState	27/09/2020	18.59		Continued.	T	Distance Protection(Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Khadka-Aurangabad (Waluj)	IntraState	30/10/2020	19.57	31/10/2020	08.04	HT	Over Voltage
Dhule- Bableshtar - I	IntraState	31/10/2020	11.03	01/11/2020	12.03	EO	LA Replacement Work.
Khadka-Aurangabad (Waluj)	IntraState	31/10/2020	18.13	01/11/2020	11.40	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	31/10/2020	23.25	01/11/2020	10.07	HT	Over Voltage
Kalwa - Talegaon(PG)	IntraState	01/11/2020	05.49	01/11/2020	09.52	EO	To attend Hot Spot at Loc.No.33
Khadka-Aurangabad (Waluj)	IntraState	01/11/2020	19.21		Continued.	HT	Over Voltage
Dhule- Bableshtar - I	IntraState	01/11/2020	20.12		Continued.	HT	Over Voltage
Pune(GIS)-A'bad(Waluj) Ckt 1	IntraState	01/11/2020	22.47		Continued.	EO	Attending Hot Spot
Lonikand I - Koyna stage-IV	IntraState	01/11/2020	23.18		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/09/2020	09.58		Continued.	PO	Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	30/10/2020	08.12	31/10/2020	02.12	PO	Bushing replacement of HV & LV sidw.
400/220KV 315MVA ICT-I@bhusawal(khadka)	IntraState	31/10/2020	11.31	31/10/2020	14.16	EO	Attending Hot Spot
400/220/33 315MVA ICT-III @ KHADKA	IntraState	31/10/2020	11.31	31/10/2020	14.16	EO	To attend Hot Spot
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	01/11/2020	03.34		Continued.	T	Differential protection
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Kharghar-Borivali ckt II	IntraState	11/08/2020	01.45		Continued.	T	Special Repair Cable work.
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage Arrangement HTLS Work.
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage Arrangement HTLS Work.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
Lonikand1 (400 Kv)-Theur II	IntraState	06/10/2020	08.54		Continued.	PO	HTLS Stringing work
MAHAPE - RELIANCE GIS	IntraState	31/10/2020	09.02	31/10/2020	12.07	PO	Tan Delta Measurment of CTs
Kalwa Salsette III	IntraState	31/10/2020	09.09	31/10/2020	15.02	PO	Replacement of spring charging Motor B Phase Pole
Trombay Dharavi 6	IntraState	31/10/2020	09.47	31/10/2020	17.59	PO	Work in Vicinity

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 31/Oct/2020

Statement-VII

Position as on 6.30 Hrs of 01/Nov/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Talandge-Hamidwada	IntraState	31/10/2020	09.52	31/10/2020	15.24	PO	Replacement of Flashover Insulator
Boisar-Viraj	IntraState	31/10/2020	09.53	31/10/2020	19.25	PO	Testing Work
MALEGAON - KALWAN CKT-1	IntraState	31/10/2020	10.01	31/10/2020	18.10	EO	To attend Hot Spot
Centuri Enka- Bhosari	IntraState	31/10/2020	10.18	31/10/2020	18.10	PO	Tan Delta Measurment of CTs
Infosys - Hinjawadi 1	IntraState	31/10/2020	10.34	31/10/2020	17.41	PO	Half yearly maintenance work
Khadka-Chalisgaon-1	IntraState	31/10/2020	11.20	31/10/2020	14.36	PO	Load Manage.
Apta - Kalwa1	IntraState	31/10/2020	11.47	31/10/2020	13.13	PO	Providing of additional Jumper at Cut Point
Vita - Mhaishal	IntraState	31/10/2020	12.18	31/10/2020	14.25	PO	Tan Delta Measurment of CTs
Miraj - Mhaishal	IntraState	31/10/2020	14.32	31/10/2020	15.47	PO	Tan Delta Measurment of CTs
Urse-Chinchwad (ST tap)	IntraState	01/11/2020	08.54	01/11/2020	19.25	HT	B-Ph CT burst.
Sonkhar - Trombay	IntraState	01/11/2020	10.09	01/11/2020	17.04	PO	Diagnostic testing work.
BHIRA (T) - KARANJADE CKT - 7	IntraState	01/11/2020	10.26	01/11/2020	17.14	PO	Vicinity Emergency clearance 5 mins.
Theur- Magar Patta City	IntraState	01/11/2020	10.45	01/11/2020	18.45	PO	Dismantling of old conductor, hardware & Stringing of HTLS Drake conductor between span of L.N.33 to 38-Y Ph, 38 To 38A of 220kv Theur Lonikand Ckt 2.
GIS Bhandup - Borivali	IntraState	01/11/2020	10.48	01/11/2020	17.09	PO	Attending Hot Spot at Cable Termination Tower.
Padgha - Temghar I	IntraState	01/11/2020	10.50	01/11/2020	14.20	PO	Diagnostic Testing Work.
NERUL - SEAWOOD CABLE CKT - 1	IntraState	01/11/2020	12.02	01/11/2020	13.00	EO	Emergency AMR Work.
NERUL - SEAWOOD CABLE CKT - 2	IntraState	01/11/2020	13.01	01/11/2020	15.07	EO	Emergency AMR Work.
Padgha-Temghar-II	IntraState	01/11/2020	15.10	01/11/2020	18.32	PO	Diagnostic Testing Work
220 KV ICT Outages/Trippings							
220/22KV 100MVA T/F 4 @Mulund	IntraState	31/10/2020	06.06	31/10/2020	11.06	PO	CT,Bushing and winding tan-d test
100 MVA T/F I @ Oglewadi	IntraState	31/10/2020	09.21	31/10/2020	17.40	PO	Quarterly Maintenance Work
220/132 Kv 100mva Cgl Ptr No 6 @Chinchwad	IntraState	31/10/2020	10.03	31/10/2020	18.20	PO	Testing Work
220/132kv 100mva lct 1 @Peth	IntraState	31/10/2020	10.22	31/10/2020	15.15	PO	Quarterly Maintenance Work
220/132 kv 200MVA ICT II @ Girwali	IntraState	31/10/2020	11.31	31/10/2020	17.02	PO	Testing Work
220/132kv 100 Mva lct 2 @Peth	IntraState	31/10/2020	12.58	31/10/2020	17.49	PO	Quarterly Maintenance Work
Salsette : 220 / 110 / 22 250 MVA ICT 2	IntraState	01/11/2020	10.17		Continued.	PO	Attending bushing oil leakage.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage