

Maharashtra Renewable (Wind and Solar) Curtailment Details for the month of February-2025						
Sr. No.	Date	Wind Curtailment		Solar Curtailment		Reason for Curtailment
		Max MW	Energy (MU)	Max MW	Energy (MU)	
1	01-02-2025	NIL	NIL	NIL	NIL	
2	02-02-2025	NIL	NIL	8.83	0.015	Overloading of 132KV Naldurg Bale line . O/C Setting 540 Amp for 2 Sec
3	03-02-2025	NIL	NIL	13.08	0.032	Overloading of 132KV Naldurg Bale line . O/C Setting 540 Amp for 2 Sec
4	04-02-2025	NIL	NIL	15.23	0.02	Overloading of 132KV Naldurg Bale line . O/C Setting 540 Amp for 2 Sec
5	05-02-2025	NIL	NIL	75.28	0.15	Tripping of 132 kV Bale South Solapur line on overload, Overloading of 132 kV Wagdari Naldurg line
6	06-02-2025	NIL	NIL	116.00	0.32	Tripping of 132 kV Bale - South Solapur line on overload, Overloading of 132 kV Wagdari Naldurg line
7	07-02-2025	NIL	NIL	81.34	0.42	Tripping of 132 kV Bale South Solapur line on overload, Overloading of 132 kV Wagdari Naldurg line
8	08-02-2025	NIL	NIL	28.70	0.16	Tripping of 132 kV Bale - South Solapur line on overload, Overloading of 132 kV Wagdari Naldurg line
9	09-02-2025	NIL	NIL	111.48	0.48	1)Tripping of 132 kV Bale - South Solapur line on overload, Overloading of 132 kV Wagdari Naldurg line. 2)Overloading of 132KV Naldurg Bale line . O/C Setting 540 Amp for 2 Sec
10	10-02-2025	NIL	NIL	113.97	0.47	1)Tripping of 132 kV Bale - South Solapur line on overload, Overloading of 132 kV Wagdari Naldurg line. 2)Overloading of 132KV Naldurg Bale line . O/C Setting 540 Amp for 2 Sec
11	11-02-2025	NIL	NIL	127.20	0.70	Tripping of 132 kV Bale - South Solapur line on overload, Overloading of 132 kV Wagdari Naldurg line. Overloading of 132 kV Akkalkot Karajgi line.Increased loading on 132KV Wagdari Akkalkot ckt-1 and 132KV Wagdari Akkalkot ckt-2,
12	12-02-2025	NIL	NIL	70.08	0.20	Overloading of 132 kV Bale South Solapur line , Overloading of 132 kV Wagdari Naldurg line, Tripping of 132 kV Bale South Solapur line on overload, GTS Operated
13	13-02-2025	NIL	NIL	67.02	0.17	Overloading of 132 kV Bale South Solapur line , Overloading of 132 kV Wagdari Naldurg line
14	14-02-2025	NIL	NIL	95.04	0.49	Overloading of 132 kV Bale South Solapur line , Overloading of 132 kV Wagdari Naldurg line
15	15-02-2025	NIL	NIL	42.76	0.14	Overloading of 132 kV Bale South Solapur line , Overloading of 132 kV Wagdari Naldurg line, Overloading of 132 kV Wagdari Naldurg line
16	16-02-2025	NIL	NIL	121.47	0.47	Tripping of 132 kV Bale South Solapur & 132 kV Wagdari Naldurg line Overloaded, Increased loading on 132KV Naldurg-Wagdari Line Over 570 Amp, Overloading of 132 kV Naldurg Bale line upto 540Amp & GTS operation at 132KV Naldurg SS
17	17-02-2025	NIL	NIL	68.44	0.39	Tripping of 132 kV Bale South Solapur & 132 kV Wagdari Naldurg line Overloaded, Overloading of 132 kV Naldurg Bale line upto 540Amp & GTS operation at 132KV Naldurg SS
18	18-02-2025	NIL	NIL	94.35	0.38	Overloading of 132 kV Bale South Solapur line , Overloading of 132 kV Wagdari Naldurg line , tripping of 132 kV Bale South Solapur line, Overloading of 132 kV Naldurg Bale line upto 540Amp & GTS operation at 132KV Naldurg SS
19	19-02-2025	NIL	NIL	80.44	0.34	Overloading Trip of 132 kV Bale South Solapur line , Overloading of 132 kV Wagdari Naldurg line,
20	20-02-2025	NIL	NIL	118	0.47	Increased loading on 132KV Naldurg-Wagdari Line Over 570 Amp, tripping of 132 kV Bale South Solapur line, Overloading of 132 kV Naldurg Bale line upto 540Amp & GTS operation at 132KV Naldurg SS,
21	21-02-2025	NIL	NIL	NIL	NIL	
22	22-02-2025	NIL	NIL	NIL	NIL	
23	23-02-2025	NIL	NIL	NIL	NIL	
24	24-02-2025	NIL	NIL	NIL	NIL	
25	25-02-2025	NIL	NIL	NIL	NIL	
26	26-02-2025	NIL	NIL	NIL	NIL	
27	27-02-2025	NIL	NIL	NIL	NIL	
28	28-02-2025	NIL	NIL	NIL	NIL	