

Outages list for the month of MARCH/2023 finalized in MOCM															
MOC No.	Voltage (kV)	Substation/Division	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOCM Remark	MOCM Status
1	220		220 KV Kalwa-Panchanand	01-03-2023	22:00	03-03-2023	5:00	Continuous	For erection of Termination Kit	MSETCL	Kalwa Circle		MOCM	kalwa interconnector to be closed	A
2	220		220 KV Kalwa-Panchanand	01-03-2023	22:00	03-03-2023	5:00	Continuous	For erection of Termination Kit	MSETCL	EHV O&M Circle Panvel		MOCM	kalwa interconnector to be closed	A
3	110	Bhira	25 MW Unit 2 with Bkr	01-03-2023	6:00	10-03-2023	10:00	Continuous	Generator cryogenic cleaning & O/H	Tata power	Tata power	Hydro Generation Available 437 MW. Outage will be taken instead of Approved bhivpuri unit-11 outage	MOCM	All other hydro Gen. to be available. (11 days outage)	A
4	220		220 KV Kalwa Trombay Line	01-03-2023	8:00	03-03-2023	18:00	Daily	Auto Redose function is to be kept out of service during replacement of OPGW between loc. No. 10 to 14	MSETCL	Kalwa Circle	M/s MTCL will carry out OPGW replacement work.	MOCM	AR only (subject to system condition on D-1 basis)	A
5	220		220 KV Kalwa Mulund 2 Line	01-03-2023	8:00	05-03-2023	18:00	Daily	Auto Redose function is to be kept out of service during replacement of OPGW between loc. No. 10 to Mulund gantry	MSETCL	Kalwa Circle	M/s MTCL will carry out OPGW replacement work.	MOCM	AR only (subject to system condition on D-1 basis)	A
6	220		220 KV TROMBAY - CHEMBUR LINE	01-03-2023	8:00	20-03-2023	18:00	Daily	Auto Redose function is to be kept out of service during installation of OPGW between loc. No. 720 to Trombay gantry	MSETCL	Kalwa Circle	M/s MTCL will carry out OPGW replacement work.	MOCM	AR only (subject to system condition on D-1 basis)	A
7	220		220 KV SONKHAR - TROMBAY LINE	01-03-2023	8:00	30-03-2023	18:00	Daily	Auto Redose function is to be kept out of service during installation of OPGW between loc. No. 699 to Trombay gantry	MSETCL	Kalwa Circle	M/s MTCL will carry out OPGW replacement work.	MOCM	AR only (subject to system condition on D-1 basis)	A
8	220V Reliance GIS Substation	220KV Reliance GIS-Mahape Line Bay		01-03-2023	11:00	01-03-2023	18:00	Daily	Annual Relay Testing work.	MSETCL	Kalwa Circle	220KV Siemens-Reliance GIS Line will be in service	MOCM	NOC of consumers required.	A
9	110	Khopoli	24 MW Unit 7 with Bkr	01-03-2023	22:00	02-03-2023	6:00	Continuous	Routine maintenance & Testing	Tata power	Tata power	Hydro Generation Available 438 MW.	MOCM	All other hydro Gen. to be available.	A
10	220		220KV Trombay Dharavi # 9	01-03-2023	22:00	06-03-2023	6:00	Daily	Third Party Work - Diversion of Line at Sejal Shakti Project site	Tata power	Tata power	220KV Trombay Dharavi-5, 6 & Waghvadi Dharavi -7 & 8 in service.	MOCM	All other lines to dharavi to be in service.	A
11	400		KALWA - TALEGAON (PG)	01-03-2023	9:00	01-03-2023	18:00	Daily	PID Testing of Insulators Auto-Redose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Redose function to be out of service.	OCC	Subject to approval of WRDC	A
12	110		110KV Waghvadi-Mankhurd Line	02-03-2023	0:00	02-03-2023	6:00	Daily	Project Work - Working in vicinity of line for tower foundation work in Vashi creek	Tata power	Tata power	Line to be kept open and isolated at both ends. Emergency clearance - 15 Min.	MOCM	All other hydro lines to be in service.	A
13	220KV Trombay substation	220/100KV 200MVA ICT-2		02-03-2023	9:00	02-03-2023	18:00	Daily	For 1) Addition of Off Delay timer in cooling pump circuit and AHC work of NPPS 2) Oil leakage from neutral bushing stud and 3) O&M Work	MSETCL	Kalwa Circle		MOCM	TATA NOC required.	A
14	220	220KV Uran	220 KV TBC	02-03-2023	9:00	02-03-2023	18:00	Daily	Insulator Replacement & Diagnostic Testing	MSETCL	EHV O&M Circle Panvel		MOCM	TBC to be free	A
15	110		110KV Kalyan Kalwa Salsette 1 Line	02-03-2023	10:00	02-03-2023	15:00	Daily	Loop Open & Coil back at loc. 43 towards salsette side (After Loop open Line will be go in service between Kalwa & Kalyan) Work for Metro 4 section between Kalwa & Salsette will remain out till 31.03.2023	Tata power	Tata power	110KV Kalwa salsette-1 & 2 line will remain in service between Kalwa & Kalyan.	MOCM	All other hydro lines to be in service.	A
16	220V Siemens Substation	220KV Siemens-Reliance GIS Line Bay		02-03-2023	11:00	02-03-2023	18:00	Daily	Annual Relay Testing work.	MSETCL	Kalwa Circle	220KV Kalwa-Siemens Line will be in service	MOCM	EHV consumer NOC required.	A
17	220	Salsette	220KV Bus#1	02-03-2023	23:00	03-03-2023	7:00	Continuous	Project Activity: 220KV Kalwa-Salsette # 5 bay installation	Tata power	Tata power	All equipment remain in service on 220KV Bus-2	MOCM	All equipment remain in service on 220KV Bus-2	A
18	400		KALWA - TALEGAON (PG)	02-03-2023	9:00	02-03-2023	18:00	Daily	PID Testing of Insulators Auto-Redose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Redose function to be out of service.	OCC	Subject to approval of WRDC	A
19	400V Padghe	220KV Bus 2		02-03-2023	12:00	03-03-2023	12:00	Daily	Hybrid Pass work		Padghe circle			All elements to be in service through Bus 1	A
20	220V uran	220kv Main Bus 2		03-03-2023	9:00	05-03-2023	18:00	Daily	Insulator Replacement	MSETCL	EHV O&M Circle Panvel		MOCM	All elements to be in service through Bus 1	A
21	400		PADGHE - KALWA CKT - 2	03-03-2023	22:00	06-03-2023	6:00	Continuous	To complete Balance work of replacement of existing Conductor. Hardware. Insulators by equivalent HTLS Conductor. Hardware	MSETCL	Kalwa Circle	To complete Balance work of replacement of existing Conductor. Hardware. Insulators by equivalent HTLS Conductor. Hardware	OCC	Subject to approval of WRDC	A
22	220	Trombay	220/100KV 200MVA ICT-3	03-03-2023	8:00	03-03-2023	17:00	Daily	For diagnostic testing of equipments & Bay maintenance work	MSETCL	Kalwa Circle		MOCM	TATA NOC required.	A
23	220		220kv Uran- Apta 4	03-03-2023	9:00	03-03-2023	18:00	Daily	Insulator Replacement & Diagnostic Testing	MSETCL	EHV O&M Circle Panvel		MOCM	All other lines to uran to be in service.	A
24	400V Padghe	315MVA ICT-4		03-03-2023	9:00	03-03-2023	21:30	Daily	1) MTAMC work 2) Bay Maint work 3) Diagnostic Testing work 4) Oil leakage attending work if any	MSETCL	Padghe	1) Weather condition should be clear	MOCM	Subject to real time loading condition.	A
25	220	220KV Roma - Bhavghar Line		03-03-2023	10:00	03-03-2023	17:00	Daily	Outage required for insulator cleaning work	MSETCL	Kalwa Circle		MOCM	Deferred due to kolshet bus section	D
26	220	Kolshet	220KV Bus-2 along with 1) 220KV Kharbaao TSS line. 2) 200MVA 220/100KV ICT-2, 3) 220KV Bus-PT-2 4) 220KV Bus section & 5) 50MVA TF no-3,220/220KV	03-03-2023	10:00	03-03-2023	18:00	Daily	1) CTR system reinstallation & commissioning work of 200 MVA, 220/100 KV ICT no-2 2) POR problem attending work for 220 KV Kharbaao-TSS Line. 3) Isolator servicing and alignment. 4) 220kv Bus maintenance. 5) 220kv Bay maintenance 6) Isolator jaw and gear box replacement. 7) Painting work. RMW	MSETCL	Kalwa Circle		MOCM	Kharbaao TSS NOC required.	A
27	220	220KV Siemens Substation	220KV Siemens-Kalwa Line Bay	03-03-2023	11:00	03-03-2023	18:00	Daily	Annual Relay Testing work.	MSETCL	Kalwa Circle	220KV Reliance GIS-Siemens Line will be in service	MOCM	EHV consumer NOC required.	A
28	220		220KV Bus#2	03-03-2023	23:00	04-03-2023	7:00	Continuous	Project Activity: 220KV Kalwa-Salsette # 5 bay installation	Tata power	Tata power	All equipment remain in service on 220KV Bus-1	MOCM	All equipment remain in service on 220KV Bus-1	A
29	220		BOISAR II - BOISAR (PG) CKT - 1	03-03-2023	7:00	03-03-2023	17:00	Daily	Bay Maintenance Work at 220KV Boisar-II S/s	MSETCL	Kalwa Circle	Bay Maintenance Work at 220KV Boisar-II S/s	OCC	Subject to approval of WRDC	A
30	400		KALWA - TALEGAON (PG)	03-03-2023	9:00	03-03-2023	18:00	Daily	PID Testing of Insulators Auto-Redose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Redose function to be out of service.	OCC	Subject to approval of WRDC	A
31	220	220KV Boisar-II	220KV Boisar - Viraj Line	03-03-2023	14:00	03-03-2023	15:00	Daily	Control & relay panel 220VDC Supply shifting from old charger to new DCDB.	AEML-T	Kalwa Circle		MOCM	Viraj NOC required.	A
32	220		220 KV Apta Uran 2	04-03-2023	9:00	04-03-2023	18:00	Daily	Insulator Replacement & Bay Maintenance Work and C & Tan-Delta Testing and Routine Maint. Work of Lines S/Dn	MSETCL	EHV O&M Circle Panvel		MOCM	All other lines to uran to be in service.	A
33	220	Sonkhar SS	220 KV Sonkhar Trombay Line	04-03-2023	8:00	04-03-2023	17:00	Daily	Diagnostic testing work & RM work of Trombay line bay	MSETCL	Kalwa Circle		MOCM	will be considered if kalwa padghe ckt 2 not availd	A
34	220		220 KV Mulund - Trombay Line	04-03-2023	8:00	31-03-2023	18:00	Daily	Auto Redose function is to be kept out of service during replacement of OPGW between Mulund gantry to Trombay gantry	MSETCL	Kalwa Circle	M/s MTCL will carry out OPGW replacement work.	MOCM	AR out (approved on D-1 basis system condition.	A
35	220	400KV Kharghar	220KV Kharghar - Sonkhar	04-03-2023	8:30	04-03-2023	18:00	Daily	For Bay strengthening Work & Routine Maintenance Work	MSETCL	EHV O&M Circle Panvel		MOCM	approved	A
36	220		220 KV Salsette - Sahar line	04-03-2023	9:00	04-03-2023	16:00	Daily	Tree Trimming	Tata power	Tata power	Emergency clearance- 20 Mins 220KV Saki Sahar cable will remain in service	MOCM	220KV Saki Sahar cable to be in remain in service	A
37	220	220KV Boisar-II	220KV Boisar - Borivali Line	04-03-2023	11:00	04-03-2023	17:00	Daily	1) To attend damaged conductor b/w loc. No. 240-241 by fixing repair sleeve by Line Maint.	MSETCL	Kalwa Circle		MOCM	Deferred due to kharghar sonkhar.	A
38	220		220 KV Ghodbandar-Boisar Line	04-03-2023	11:00	04-03-2023	17:00	Daily	1) For safety purpose during maintenance work on 220 KV Borivali-Boisar line b/w loc. No. 240-241 2) Also at 220KV Boisar S/s work of Control & relay panel 220VDC Supply shifting from old charger to new DCDB will be carried out between 11:00 hrs to 12:00 hrs	MSETCL	Kalwa Circle	Safety outage required due to multi circuit configuration	MOCM	All lines at boisar and ghodbandar to be in service.	A
39	110	Ambernath	110KV BS 3,4,5,6 Outage	04-03-2023	22:00	05-03-2023	6:00	Continuous	RM & Protection testing	Tata power	Tata power	Emergency clearance- 30 Mins 110KV Bhivpuri Ambarnath-1 & Ambarnath Kalyan-2 will remain charge from remote end.	MOCM	will be considered if 400KV kalwa bus outage not availd.	A
40	400		MAIN BUS - 1 @ KALWA	04-03-2023	0:02	05-03-2023	23:59	Continuous	Strengthening of 400KV Padghe-II bay at 400KV RS Kalwa by replacement of existing 0.5ACSR Shub Bus conductor of 400 KV Kalwa-Padghe-II line by HTLS conductor at 400KV RS Kalwa S/s by availing the Partial Outage on 400KV A-Bus as follows: 1) Shifting of Partial 400KV A-Bus element (500MVA, 400/22KV ICT-1 & 4, 400KV Kalwa-Kharghar Line to B-Bus through TBC and hand tripping the Bus-coupler) to B-Bus 2) Removing of Quadra A bus jumper (R,Y & B ph) as A bus dead. Near TBC & Padghe I gantry. 3) SHIFTING OF 400 KV ELEMENTS (400KV Padghe-1, 500MVA ICT-1 & 4 and closing of Bus Coupler CB) FROM B BUS TO A BUS 4) Stringing of HTLS conductor in Shub bus of 400 KV Padghe I line 5) Shifting of following elements on A bus to B bus to make A-Bus dead again, 400KV Busbar-1	MSETCL	Kalwa Circle		OCC	either 400KV Kalwa bus or Boisar - Boisar PG 2 readiness to be submitted	A
41	220		BOISAR II - BOISAR (PG) CKT - 2	04-03-2023	7:00	04-03-2023	17:00	Daily	Bay Maintenance Work	MSETCL	Kalwa Circle	Bay Maintenance Work	OCC	either 400KV Kalwa bus or Boisar - Boisar PG 2 readiness to be submitted	A
42	400		KALWA - TALEGAON (PG)	04-03-2023	9:00	04-03-2023	18:00	Daily	PID Testing of Insulators Auto-Redose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Redose function to be out of service.	OCC	Subject to approval of WRDC	A

MOC No.	Voltage (kV)	Substation	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.	Type	MOCM Remark	MOCM Status
1	220		220 KV Kalwa-Panchanand	01-03-2023	22:00	03-03-2023	5:00	Continuous	For erection of Termination Kit	MSETCL	Kalwa Circle		MOCM	kalwa interconnector to be closed	A
43	110	Bhivpuri	Bhivpuri Unit 10	04-03-2023	8:00	04-03-2023	18:30	Daily	RM	Tata power	Tata power	Emergency clearance 15 Mins. (Hydro generation available 413MW)	MOCM	All other generation to be available.	A
44	110		110KV Waghival-Mankhurd Line	05-03-2023	0:00	05-03-2023	6:00	Daily	Project Work- Working in vicinity of line for tower foundation work in Vashi creek	Tata power	Tata power	Line to be kept open and isolated at both ends. Emergency clearance - 15 Min.	MOCM	All other hydro lines to be in service	A
45	220	400KV Kharghar	220KV Buscoupler	05-03-2023	8:30	05-03-2023	18:00	Daily	For Bay strengthening Work & Routine Maintenance Work	MSETCL	EHV O&M Circle Panel		MOCM	will be considered if 400KV Kalwa bus coupler or boiler PG ckt 3 outage not availed.	under review
46	220	220KV Vasa	100 MVA, 220/100 KV, ICT-2	05-03-2023	9:00	05-03-2023	13:00	Daily	Diagnostic Testing and Bay maintenance work	MSETCL	Kalwa Circle		MOCM	Load to be managed on other ICTs	A
47	220	400 KV Kalwa	220 KV kalwa - Interconnector	05-03-2023	9:00	05-03-2023	18:00	Daily	Diagnostic Testing & Bay Maintenance work.	MSETCL	Kalwa Circle		MOCM	will be considered if 400KV Kalwa bus coupler or boiler PG ckt 3 outage not availed.	under review
48	220	Borivali SS	220 KV Borivali - Kalwa Line	05-03-2023	10:00	05-03-2023	18:00	Daily	For Annual Diagnostic Tests and R&M Work	MSETCL	Kalwa Circle		MOCM	will be considered if 400KV Kalwa bus coupler or boiler PG ckt 3 outage not availed.	under review
49	220	Trombay B	220KV Tie-1 M5EB end Breaker	05-03-2023	10:00	05-03-2023	19:00	Daily	To identify SF6 gas leakage at MSETCL end Breaker	Tata power	Tata power	Emergency clearance - 30 Mins	MOCM	will be considered if 400KV Kalwa bus coupler or boiler PG ckt 3 outage not availed.	under review
50	220	220KV Vasa	100 MVA, 220/100 KV, ICT-1	05-03-2023	14:00	05-03-2023	18:00	Daily	Diagnostic Testing and Bay maintenance work	MSETCL	Kalwa Circle		MOCM	Load to be managed on other ICTs	A
51	220		BOISAR II - BOISAR (PG) CKT - 3	05-03-2023	7:00	05-03-2023	17:00	Daily	Bay Maintenance Work & Line Maintenance Work	MSETCL	Kalwa Circle	Bay Maintenance Work & Line Maintenance Work	OCC	either kalwa bus coupler or boiler-Boiler PG ckt 3 readiness to be done	under review
52	400		BUS COUPLER @ KALWA	05-03-2023	9:00	05-03-2023	18:00	Daily	Bay maintenance work & Diagnostic Testing work	MSETCL	Kalwa Circle	Bay maintenance work & Diagnostic Testing work.	OCC	either kalwa bus coupler or boiler-Boiler PG ckt 3 readiness to be done	under review
53	400		KALWA - TALEGAON (PG)	05-03-2023	9:00	05-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	subject to approval of WRILDC	A
54	220	Trombay B	220KV Bus Sec 3 Breaker	06-03-2023	8:00	10-03-2023	19:00	Continuous	Breaker Replacement	Tata power	Tata power		MOCM	Load to be managed on bus section 4	A
55	220	Bhira	220KV Bus 2	06-03-2023	6:00	06-03-2023	18:00	Daily	RM & Protection testing	Tata power	Tata power	All equipment remain in service through Bus coupler.	MOCM	All equipment remain in service through Bus coupler.	A
56	220	Colourchem	220 Kv TBC bay	06-03-2023	8:00	06-03-2023	19:00	Daily	Annual Diagnostics	MSETCL	Kalwa Circle		MOCM	TBC to be free	A
57	220		220 KV Kalwa Trombay Line	06-03-2023	8:00	31-03-2023	18:00	Daily	Auto Reclose function is to be kept out of service during replacement of OPGW between Loc. No. 14 to Trombay gantry	MSETCL	Kalwa Circle	Mts MTCL will carry out OPGW replacement work.	MOCM	AR only (will be approved on D-1 basis as per other outages in this corridor)	A
58	220		220 kv Kharghar-Panel TSS line	06-03-2023	9:00	09-03-2023	18:00	Continuous	For erection of MDN+12 Mtr tower For MRVCL	MSETCL	EHV O&M Circle Panel		MOCM	Panel TSS NOC required.	A
59	220	Borivali SS	220 KV Borivali - Tata 5 Line	06-03-2023	10:00	06-03-2023	18:00	Daily	For Annual Diagnostic Tests and R&M Work	MSETCL	Kalwa Circle		MOCM	TATA NOC required.	A
60	220	Sailette	220KV Bus#1	06-03-2023	23:00	07-03-2023	7:00	Continuous	Project Activity, 220KV Kalwa-Sailette # 5 bay installation	Tata power	Tata power	All equipment remain in service on 220KV Bus-2	MOCM	All equipment remain in service on 220KV Bus-2	A
61	400		MAIN BAY (403) OF FUTURE LINE @ KUDUS	06-03-2023	7:00	06-03-2023	19:00	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	MSETCL	Kalwa Circle	Annual Maintenance of bays equipment & Diagnostics Testing Work	OCC	subject to approval of WRILDC	A
62	400		KALWA - TALEGAON (PG)	06-03-2023	9:00	06-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
63	220		220 KV Kalwa-Baggaon	07-03-2023	8:00	08-03-2023	21:00	Continuous	For Erection of CTT Monopole	MSETCL	EHV Project Division Kalwa		MOCM	Temprary bunching arrangement to be done between AKP-Baggaon Nashik	A
64	220		220 KV AKP-- Eklahare (GCR) Nashik	07-03-2023	8:00	08-03-2023	21:00	Continuous	For Erection of CTT Monopole(safety Purpose)	MSETCL	EHV Project Division Kalwa		MOCM	Temprary bunching arrangement to be done between AKP-Baggaon Nashik	A
65	220	Sailette	220KV Bus#2	07-03-2023	23:00	08-03-2023	7:00	Continuous	Project Activity, 220KV Kalwa-Sailette # 5 bay installation	Tata power	Tata power	All equipment remain in service on 220KV Bus-1	MOCM	All equipment remain in service on 220KV Bus-1	A
66	400		KALWA - TALEGAON (PG)	07-03-2023	9:00	07-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
67	110	Bhira	110KV Bhira Khopoli # 2 line	08-03-2023	6:00	08-03-2023	16:00	Daily	Attending to Hot spot on line side isolator at Bhira	Tata power	Tata power	Emergency clearance - 45 Mins	MOCM	All other hydro lines to be in service	A
68	220	Ghodbunder	Bus Sectionalizer-1 (GIS Bay No.11)	08-03-2023	8:00	08-03-2023	17:00	Daily	Annual Maintenance of Bay equipments	AEML-T	AEML-T		MOCM	All elements to be in service through Each bus	A
69	220	Aarey	Aarey - Goregaon Line-2 on TBC	08-03-2023	9:00	08-03-2023	17:00	Daily	Annual Maintenance of Circuit Breaker	AEML-T	AEML-T	Line will be in service through TBC	MOCM	Line will be in service through TBC	A
70	110	Trombay A	ICT 5	08-03-2023	9:00	08-03-2023	19:00	Daily	110KV Ring bus 3 outage	Tata power	Tata power	ICT 2,3,4 are in service	MOCM	Load to be managed on other ICTs	A
71	220	Trombay B	220KV Trombay Sailette-1 Breaker	08-03-2023	9:00	13-03-2023	19:00	Continuous	Breaker Replacement work at Trombay end	Tata power	Tata power	Line will be controlled by Transfer Breaker.	MOCM	Line to be in service through TBC	A
72	220	Trombay B	220KV Trombay Antop Hill-2 Bay	08-03-2023	16:00	08-03-2023	20:00	Daily	Work in vicinity of 220KV Trombay Sailette-1 Breaker Replacement work.	Tata power	Tata power	Emergency clearance- 15 min	MOCM	Load to be managed on ckt 1	A
73	220		220 kv Kharghar Topworth line	08-03-2023	18:00	11-03-2023	18:00	Continuous	For erection of DO+6 Mtr tower inline For MRVCL	MSETCL	EHV O&M Circle Panel		MOCM	topworth, GPR, MSL NOC required.	A
74	220	BORIVALI - TARAPUR		08-03-2023	7:00	08-03-2023	17:00	Daily	Replacement of Rusted Hardware, conductor & old earthwire.	MSETCL	Kalwa Circle	Replacement of Rusted Hardware, conductor & old earthwire	OCC	Subject to approval of WRILDC	A
75	220		BOISAR II - BOISAR (PG) CKT - 3	08-03-2023	7:00	09-03-2023	17:00	Continuous	CB Maintenance Work by shifting the line on TBC	MSETCL	Kalwa Circle	BOISAR II - BOISAR (PG) CKT - 3 will be shifted on TBC & will be in service.	OCC	Subject to approval of WRILDC	A
76	400		KALWA - TALEGAON (PG)	08-03-2023	9:00	08-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
77	110		110KV Waghival-Mankhurd Line	09-03-2023	0:00	09-03-2023	6:00	Daily	Project Work- Working in vicinity of line for tower foundation work in Vashi creek	Tata power	Tata power	Line to be kept open and isolated at both ends. Emergency clearance - 15 Min.	MOCM	All other hydro lines to be in service	A
78	220	Ghodbunder	Bus Sectionalizer-2 (GIS Bay No.12)	09-03-2023	8:00	09-03-2023	17:00	Daily	Annual Maintenance of Bay equipments	AEML-T	AEML-T		MOCM	All elements to be in service	A
79	220	AKP SS	220 KV Akp kalwa line	09-03-2023	10:00	09-03-2023	19:00	Daily	Diagnostic testing & Bay Maintenance work.	MSETCL	Kalwa Circle	load manage by 220 kv AKP Nashik line	MOCM	subject to real time load management on 220KV Nashik - baleshwar DC (plan after 22.00 hrs)	A
80	220	Trombay B	220KV Trombay Antop Hill-2 Bay	09-03-2023	16:00	09-03-2023	20:00	Daily	Work in vicinity of 220KV Trombay Sailette-1 Breaker Replacement work.	Tata power	Tata power	Emergency clearance- 15 min	MOCM	load to be managed on ckt 1	A
81	400		PADGHE - KALWA CKT - 1	09-03-2023	6:00	14-03-2023	18:00	Continuous	work of replacement of existing Conductor, Hardware, Insulators by equivalent HTLS Conductor. Hardware in ROW issue area of line in Jambhul-Gaon, Ambemah.	MSETCL	Kalwa Circle	work of replacement of existing Conductor, Hardware, Insulation by equivalent HTLS Conductor, Hardware in ROW issue area of line in Jambhul-Gaon, Ambemah.	OCC	Subject to approval of WRILDC	A
82	220		BORIVALI - TARAPUR	09-03-2023	7:00	09-03-2023	17:00	Daily	Replacement of Rusted Hardware, conductor & old earthwire.	MSETCL	Kalwa Circle	Replacement of Rusted Hardware, conductor & old earthwire	OCC	Subject to approval of WRILDC	A
83	400		PADGHE - NAGOTHANE CKT - 1	09-03-2023	8:00	18-03-2023	17:00	Continuous	CB replacement work	MSETCL	Padghe	400 KV Nagothane Padgha-I will be in service through TBC	OCC	Subject to approval of WRILDC	A
84	400		PADGHE - NAGOTHANE CKT - 1	09-03-2023	8:00	18-03-2023	17:00	Continuous	CB replacement work	MSETCL	Panel	400 KV Nagothane Padgha-I will be in service through TBC	OCC	Subject to approval of WRILDC	A
85	400		KALWA - TALEGAON (PG)	09-03-2023	9:00	09-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
86	220		220 KV Sailette - Saki-7 line	10-03-2023	8:00	10-03-2023	19:00	Daily	Tree Trimming	Tata power	Tata power	Emergency clearance- 20 Mins AEML saki-1 & 2,220KV Saki Sahar cable will remain in service	MOCM	all other lines to be in service.	A
87	220		220 KV Kalwa-Colourchem	10-03-2023	8:00	10-03-2023	17:00	Continuous	For removing of jumper and making LLO at 220 KV DCHI GIS Stn.	MSETCL	EHV Project Division Kalwa		MOCM	plan on sunday or night hrs., summer high demand	A
88	110	Davdi	110KV khopoli Davdi	10-03-2023	8:00	13-03-2023	18:00	Daily	Breaker OH	Tata power	Tata power	Emergency clearance- on completion, Khopoli Davdi line will remain charge from Khopoli after disconnecting breaker	MOCM	All other hydro lines to be in service	A
89	220	400KV Kharghar	220KV Kharghar-NetMagic Bay	10-03-2023	8:30	10-03-2023	18:00	Daily	For Bay strengthening Work & Routine Maintenance Work	MSETCL	EHV O&M Circle Panel		MOCM	will be considered if tarapur borivali outage not availed.	A
90	220	Verisva	Main Bus-2	10-03-2023	9:00	10-03-2023	17:00	Daily	Annual Maintenance of Bus Side isolators	AEML-T	AEML-T		MOCM	All elements to be in service on other bus	A
91	220	220KV Kamba substation	220KV Padghe-Kamba 2 line	10-03-2023	9:00	11-03-2023	18:00	Continuous	Breaker overhauling work and dagnostic testing	MSETCL	Kalwa Circle	The last outage proposed on dtd. 10.02.2023 due to non availability of material it is proposed on 10 & 11.02.2023 as matril received but it is deferred by L.D. hence proposed. It is necessary for overhauling work of CB.	MOCM	subject to real time loading condition , summer high demand	A
92	220	220 KV AKP	220 KV BUS Section	10-03-2023	10:00	10-03-2023	17:00	Daily	Diagnostic testing & Isolator Maintenance work	MSETCL	Kalwa Circle		MOCM	Deferred due to kalwa agta line	D
93	220	220KV Boisar-II	200 MVA, 220/132 KV, ICT-1	10-03-2023	11:00	10-03-2023	12:00	Daily	Control & relay panel 220VDC Supply shifting from old charger to new DCDB.	MSETCL	Kalwa Circle		MOCM	Load to be managed on other ICTs	A
94	220	220KV Boisar-II	200 MVA, 220/132 KV, ICT-2	10-03-2023	14:00	10-03-2023	15:00	Daily	Control & relay panel 220VDC Supply shifting from old charger to new DCDB.	MSETCL	Kalwa Circle		MOCM	Load to be managed on other ICTs	A
95	220	220KV Boisar-II	200 MVA, 220/132 KV, ICT-3	10-03-2023	16:00	10-03-2023	17:00	Daily	Control & relay panel 220VDC Supply shifting from old charger to new DCDB.	MSETCL	Kalwa Circle		MOCM	Load to be managed on other ICTs	A

MOC MNC No.	Voltage (kV)	Substation	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOC/M Remark	MOC/M Status
1	220		220 KV Kalwa-Panchanand	01-03-2023	22:00	03-03-2023	5:00	Continuous	For erection of Termination Kit	MSETCL	Kalwa Circle		MOC/M	kalwa interconnector to be closed	A
96	220	Salsette	220KV Bus#1	10-03-2023	23:00	11-03-2023	7:00	Continuous	Project Activity: 220KV Kalwa-Salsette # 5 bay installation	Tata power	Tata power	All equipment remain in service on 220KV Bus-2	MOC/M	All equipment remain in service on 220KV Bus-2	A
97	220		BORIVALI - TARAPUR	10-03-2023	7:00	10-03-2023	17:00	Daily	Replacement of Rusted Hardware, conductor & old earthing	MSETCL	Kalwa Circle	Replacement of Rusted Hardware, conductor & old earthing	OCC	Subject to approval of WRILDC	A
98	400		KALWA - TALEGAON (PG)	10-03-2023	9:00	10-03-2023	18:00	Daily	PID Testing of Insulators Auto-Restore function to be out of service	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Restore function to be out of service	OCC	Subject to approval of WRILDC	A
99	110	Trombay A	KRS ICT 3	10-03-2023	8:00	10-03-2023	18:00	Daily	Bus outage at Trombay A	Tata power	Tata power	ICT 2,4,5 will remain in service	MOC/M	all other ICTs at trombay m and trombay T to be in service.	A
100			Apta - Kalwa	10-03-2023	22:00	11-03-2023	22:00	Continuous	project					kalwa interconnector to be made ON	A
101	220	Trombay SS	220KV Bus-Section-1 which includes: a) 220KV Trombay-Chembur-3 line b) 220100KV 200MVA ICT-2	11-03-2023	8:00	11-03-2023	18:00	Daily	1) 220KV Rph CB Pole replacement work of Trombay-Chembur-3 line 2) Diagnostic testing of equipments & 3) Bus Section bay maintenance work	MSETCL	Kalwa Circle		MOC/M	TATA NOC required.	A
102	220		220 KV CTRLS-Borivali line	11-03-2023	8:00	11-03-2023	14:00	Daily	To attend damaged conductor b/w loc. No. 45-46 by fitting repair sleeve	MSETCL	Kalwa Circle	Work will be carried out by AMC agency	MOC/M	Deferred due to trombay M bus section outage	D
103	220		220 KV Kalwa-Borivali line	11-03-2023	8:00	11-03-2023	14:00	Daily	For safety purpose during maintenance work on 220 KV CTRLS-Borivali line b/w loc. No. 45-46	MSETCL	Kalwa Circle	Safety outage required due to multi circuit configuration	MOC/M	Deferred due to trombay M bus section outage	D
104	220	400 KV Kalwa	220 KV Kalwa - Colourschem	11-03-2023	9:00	12-03-2023	18:00	Continuous	Pole Overhauling work. Line will be service in through TBC	MSETCL	Kalwa Circle		MOC/M	Line to be in service through TBC	A
105	220	220KV Boisar-II	220KV Bus Coupler	11-03-2023	10:00	11-03-2023	12:00	Daily	Control & relay panel 220VDC Supply shifting from old charger to new DCDB.	MSETCL	Kalwa Circle		MOC/M	Not proposed in OCC	D
106	220	Salsette	220KV Bus#2	11-03-2023	23:00	12-03-2023	7:00	Continuous	Project Activity: 220KV Kalwa-Salsette # 5 bay installation	Tata power	Tata power	All equipment remain in service on 220KV Bus-1	MOC/M	All equipment remain in service on 220KV Bus-1	A
107	220		BORIVALI - TARAPUR	11-03-2023	7:00	11-03-2023	17:00	Daily	Replacement of Rusted Hardware, conductor & old earthing	MSETCL	Kalwa Circle	Replacement of Rusted Hardware, conductor & old earthing	OCC	Subject to approval of WRILDC	A
108	400		KALWA - TALEGAON (PG)	11-03-2023	9:00	11-03-2023	18:00	Daily	PID Testing of Insulators Auto-Restore function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Restore function to be out of service.	OCC	Subject to approval of WRILDC	A
109	220	MAIN BUS - 1 @ BOISAR II		11-03-2023	8:00	12-03-2023	21:00	Continuous	Bus Isolator R/M & other R/M Work.	MSETCL	Kalwa Circle	Bus Isolator R/M & other R/M Work.	OCC	Subject to approval of WRILDC	A
110	220		220 KV Kalwa-Apta	11-11-2023	6:00	12-03-2023	20:00	Continuous	For erection of Termination Kit and Routine Line Maintenance work.	MSETCL	BHV O&M Circle Panel		MOC/M	kalwa interconnector to be made ON. Plan sat/sunday	A
111	110		110KV Wagholi-Mankhurd Line	12-03-2023	0:00	12-03-2023	6:00	Daily	Project Work- Working in vicinity of line for tower foundation work at Vashi creek	Tata power	Tata power	Line to be kept open and isolated at both ends. Emergency clearance - 15 Min.	MOC/M	All other hydro lines to be in service.	A
112	220	Trombay SS	220KV Bus-Section-2 which includes: a) 220KV Trombay-Sonkhar line b) 220100KV 200MVA ICT-3	12-03-2023	8:00	12-03-2023	18:00	Daily	1) Diagnostic testing of equipments, &2) Bus Section bay maintenance work	MSETCL	Kalwa Circle		MOC/M	either kalwa padghe 1 or bus outage to be aailed. Load to be managed on Kharghar sonkhar, MSETCL and TATA to be informed.	A
113	220		220 KV Salsette-Borivali-2	12-03-2023	8:00	12-03-2023	16:00	Daily	Closer inspection	Tata power	Tata power	Emergency clearance- 30 min	MOC/M	Deferred due to trombay bus 2 outage or 400KV kalwa padghe ckt 1	D
114	110		110 KV Kothel BMC BO-BO-1	12-03-2023	8:00	12-03-2023	16:00	Daily	Work in vicinity of 220KV Salsette Borivali-2 line.	Tata power	Tata power	Emergency clearance- 30 min	MOC/M	Deferred due to trombay bus 2 outage or 400KV kalwa padghe ckt 1	D
115	110	Rhopoli	72 MW Plant	12-03-2023	8:00	12-03-2023	18:00	Daily	Outline work	Tata power	Tata power	Hydro Generation Available 390 MW.	MOC/M	Deferred due to trombay bus 2 outage or 400KV kalwa padghe ckt 1	D
116	220	400KV Kharghar	220KV Kharghar- Neral Bay	12-03-2023	8:30	12-03-2023	18:00	Daily	For Bay strengthening Work & Routine Maintenance Work	MSETCL	BHV O&M Circle Panel		MOC/M	Deferred due to trombay bus 2 outage or 400KV kalwa padghe ckt 1	D
117	220	Borivali SS	220 KV GIS Bus Coupler	12-03-2023	12:00	12-03-2023	18:00	Daily	For Annual Relay Testing Work	MSETCL	Kalwa Circle		MOC/M	Deferred due to trombay bus 2 outage or 400KV kalwa padghe-ckt 1	D
118	400		PADGHE - KALWA CKT - 1	12-03-2023	9:00	12-03-2023	18:00	Daily	Diagnostic Testing and Bay maintenance work.	MSETCL	Kalwa Circle	Diagnostic Testing and Bay maintenance work.	OCC	Subject to approval of WRILDC	A
119	220		NALASOPARA - BOISAR PG	13-03-2023	9:00	13-03-2023	18:00	Daily	Bay Maintenance Work & Line Maintenance Work	MSETCL	Kalwa Circle	Bay Maintenance Work & Line Maintenance Work	OCC	Subject to approval of WRILDC	A
120	110	Kalyan	110 KV Ambemah Kalyan-1 line with Breaker	13-03-2023	8:00	13-03-2023	18:00	Daily	CT & Line PT Testing	Tata power	Tata power	Emergency clearance- 20 min.	MOC/M		A
121	220	Versova	Versova-Ghodabunder Line on TBC	13-03-2023	9:00	13-03-2023	17:00	Daily	Annual Maintenance of Circuit Breaker	AEMLT	AEMLT	Line will be in service through TBC	MOC/M	Line to be in service through TBC	A
122	220		220KV Apta - Tambali line	13-03-2023	9:00	13-03-2023	18:00	Daily	Routine line maintenance work.	MSETCL	BHV O&M Circle Panel		MOC/M	MISDCL to be informed for radial operation of Tambali ss	A
123	400		NAGOTHANE - DABHOL CKT - 1	13-03-2023	8:00	13-03-2023	17:00	Continuous	Over voltage Relay replacement work	MSETCL	Padghe	outage required	OCC	Subject to approval of WRILDC	A
124	400		NAGOTHANE - DABHOL CKT - 1	13-03-2023	8:00	13-03-2023	17:00	Continuous	Over voltage Relay replacement work	MSETCL	Panel	outage required	OCC	Subject to approval of WRILDC	A
125	400		KHARGHAR - TALEGAON (PG)	13-03-2023	9:00	13-03-2023	18:00	Daily	PID Testing of Insulators Auto-Restore function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Restore function to be out of service.	OCC	Subject to approval of WRILDC	A
126	400	400kv Padghe	80MVAR Bus Reactor	14-03-2023	9:00	14-03-2023	17:30	Daily	1) MTAMC work 2) Bay Maint work 3) Diagnostic Testing work 4) NPPS Maint work	MSETCL	Padghe	1) Weather condition should be clear	MOC/M	SLDC code to be given, work be completed within time.	A
127	220		220 KV Apta Bombay Dyeing	14-03-2023	9:00	14-03-2023	18:00	Daily	Bay Maintenance Work and C & Tan-Delta Testing and Routine Maint. Work of Lines S/Dn	MSETCL	BHV O&M Circle Panel		MOC/M	Bombay dyeing NOC required.	A
128	220		BOISAR II - TARAPUR	14-03-2023	7:00	14-03-2023	17:00	Daily	Replacement of Rusted Hardware, Old earthing and other maintenance work.	MSETCL	Kalwa Circle	Replacement of Rusted Hardware, Old earthing and other maintenance work.	OCC	Subject to approval of WRILDC	A
129	400		NAGOTHANE - DABHOL CKT - 2	14-03-2023	8:00	14-03-2023	17:00	Continuous	Over voltage Relay replacement work	MSETCL	Padghe	outage required	OCC	Subject to approval of WRILDC	A
130	400		NAGOTHANE - DABHOL CKT - 2	14-03-2023	8:00	14-03-2023	17:00	Continuous	Over voltage Relay replacement work	MSETCL	Panel	outage required	OCC	Subject to approval of WRILDC	A
131	400		KHARGHAR - TALEGAON (PG)	14-03-2023	9:00	14-03-2023	18:00	Daily	PID Testing of Insulators Auto-Restore function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Restore function to be out of service.	OCC	Subject to approval of WRILDC	A
132	110	Rhopoli	110 KV Khopoli Karanjade line	15-03-2023	9:00	15-03-2023	18:00	Daily	Bay R/M at Rhopoli	Tata power	Tata power	Emergency clearance- 30 min.	MOC/M	All other hydro lines to be in service	A
133	110	Rhopoli	24 MW Unit 8	15-03-2023	4:00	04-04-2023	18:00	Daily	Excitation PLC Prot Panel Replacement	Tata power	Tata power	Hydro Generation Available 438 MW.	MOC/M	Deferred due to summer demand	D
134	220		220 kv ONGC Panel TSS line	15-03-2023	8:00	16-03-2023	18:00	Continuous	Charging of 220 kv karanjade TSS & OPGW stringing work from monopole to ONGC substation.	MSETCL	BHV O&M Circle Panel		MOC/M	Panel TSS, EI NOC	A
135	220	Dharavi	ICT-7	15-03-2023	8:00	22-03-2023	20:00	Continuous	Project work-Shifting to new 145KV GIS	Tata power	Tata power	ICT-8,9,10 will remain in service. Emergency clearance - After work.	MOC/M	Load to be managed on ICT-8,9,10	A
136	110	Trombay A	ICT 5 220/110KV_250MVA	15-03-2023	9:00	15-03-2023	19:00	Daily	110KV Ring bus 3 outage	Tata power	Tata power	ICT 2,3,4 are in service	MOC/M	All other ICTs at trombay M and trombay T to be in service.	A
137	220		BOISAR II - TARAPUR	15-03-2023	7:00	15-03-2023	17:00	Daily	Replacement of Rusted Hardware, Old earthing and other maintenance work.	MSETCL	Kalwa Circle	Replacement of Rusted Hardware, Old earthing and other maintenance work.	OCC	Subject to approval of WRILDC	A
138	400		PADGHE - NAGOTHANE CKT - 1	15-03-2023	8:00	15-03-2023	17:00	Continuous	Over voltage Relay replacement work	MSETCL	Padghe	outage required	OCC	Subject to approval of WRILDC	A
139	400		PADGHE - NAGOTHANE CKT - 1	15-03-2023	8:00	15-03-2023	17:00	Continuous	Over voltage Relay replacement work	MSETCL	Panel	outage required	OCC	Subject to approval of WRILDC	A
140	400		KHARGHAR - TALEGAON (PG)	15-03-2023	9:00	15-03-2023	18:00	Daily	PID Testing of Insulators Auto-Restore function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Restore function to be out of service.	OCC	Subject to approval of WRILDC	A
141	220	Uran	220KV Main Bus 1	16-03-2023	9:00	17-03-2023	18:00	Daily	Insulator Replacement.	MSETCL	BHV O&M Circle Panel		MOC/M		A
142	110	Bhira	110KV Bhira David	16-03-2023	8:00	16-03-2023	16:00	Daily	Bay maintenance & Testing at Bhira	Tata power	Tata power	Emergency Clearance-45 min	MOC/M	All other hydro lines to be in service	A
143	220		220kv Uran-Apta 2	16-03-2023	9:00	16-03-2023	18:00	Daily	Insulator Replacement & Diagnostic Testing	MSETCL	BHV O&M Circle Panel		MOC/M	All other lines at uran and apta to be in service	A
144	400		MAIN BAY (400) OF FUTURE CKT @ KUDUS	16-03-2023	7:00	16-03-2023	15:00	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	MSETCL	Kalwa Circle	Annual Maintenance of bays equipment & Diagnostics Testing Work	OCC	Subject to approval of WRILDC	A
145	220		BOISAR II - TARAPUR	16-03-2023	7:00	16-03-2023	17:00	Daily	Replacement of Rusted Hardware, Old earthing and other maintenance work.	MSETCL	Kalwa Circle	Replacement of Rusted Hardware, Old earthing and other maintenance work.	OCC	Subject to approval of WRILDC	A
146	400		PADGHE - NAGOTHANE CKT - 2	16-03-2023	8:00	16-03-2023	17:00	Continuous	Over voltage Relay replacement work	MSETCL	Padghe	outage required	OCC	Subject to approval of WRILDC	A
147	400		PADGHE - NAGOTHANE CKT - 2	16-03-2023	8:00	16-03-2023	17:00	Continuous	Over voltage Relay replacement work	MSETCL	Panel	outage required	OCC	Subject to approval of WRILDC	A

MOC No.	Voltage (kV)	Substation	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.	Type	MOCM Remark	MOCM Status
1	220		220 KV Kalwa-Panchanand	01-03-2023	22:00	03-03-2023	5:00	Continuous	For erection of Termination Kit	MSETCL	Kalwa Circle		MOCM	Kalwa interconnector to be closed	A
148	400		KHARGHAR - TALEGAON (PG)	16-03-2023	9:00	16-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
149	220		220kv Uran-Apta 3	17-03-2023	9:00	17-03-2023	18:00	Daily	Q1 Isolator Maintenance Work by Agency.	MSETCL	EHV O&M Circle Panel		MOCM	All other lines at uran and apta to be in service.	A
150	400	400kv Padghe	400KV Nagothane - 1	17-03-2023	9:00	17-03-2023	18:30	Daily	1) MT&MC work 2) Bay Maint work 3) Diagnostic Testing work	MSETCL	Padghe	1) Weather condition should be clear	MOCM	Subject to other outage approved by WRILDC in same corridor on D-1 basis.	A
151	220		220KV Kharghar-Bornali-8	17-03-2023	8:00	17-03-2023	17:00	Continuous	For safety purpose only while working on 220 KV Kalwa-Tiffle Line.	MSETCL	EHV Project Division Kalwa		MOCM	All other lines to Bornali to be in service.	A
152	220		220 KV Kalwa-Tiptal	17-03-2023	8:00	17-03-2023	17:00	Continuous	For removing of jumper and making LLO at 220 KV Pawane GIS Stn.	MSETCL	EHV Project Division Kalwa		MOCM	EHV consumer NDC required, EI approval required.	A
153	220	Trombay B	220KV Trombay-Carnac-7 Line	17-03-2023	8:00	17-03-2023	19:00	Daily	CVT testing at Trombay	Tata power	Tata power	220KV Trombay Carnac 5 & 6 will remain in service.	MOCM	All other lines to carnac to be in service.	A
154	110		110KV Bhira Khopoli # 2 line	17-03-2023	8:00	18-03-2023	16:00	Daily	Providing D shackle to insulators	Tata power	Tata power	Emergency Clearance-45 min	MOCM	All other hydro lines to be in service	A
155	220	Saki	AEML Saki - TPC Saki Line-1	17-03-2023	9:00	17-03-2023	17:00	Daily	Annual Maintenance of Bay equipments	AEML-T	AEML-T		MOCM	Salihet saki and asny saki to be in service.	A
156	220		220 KV Uran-ONGC	17-03-2023	9:00	17-03-2023	18:00	Daily	Insulator Replacement & Diagnostic Testing at ONGC	MSETCL	EHV O&M Circle Panel		MOCM	ONGC NDC required.	A
157	400	400kv Padghe	315MVA ICT-II	17-03-2023	9:00	17-03-2023	21:30	Daily	1) MT&MC work 2) Bay Maint work 3) Diagnostic Testing work 4) Oil leakage attending work if any 5) WPPSS Maint work	MSETCL	Padghe	1) Weather condition should be clear	MOCM	Subject to real time loading condition and other outages approved by WRILDC on D-3 basis.	A
158	220	220KV Kamba substation	220kv Kamba-Kharbhao line	17-03-2023	9:00	18-03-2023	18:00	Continuous	Breaker overhauling work and diagnostic testing	MSETCL	Kalwa Circle	The opportunity outage is proposed on 22.01.2023 due to agency problem the outage not availed , the outage is proposed on dtd. 17.03.2023 & 18.03.2023. It is necessary for CB overhauling and diagnostic work .	MOCM	Kharbao TSS NDC required and MSDCL to be informed for substation on radial mode.	A
159	220		220KV Trombay-Salsette # 1 220KV Trombay-Dharavi # 5	17-03-2023	22:00	23-03-2023	8:00	Daily	Third Party Work - Diversion of Line at Sejal Shakti Project site	Tata power	Tata power	220KV Trombay Dharavi-5 & 6 & Waghivali Dharavi -7 & 8 in service.	MOCM	After restoration of Kharghar bornali 2 and Boiser Tarapur lines if outage availed, (will be approved on D-1 basis as per real time system condition.	A
160	220		BOISAR II - TARAPUR	17-03-2023	7:00	17-03-2023	17:00	Daily	Replacement of Rusted Hardware, Old earthing and other maintenance work.	MSETCL	Kalwa Circle	Replacement of Rusted Hardware, Old earthing and other maintenance work.	OCC	Subject to approval of WRILDC	A
161	220		BOISAR II - TARAPUR	17-03-2023	9:00	17-03-2023	17:00	Daily	Bay Maintenance Work	MSETCL	Kalwa Circle	Bay Maintenance Work	OCC	Subject to approval of WRILDC	A
162	400		KHARGHAR - TALEGAON (PG)	17-03-2023	9:00	17-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
163	110	Kalyan	110 KV Ambarnath Kalyan-2 line with Breaker	18-03-2023	8:00	18-03-2023	18:00	Daily	CT & Line PT Testing	Tata power	Tata power	Emergency clearance- 20 min.	MOCM	All other hydro lines to be in service.	A
164	220	Trombay B	220KV Trombay-Dharavi-9 Line	18-03-2023	8:00	18-03-2023	19:00	Daily	CVT testing at Trombay	Tata power	Tata power	220KV Trombay Dharavi 5, 6 & Waghivali Dharavi -7 & 8 will remain in service.	MOCM	Deferred due to bhira bus	D
165	220		220KV Apta - Talga line	18-03-2023	9:00	18-03-2023	18:00	Daily	Routine line maintenance work.	MSETCL	EHV O&M Circle Panel		MOCM	Kalwa interconnector to be made ON.	A
166	400	400kv Padghe	400KV Nagothane - 2	18-03-2023	9:00	18-03-2023	18:30	Daily	1) MT&MC work 2) Bay Maint work 3) Diagnostic Testing work	MSETCL	Padghe	1) Weather condition should be clear	MOCM	Will be considered after stages approved by WRILDC	A
167	220	Backbay	AT-1 & 2	18-03-2023	9:30	18-03-2023	17:30	Daily	Preparatory work for 220KV CRP Replacement.	Tata power	Tata power	AT-2 will remain in service.	MOCM	one at a time.	A
168	400		KHARGHAR - TALEGAON (PG)	18-03-2023	9:00	18-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
169	220	Bornali	220KV main Bus 2	18-03-2023	7:00	19-03-2023	19:00:00 PM	Continuous	Docking of 220KV single Phase VT	Tata power	Tata power		MOCM	All elements to be in service through Bus 1	A
170	110		110KV Waghivali-Mankhund Line	19-03-2023	0:00	19-03-2023	6:00	Daily	Project Work- Working in vicinity of line for tower foundation work in Vashi creek.	Tata power	Tata power	Line to be kept open and isolated at both ends. Emergency clearance - 15 Min.	MOCM	All other hydro lines to be in service.	A
171	110	Bhivpuri	110 KV BUS SECTION IV-V-VI	19-03-2023	6:00	19-03-2023	15:00	Daily	RM	Tata power	Tata power	Hydro Generation Available - 598MW, 24 MW unit 9 & 10 not Available. 110KV Khopoli Bhivpuri-1 will remain charge from Khopoli end. Bhivpuri Neral will go on Transfer Breaker.	MOCM	110KV Khopoli Bhivpuri-1 will be out	A
172	220	Bornali SS	220 KV Bus Section 1 which includes: 1) 220KV Tarapur Line 2) 220KV Bandup GIS Line 3) 220KV PGCL 4) 220KV Kharghar-2 5) 220KV TATA-VI 6) 220KV AdaniAsrey-2 7) 220KV Adani Bornali-2 8) 220KV Adani Gera-2 8) 100MVA 220/100KV ICT	19-03-2023	8:00	19-03-2023	18:00	Daily	For Earth Wire Replacement and Routine Maintenance of Main Bus	MSETCL	Kalwa Circle		MOCM	Deferred due to high demand, submit the contingency plan.	D
173	220	220KV Vasa	220KV Padghe - Nalasopara-Vasa Tap Line	19-03-2023	9:00	19-03-2023	17:00	Daily	Outage required for Damaged conductor repairing work & Hot spot attending work & Diagnostic Testing and Bay maintenance work at 220KV Vasa Sub.	MSETCL	Kalwa Circle		MOCM	subject to load management on Padghe ICT outage	A
174	220	400 KV Kalwa Backbay	220 KV Kalwa- Siemens Bus Coupler	19-03-2023	9:00	19-03-2023	18:00	Daily	Diagnostic testing work. Outage work.	MSETCL	Kalwa Circle		MOCM	EHV consumer NDC required.	A
175	220		Bus Coupler	19-03-2023	9:30	19-03-2023	17:30	Daily	Preparatory work for 220KV CRP Replacement.	Tata power	Tata power	Emergency clearance- 30 min	MOCM	All elements to be in service through Each bus	A
176	400		KALWA - KHARGHAR	19-03-2023	8:00	19-03-2023	18:00	Daily	Routine Maintenance & Insulator cleaning work	MSETCL	Kalwa Circle	Routine Maintenance & Insulator cleaning work	OCC	Subject to approval of WRILDC	A
177	400		KHARGHAR - TALEGAON (PG)	19-03-2023	9:00	19-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
178	220	Bornali T	220KV Main Bus 1	19-03-2023	8:00	20-03-2023	8:00	continuous	Docking of single phase VT	Tata power	Tata power		MOCM	All elements to be in service through Bus 2	A
179	220	Trombay B	220 KV Trombay Salsette-1	20-03-2023	6:00	20-03-2023	10:00	Daily	CVT testing at Trombay end	Tata power	Tata power	220KV Tie-1 & Tie-2 (600MW each) , 220KV Trombay Salsette -2 will remain in service.	MOCM	Deferred due to high demand , monday	D
180	220	Versova TBC	Versova-Gorgan Line-1 on TBC	20-03-2023	9:00	20-03-2023	17:00	Daily	Annual Maintenance of Circuit Breaker	AEML-T	AEML-T	Line will be in service through TBC	MOCM	Line to be in service through TBC	A
181	400		PADGHE - NAGOTHANE CKT - 2	20-03-2023	8:00	28-03-2023	17:00	Continuous	CB replacement work	MSETCL	Padghe	400 KV Nagothane Padghe-4 will be in service through TBC	OCC	Subject to approval of WRILDC	A
182	400		PADGHE - NAGOTHANE CKT - 2	20-03-2023	8:00	28-03-2023	17:00	Continuous	CB replacement work	MSETCL	Panel	400 KV Nagothane Padghe-4 will be in service through TBC	OCC	Subject to approval of WRILDC	A
183	400		KHARGHAR - TALEGAON (PG)	20-03-2023	9:00	20-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
184	220		220 KV NERUL - CHEMBUR LINE	21-03-2023	8:00	30-03-2023	18:00	Daily	Auto Reclose function is to be kept out of service during replacement of OPGW between loc. No. B69 to T20	MSETCL	Kalwa Circle	M/s MTCL will carry out OPGW replacement work.	MOCM	AR only line to be in service	A
185	220		220KV Kharghar-Uran1	21-03-2023	8:00	28-03-2023	18:00	Continuous	Making LLO of 220KV Cable at 220KV Ulwe GIS and routine line Maintenance	MSETCL	EHV O&M Circle Panel		MOCM	All other lines to uran to be in service. EI approval required.	A
186	400		KHARGHAR - TALEGAON (PG)	21-03-2023	9:00	21-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
187	220		220KV Tata Bornali MSETCL Bornali line #4 220KV Salsette Bornali Line #1	22-03-2023	8:00	22-03-2023	16:00	Daily	Closer inspection	Tata power	Tata power	Emergency clearance- 30 min	MOCM	under review due to high loading	A
188	400		KHARGHAR - TALEGAON (PG)	22-03-2023	9:00	22-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
189	110		110KV Waghivali-Mankhund Line	23-03-2023	0:00	23-03-2023	6:00	Daily	Project Work- Working in vicinity of line for tower foundation work in Vashi creek.	Tata power	Tata power	Line to be kept open and isolated at both ends. Emergency clearance - 15 Min.	MOCM	All other hydro lines to be in service	A
190	220	Trombay B	220 KV Trombay Salsette-2	23-03-2023	7:00	23-03-2023	14:00	Daily	CVT testing at Trombay end	Tata power	Tata power	220KV Tie-1 & Tie-2 (600MW each) , 220KV Trombay Salsette -1 will remain in service.	MOCM	Deferred due to high demand	D
191	220	Backbay	Bus Coupler	23-03-2023	8:00	24-03-2023	17:30	Continuous	Project Work-220KV CRP Replacement.	Tata power	Tata power	Emergency clearance- After work	MOCM	all elements to be in service	A
192	220		220 KV SEZ ,JNPT	23-03-2023	9:00	23-03-2023	18:00	Daily	Diagnostic Testing at Both Ends & Attending Breaker Problem at JNPT End.	MSETCL	EHV O&M Circle Panel		MOCM	JNPT NDC required.	A
193	110	Salsette	110KV Bus Zone 1	23-03-2023	23:00	24-03-2023	6:00	Continuous	RM	Tata power	Tata power	ICT 3 will be in service between 110KV & 220V , Sal Saki 3 and Sal BMC will remain charged from remote end	MOCM	Sal Saki 3 and Sal BMC will be out	A
194	400		KALWA - KHARGHAR	23-03-2023	9:00	23-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A
195	220	Saki	AEML Saki - TPC Saki Line-1	24-03-2023	9:00	24-03-2023	17:00	Daily	Annual Maintenance of Bay equipments	AEML-T	AEML-T		MOCM	all other lines saki salihet and saki asrey to be in service.	A
196	220		220 KV ONGC-JNPT	24-03-2023	9:00	24-03-2023	18:00	Daily	Diagnostic Testing at Both Ends.	MSETCL	EHV O&M Circle Panel		MOCM	JNPT and ONGC NDC required.	A
197	220	220KV Bhavghar	220KV Bhavghar - Wada Line	24-03-2023	10:00	24-03-2023	17:00	Daily	Diagnostic and Relay Testing Work	MSETCL	Kalwa Circle		MOCM	MSDCL to be informed for radial operation	A
198	110	Kalyan	110KV Bus Zone-1	24-03-2023	23:00	25-03-2023	6:00	Continuous	RM	Tata power	Tata power	Emergency clearance- 30 min KGS-2 will be taken on Transfer Breaker Chola Kalyan -1 will remain out & AK-2 will remain in service between Ambarnath & DGA.	MOCM	Chola Kalyan -1 will remain out. Railway to be informed	A
199	400		KALWA - KHARGHAR	24-03-2023	9:00	24-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRILDC	A

MOC No. / Nc.	Voltage (kV)	Substation	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.	Type	MOCM Remark	MOCM Status
1	220		220 KV Kalwa-Panchanand	01-03-2023	22:00	03-03-2023	5:00	Continuous	For erection of Termination Kit	MSETCL	Kalwa Circle		MOCM	kalwa interconnector to be closed	A
200	220		220 KV Bhira Karanjade-7	25-03-2023	8:00	25-03-2023	18:00	Daily	Project job-TLA installation	Tata power	Tata power	Emergency clearance- 30 mins Bhira Karanjade-8 will remain in service.	MOCM	All other hydro lines to be in service. (Will be considered if no major outage at 400KV Kalwa /Padghe/Kharghar)	A
201	220	Trombay B	220KV Trombay Carnao-6 Breaker	25-03-2023	8:00	25-03-2023	19:00	Daily	CT testing at Trombay end.	Tata power	Tata power	Line will be controlled by Transfer Breaker-2.	MOCM	Line to be in service through TBC	A
202	220	Backbay	AT-1 250MVA 22110KV	25-03-2023	8:00	26-03-2023	20:30	Continuous	Project Work-220KV CRP Replacement.	Tata power	Tata power	AT-2, CBB-1,CBB-2 line will remain in service.	MOCM		A
203	220		220KV Trombay-Dharavi # 6	25-03-2023	22:00	31-03-2023	8:00	Daily	Third Party Work - Diversion of Line at Sejal Shakti Project site	Tata power	Tata power	220KV Trombay Dharavi-9, 5 & Waghivali Dharavi -7 & 8 in service.	MOCM	All other lines to dharavi to be in service. (Will be considered if no major outage at 400KV Kalwa /Padghe/Kharghar)	A
204	400		PADGHE - KALWA CKT - 2	25-03-2023	6:00	25-03-2023	18:00	Daily	1) For shifting of 400KV Kalwa-Padghe-II Line (between suitable location) on 400KV Dead Ckt to facilitate HTLS work on 400KV Kalwa-Padghe-I line from 26.03.2023. (After above shifting, 400KV Kalwa-Padghe-I line will be shifted on dead portion of 400KV Kalwa-Padghe-II line so as to make the 400KV Kalwa-Padghe-I line dead between the above suitable location) 2) 400KV Kalwa-Padghe-II Line will be charged through Dead Ckt till the completion of HTLS work on dead portion of 400KV Kalwa-Padghe-I line after above arrangement.	MSETCL	Kalwa Circle	-	OCC	Subject to approval of WRLDC	A
205	400		KALWA - KHARGHAR	25-03-2023	9:00	25-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRLDC	A
206	220		MAIN BUS - 2 @ BOISAR II	25-03-2023	9:00	26-03-2023	20:00	Continuous	Bus Isolator R/M & other R/M Work	MSETCL	Kalwa Circle	Bus Isolator R/M & other R/M Work.	OCC	Subject to approval of WRLDC	A
207	110		110KV Waghivali-Mankhund	26-03-2023	0:00	26-03-2023	6:00	Daily	Project Work- Working in vicinity of line for tower foundation work in Vashi creek.	Tata power	Tata power	Line to be kept open and isolated at both ends. Emergency clearance - 15 Min.	MOCM	All other hydro lines to be in service. (Will be considered if no major outage at 400KV Kalwa /Padghe/Kharghar)	under review
208	220		220KV Tata Borivali MSETCL Borivali line # 5 220KV Salsette Borivali Line # 2	26-03-2023	8:00	26-03-2023	18:00	Daily	Closer inspection	Tata power	Tata power	Emergency clearance- 30 min 220KV Tata Borivali MSETCL Borivali line # 4 220KV Salsette Borivali Line # 1 will remain in service	MOCM	(Will be considered if no major outage at 400KV Kalwa /Padghe/Kharghar)	under review
209	110	Bhivpuri	Bhivpuri Unit 9	26-03-2023	8:00	26-03-2023	16:30	Daily	R/M	Tata power	Tata power	Emergency clearance 15 Mins. (Hydro generation available 413MW)	MOCM	(Will be considered if no major outage at 400KV Kalwa /Padghe/Kharghar)	under review
210	220	Borivali SS	220 KV Bus Section 2 which includes: 1) 220KV Boisar Line 2) 220KV CTRLS Line 3) 220KV Adani Ghodbunder 4) 220KV Kalwa 5) 220KV TATA-V 6) 220KV Adani-Karaj-1 7) 220KV Adani Borivali-1 8) 220KV Adani Gorai-1	26-03-2023	8:00	26-03-2023	18:00	Daily	For Earth Wire Replacement and Routine Maintenance of Main Bus	MSETCL	Kalwa Circle		MOCM	High demand	D
211	220		220 KV Bhira Karanjade-8	26-03-2023	8:00	26-03-2023	18:00	Daily	Project job-TLA installation	Tata power	Tata power	Emergency clearance- 30 mins Bhira Karanjade-7 will remain in service.	MOCM	(Will be considered if no major outage at 400KV Kalwa /Padghe/Kharghar)	under review
212	220	220KV Vasa	220KV Kamba - Vasa Line	26-03-2023	9:00	26-03-2023	17:00	Daily	Outage required for insulator cleaning work & Diagnostic Testing and Bay maintenance work at 220KV/Vasa SS.	MSETCL	Kalwa Circle		MOCM	All other lines to kamba and vasa to be in service.	under review
213	220	400 KV Kalwa	220 KV kalwa - Salsette IV Line	26-03-2023	9:00	26-03-2023	18:00	Daily	Diagnostic Testing & Bay Maintenance work.	MSETCL	Kalwa Circle		MOCM	(Will be considered if no major outage at 400KV Kalwa /Padghe/Kharghar)	under review
214	400		KHARGHAR - TALEGAON (PS)	26-03-2023	8:00	26-03-2023	18:00	Daily	Routine Maintenance & Insulator cleaning work	MSETCL	Kalwa Circle	Routine Maintenance & Insulator cleaning work.	OCC	Subject to approval of WRLDC	A
215	400		KALWA - KHARGHAR	26-03-2023	9:00	26-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRLDC	A
216	220	Trombay B	220KV Trombay Dharavi-6 Bay	27-03-2023	8:00	27-03-2023	19:00	Daily	CVT testing at Trombay end.	Tata power	Tata power	220KV Trombay Dharavi-5, 9, Waghivali Dharavi-7 & 8 will remain in service.	MOCM	load to be managed by PSCC on other lines of Carnao.	A
217	220		220/22 KV 25 MVA PTR 2 @ NAGOTHANE	27-03-2023	8:00	31-03-2023	17:00	Continuous	CB replacement work	MSETCL	Padghe	25 MVA T/F - 2 will be in service through TBC.	OCC	Subject to approval of WRLDC	A
218	220		220/22 KV 25 MVA PTR 2 @ NAGOTHANE	27-03-2023	8:00	31-03-2023	17:00	Continuous	CB replacement work	MSETCL	Panel	25 MVA T/F - 2 will be in service through TBC.	OCC	Subject to approval of WRLDC	A
219	400		KALWA - KHARGHAR	27-03-2023	9:00	27-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRLDC	A
220	220	Backbay	AT- 2	28-03-2023	8:00	29-03-2023	20:30	Continuous	Project Work-220KV CRP Replacement.	Tata power	Tata power	AT-1, CBB-1,CBB-2 line will remain in service.	MOCM	load to be managed on other TFS.	A
221	220	Versova & Ghodbunder	Versova -Ghodbunder Line	28-03-2023	9:00	28-03-2023	17:00	Daily	Annual Maintenance of Bay equipments	AEML-T	AEML-T		MOCM	all other lines to versova and ghodbunder to be in service.	A
222	400		MAIN BAY (409) OF FUTURE CKT @ KUDUS	28-03-2023	7:00	28-03-2023	16:00	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	MSETCL	Kalwa Circle	Annual Maintenance of bays equipment & Diagnostics Testing Work	OCC	Subject to approval of WRLDC	A
223	400		KALWA - KHARGHAR	28-03-2023	9:00	28-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRLDC	A
224	220	Bhira	220KV Bus 1	29-03-2023	6:30	29-03-2023	16:30	Daily	R/M & Protection testing	Tata power	Tata power	All equipment remain in service through Bus coupler.	MOCM	All equipment remain in service through Bus coupler.	A
225	220		220KV Kharghar - Uran II line	29-03-2023	9:00	08-04-2023	18:00	Daily	Routine line maintenance work & For making LLO of 220KV Cable at 220KV Ulwe GIS	MSETCL	BHV O&M Circle Panel		MOCM	Load to be manged on ckt 1	A
226	400		KALWA - KHARGHAR	29-03-2023	9:00	29-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRLDC	A
227	220	Backbay	220KV Backbay Mahalaxmi	30-03-2023	8:00	31-03-2023	20:30	Continuous	Project Work-220KV CRP Replacement.	Tata power	Tata power	220KV Carnao Backbay will remain in service.	MOCM	All other lines to mahalaxmi and back bay to be in service.	A
228	220	Ghodbunder	Ghodbunder - MSETCL Borivali Line	30-03-2023	9:00	30-03-2023	17:00	Daily	Annual Maintenance of Bay equipments	AEML-T	AEML-T		MOCM	All other lines to ghodbunder and Borivali to be in service.	A
229	400		KALWA - KHARGHAR	30-03-2023	9:00	30-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRLDC	A
230	400		KALWA - KHARGHAR	31-03-2023	9:00	31-03-2023	18:00	Daily	PID Testing of Insulators Auto-Reclose function to be out of service.	MSETCL	Kalwa Circle	PID Testing of Insulators Auto-Reclose function to be out of service.	OCC	Subject to approval of WRLDC	A