

Maharashtra State Load Despatch Centre															
Monthly Outages(MOCM) from 01/Jun/2024 To 30/Jun/2024															
Note	1) Outages will be apporved on D-1 basis and will be facilitated as per real time loading/system coditions.														
	2) Outages may be deferred due to outage approved by WRDC at 400 level in MSETCL/Powergrid Network on D-1 basis														
	3) A-Approved, P-Pending, D-Deferred. U-Underreview.														
Sr.No.	Voltage	Substation/ Division	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOCM Remark	MOCM Status
1	220	COLOURCHEM	220KV GIS DCHI - COLOURCHEM	01-Jun-24	05:00	01-Jun-24	09:00	D	Pre-monsoon maintenance work which include polythene paper wrapping on CB , CT terminal box , LA IR test , Insulator cleaning and R&M work	MSETCL	MSETCL	Pre-monsoon maintenance work which include polythene paper wrapping on CB , CT terminal box , LA IR test , Insulator cleaning and R&M work	MOCM	NOC required from DCHI. 220KV C'Chem - Kalwa will be in service.	A
2	220	KALWA	KALWA - SIEMENS	01-Jun-24	07:00	01-Jun-24	13:00	D	For the installation of saver assembly sets at TL no. 43, 45, 46, 47 & 48 (Total 18 sets out of 18 sets are to be installed)	MSETCL	MSETCL	Work at Airoli-Katai naka road & MIDC road crossing & Slum crossing at Rabale & at Mahape-Shil Phata road flyover crossing. Due to M/C Configuration ouage is requires as follows: 1) 220kV Kharghar-Borivali-II: 01.06.2024 @ 07:00 Hrs to 18:00 2) 220 kV Kalwa-Siemens line: 01.06.2024 @ 07:00 Hrs to 13:00 Hrs. 3) 220 kV Mahape-Reliance line 01.06.2024 @ 13:30 Hrs to 18:00 Hrs.	MOCM	Availed in night hours	U
3	220 KV	WAGHIVALI	WAGHIVALI - DHARAVI 8	01-Jun-24	05:30	01-Jun-24	10:00	D	Resagging of conductor at S G Barve Metro - 2B crossing	TATA	TATA	Waghivali Dharavi 7 will remain in service. In 220KV N-1 contingency Bhira generation will restricted to 183 MW. Line outages required with 220KV Trombay Vikhroli 3 line	MOCM		A
4	220	BORIVALI	KHARGHAR - BORIVALI CKT - 2	01-Jun-24	07:00	01-Jun-24	18:00	D	For the installation of saver assembly sets at TL no. 43, 45, 46, 47 & 48, 27/3 & 28 (Total 24 sets out of 66 sets are to be installed, total completed - 6 sets	MSETCL	MSETCL	Work at Airoli-Katai naka road & MIDC road crossing & Slum crossing at Rabale & at Mahape-Shil Phata road flyover crossing. Due to M/C Configuration ouage is requires as follows: 1) 220kV Kharghar-Borivali-II: 01.06.2024 @ 07:00 Hrs to 18:00 2) 220 kV Kalwa-Siemens line: 01.06.2024 @ 07:00 Hrs to 13:00 Hrs. 3) 220 kV Mahape-Reliance line 01.06.2024 @ 13:30 Hrs to 18:00 Hrs.	MOCM	Availed in night hours	U
5	220	BORIVALI	KHARGHAR - BORIVALI CKT - 2	01-Jun-24	07:00	01-Jun-24	18:00	D	For the installation of saver assembly sets at TL no. 43, 45, 46, 47 & 48, 27/3 & 28 (Total 24 sets out of 66 sets are to be installed, total completed - 6 sets	MSETCL	MSETCL	Work at Airoli-Katai naka road & MIDC road crossing & Slum crossing at Rabale & at Mahape-Shil Phata road flyover crossing. Due to M/C Configuration ouage is requires as follows: 1) 220kV Kharghar-Borivali-II: 01.06.2024 @ 07:00 Hrs to 18:00 2) 220 kV Kalwa-Siemens line: 01.06.2024 @ 07:00 Hrs to 13:00 Hrs. 3) 220 kV Mahape-Reliance line 01.06.2024 @ 13:30 Hrs to 18:00 Hrs.	MOCM	Availed in night hours	U
6	220 KV	GHODBUNDER	DAHANU - GHODBUNDER CKT - 1	01-Jun-24	11:00	01-Jun-24	13:00	D	Pre-Monsoon Activity of CB Covering	AEML	AEML	Line will be in service through TBC	MOCM		A
7	220	MAHAPE	MAHAPE - RELIANCE GIS	01-Jun-24	13:30	01-Jun-24	18:00	D	For the installation of saver assembly sets at TL no. 27/3 & 28 (Total 6 sets out of 6 sets are to be installed)	MSETCL	MSETCL	Work at Airoli-Katai naka road & MIDC road crossing & Slum crossing at Rabale & at Mahape-Shil Phata road flyover crossing. Due to M/C Configuration ouage is requires as follows: 1) 220kV Kharghar-Borivali-II: 01.06.2024 @ 07:00 Hrs to 18:00 2) 220 kV Kalwa-Siemens line: 01.06.2024 @ 07:00 Hrs to 13:00 Hrs. 3) 220 kV Mahape-Reliance line 01.06.2024 @ 13:30	MOCM	Availed in night hours	U
8	220 KV	GHODBUNDER	DAHANU - GHODBUNDER CKT - 2	01-Jun-24	14:00	01-Jun-24	16:00	D	Pre-Monsoon Activity of CB Covering	AEML	AEML	Line will in service through TBC	MOCM		A

Maharashtra State Load Despatch Centre															
Monthly Outages(MOCM) from 01/Jun/2024 To 30/Jun/2024															
Note	1) Outages will be apporved on D-1 basis and will be facilitated as per real time loading/system coditions. 2) Outages may be deferred due to outage approved by WRDLC at 400 level in MSETCL/Powergrid Network on D-1 basis 3) A-Approved, P-Pending, D-Deferred. U-Underreview.														
Sr.No.	Voltage	Substation/ Division	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOCM Remark	MOCM Status
9	220	TROMBAY (MSETCL)	SONKHAR - TROMBAY	02-Jun-24	06:00	02-Jun-24	11:00	D	For 1) Safety purpose for Gantry painting work as CCs are on the Stub Bus gantry & WTs are above main Bus gantry & 2) RM work	MSETCL	MSETCL	For 1) Safety purpose for Gantry painting work as CCs are on the Stub Bus gantry & WTs are above main Bus gantry & 2) RM work	MOCM		A
10	220	KALWA	KALWA - PANCHANAND	02-Jun-24	11:00	02-Jun-24	18:00	D	For replacing STN H/w with DTN h/w of all three phases at Shil-phata Road crossing loc. No. 677-678, also to replace old rusted d-shackles at TL no. 674 & 673	MSETCL	MSETCL	Work to be carried out to avoid any mishap / occurrence during monsoon season.	MOCM		A
11	400	KALWA	400/220/20 KV 500MVA ICT - 1 @ KALWA	02-Jun-24	05:00	02-Jun-24	08:00	D	Pre-monsoon maintenance activity	MSETCL	MSETCL	Pre-monsoon maintenance activity	MOCM	All other ICT will be in service. Load to be managed on other 3 ICT.	A
12	220	COLOURCHEM	COLOURCHEM - TEMGHAR	02-Jun-24	06:00	02-Jun-24	10:00	D	Pre-monsoon maintenance work which include polythene paper wrapping on CB , CT terminal box , LA IR test , Insulator cleaning and R&M work.	MSETCL	MSETCL	Pre-monsoon maintenance work which include polythene paper wrapping on CB , CT terminal box , LA IR test , Insulator cleaning and R&M work.	MOCM		A
13	220	SONKAR	BUS COUPLER @ SONKAR	02-Jun-24	06:00	02-Jun-24	11:00	D	Premonsoon maintenance.	MSETCL	MSETCL	Premonsoon maintenance.	MOCM		A
14	110 KV	KHOPOLI	ZONE 1 (BUS SECTION 1& 2) @ KHOPOLI	02-Jun-24	06:00	02-Jun-24	16:00	D	Main Bus GOD R/M, PT 1 LA R/M & test, DT 5 relay test	TATA	TATA	0600 to 0800 hrs Khopoli Karanjade Khopoli Bhivpuri 2 and Khopoli Davdi will remain charge from remote end after 0800 hrs Khopoli B Karanjade will controlled by Transfer breaker. Unit 7 N.A	MOCM	Khopoli generation 48 MW to be available .	A
15	220	BORIVALI	BORIVALI - CTRLS CKT	02-Jun-24	07:00	02-Jun-24	17:00	D	For the installation of saver assembly sets at TL no. 27/3, 28 & 43 (Total 9 sets out of 60 sets are to be installed)	MSETCL	MSETCL	Simultaneously outage is required on 220 kV CtrlS-Borivali line & 220 kV Kalwa-Tifpl & Pawane Tap line due to M/C configuration.	MOCM	Availed in night hours	U
16	220	KALWA	TIFIL - KALWA	02-Jun-24	07:00	02-Jun-24	17:00	D	For the installation of saver assembly sets at TL no. 27/3, 28 & 43 (Total 9 sets out of 60 sets are to be installed)	MSETCL	MSETCL	Simultaneously outage is required on 220 kV CtrlS-Borivali line & 220 kV Kalwa-Tifpl & Pawane Tap line due to M/C configuration. 3) As 220kV Pawane S/stn is tapped on 220kV Kalwa-TFIPL line, 220kV Pawane S/stn will be in dark during the outage. LV Load will be diverted by MSEDCL.	MOCM	Availed in night hours	U
17	220	TROMBAY (MSETCL)	220/100 KV 200 MVA ICT 2 @ TROMBAY	02-Jun-24	08:00	02-Jun-24	18:00	D	For 1)Diagnostic testing, 2) Premonsoon maintenance, 3)RM work & 4) Gantry painting in 220KV Switchyard & tower painting work in 100KV Switchyard.	MSETCL	MSETCL	For 1)Diagnostic testing, 2) Premonsoon maintenance, 3)RM work & 4) Gantry painting in 220KV Switchyard & tower painting work in 100KV Switchyard.	MOCM	All other ICTs will be in service at Trombay (M) and Trombay (T). Load will be in service	A
18	220	VASAI-II	220/100 KV 100 MVA ICT 2 @ VASAI II	02-Jun-24	09:00	02-Jun-24	18:00	D	Diagnostic Testing, Pre-monsoon Maintenance Work and Relay Replacement Work by Testing Unit, Kalwa.	MSETCL	MSETCL	Diagnostic Testing, Pre-monsoon Maintenance Work and Relay Replacement Work by Testing Unit, Kalwa.	MOCM	Load to be managed on IC	A
19	110 KV	KHOPOLI	KHOPOLI - BHIVPURI CKT - 2	03-Jun-24	05:00	03-Jun-24	09:00	D	Disconnection of Line Side to CT jumpers for faciliating CT replacement	TATA	TATA	Khopoli Bhivpuri 1 and other hydro lines will remain in service.	MOCM	Line to be in service through TBC after outage,	A
20	220 KV	GHODBUNDER	GHODBUNDER - GORAI	03-Jun-24	08:00	03-Jun-24	10:00	D	Pre-Monsoon Activity of CB Covering	AEML	AEML	Line will be in service through TBC	MOCM		A
21	220 KV	GHODBUNDER	VERSOVA - GHODBUNDER	03-Jun-24	11:00	03-Jun-24	13:00	D	Pre-Monsoon Activity of CB Covering	AEML	AEML	Line will be in service through TBC	MOCM		A

Maharashtra State Load Despatch Centre															
Monthly Outages(MOCM) from 01/Jun/2024 To 30/Jun/2024															
Note	1) Outages will be apporved on D-1 basis and will be facilitated as per real time loading/system coditions.														
	2) Outages may be deferred due to outage approved by WRDLC at 400 level in MSETCL/Powergrid Network on D-1 basis														
	3) A-Approved, P-Pending, D-Deferred. U-Underreview.														
Sr.No.	Voltage	Substation/ Division	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOCM Remark	MOCM Status
22	220 KV	TROMBAY (TATA)	TROMBAY - VIKHROLI (GIS) CKT - 4	03-Jun-24	22:00	04-Jun-24	06:00	D	Resagging of conductor at S G Barve Metro - 2B crossing	TATA	TATA	220KV Trombay Vikhroli 1,2,3 will remain in service.Outage required with Waghivali Dharavi 7 Antop hill 1	MOCM		A
23	220 KV	DHARAVI	WAGHIVALI - DHARAVI 7	03-Jun-24	22:00	04-Jun-24	06:00	D	Resagging of conductor at S G Barve Metro - 2B crossing	TATA	TATA	Waghivali Dharavi 8 will remain in service In 220KV N-1 contingency Bhira generation will restricted to 183MW. Outage required with 220KV Trombay Vikhroli 4 line.	MOCM		A
24	220	APTA	URAN - APTA 3	04-Jun-24	16:00	04-Jun-24	22:00	D	"Routine line maintenance work. "	MSETCL	MSETCL	..	MOCM		A
25	220 KV	WAGHIVALI	WAGHIVALI - DHARAVI 7	04-Jun-24	22:00	05-Jun-24	06:00	D	Resagging of conductor at S G Barve Metro - 2B crossing	TATA	TATA	220KV Waghivali Dharavi 8 will remain in service. In 220KV N-1 contingency Bhira generation will restricted to 183 MW	MOCM		A
26	110 KV	AMBERNATH	AMBERNATH - KALYAN CKT - 1	05-Jun-24	05:00	05-Jun-24	09:00	D	Insulator replacement	TATA	TATA	Ambernath Kalyan 2 and other hydro lines will remain in service	MOCM		A
27	220	ONGC PANVEL	ONGC PANVEL - TSS PANVEL	05-Jun-24	08:00	05-Jun-24	18:00	D	For SCADA testing and complete charging of Karanjade TSS.(LILO arrangement) and OPGW stringing	MSETCL	MSETCL	Outage proposed by EHV Project Dn. Kalwa	MOCM	Noc required from Railway/After Detailed discussion	U
28	220	TROMBAY (MSETCL)	220/100 KV 200 MVA ICT 3 @ TROMBAY	06-Jun-24	05:00	06-Jun-24	09:00	D	For 1) Premonsoon maintenance work & 2) RM work.	MSETCL	MSETCL	For 1) Premonsoon maintenance work & 2) RM work.	MOCM	All other ICTs will be in service at Trombay (M) and Trombay (T). Load will be in service	A
29	110 KV	KALYAN	KALWA KALYAN	06-Jun-24	06:00	06-Jun-24	10:00	D	Guard wire replacement	TATA	TATA	110KV KKS 1,2, Ambernath Kalyan 1,2 will remain in service.	MOCM		A
30	220	KALWA	NTT - KALWA	06-Jun-24	06:00	12-Jun-24	18:00	D	For making LILO at 220 KV GIS Gigaplex S/St also during this outage, removing of jumper and making auxillary jumper for 220 KV NTT Neon S/Stn.	MSETCL	MSETCL	For making LILO at 220 KV GIS Gigaplex S/St also during this outage, removing of jumper and making auxillary jumper for 220 KV NTT Neon S/Stn.	MOCM	After Detailed discussion	U
31	220	ONGC PANVEL	ONGC PANVEL - TSS PANVEL	06-Jun-24	08:00	06-Jun-24	18:00	D	For SCADA testing and complete charging of Karanjade TSS.(LILO arrangement) and OPGW stringing	MSETCL	MSETCL	Outage proposed by EHV Project Dn. Kalwa	MOCM	Noc required from Railway/After Detailed discussion	U
32	220	VIRAJ	DAHANU - VIRAJ	06-Jun-24	10:00	06-Jun-24	13:00	D	Pre Monsoon Maintenance.	MSETCL	MSETCL	Pre Monsoon Maintenance.	MOCM		A
33	220	VIRAJ	BOISAR II - VIRAJ	06-Jun-24	14:00	06-Jun-24	18:00	D	Pre Monsoon Maintenance.	MSETCL	MSETCL	Pre Monsoon Maintenance.	MOCM		A
34	220	MULUND	MULUND - GIS BHANDUP	07-Jun-24	05:00	07-Jun-24	09:00	D	1.CT TAN DELTA & CT IR TAKEN 2. RMW WORK DONE.	MSETCL	MSETCL	1.CT TAN DELTA & CT IR TAKEN 2. RMW WORK DONE.	MOCM		A
35	220	KALWA	TEMGHAR - KALWA	07-Jun-24	05:00	07-Jun-24	10:00	D	Diagnostic testing & RM work.	MSETCL	MSETCL	Diagnostic testing & RM work.	MOCM		A
36	110 KV	BHIVPURI	KHOPOLI - BHIVPURI CKT - 1	07-Jun-24	06:00	07-Jun-24	10:00	D	R/M of GOD and breaker testing	TATA	TATA	110KV Khopoli Bhivpuri 2 and other hydro lines will reamin in service	MOCM		A
37	220	SIEMENS	KALWA - SIEMENS	07-Jun-24	07:00	07-Jun-24	12:00	D	Pre-Monsoon Maintenance work.	MSETCL	MSETCL	Pre-Monsoon Maintenance work.	MOCM		A
38	220	KHARGHAR	KHARGHAR - SONKHAR	07-Jun-24	07:00	07-Jun-24	12:00	D	For the installation of saver assembly sets at TL no. 679 (Total 3 sets out of 6 sets are to be installed)	MSETCL	MSETCL	1) Due to M/C configuration outage required on both 220 kv Kharghar-Sonkhar line & 220 kv Kharghar-Netmagic line. 2) There is 400 kv Kharghar-Vikhroli 1 & 2 line crossing at this location.	MOCM	Availed in night hours	U

Maharashtra State Load Despatch Centre															
Monthly Outages(MOCM) from 01/Jun/2024 To 30/Jun/2024															
Note	1) Outages will be apporved on D-1 basis and will be facilitated as per real time loading/system coditions. 2) Outages may be deferred due to outage approved by WRDLC at 400 level in MSETCL/Powergrid Network on D-1 basis 3) A-Approved, P-Pending, D-Deferred. U-Underreview.														
Sr.No.	Voltage	Substation/ Division	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOCM Remark	MOCM Status
39	220	KHARGHAR	KHARGHAR - NET MAGIC GIS	07-Jun-24	07:00	07-Jun-24	12:00	D	For safety purpose during saver assembly installation work on 220 kV Kharghar-Sonkhar line	MSETCL	MSETCL	1) Due to M/C configuration outage required on both 220 kV Kharghar-Sonkhar line & 220 kV Kharghar-Netmagic line. 2) There is 400 kV Kharghar-Vikhroli 1 & 2 line crossing at this location.	MOCM	Availed in night hours	U
40	220	WADA	PADGHE - WADA	07-Jun-24	09:00	07-Jun-24	18:00	D	Insulator replacement Work identified in PID.	MSETCL	MSETCL	Insulator replacement Work identified in PID.	MOCM		A
41	220	BORIVALI	220/100 KV 200 MVA ICT 1 @ BORIVALI	07-Jun-24	10:00	07-Jun-24	18:00	D	To Carry out Pre-Monsoon Protection work and Cooling trials of ICT.	MSETCL	MSETCL	ICT-1 rating is 100MVA, 220/100kV at site	MOCM	All other ICTs will be in service Load will be managed on other ICT.	A
42	220	SIEMENS	SIEMENS - RELIANCE GIS	07-Jun-24	13:00	07-Jun-24	16:00	D	Pre-Monsoon Maintenance work.	MSETCL	MSETCL	Pre-Monsoon Maintenance work.	MOCM		A
43	220 KV	TROMBAY (TATA)	TROMBAY - DHARAVI 9	07-Jun-24	21:00	08-Jun-24	04:00	D	Attending Hot spot at loc 23A 'C' phase	TATA	TATA	220KV Trombay Dharavi 5,6 will remain in service. Considering N-1 contingency Bhira generation will kept as per line loading.	MOCM		A
44	400	PADGHE	400/220/33 KV 600 MVA ICT - 4 @ PADGHE	08-Jun-24	00:00	09-Jun-24	06:00	D	1. Oil Top in Yph unit due to radiator leakage 2) Hot Spot attending work if any 3) Replacement of faulty YpH WTI 4) premonsson maint work	MSETCL	MSETCL	weather condition should be clear	MOCM	Subjected to real time loading	U
45	220	TEMGHAR	PADGHE - TEMGHAR - 1	08-Jun-24	00:00	09-Jun-24	23:00	D	1) 220 kV Padghe -Temghar line 1 CB and Line isolator replacement and wave trap erection work under bay strengthening scheme	MSETCL	MSETCL	1) 220 kV Padghe iTemghar line 1 CB and Line isolator replacement and wave trap erection work under bay strengthening scheme	MOCM	After stablising demand in Mansoon	D
46	220	KALWA	KALWA - BORIVALI	08-Jun-24	04:30	08-Jun-24	08:30	D	R ph LA replacement work due to LCM value heigher side .	MSETCL	MSETCL	R ph LA replacement work due to LCM value heigher side .	MOCM		A
47	110 KV	BHIRA (T)	BHIRA (T) - DAVDI	08-Jun-24	06:00	08-Jun-24	10:00	D	CVT and Ct testing	TATA	TATA	Khopoli Davdi and other hydro lines will remain in service	MOCM		A
48	220	APTA	URAN - APTA 2	08-Jun-24	09:00	08-Jun-24	18:00	D	"Routine line maintenance work." "	MSETCL	MSETCL	..	MOCM		A
49	220	NERUL	MAIN BUS SECTION - 2 @ NERUL	09-Jun-24	04:00	09-Jun-24	11:00	D	1) Y ph 220KV main bus conductor replacement work will be carried out. and O/H of 220KV Bus Iso & Bus section Isolator. 2) 220KV Kharghar line will be under outage for Diagnostic and testing work.	MSETCL	MSETCL	1) Bays fall in section II are 220KV TF II,kharghar line,TF IV,220KV TSS Line 1. 220/33-22KV TF 2 will be kept OFF and load diverted on other TF. 2) 220/33-22KV TF 4 will be taken on TBC. 3) 220KV TSS I load will be shifted on 220KV TSS II.	MOCM	Subject to revival of Kharghar sonkhar damaged bushing	U
50	400	KALWA	400/220 KV 3X200 MVA ICT - 2 @ KALWA	09-Jun-24	05:00	09-Jun-24	08:00	D	premonsoon maintenance activity	MSETCL	MSETCL	premonsoon maintenance activity	MOCM	All other ICT will be in service. Load to be managed on other 3 ICT.	A
51	220	KALWA	INTERCONNECTOR @ KALWA	09-Jun-24	05:00	09-Jun-24	08:30	D	hot spot attending work	MSETCL	MSETCL	hot spot attending work	MOCM		A
52	220 KV	TROMBAY (TATA)	TROMBAY - VIKHROLI (GIS) CKT - 4	09-Jun-24	06:00	09-Jun-24	16:00	D	CT & LINE CT TESTING.	TATA	TATA	220KV Trombay Vikhroli 1,2 and 3 will remain in service	MOCM		A
53	220	APTA	APTA - PRINT HOUSE LINE	09-Jun-24	07:00	09-Jun-24	17:00	D	For replacing STN H/w with DTN h/w of all three phases at Shil-phata Road crossing loc. No. 677-678	MSETCL	MSETCL	Work to be carried out to avoid any mishap / occurrence during monsoon season.	MOCM	Noc required from Print House	A

Maharashtra State Load Despatch Centre															
Monthly Outages(MOCM) from 01/Jun/2024 To 30/Jun/2024															
Note	1) Outages will be apporved on D-1 basis and will be facilitated as per real time loading/system coditions.														
	2) Outages may be deferred due to outage approved by WRDC at 400 level in MSETCL/Powergrid Network on D-1 basis														
	3) A-Approved, P-Pending, D-Deferred. U-Underreview.														
Sr.No.	Voltage	Substation/ Division	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOCM Remark	MOCM Status
54	220	NERUL	KHARGHAR - NERUL	09-Jun-24	07:00	09-Jun-24	18:00	D	For the installation of saver assembly sets at TL no. 678 & 679 (Total 6 out of 6 sets are to be installed).	MSETCL	MSETCL	Due to M/C simultaneous outage is required on 220 kV Kharghar-Borivali line & 220 kV Kharghar-Nerul line.	MOCM	Availed in night hours	U
55	220	BORIVALI	KHARGHAR - BORIVALI CKT - 2	09-Jun-24	07:00	09-Jun-24	18:00	D	For the installation of saver assembly sets at TL no. 678 & 679 (Total 6 sets out of 66 sets are to be installed) Total completed - 6 sets	MSETCL	MSETCL	Due to M/C simultaneous outage is required on 220 kV Kharghar-Borivali line & 220 kV Kharghar-Nerul line.	MOCM	Availed in night hours	U
56	220 KV	MAHALAXMI GIS (T)	220/110/33KV 250 MVA ICT-5 @ MAHALAXMI GIS (T)	09-Jun-24	08:00	09-Jun-24	17:00	D	R/M	TATA	TATA	ICT 4 and Transformer 8 will 33KV load	MOCM		A
57	220	BOISAR-II	BOISAR II - VIRAJ	09-Jun-24	09:00	09-Jun-24	17:00	D	B/U Relay Retrofitting Work at 220kV Boisar-II S/S.	MSETCL	MSETCL	B/U Relay Retrofitting Work at 220kV Boisar-II S/S.	MOCM		A
58	220	VASAI-II	220/100 KV 100 MVA ICT 1 @ VASAI-II	09-Jun-24	09:00	09-Jun-24	18:00	D	Diagnostic Testing, Pre-monsoon Maintenance Work and Relay Replacement Work by Testing Unit, Kalwa.	MSETCL	MSETCL	Diagnostic Testing, Pre-monsoon Maintenance Work and Relay Replacement Work by Testing Unit, Kalwa.	MOCM	Load to be managed on IC	A
59	220	KALWA	220/100 KV 200 MVA ICT 2 @ KALWA	09-Jun-24	09:00	09-Jun-24	18:00	D	Diagnostic testing & RM work	MSETCL	MSETCL	Diagnostic testing & RM work	MOCM	All other ICT will be in service. Load to be managed on other 3 ICT.	A
60	220	TROMBAY (MSETCL)	BUS SECTION - 3 @ TROMBAY	09-Jun-24	11:00	09-Jun-24	18:00	D	For 1) PT selection scheme work by PAC unit Kalwa, 2) Diagnostic testing & 3) RM work.	MSETCL	MSETCL	220 KV Bus section-3 which includes: 1) 220KV Trombay Mulund line, 2) 220kV TATA TIE-1 Line & 3) 220KV Bus Sectionalizer Breaker	MOCM		A
61	110 KV	KALYAN	AMBERNATH - KALYAN CKT - 2	10-Jun-24	05:00	10-Jun-24	09:00	D	Insulator replacement	TATA	TATA	10KV Ambernath Kalyan 1 and other Hydro lines will remain in service	MOCM		A
62	220	KHANDESHWAR	PANVEL TSS - KHANDESHWAR	10-Jun-24	08:00	20-Jun-24	16:00	D	1) For making LILO of 220KV Cable at upcoming 220/33KV Panvel Timber Market GIS. 2) For the MRVCL height rising work. Only ( MDN+12) Tower erection work and 3 nos conductor stringing over railway line at Panvel site.	MSETCL	MSETCL	1) For making LILO work at 220/33KV Panvel Timber Market GIS, recommended for bunching at loc. 648 & 649 for availability of Second source to 220kV ONGC & 220kV TSS Panvel. 2) For the MRVCL height rising work not feasible for bunching at loc. 648 & 649 hence 220kV ONGC & 220kV TSS Panvel will be having Single source i.e. 220kV ONGC - Kandlagaon	MOCM	Det	U
63	220	KHANDESHWAR	TOPWORTH - KHANDESHWAR	10-Jun-24	08:00	20-Jun-24	16:00	D	"1) For making LILO of 220KV Cable at upcoming 220/33KV Panvel Timber Market GIS. 2) For erection of 1 no lattic tower ND+6 for hegiht raising work of MRVCL and 03 nos conductor stringing over railway line at Chikhale site."	MSETCL	MSETCL	"1) For making LILO work at 220/33KV Panvel Timber Market GIS, recommended for bunching at loc. 648 & 649 for availability of Second source to 220kV ONGC & 220kV TSS Panvel. 2) For the MRVCL height rising work not feasible for bunching at loc. 648 & 649 hence 220kV ONGC & 220kV TSS Panvel will be having Single source i.e. 220kV ONGC - Kandlagaon "	MOCM		U
64	220	TAMBATI	TAMBATI - ADLABS	11-Jun-24	16:00	11-Jun-24	23:00	D	"Routine line maintenance work." "	MSETCL	MSETCL	..	MOCM	Noc required from Adlab	A
65	220	KHARGHAR	KHARGHAR - BORIVALI CKT - 2	11-Jun-24	08:00	11-Jun-24	15:00	D	For safety purpose only during LILO work on 220 KV Kalwa-Tiffle Line to 220kV Pawane S/stn.	MSETCL	MSETCL	For safety purpose only during LILO work on 220 KV Kalwa-Tiffle Line to 220kV Pawane S/stn.	MOCM		U

Maharashtra State Load Despatch Centre															
Monthly Outages(MOCM) from 01/Jun/2024 To 30/Jun/2024															
Note	1) Outages will be apporved on D-1 basis and will be facilitated as per real time loading/system coditions. 2) Outages may be deferred due to outage approved by WRDC at 400 level in MSETCL/Powergrid Network on D-1 basis 3) A-Approved, P-Pending, D-Deferred. U-Underreview.														
Sr.No.	Voltage	Substation/ Division	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOCM Remark	MOCM Status
66	220	KALWA	KALWA - TFIPL	11-Jun-24	08:00	11-Jun-24	18:00	D	For removing of jumper and making LIO at 220 KV Pawane GIS S/stn.	MSETCL	MSETCL	For safety purpose outage is also required on 220KV Kharghar-Borivali-II	MOCM		U
67	110 KV	BHOKARPADA	KARANJADE - BHOKARPADA	12-Jun-24	05:00	12-Jun-24	09:00	D	Insulator replacement	TATA	TATA	110KV Khopoli Karanjade and other Hydro lines will remain in service	MOCM		A
68	220 KV	VERSOVA (AEML)	BOISAR - VERSOVA	12-Jun-24	09:00	12-Jun-24	12:00	D	Pre-monsoon Maintenance work	AEML	AEML	Line will be in service through TBC	MOCM		A
69	400	PADGHE	80 MVAR BUS REACTOR @ PADGHE	12-Jun-24	09:00	12-Jun-24	19:00	D	1) Relay replacement work of Reactor 2) Bay maint work 3) Replacement of 29C bus PG isolator	MSETCL	MSETCL	weather condition should be clear	MOCM		A
70	220 KV	VERSOVA (AEML)	DAHANU - VERSOVA	12-Jun-24	14:00	12-Jun-24	17:00	D	Pre-monsoon Maintenance work	AEML	AEML	Line will be in service through TBC	MOCM		A
71	110 KV	AMBERNATH	NERAL - AMBERNATH	13-Jun-24	06:00	13-Jun-24	10:00	D	Installation of Vibration dampers	TATA	TATA	Bhivpuri Ambernath and other Hydro lines will remain in service	MOCM		A
72	220	BORIVALI	GIS BHANDUP - BORIVALI	13-Jun-24	07:00	15-Jun-24	19:00	D	Stringing on Twin monopole in between Loc. 22-23 for MMRDA.	MSETCL	MSETCL	Simultaneous outage is required on 220 KV Kharghar Borivali -II & 220 KV Borival- Bhandup.	MOCM		U
73	220	BORIVALI	KHARGHAR - BORIVALI CKT - 2	13-Jun-24	07:00	15-Jun-24	19:00	D	Stringing on Twin monopole in between Loc. 22-23 for MMRDA	MSETCL	MSETCL	Simultaneous outage is required on 220 KV Kharghar Borivali -II & 220 KV Borival- Bhandup.	MOCM		U
74	220 KV	VERSOVA (AEML)	GOREGAON - VERSOVA CKT - 1	13-Jun-24	09:00	13-Jun-24	12:00	D	Pre-monsoon Maintenance work	AEML	AEML	Line will be in service through TBC	MOCM		A
75	220 KV	VERSOVA (AEML)	GOREGAON - VERSOVA CKT - 2	13-Jun-24	14:00	13-Jun-24	17:00	D	Pre-monsoon Maintenance work	AEML	AEML	Line will in service throigh TBC	MOCM		A
76	110 KV	BHIVPURI	TATA BHIVPURI MSETCL NERAL	14-Jun-24	05:00	14-Jun-24	09:00	D	R/M of TBS GOD and Testing	TATA	TATA	110KV Ambernath and Neral line and other hydro lines will remain in service	MOCM		A
77	220	MAHAPE	MAHAPE - TFIPL	14-Jun-24	06:00	14-Jun-24	10:00	D	Pre-Monsoon Maintenance work at both ends Substation.	MSETCL	MSETCL	Pre-Monsoon Maintenance work at both ends Substation.	MOCM		A
78	400	PADGHE	400/220/33 KV 315 MVA ICT - 2 @ PADGHE	14-Jun-24	20:00	15-Jun-24	06:00	D	1) Replacement of Differential relay 2) Bay Maint work 3) MTAMC work 4) replacement of 29C bus PG isolator	MSETCL	MSETCL	weather condition should be clear	MOCM	Subjected to real time loading	U
79	220	BOISAR-II	BORIVALI - BOISAR II LINE	14-Jun-24	06:00	16-Jun-24	22:00	D	Line Bay shifting at 220kV Boisar-II S/S (from Bay No. 14 to Bay No. 13) under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S. Note: Outages scheduled on 220kV PGCIL-Boisar Lines 1 & 3 on dated 15.06.2024 to 17.06.2024 are correlated to this work	MSETCL	MSETCL	Note: Outages proposed in OCCM on 220kV PGCIL-Boisar Lines 1 & 3 on dated 15.06.2024 to 17.06.2024 are correlated to this work.	MOCM		U
80	220	MULUND	KALWA - MULUND 1	14-Jun-24	07:00	14-Jun-24	13:00	D	For the installation of saver assembly sets at TL no. 4 & 7 (Total 6 sets out of 6 sets are to be installed)	MSETCL	MSETCL	Due to M/C configuration simultaneous outage is required on 220 kV Kharghar-Borivali line & 220 kV Kalwa-Mulund 1 line.	MOCM	Availed in night hours	U

Maharashtra State Load Despatch Centre															
Monthly Outages(MOCM) from 01/Jun/2024 To 30/Jun/2024															
Note	1) Outages will be apporved on D-1 basis and will be facilitated as per real time loading/system coditions. 2) Outages may be deferred due to outage approved by WRDC at 400 level in MSETCL/Powergrid Network on D-1 basis 3) A-Approved, P-Pending, D-Deferred. U-Underreview.														
Sr.No.	Voltage	Substation/ Division	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOCM Remark	MOCM Status
81	220	BORIVALI	KHARGHAR - BORIVALI CKT - 2	14-Jun-24	07:00	14-Jun-24	13:00	D	For the installation of saver assembly sets at TL no. 4 & 7 (Total 6 sets out of 66 sets are to be installed) Total completed - 6 sets	MSETCL	MSETCL	Due to M/C configuration simultaneous outage is required on 220 kV Kharghar-Borivali line & 220 kV Kalwa-Mulund 1 line.	MOCM	Availed in night hours	U
82	220 KV	VERSOVA (AEML)	VERSOVA - GORAI	14-Jun-24	09:00	14-Jun-24	14:00	D	Pre-monsoon Maintenance work	AEML	AEML	Line will be in service through TBC	MOCM		A
83	220	BHAVEGHAR	BHAVEGHAR - ROMA	14-Jun-24	09:00	14-Jun-24	18:00	D	Insulator replacement Work identified in PID.	MSETCL	MSETCL	Insulator replacement Work identified in PID.	MOCM		A
84	220 KV	TROMBAY (TATA)	BUS SECTION - 4 @ TROMBAY (TATA)	14-Jun-24	23:00	15-Jun-24	06:00	D	LBBU and Relay testing	TATA	TATA	220KV Bus 2+4+6 will operated sectionalized. Unit 7 will remain in service	MOCM		A
85	220 KV	BORIVALI (TATA)	TATA BORIVLI MSETCL BORIVLI - 4	15-Jun-24	05:00	15-Jun-24	09:00	D	Protection testing & trials	TATA	TATA	220KV BO BO 5, Salsette Borivali 1,2, Tata Borivali AEML Borivali , Borivali Aarey lines will remain in service.	MOCM		A
86	220	BORIVALI	KALWA - BORIVALI	15-Jun-24	07:00	15-Jun-24	18:00	D	For the installation of saver assembly sets at TL no. 4, 7, 20, 21, 22 & 23 (Total 17 sets out of 33 sets are to be installed) Total Completed - 16 sets	MSETCL	MSETCL	Due to M/C configuration simultaneous outage is required on 220 kV CtrlS-Borivali line & 220 kV Kalwa-Borivali line.	MOCM	Availed in night hours	U
87	220	BORIVALI	BORIVALI - CTRLS CKT	15-Jun-24	07:00	15-Jun-24	18:00	D	For the installation of saver assembly sets at TL no. 4, 7, 20, 21, 22 & 23 (Total 15 sets out of 33 sets are to be installed)	MSETCL	MSETCL	Due to M/C configuration simultaneous outage is required on 220 kV CtrlS-Borivali line & 220 kV Kalwa-Borivali line.	MOCM	Availed in night hours	U
88	400	KALWA	400/220 KV 500MVA ICT - 4 @ KALWA	16-Jun-24	05:00	16-Jun-24	08:00	D	premonsoon maintenance activity	MSETCL	MSETCL	premonsoon maintenance activity	MOCM	All other ICT will be in service. Load to be managed on other 3 ICT.	A
89	220	TEMGHAR	BUS SECTION-4 @ TEMGHAR	16-Jun-24	06:00	16-Jun-24	20:00	D	1) 220kV Bus strengthing work (Replacement of Bus section 4 bus conductor 0.4 ACSR to 0.5 ACSR Moose)  2) 220kv Padgha Temghar line 2 Bus Isolator replacement 3) 220 kV Padgha-Temghar 2 & Kalwa line IED commissioning work.	MSETCL	MSETCL	Bay under outage as follows: 220KV Padgha-Temghar-2, 220 KV Temghar -Kalwa lines & 220/22kv 50 MVA T/F No- 4 & 5 (TF no 4 &5 load shall be shifted to Tf no. 2 & 3 Resp.)	MOCM		U
90	220	BORIVALI	GIS BHANDUP - BORIVALI	16-Jun-24	07:00	16-Jun-24	13:00	D	For the installation of saver assembly sets at TL no. 22, 23, 25 & 26 (Total 15 sets out of 21 sets are to be installed) Total completed - 15 sets	MSETCL	MSETCL	1) Work at Fortis Hospital Road Crossing, LBS road crossing & slum crossing at Sonapur. 2) Due to M/C Configuration ouage is requires as follows: 1) 220kV Kharghar-Borivali-II: 16.06.2024 @ 07:00 Hrs to 18:00 2) 220 kV Bhandup GIS-Borivali line: 16.06.2024 @ 07:00 Hrs to 13:00 Hrs. 3) 220 kV Mulund-Bhandup GIS line: 16.06.2024 @ 13:30 Hrs to 18:00 Hrs.	MOCM	Availed in night hours	U
91	220 KV	TROMBAY (TATA)	TROMBAY - ANTOP HILL CKT - 2	16-Jun-24	07:00	16-Jun-24	16:00	D	Protection trial & LBBU TESTING, CT & CVT Testing	TATA	TATA	220KV Waghivali Dharavi 7 Antop hill 1 will feed Antop hill load	MOCM		A

Maharashtra State Load Despatch Centre															
Monthly Outages(MOCM) from 01/Jun/2024 To 30/Jun/2024															
Note	1) Outages will be apporved on D-1 basis and will be facilitated as per real time loading/system coditions. 2) Outages may be deferred due to outage approved by WRDLC at 400 level in MSETCL/Powergrid Network on D-1 basis 3) A-Approved, P-Pending, D-Deferred, U-Underreview.														
Sr.No.	Voltage	Substation/ Division	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOCM Remark	MOCM Status
92	220	BORIVALI	KHARGHAR - BORIVALI CKT - 2	16-Jun-24	07:00	16-Jun-24	18:00	D	For the installation of saver assembly sets at TL no. 20, 21, 22, 23, 25 & 26 (Total 24 sets out of 66 sets are to be installed) Total Completed - 6 sets.	MSETCL	MSETCL	1) Work at Fortis Hospital Road Crossing, LBS road crossing & slum crossing at Sonapur. 2) Due to M/C Configuration ouage is requires as follows: 1) 220kV Kharghar-Borivali-II: 16.06.2024 @ 07:00 Hrs to 18:00 2) 220 kV Bhandup GIS-Borivali line: 16.06.2024 @ 07:00 Hrs to 13:00 Hrs. 3) 220 kV Mulund-Bhandup GIS line: 16.06.2024 @ 13:30 Hrs to 18:00 Hrs.	MOCM	Availed in night hours	U
93	220 KV	MAHALAXMI GIS (T)	BUS COUPLER @ MAHALAXMI GIS (T)	16-Jun-24	08:00	16-Jun-24	16:00	D	R/m Testing	TATA	TATA	All 220KV equipments will taken on bus 1/ 2	MOCM		A
94	110 KV	BHOKARPADA	KARANJADE - BHOKARPADA	16-Jun-24	08:00	16-Jun-24	16:00	D	Bkr, CT, LS GOD, TBS GOD	TATA	TATA	110KV Khopoli Karanjade and other Hydro lines will remain in service	MOCM		A
95	220	VASAI-II	PADGHE - NALASOPARA - VASAI (T)	16-Jun-24	09:00	16-Jun-24	18:00	D	1) Insulator replacement Work identified in PID. 2) Diagnostic Testing and Pre-monsoon Maintenance Work at Vasai s/stn.	MSETCL	MSETCL	1) Insulator replacement Work identified in PID. 2) Diagnostic Testing and Pre-monsoon Maintenance Work at Vasai s/stn.	MOCM	To be done along with project work	U
96	220	KOLSHET	BUS SECTION @ KOLSHET	16-Jun-24	10:00	16-Jun-24	18:00	D	1) CT tan delta, CB timing and CRM. 2) For replacement of Backup relay by PAC division Kalwa.	MSETCL	MSETCL	1) CT tan delta, CB timing and CRM. 2) For replacement of Backup relay by PAC division Kalwa.	MOCM		A
97	220	GIS BHANDUP	MULUND - GIS BHANDUP	16-Jun-24	13:30	16-Jun-24	18:00	D	For the installation of saver assembly sets at TL no. 20 & 21 (Total 6 sets out of 6 sets are to be installed)	MSETCL	MSETCL	1) Work at Fortis Hospital Road Crossing, LBS road crossing & slum crossing at Sonapur. 2) Due to M/C Configuration ouage is requires as follows: 1) 220kV Kharghar-Borivali-II: 16.06.2024 @ 07:00 Hrs to 18:00 2) 220 kV Bhandup GIS-Borivali line: 16.06.2024 @ 07:00 Hrs to 13:00 Hrs. 3) 220 kV Mulund-Bhandup GIS line: 16.06.2024 @ 13:30 Hrs to 18:00 Hrs.	MOCM	Availed in night hours	U
98	110 KV	BHIVPURI	KHOPOLI - BHIVPURI CKT - 1	17-Jun-24	06:00	17-Jun-24	10:00	D	R/M of GOD and Testing	TATA	TATA	110KV Khopoli Bhivpuri 2 and other Hydro lines will remain in service	MOCM		A
99	110 KV	BHOKARPADA	KARANJADE - BHOKARPADA	17-Jun-24	08:00	17-Jun-24	16:00	D	Bkr, CT, LS GOD, TBS GOD	TATA	TATA	110KV Khopoli Karanjade and other Hydro lines will remain in service	MOCM		A
100	220	BORIVALI	GIS BHANDUP - BORIVALI	17-Jun-24	23:00	19-Jun-24	07:00	D	Stringing on Twin monopole in between Loc. 22-23 for MMRDA.	MSETCL	MSETCL	Simultaneous outage is required on 220 KV Kharghar Borivali -II & 220 KV Borival- Bhandup.	MOCM		U
101	220	BORIVALI	KHARGHAR - BORIVALI CKT - 2	17-Jun-24	23:00	19-Jun-24	07:00	D	Stringing on Twin monopole in between Loc. 22-23 for MMRDA	MSETCL	MSETCL	Simultaneous outage is required on 220 KV Kharghar Borivali -II & 220 KV Borival- Bhandup.	MOCM		U
102	220	KOLSHET	KOLSHET - KHARBAO	18-Jun-24	00:00	22-Jun-24	06:00	D	Erection of 1 No M/C Monopole and stringing work for Height rising work of MMRDA Metro 4	MSETCL	MSETCL	Erection of 1 No M/C Monopole and stringing work for Height rising work of MMRDA Metro 4	MOCM		A
103	220	APTA	APTA - TALOJA	18-Jun-24	09:00	18-Jun-24	18:00	D	"Routine line maintenance work." "	MSETCL	MSETCL	..	MOCM		U
104	220 KV	WAGHIVALI	WAGHIVALI - DHARAVI 7	19-Jun-24	06:00	19-Jun-24	10:00	D	Work in vicinity - outage required for preparatory work for UILO of 110kV DV2 Lines for Mandale Project	TATA	TATA	220KV Waghivali Dharavi 8 will remain in service. In 220KV N-1 contingency Bhira generation will restricted to 183 MW	MOCM		A



Maharashtra State Load Despatch Centre															
Monthly Outages(MOCM) from 01/Jun/2024 To 30/Jun/2024															
Note	1) Outages will be apporved on D-1 basis and will be facilitated as per real time loading/system coditions.														
	2) Outages may be deferred due to outage approved by WRDLC at 400 level in MSETCL/Powergrid Network on D-1 basis														
	3) A-Approved, P-Pending, D-Deferred. U-Underreview.														
Sr.No.	Voltage	Substation/ Division	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOCM Remark	MOCM Status
105	220 KV	TROMBAY (MSETCL)	TROMBAY (M) - CHEMBUR CKT-1	19-Jun-24	12:00	19-Jun-24	17:00	D	For bay integration in RTU Panel by PAC unit Kalwa	AEML	MSETCL	For bay integration in RTU Panel by PAC unit Kalwa	MOCM		A
106	220 KV	WAGHIVALI	WAGHIVALI - DHARAVI 8	20-Jun-24	06:00	20-Jun-24	10:00	D	Work in vicinity - outage required for preparatory work for LILO of 110kV DV2 Lines for Mandale Project	TATA	TATA	220KV Waghivali Dharavi 7 will remain in service. In 220KV N-1 contingency Bhira generation will restricted to 183 MW	MOCM		A
107	220	TEMGHAR	BUS SECTION-1 @ TEMGHAR	21-Jun-24	07:00	21-Jun-24	19:00	D	For replacement of existing Twin 0.4 ACSR Zebra Bus conductor with Twin 0.5 Moose conductor of 220 KV Bus section 2 under bay strengthening scheme	MSETCL	MSETCL	1) Outage is required on 220kV Bus section-2 but option not in OMS. 2) Bay under outage as follows 1)220KV Temghar -Padgha-1,(only for 15 min.(07:00 to 07:15 hrs) to change over PT protection from PT 1 to PT 2 bay ) 2)220/22kv 80 MVA T/F No-2 ,(only for 15 min.(07:00 to 07:15 hrs) to change over PT protection from PT 1 to PT 2 bay ) Bay in service without Busbar Protection (Due to PT 1 Bay out)  1) 220 KV Temghar-colorchem line (Radial) 2) 220/22kv 50 MVA T/F No-1 3) 220/22kv 50 MVA T/F No-3	MOCM		U
108	220	BORIVALI	GIS BHANDUP - BORIVALI	21-Jun-24	23:00	23-Jun-24	07:00	D	Stringing on Twin monopole in between Loc. 22-23 for MMRDA.	MSETCL	MSETCL	Simultaneous outage is required on 220 KV Kharghar Borivali -II & 220 KV Borival- Bhandup.	MOCM		U
109	220	BORIVALI	KHARGHAR - BORIVALI CKT - 2	21-Jun-24	23:00	23-Jun-24	07:00	D	Stringing on Twin monopole in between Loc. 22-23 for MMRDA	MSETCL	MSETCL	Simultaneous outage is required on 220 KV Kharghar Borivali -II & 220 KV Borival- Bhandup.	MOCM		U
110	110 KV	BHIRA (T)	BHIRA (T) - KHOPOLI 2	22-Jun-24	06:00	22-Jun-24	10:00	D	CVT ,CT Protection testing	TATA	TATA	110KV Bhira Davdi and other Hydro lines are in service	MOCM		A
111	220 KV	BORIVALI (TATA)	TATA BORIVLI MSETCL BORIVLI - 4	22-Jun-24	07:00	22-Jun-24	12:00	D	Islanding relay testing	TATA	TATA	E.C. 10 mins	MOCM		A
112	220	BOISAR-II	BORIVALI - BOISAR II LINE	22-Jun-24	07:00	22-Jun-24	17:00	D	For the installation of saver assembly sets at TL no. 181, 184, 238 & 239 (Total 24 sets out of 24 sets are to be installed)	MSETCL	MSETCL	Due to M/C configuration simultaneous outage is required on 220 kV Borivali-Boisar line & 220 kV Ghodbunder-Boisar line.	MOCM	Availed in night hours	U
113	220	BOISAR-II	GHODBUNDER - MSETCL BOISAR	22-Jun-24	07:00	22-Jun-24	17:00	D	For the installation of saver assembly sets at TL no. 181, 184, 238 & 239 (Total 24 sets out of 24 sets are to be installed)	MSETCL	MSETCL	Due to M/C configuration simultaneous outage is required on 220 kV Borivali-Boisar line & 220 kV Ghodbunder-Boisar line.	MOCM	Availed in night hours	U
114	220	KALWA	KALWA SALSETTE - 4	22-Jun-24	09:00	22-Jun-24	17:30	D	RM work	MSETCL	MSETCL	RM work	MOCM	220KV kalwa-Salsatte-5 will be taken in service before availing outage	A
115	220 KV	BORIVALI (TATA)	TATA BORIVLI MSETCL BORIVLI - 5	22-Jun-24	13:00	22-Jun-24	17:00	D	Islanding relay testing	TATA	TATA	E.C. 20 mins	MOCM		A
116	220 KV	TROMBAY (TATA)	BUS SECTION-5 @ TROMBAY (TATA)	22-Jun-24	23:00	23-Jun-24	08:00	D	Main bus side GODs R/M and bus bar protection trials	TATA	TATA	220KV Tata Trombay Carnac-5, Trombay Vikhroli 2,Trombay Dharavi-6 & Trombay Antop Hill-2 will remain charge from remote end.ST-7 not available . Station supply will be feed through ST-5. Transfer Breaker-2 will not be available.	MOCM		A
117	220	KOLSHET	KOLSHET - ROMA	23-Jun-24	00:00	24-Jun-24	06:00	D	For Stringing on M/C Tower for Height rising work of MMRDA Metro 4	MSETCL	MSETCL	For Stringing on M/C Tower for Height rising work of MMRDA Metro 4	MOCM	After Detailed discussion	U

Maharashtra State Load Despatch Centre															
Monthly Outages(MOCM) from 01/Jun/2024 To 30/Jun/2024															
Note	1) Outages will be apporved on D-1 basis and will be facilitated as per real time loading/system coditions. 2) Outages may be deferred due to outage approved by WRDLC at 400 level in MSETCL/Powergrid Network on D-1 basis 3) A-Approved, P-Pending, D-Deferred. U-Underreview.														
Sr.No.	Voltage	Substation/ Division	Line/Element	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	Type	MOCM Remark	MOCM Status
118	400	KALWA	400/220/20 KV 500MVA ICT - 3 @ KALWA	23-Jun-24	05:00	23-Jun-24	08:00	D	premonsoon maintenance activity	MSETCL	MSETCL	premonsoon maintenance activity	MOCM	All other ICT will be in service. Load to be managed on other 3 ICT.	A
119	110 KV	BHIVPURI	ZONE 2 (BUS SECTION 3+4+5+6) @ BHIVPURI	23-Jun-24	07:00	23-Jun-24	16:00	D	R/M of Main bu side GODs.	TATA	TATA	Hydro Generation Available - 414 MW. 24 MW unit 9 & 10 not Available. 110kV Khopoli Bhivpuri-1 will remain charge from Khopoli end. Bhivpuri Neral will go on Transfer Breaker.	MOCM		A
120	220	KAMBA	KAMBA - VASAI	23-Jun-24	08:00	23-Jun-24	22:00	D	Work of Replacement of old C & R panel by new C & R panel	MSETCL	MSETCL	Work of Replacement of old C & R panel by new C & R panel	MOCM	To be done along with project work	U
121	220	KALWA	KALWA - SIEMENS	23-Jun-24	09:00	23-Jun-24	17:30	D	CT replacement work due to aging and bus isolator maintenance work and RM work.	MSETCL	MSETCL	CT replacement work due to aging and bus isolator maintenance work and RM work.	MOCM		A
122	220	APTA	APTA - TAMBATI	24-Jun-24	09:00	24-Jun-24	18:00	D	"Routine line maintenance work."	MSETCL	MSETCL	..	MOCM		A
123	220 KV	TROMBAY (MSETCL)	TROMBAY (M) - CHEMBUR CKT-2	26-Jun-24	12:00	26-Jun-24	17:00	D	For bay integration in RTU Panel by PAC unit Kalwa	AEML	MSETCL	For bay integration in RTU Panel by PAC unit Kalwa	MOCM		A
124	220	TIFIL	TIFIL - KALWA	27-Jun-24	06:00	28-Jun-24	18:00	D	For making LILO at 220 KV GIS Nxtra S/St.	MSETCL	MSETCL	For making LILO at 220 KV GIS Nxtra S/St.	MOCM	After Detailed discussion	U
125	220	APTA	ACCIL - APTA	27-Jun-24	09:00	27-Jun-24	18:00	D	"Routine line maintenance work."	MSETCL	MSETCL	..	MOCM	Noc required from ACCIL	A
126	220	TEMGHAR	BUS SECTION - 3 @ TEMGHAR	28-Jun-24	00:00	29-Jun-24	19:00	D	220kv Padgha Temghar line1 Bus Isolator replacement	MSETCL	MSETCL	Bay under outage as follows: 220KV Temghar -Padgha-1, 220/22kv 80 MVA T/F No- 2 (TF no 2 load shall be shifted to Tf no. 1&4 )	MOCM	After Detailed discussion	U
127	400	PADGHE	400/220/33 KV 315 MVA ICT - 3 @ PADGHE	28-Jun-24	09:00	28-Jun-24	19:00	D	1) Replacement of Differential Realy 2) Bay Maint work 3) MTAMC work 4) Bph IV Bushing Tand rechecking work if weather is clear 5.replacement of 29C bus PG isolator replacement work	MSETCL	MSETCL	1) Weather condition should be clear	MOCM		A
128	220	MAHAPE	MAHAPE - TFIPL	29-Jun-24	06:00	30-Jun-24	18:00	D	For making LILO at 220 KV GIS STT Global S/St.	MSETCL	MSETCL	For making LILO at 220 KV GIS STT Global S/St.	MOCM		A
129	220 KV	BHIRA (T)	BHIRA - KARANJADE 7	30-Jun-24	06:00	30-Jun-24	11:00	D	Relay testing	TATA	TATA	Bhira Karanjade 8 will remain in service. In 220KV N-1 contingency Bhira generation will restricted to 183 MW	MOCM		A
130	220	NALASOPARA	PALGHAR - NALASOPARA	30-Jun-24	09:00	30-Jun-24	18:00	D	Insulator replacement Work identified in PID.	MSETCL	MSETCL	Insulator replacement Work identified in PID.	MOCM		A