

Monthly outage list approved in MOCM for the month of December'22

Sr. No.	Voltage level	Name of Substation	Name of the Equipment	From		To		Continuous / Daily Basis	Reason	System owner	Outage requesting circle	Remark	MOCM Remark
				Date	Time	Date	Time						
1	220KV	Trombay B	Tata Trombay- MSETCL Trombay 2	28-11-2022	08:00	3-Dec-22	12:00	Continuous	Breaker replacement at Tata and MSETCL end	Tata power	Tata power	220KV Tata Trombay MSETCL Trombay 1 (Capacity 600MW), Trombay Salsette 1 & 2 (Capacity 300MW each) will remain in service Trombay Load 900 MW	Approved
2	110kV	Khopoli	110 KV Khopoli-Bhivpuri-2	01-12-2022	08:00	1-Dec-22	15:00	Daily	CVT testing	Tata power	Tata power	Emergency clearance 30 Mins Khopoli Bhivpuri Tie -1 will remain in service.	Approved,All other hydro lines to be in service
3	400KV	PADGHE	400KV/220KV PADGHE-ICT-4 (600MVA)	01-12-2022	00:28	15-Dec-22	23:59	Continuous	1. Replacement of B-Ph Unit due to PD and Increasing Key gases Presence of thermal fault. 2. Filtration of Yph Unit 3. Attending oil leakage of R&Y ph Unit from various points. 4. CB overhauling work 5. MTAMC Work. 6. If outage not Approved for replacement TBC charging permission required for 4 Days for CB Mechanism overhauling work.	MSETCL	MSETCL	Weather condition should be clear.	Subject to approval of WRDC
4	400KV	CHAKAN	400KV-CHAKAN-PUNE-PG-1	01-12-2022	10:00	1-Dec-22	18:00	Daily	Installation of spacers, and other maintenance work	MSETCL	MSETCL		Subject to approval of WRDC
5	400KV	KHARGHAR	400KV-KHARGHAR-PUNE-PG-1	01-12-2022	07:00	4-Dec-22	18:00	Continuous	Maintenance work in span between loc no. 33 & 34 w.r.to conductor replacement and insulator replacement	MSETCL	MSETCL		Subject to approval of WRDC
6	400KV	PUNE-GIS	400KV-PUNE-GIS-PUNE-PG-1	01-12-2022	07:00	5-Dec-22	18:00	Continuous	For attending SF6 gas leakage	POWERGRID_WRI	POWERGRID_WRI		Subject to approval of WRDC
7	400KV	KALWA	400KV-KALWA-PADGHE-1	01-12-2022	09:00	10-Dec-22	18:00	Continuous	PID Testing Auto-Reclose function to be out of service.	MSETCL	MSETCL		Subject to approval of WRDC
8	110kV	Khopoli	110 KV Khopoli-Davdi	02-12-2022	08:00	2-Dec-22	15:00	Daily	Line GOD defect attending work	Tata power	Tata power	Emergency clearance 30 Mins. No gen. restriction	Approved, all other hydro lines to be in service.
9	220kV	Padghe	220kV Padghe - Nalasopara	02-12-2022	09:00	2-Dec-22	17:30	Daily	1. Bay Maintenance Work 2. Diagnostic testing work 3. Attending hotspot 4. MTAMC Project work	MSETCL	Padghe		Approved.
10	220KV	220kV Mulund S/s & 400KV RS Kalwa	220kV Mulund-kalwa 2 Line	02-12-2022	08:00	2-Dec-22	17:00	Daily basis	1) CT & CB diagnostic test and bay maintenance work at 220KV Mulund S/s/in 2) R,Y & B CT Replacement work at 400KV RS Kalwa	MSETCL	Kalwa Circle		Approved
11	400KV	LONIKHAND	400KV-LONIKHAND-PUNE-PG-1	02-12-2022	09:00	2-Dec-22	18:00	Daily	For AMP WORK	MSETCL	MSETCL		Subject to approval of WRDC
12	400KV	KHARGHAR	400KV-KHARGHAR-PUNE-PG-1	02-12-2022	10:00	2-Dec-22	18:00	Daily	Outage for modification/power amplifier upgradation of PLCC of 400kV Talegaon-Kharghar line at both ends for LILO of 400kV Talegaon-Kharghar line at Navi Mumbai Substation. and end to end testing of PLCC after completion of modification.	MSETCL	MSETCL	Outage for modification/power amplifier upgradation of PLCC of 400kV Talegaon-Kharghar line at both ends for LILO of 400kV Talegaon-Kharghar line at Navi Mumbai Substation. and end to end testing of PLCC after completion of modification.	Subject to approval of WRDC
13	400KV	KALWA	400KV-KALWA-PADGHE-2	02-12-2022	06:00	4-Dec-22	19:00	Continuous	Replacement of existing Conductor by HTLS Conductor	MSETCL	MSETCL	Replacement of existing Conductor by HTLS Conductor	Subject to approval of WRDC
14	400KV	PADGHE	MAIN BAY - 400KV/220KV PADGHE-ICT-4 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV	02-12-2022	08:00	6-Dec-22	20:00	Continuous	1)CB mechanism overhauling work on HV side 2) 600MVA ICT-IV in service through TBC. 3) A&B Bus PG Isolator Maint. work	MSETCL	MSETCL		Subject to approval of WRDC
15	220KV	Bhira	ICT 1	03-12-2022	06:00	3-Dec-22	19:00	Daily	R/M and Testing	Tata power	Tata power	Emergency clearance 30 Mins. 155MVA ICT 2 will remain in service.No generation Restriction in N-1.	Approved.
16	220 KV	220KV Colourchem S/s.	220 Kv Colourchem-Tenghar Line	03-12-2022	08:00	3-Dec-22	16:00	Daily basis	Annual Diagnostics & Isolator Overhauling & RMW	MSETCL	Kalwa Circle	Bus Jumper will be removed by HLU, Kalwa For Bus-Isolator Maintenance.	Approved. DCH NOC required
17	220kV	220/100-22kV Vasai S/S	220kV Kamba Vasai line	04-12-2022	09:00	4-Dec-22	17:00	Daily basis	Diagnostic Testing and Bay maintenance work	MSETCL	Kalwa Circle		Approved
18	400KV	KALWA	400KV-KALWA-PADGHE-2	04-12-2022	00:00	4-Dec-22	07:00	Daily	For Tapping of 400KV PADGHE - KALWA CKT - 2 line on 400KV Kharghar-Talegaon Line to form Temporary 400KV Kalwa-Kharghar-Talegaon line for carrying out HTLS work on 400KV Kalwa-Padghe-2 line (dead portion after tapping)	MSETCL	MSETCL	For Tapping of 400KV PADGHE - KALWA CKT - 2 line on 400KV Kharghar-Talegaon Line to form Temporary 400KV Kalwa-Kharghar-Talegaon line for carrying out HTLS work on 400KV Kalwa-Padghe-2 line (dead portion after tapping)	Subject to approval of WRDC

Sr. No.	Voltage level	Name of Substation	Name of the Equipment	From		To		Continuous / Daily Basis	Reason	System owner	Outage requesting circle	Remark	MOCM Remark
				Date	Time	Date	Time						
19	220kV	BOISAR	220KV-BOISAR-BOISAR-M-1	04-12-2022	07:00	4-Dec-22	17:00	Daily	Bay Maintenance works at 220KV Boisar-II ss.	MSETCL	MSETCL	Bay Maintenance works at 220KV Boisar-II ss.	Subject to approval of WRDC
20	400KV	KHARGHAR	400KV-KHARGHAR-PUNE-PG-1	04-12-2022	00:00	4-Dec-22	07:00	Daily	For Tapping of 400KV Kalwa-Padgha-2 Line on KHARGHAR - TALEGAON (PG) so as to form temporary 400KV Kalwa-Kharghar-Talegaon Line for replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line.	MSETCL	MSETCL	Simultaneously outage will be availed on 400KV Kalwa-Padgha-2 line.	Subject to approval of WRDC
21	220KV	Bhira	BPSU/ 24MW Unit 1,2 (one at a time)	04-12-2022	06:00	4-Dec-22	17:00	Daily	R/M and Testing	Tata power	Tata power	Emergency clearance 15 Mins. (generation Restriction in Bhira 150MW during BPSU outage and 290MW during set 1.2 outage.	Subject to real time loading conditon after restoration of tapping arrangemnt
22	110kV	Khopoli	24 MW Unit 8 with Bkr	04-12-2022	08:00	4-Dec-22	12:00	Daily	Disconnection of Line GOD to CT jumpers for Replacement of 145 KV CT	Tata power	Tata power	Hydro Generation Available 438 MW.	Subject to real time loading conditon after restoration of tapping arrangemnt
23	220kV	Apta	220kv Apta - Uran II	05-12-2022	09:00	5-Dec-22	18:00	Daily	Bay Maintenance Work and C & Tan-Delta Testing	MSETCL	EHV(O&M)Circle,Panel		Approved.
24	220 KV	400 KV RS Kalwa	220 kv Kalwa Mulund I	05-12-2022	09:00	7-Dec-22	18:00:00	Continuous	CB pole O/H work line will be in service through in TBC	MSETCL	Kalwa Circle		Approved. Line to be in service through TBC.
25	400KV	PUNE-PG	MAIN BAY - 400KV-KHARGHAR-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	05-12-2022	09:00	5-Dec-22	18:00	Daily	For AMP WORK	POWERGRID_WR1	POWERGRID_WR1		Subject to approval of WRDC
26	220kv	Taloja	220kv Taloja-OCIL LINE-1	06-12-2022	07:00	6-Dec-22	21:00	Daily	For Annual Maint. of CT, CB, PT, Isolator at OCIL End	MSETCL	EHV(O&M)Circle,Panel		Approved
27	220 kV	Apta	220 kV Apta Tambati	06-12-2022	10:00	6-Dec-22	18:00	Daily	CT Tan delta and R&M maintenance at both ends	MSETCL	EHV(O&M)Circle,Panel		Approved
28	220kV	Padghe	220kv TBC @ Padghe	06-12-2022	09:00	6-Dec-22	17:30	Daily	1. Diagnostic testing work 2. Attending hotspot 3. MTAMC Project work	MSETCL	Padghe		Approved.
29	220kV	BOISAR PG	220KV-BOISAR-BOISAR-M-3	06-12-2022	09:00	6-Dec-22	17:30	Daily	For LTE AMP works at Boisar PG end	MSETCL	POWERGRID_WR2		Subject to approval of WRDC
30	220kv	Taloja	220kv Taloja-OCIL LINE-2	07-12-2022	07:00	7-Dec-22	21:00	Daily	For Annual Maint. of CT, CB, PT, Isolator at OCIL End	MSETCL	EHV(O&M)Circle,Panel		Approved
31	220kv	Tambati	220kv Apta-ACCIL Line	07-12-2022	10:00	7-Dec-22	18:00	Daily	Bay Maintenance Work and C & Tan-Delta Testing	MSETCL	EHV(O&M)Circle,Panel		Approved
32	220kV	BOISAR PG	220KV-BOISAR-BORIVALI-1	07-12-2022	09:00	7-Dec-22	17:30	Daily	For LTE AMP works at Boisar PG end	MSETCL	POWERGRID_WR2		Subject to approval of WRDC
33	220kV	Kharghar	220kV Kharghar- Topworth line	08-12-2022	8:00	8-Dec-22	16:00	Daily	Making of tap (Cable portion) and test charging of 220KV Khandeshwar GIS	MSETCL	EHV(O&M)Circle,Panel		Approved
34	220 KV	400 KV RS Kalwa	220 KV KALWA Colourchem	08-12-2022	09:00	10-Dec-22	18:00:00	Continuous	CB pole O/H work line will be in service through in TBC	MSETCL	Kalwa Circle		Approved
35	220kV	BOISAR PG	220KV-BOISAR-BOISAR-M-1	08-12-2022	09:00	8-Dec-22	17:30	Daily	For LTE AMP works at Boisar PG end	MSETCL	POWERGRID_WR2		Subject to approval of WRDC
36	220kV	BOISAR	220KV-TARAPUR 1&2-BOISAR-M-1	08-12-2022	09:00	8-Dec-22	17:00	Daily	Bay Maintenance works.	MSETCL	MSETCL		Subject to approval of WRDC
37	110KV	Bhivpuri	110KV Bhivpuri Ambernath 1 Line with breaker	09-12-2022	08:00	9-Dec-22	17:00	Daily	For CVT Testing, Line Side GOD and Breaker R/M	Tata power	Tata power	110kV Kalwa Kalyan , KKS-1 & KKS-2 line will remain in service	Apporved
38	110KV	Trombay A	110kV Group-1 / 2 (KRS ICT-3, ICT-2) One at a time	09-12-2022	08:00	9-Dec-22	22:00	Daily	RPUF protection Testing	Tata power	Tata power	110kV Breaker will remain open during trial operation.	Approved
39	220 kV	Aarey	Main Bus-1	09-12-2022	09:00	9-Dec-22	17:00	Daily	Annual Maintenance of Bus Side isolators	AEML-T	AEML-T		Approved, all elements to be in servcie through bus 2
40	220KV	220kV TFIPL-Mahape Substation	220kV TFIPL-Kalwa Line Bay with 220kV Bus Section-2	09-12-2022	08:00	9-Dec-22	18:00	Daily basis	Diagnostic testing and Bay equipment & Bus maintenance work.	MSETCL	Kalwa Circle		Approved
41	220kV	BOISAR PG	BOISAR - 220KV - BUS 2	09-12-2022	09:00	9-Dec-22	17:30	Daily	For AMP Works	POWERGRID_WR2	POWERGRID_WR2		Subject to approval of WRDC
42	400KV-	KALWA	400KV-KALWA-PADGHE-2	09-12-2022	06:00	11-Dec-22	19:00	Continuous	Replacement of existing Conductor by HTLS Conductor.	MSETCL	MSETCL		Subject to approval of WRDC
43	400KV-	KALWA	400KV-KALWA-PUNE-PG-1	09-12-2022	07:00	12-Dec-22	18:00	Continuous	Maintenace work in span between loc no. 33 & 34 w.r.to conductor replacement and insulator replament	MSETCL	MSETCL		Subject to approval of WRDC

Sr. No.	Voltage level	Name of Substation	Name of the Equipment	From		To		Continuous / Daily Basis	Reason	System owner	Outage requesting circle	Remark	MOCM Remark
				Date	Time	Date	Time						
44	220kV	Salsette	220KV Bus fault relay Zone 1 & 2 one at a time	10-12-2022	07:00	10-Dec-22	11:00	Daily	Relay Testing	Tata power	Tata power	Emergency clearance 20 Mins	Approved
45	220KV	Saki	220KV Bus coupler	10-12-2022	11:30	10-Dec-22	18:00	Daily	Protection testing	Tata power	Tata power	Bus to be kept sectionalised /All equipments in service on one bus	Approved.
46	220KV	220KV Trombay S/s.	220KV Trombay-Chembur-3 line	10-12-2022	09:00	10-Dec-22	17:00	Daily basis	For diagnostic testing of equipments & Bay maintenance work	MSETCL	Kalwa Circle		Approved.
47	400kV	Padghe	315MVA ICT-1	10-12-2022	07:00	11-Dec-22	21:30	Continuous	1. MTAMC work Maint work 2. Bay Diagnostic work 3. Oil leakage attending work 4. Oil filtration of R ph unit due to low BDV 54kV & water content 18 mg/kg	MSETCL	Padghe	1) Weather condition should be clear	Subject to real time loading condition after restoration of tapping arrangement
48	220kV	BOISAR	BOISAR-M - 220KV - BUS 1	10-12-2022	07:00	11-Dec-22	20:00	Continuous	Bus Iso. r/m & r/m works.	MSETCL	MSETCL	Bus Iso. r/m & r/m works.	Subject to approval of WRLDC
49	220KV	Saki	SAKI- 220KV SAL-SAKI-7 Line	11-12-2022	10:00	11-Dec-22	15:00	Daily	LBBU relay testing, Protection trials and CR trials	Tata power	Tata power	Emergency clearance - 20 Mins	Approved
50	110KV	Khopoli	110kV Main Bus Sec-1 and 2	11-12-2022	23:00	11-Dec-22	06:00	Daily	Main Bus section I & II R/M with GOD 110 KV Khopoli Karanjade Bkr jumper dis-connection	Tata power	Tata power	110kV Khopoli Bhivpuri-2 line will remain out between 06:00 to 08:00 Hrs (Bus Sec-II will be cleared at 10:00 Hrs) Between 06:00 to 18:00 Hrs Khopoli Karanjade & Khopoli Davdi line will remain charge from remote end.	48 MW hydro restriction. Approved in night hours
51	220kV	Transmission line	220 kV Waghivali Dharavi Line 7	11-12-2022	08:00	11-Dec-22	18:00	Daily	Mero Project Work-Work in vicinity for removal of old OPGW in span 38A to 40 at Kurla Metro 2B site.	Tata power	Tata power	Bhira Generation will be restricted to 180 MW in case of N-1 (Other Bhira 220kV line tripping)	Approved.
52	220 kV	Ghodbunder	Main Bus-2	12-12-2022	07:00	12-Dec-22	19:00	Daily	Annual Maintenance of Bus Side isolators	AEML-T	AEML-T		Approved , all elements to be in service through main bus 1
53	220 kV	Ghodbunder	Bus Sectionalizer-2 (GIS Bay No.12)	12-12-2022	07:00	12-Dec-22	19:00	Daily	Annual Maintenance of Bus Side isolators	AEML-T	AEML-T		Approved , all elements to be in service through main bus 1
54	220kV	PUNE-PG	PUNE-PG - 220KV - BUS 1	12-12-2022	09:00	12-Dec-22	18:00	Daily	For AMP WORK	POWERGRID _WR1	POWERGRID _WR1		Subject to approval of WRLDC
55	400KV	KALWA	400KV-KALWA-PUNE-PG-1	12-12-2022	09:00	17-Dec-22	18:00	Daily	PID Testing / Auto-Reclose function to be out of service.	MSETCL	MSETCL		Subject to approval of WRLDC
56	220 kV	Ghodbunder	Ghodbunder - MSETCL Boisar Line	13-12-2022	09:00	13-Dec-22	17:00	Daily	Preventive Maintenance of Bay Equipments and attending optical CT communication issue	AEML-T	AEML-T		Approved
57	220KV	220KV KOLSHET S/STN	220KV KHARBAO TSS-KOLSHET LINE	13-12-2022	10:00	13-Dec-22	17:00	Continuous	Replacement of CB Auxiliary contact assembly, Relay testing & RMW	MSETCL	Kalwa Circle		Approved
58	110KV	Trombay A	110kv ICT-5 breaker	14-12-2022	10:00	14-Dec-22	22:00	Daily	ICT-5 110KV breaker maintenance and testing	Tata power	Tata power	Emergency clearance - After work	Approved
59	110KV	Khopoli	110kV Main Bus Sec-1	14-12-2022	23:00	15-Dec-22	06:00	Continuous	110 KV Khopoli Karanjade Bkr jumper connection	Tata power	Tata power	110kV Khopoli Bhivpuri-2 line will control by Transfer Breaker. Khopoli Karanjade & Khopoli Davdi line will remain charge from remote end. 24 MW unit-7 not available. Hydro generation available - 438MW.	Approved
60	220 kV	Ghodbunder	Main Bus-1	14-12-2022	07:00	14-Dec-22	19:00	Daily	Annual Maintenance of Bus Side isolators	AEML-T	AEML-T		Approved , all elements to be in service through main bus 2
61	220 kV	Ghodbunder	Bus Sectionalizer-1 (GIS Bay No.11)	14-12-2022	07:00	14-Dec-22	19:00	Daily	Annual Maintenance of Bus Side isolators	AEML-T	AEML-T		Approved
62	220 kV	Versova	Versova -Goregaon Line-2 on TBC	14-12-2022	09:00	14-Dec-22	19:00	Daily	Annual Maintenance of Circuit Breaker	AEML-T	AEML-T	Line will be in service through TBC	Approved
63	220kv	220kv Uran	220 KV Uran-Apta- 3 Line	14-12-2022	09:00	14-Dec-22	18:00	Daily	Insulator String Replacement Bay Maintenance Work and C & Tan-Delta Testing, Lines related work	MSETCL	EHV(O&M)Circle,Panel		Approved
64	220kV	Transmission line	220 kV Trombay Salsette-1 & 220kV Trombay Salsette-2	15-12-2022	23:00	16-Dec-22	06:00	Continuous	Partial DF+5 type tower erection at loc. 46A for Proposed Metro 4 Sahakar Plaza crossing at Ghatkopar	Tata power	Tata power	220kV Tie-1 & Tie-2 (600MW each), 220kV Salsette Borivali-1 & 2 lines (300MW each) are available.	Approved, Thermal generation at trombay to be increased.
65	220kv	220kv Uran	220 KV Uran-Apta- 4 Line	15-12-2022	09:00	15-Dec-22	18:00	Daily	Insulator String Replacement and Lines Maintenance work	MSETCL	EHV(O&M)Circle,Panel		Approved.

Sr. No.	Voltage level	Name of Substation	Name of the Equipment	From		To		Continuous / Daily Basis	Reason	System owner	Outage requesting circle	Remark	MOCM Remark
				Date	Time	Date	Time						
66	220kV	Transmission line	220 kV Trombay Salsette-1 & 220kV Trombay Salsette-2	16-12-2022	23:00	17-Dec-22	06:00	Continuous	Partial DF+5 type tower erection at loc. 46A for Proposed Metro 4 Sahakar Plaza crossing at Ghatkopar	Tata power	Tata power	220kV Tie-1 & Tie-2 (600MW each), 220kV Salsette Borivali-1 & 2 lines (300MW each) are available.	Approved
67	220 kV	Ghodbunder & Versova	Versova - Ghodbunder Line	16-12-2022	09:00	16-Dec-22	17:00	Daily	Annual Maintenance of Bay equipments	AEML-T	AEML-T		Approved
68	220kV	Uran	220kV ONGC _NPT Link line	16-12-2022	10:00	16-Dec-22	18:00	Daily	Replacement of bus isolator at ONGC Uran side by DISCOM and Diagnostic testing work	MSETCL	EHV(O&M)Circle,Panvel		Approved
69	400kV	Padghe	500MVA ICT-V On TBC	16-12-2022	09:00	16-Dec-22	17:30	Daily	1. CB Testing work 2. A& B Bus PG Isolator Maint. work 3. 500MVA ICT-V HV side on TBC ICT will be in service	MSETCL	Padghe	1) Weather condition should be clear	Approved, ICT to be in service through TBC
70	220KV	220KV Kamba substation	220KV Padghe- Kamba 2 line	16-12-2022	09:00	16-Dec-22	18:00	Daily basis	Breaker overhauling	MSETCL	Kalwa Circle	work to be carried out only after material Receipt at site	Approved, either Padghe - Kamba or Roma - bhuevghar outage can be facilitated
71	220kV	Line M S/Dn Boisar	220kV Bhaveghar-Roma Line	16-12-2022	09:00	16-Dec-22	17:00	Daily basis	Line Maintenance work	MSETCL	Kalwa Circle		Approved, either Padghe - Kamba or Roma - bhuevghar outage can be facilitated
72	220kv	BOISAR PG	BOISAR - 220KV - BUS 1	16-12-2022	09:00	16-Dec-22	17:30	Daily	For AMP works	POWERGRID _WR2	POWERGRID _WR2		Subject to approval of WRLDC
73	220kV	Trombay B	Trombay Dharavi-5	17-12-2022	09:30	17-Dec-22	17:00	Daily	CVT testing at Trombay end	Tata power	Tata power	220KV Tata Trombay Dharavi 6 and 9 (each Capacity 300MW)are in service.	Apporved
74	220kV	Transmission line	220 kV Trombay Salsette-1 & 220kV Trombay Salsette-2	17-12-2022	23:00	18-Dec-22	06:00	Continuous	Partial DF+5 type tower erection at loc. 46A for Proposed Metro 4 Sahakar Plaza crossing at Ghatkopar	Tata power	Tata power	220kV Tie-1 & Tie-2 (600MW each), 220kV Salsette Borivali-1 & 2 lines (300MW each) are available.	Approved.
75	220 kV	Ghodbunder	Ghodbunder - MSETCL Borivali Line	17-12-2022	09:00	17-Dec-22	17:00	Daily	Preventive Maintenance of Bay Equipments	AEML-T	AEML-T		Approved
76	220kV	220kV Nerul S/s.	220kV Nerul TSS-1 line	17-12-2022	11:00	17-Dec-22	18:00	Daily basis	Diagnostics and Bay Maintennace Work	MSETCL	Kalwa Circle		Approved
77	220kv	PUNE-PG	PUNE-PG - 220KV - BUS 2	17-12-2022	09:00	17-Dec-22	18:00	Daily	For AMP WORK	POWERGRID _WR1	POWERGRID _WR1		Subject to approval of WRLDC
78	220kv	BOISAR-M	BOISAR-M - 220KV - BUS 2	17-12-2022	07:00	18-Dec-22	20:00	Continuous	Bus Iso. r/m & r/m works.	MSETCL	MSETCL		Subject to approval of WRLDC
79	220kV	Trombay B	Trombay Carnac-5	18-12-2022	09:30	18-Dec-22	17:00	Daily	CVT testing at Trombay end	Tata power	Tata power	220KV Tata Trombay Carnac 6 and 7 (each Capacity 300MW)	Approved
80	220kV	Transmission line	220 kV Trombay Salsette-1 & 220kV Trombay Salsette-2	18-12-2022	23:00	19-Dec-22	06:00	Continuous	Partial DF+5 type tower erection at loc. 46A for Proposed Metro 4 Sahakar Plaza crossing at Ghatkopar	Tata power	Tata power	220kV Tie-1 & Tie-2 (600MW each), 220kV Salsette Borivali-1 & 2 lines (300MW each) are available.	Approved
81	220KV	220kV Mahape Substation	220kV Bus section-2 (220KV Mahape-TFIPL, 220KV TBC, 50MVA, 220/22KV PTR-2) Alongwith 220kV Bus PT Set	18-12-2022	05:00	18-Dec-22	12:00	Daily basis	Diagnostic testing of Bus PT Set, Overhauling of Main Bus Isolator & Bus maintenance work	MSETCL	Kalwa Circle		Approved
82	220 kV	NALASOPARA	220KV-BOISAR-NALASOPARA-1	18-12-2022	09:00	18-Dec-22	17:00	Daily	For R&M, bay maintenance & line Maintenance Work	MSETCL	MSETCL	For R&M, bay maintenance & line Maintenance Work	Subject to approval of WRLDC
83	400KV	KALWA	400KV-KALWA-PADGHE-1	18-12-2022	09:00	18-Dec-22	18:00	Daily	Routine Maintenance Activity	MSETCL	MSETCL	Routine Maintenance Activity	Subject to approval of WRLDC
84	110KV	Transmission line	110KV Kalwa Kalyan	19-12-2022	08:00	19-Dec-22	17:00	Daily	Closer inspection/Tree trimming	Tata power	Tata power	110kV KKS-1 & KKS-2 , 110kV AK-1 & AK-2 will remain in service.	Approved
85	220 kV	Versova	Versova - Ghodbunder Line on TBC	19-12-2022	09:00	19-Dec-22	19:00	Daily	Annual Maintenance of Circuit Breaker	AEML-T	AEML-T	Line will be in service through TBC	Approved
86	220kv	Apta	Apta- Bombay Dyeing	19-12-2022	10:00	19-Dec-22	18:00	Daily	Bay Maintenance Work and C & Tan-Delta Testing & Lines Maintenance work	MSETCL	EHV(O&M)Circle,Panvel		Approved
87	400KV	KHARGHAR	400KV-KHARGHAR-PUNE-PG-1	19-12-2022	09:00	24-Dec-22	18:00	Daily	PID Testing Auto-Reclose function to be out of service.	MSETCL	MSETCL		Subject to approval of WRLDC
88	220 kV	Versova	Versova -Gorai Line on TBC	20-12-2022	09:00	20-Dec-22	19:00	Daily	Annual Maintenance of Circuit Breaker	AEML-T	AEML-T	Line will be in service through TBC	Approved
89	220 kV	Aarey	Main Bus-2	20-12-2022	09:00	20-Dec-22	17:00	Daily	Annual Maintenance of Bus Side isolators	AEML-T	AEML-T		Approved, all elements to be in service through bus 1
90	220KV	Padghe	Padghe - Jindal	20-12-2022	09:00	20-Dec-22	17:30	Daily	1. Diagnostic testing work 2. Attending hotspot 3. MTAMC Project work	MSETCL	Padghe		Approved
91	110KV	Transmission line	110KV KKS-1	21-12-2022	11:00	21-Dec-22	18:00	Daily	Conductor inspection by using Line Vue	Tata power	Tata power	110kV Kalwa Kalyan & KKS-2 , 110kV AK-1 & AK-2 will remain in service.	Approved

Sr. No.	Voltage level	Name of Substation	Name of the Equipment	From		To		Continuous / Daily Basis	Reason	System owner	Outage requesting circle	Remark	MOCM Remark
				Date	Time	Date	Time						
92	110KV	Kalyan	110KV Ambernath Kalyan 1	21-12-2022	06:00	21-Dec-22	11:00	Daily	Project Job-Loop Opening for Facilitating OFA North AK1 Breaker and Isolator Commissioning	Tata power	Tata power	OFA on single feed	Approved
93	220kv	220kv Uran	220 KV Uran- Apta-1 Line	21-12-2022	09:00	21-Dec-22	18:00	Daily	Insulator String Replacement & Diagnostic work	MSETCL	EHV(O&M)Circle,Panvel		Approved
94	110KV	Kalyan	110KV Ambernath Kalyan 1	22-12-2022	16:00	22-Dec-22	20:00	Daily	Project Job-Loop closing after OFA North AK1 Breaker and Isolator Commissioning.	Tata power	Tata power	OFA on single feed	Approved
95	220 KV	220 KV Airoli Knowledge Park S/S	220 KV AKP -Kalwa Line	22-12-2022	10:30	22-Dec-22	17:30	Daily basis	Diagnostic and bay maintenance work	MSETCL	Kalwa Circle		Subject to real time loading condition of 220KV Nashik - BBLR ckt 1 & 2
96	220KV	Trombay B	220kv Trombay Dharavi-9	23-12-2022	08:00	23-Dec-22	20:00	Daily	LA Replacement	Tata power	Tata power	220KV Tata Trombay Dharavi 5 and 6 (each Capacity 300MW)	Approved
97	220KV	Saki	SAKI- 220KV Saki-Sahar Line	23-12-2022	23:00	24-Dec-22	06:00	Continuous	LBBU relay testing, Protection trials and CR trials	Tata power	Tata power	Emergency clearance - 20 Mins	Approved
98	220 kv	Ghodbunder	Buscoupler	23-12-2022	08:00	23-Dec-22	17:00	Daily	Annual Maintenance of Bay equipments	AEML-T	AEML-T		Approved
99	220kv	Padghe	220KV Padghe - Kamba-1	23-12-2022	09:00	23-Dec-22	18:00	Daily	1. Diagnostic testing work 2. Attending hotspot 3. MTAMC Project work	MSETCL	Padghe		Approved.
100	220KV	220KV Kamba substation	220KV Kamba-Kharbhao line	23-12-2022	09:00	23-Dec-22	18:00	Daily basis	Breaker overhauling	MSETCL	Kalwa Circle	work to be carried out only after material Receipt at site	Approved.
101	400KV	PADGHE	400KV-PADGHE HVDC-PADGHE-1	23-12-2022	08:30	23-Dec-22	12:00	Daily	1) H/T required for safety proposed for removing jumper between HVDC 1&2 gantry buy Hot line method. 2) power restriction of 750 MW for 3 hrs.	MSETCL	MSETCL		Subject to approval of WRLDC
102	400KV	PADGHE	400KV-PADGHE HVDC-PADGHE-2	23-12-2022	05:00	25-Dec-22	23:00	Continuous	1) shifting on TBC for partial bus outage for Bus conductor replacement work 2) PG isolator alignment work	MSETCL	MSETCL		Subject to approval of WRLDC
103	400KV	PADGHE	PADGHE - 400KV - BUS 2	23-12-2022	05:00	25-Dec-22	23:59	Continuous	B Bus Conductor Replacement of Section -3 between 400kV HVDC II& Nagothane I 1) 400kV HVDC -2 on TBC & 400kV Nagothane -1 H/T required fro 3 days . 2) 400kV HVDC -1 H/T required for 3 hrs on day 1 & day 3 for jumper removing & fixing work by Hot line method. Power restriction of 750MW for 3 hrs	MSETCL	MSETCL		Subject to approval of WRLDC
104	400KV	PADGHE	400KV-KALWA-PADGHE-2	23-12-2022	06:00	25-Dec-22	19:00	Continuous	Replacement of existing Conductor by HTLS Conductor	MSETCL	MSETCL		Subject to approval of WRLDC
105	400KV	PADGHE	400KV-PADGHE-NAGOTHANE-1	23-12-2022	11:00	25-Dec-22	23:59	Continuous	1)H/T require for 3 days for Bus conductor replacement work of sec-3 between Nago-1 & HVDC-2 2) IPS tube removing work below B bus for Bus conductor replacement 3) PG isolator replacement & alignment work of B bus	MSETCL	MSETCL		Subject to approval of WRLDC
106	400kV	Padghe	315MVA ICT-III	23-12-2022	09:00	23-Dec-22	21:30	Daily	1. MTAMC work 2. Bay Maint work 3. Diagnostic Testing work 4. Oil leakage attending work If any 5. NIFPS Maint work	MSETCL	Padghe	1) Weather condition should be clear	Subject to real time loading condition of 400KV lines
107	220KV	Bhira	ICT 2	24-12-2022	06:00	25-Dec-22	19:00	Daily	R/M & Protection testing	Tata power	Tata power	No Generation restriction in N-1 contingency	Approved
108	110kv	Kolshet	110KV Kolshet BMC BO-BO-1	24-12-2022	09:30	24-Dec-22	17:30	Daily	Project work- BPI bolt replacement & IVT testing Line Vue inspection of conductor	Tata power	Tata power	Emergency clearance- 30 Mins	Approved
109	220KV	Kolshet	220 kv Salsette Borivali 1	24-12-2022	09:30	24-Dec-22	17:30	Daily	Line Vue inspection of conductor	Tata power	Tata power	Emergency clearance- 30 Mins	Approved
110	220kV	BOISAR	220KV-BOISAR-BOISAR-M-2	24-12-2022	07:00	24-Dec-22	17:00	Daily	Bay Maintenance works.	MSETCL	MSETCL		Subject to approval of WRLDC
111	400KV	KALWA	BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV	24-12-2022	08:00	24-Dec-22	18:00	Daily	All diagnostic testing work, Bay maintenance work	MSETCL	MSETCL		Subject to approval of WRLDC

Sr. No.	Voltage level	Name of Substation	Name of the Equipment	From		To		Continuous / Daily Basis	Reason	System owner	Outage requesting circle	Remark	MOCM Remark
				Date	Time	Date	Time						
112	500KV	HVDC	HVDC 500KV CHANDRAPUR HVDC POLE 1	24-12-2022	22:00	28-Dec-22	22:00	Continuous	Annual Maintenance work Earth Electrode, DC Breaker, DC Isolator, Diagnostic Testing, line Maintenance etc.	MSETCL	MSETCL		Subject to approval of WRLDC
113	500KV	HVDC	HVDC 500KV CHANDRAPUR HVDC POLE 2	24-12-2022	22:00	28-Dec-22	22:00	Continuous	Annual Maintenance work Earth Electrode, DC Breaker, DC Isolator, Diagnostic Testing, line Maintenance etc.	MSETCL	MSETCL		Subject to approval of WRLDC
114	110kV	Kolshet	110kV Kolshet BMC BO-BO-1	25-12-2022	09:30	25-Dec-22	17:30	Daily	Project work- BPI bolt replacement & IVT testing Line Vue inspection of conductor	Tata power	Tata power	Emergency clearance- 30 Mins	Approved
115	220KV	220kV Mahape Substation	220kV Bus section-1 has following elements i) 220KV Mahape-Reliance ii) 50MVA, 220/22KV PTR-3 & 4	25-12-2022	05:00	25-Dec-22	15:00	Daily basis	Overhauling of Main Bus Isolator & Bus maintenance work	MSETCL	Kalwa Circle	50MVA, 220/22KV PTR-1 will be on TBC.	Approved
116	220 kV	BOISAR	220KV-BOISAR-BOISAR-M-3	25-12-2022	07:00	25-Dec-22	17:00	Daily	Bay Maintenance works.	MSETCL	MSETCL		Subject to approval of WRLDC
117	400kV	Padghe	400KV-PADGHE-NAGOTHANE-2	25-12-2022	12:00	25-Dec-22	22:00	Daily	1) H/T requires for safety purposed for re connection of jumper by cold line method between Nago. 1 & 2. 2) shifting from A bus to B bus after Bus conductor replacement work.	MSETCL	MSETCL	Weather condition should be clear	Subject to approval of WRLDC
118	400kV	Padghe	400KV-PADGHE HVDC-PADGHE-1	25-12-2022	14:00	25-Dec-22	17:35	Daily	1) H/T requires for safety purposed for re connection of jumper between HVDC 1 & 2 gantry of B bus by Hot line method. 2) power restriction of 750MW for @ 3hrs.	MSETCL	MSETCL	Weather condition should be clear	Subject to approval of WRLDC
119	400kV	Padghe	400KV-TARAPUR 3&4-PADGHE-2	25-12-2022	15:00	25-Dec-22	23:59	Daily	1) shifting from A bus to B bus through TBC after Bus conductor replacement work	MSETCL	MSETCL	Weather condition should be clear	Subject to approval of WRLDC
120	220 kV	Ghodbunder	Dahanu - Ghodbunder Line-1 on TBC	26-12-2022	09:00	26-Dec-22	19:00	Daily	Annual Maintenance of Circuit Breaker	AEML-T	AEML-T	Line will be in service through TBC	Approved.
121	400kV	LONIKHAND	400KV-LONIKHAND-CHAKAN-1	26-12-2022	08:00	28-Dec-22	18:00	Daily	O/H & Servicing of 29A PG Isolator & Replacement of PGI mechanism box.	MSETCL	MSETCL	Line will be shifted on TBC	Subject to approval of WRLDC
122	400kV	KALWA	400KV-KALWA-KHARGHAR-1	26-12-2022	09:00	31-Dec-22	18:00	Daily	PID Testing Auto-Reclose function to be out of service.	MSETCL	MSETCL	PID Testing Auto-Reclose function to be out of service.	Subject to approval of WRLDC
123	220 kV	Ghodbunder	Ghodbunder - Goral Line on TBC	27-12-2022	09:00	27-Dec-22	19:00	Daily	Annual Maintenance of Circuit Breaker	AEML-T	AEML-T	Line will be in service through TBC	approved
124	220 kV	Chembur	Main Bus-2	27-12-2022	09:00	27-Dec-22	17:00	Daily	Annual Maintenance of Main Bus-1 and Bay Equipments	AEML-T	AEML-T		approved
125	220 kV	Chembur	Main Bus-2 VT bay	27-12-2022	09:00	27-Dec-22	17:00	Daily	Annual Maintenance of Main Bus-1 and Bay Equipments	AEML-T	AEML-T		approved
126	220 kV	Chembur	Buscoupler	27-12-2022	09:00	27-Dec-22	17:00	Daily	Annual Maintenance of Main Bus-1 and Bay Equipments	AEML-T	AEML-T		approved
127	110KV	Kalyan	110KV Ambernath Kalyan 2	28-12-2022	07:00	28-Dec-22	13:00	Daily	Project Job-Loop Opening for Facilitating OFA North AK2 Breaker and isolator Commissioning	Tata power	Tata power	OFA on single feed	Approved, OFA NOC required.
128	220 kV	Ghodbunder	Ghodbunder - Versova Line on TBC	28-12-2022	09:00	28-Dec-22	19:00	Daily	Annual Maintenance of Circuit Breaker	AEML-T	AEML-T	Line will be in service through TBC	Approved
129	220 kV	Versova	Versova -Goregaon Line-1 on TBC	28-12-2022	09:00	28-Dec-22	19:00	Daily	Annual Maintenance of Circuit Breaker	AEML-T	AEML-T	Line will be in service through TBC	Approved
130	220kv	EHV Lines S/Dn.	220KV Kharghar - Uran II	28-12-2022	09:00	28-Dec-22	18:00	Daily	Lines Maintenance work	MSETCL	EHV(O&M)Circle,Panvel		Approved.
131	110KV	Kalyan	110KV Ambernath Kalyan 2	29-12-2022	16:00	29-Dec-22	20:00	Daily	Project Job-Loop closing after OFA North AK2 Breaker and isolator Commissioning.	Tata power	Tata power	OFA on single feed	Approved
132	400KV	LONIKHAND	400KV-LONIKHAND-CHAKAN-1	29-12-2022	10:00	31-Dec-22	18:00	Continuous	For Overhauling of Bus B 89B Rph, Yph, Bph and Bus C 89C Rph, Yph, Bph PG Isolators and Routine Testing and Maintenance Work.	MSETCL	MSETCL	The Existing 89B & 89C Isolator is mechanically Jam due to which operation is difficult so Isolator overhauling is to be carried out by dismantling the Isolator. So time is required for Dismantling and Erection alongwith Overhauling.	Subject to approval of WRLDC
133	110KV	Transmission line	110KV KKS-2	30-12-2022	08:00	30-Dec-22	17:00	Daily	Conductor inspection by using Line Vue	Tata power	Tata power	110kV Kalwa Kalyan & KKS-1 , 110kV AK-1 & AK-2 will remain in service.	Approved
134	220 kV	Versova	Main Bus-2	30-12-2022	09:00	30-Dec-22	19:00	Daily	Annual Maintenance of Bus Side isolators	AEML-T	AEML-T		Approved
135	220kV	Padghe	220kV Padghe - Kamba-2	30-12-2022	09:00	30-Dec-22	18:00	Daily	1. Bay Maintenance Work 2. Diagnostic testing work 3. Attending hotspot 4. MTAMC Project work	MSETCL	Padghe		Approved

Sr. No.	Voltage level	Name of Substation	Name of the Equipment	From		To		Continuous / Daily Basis	Reason	System owner	Outage requesting circle	Remark	MOCM Remark
				Date	Time	Date	Time						
136	400kV	KALWA	400KV-KALWA-PADGHE-2	30-12-2022	06:00	1-Jan-23	19:00	Continuous	Replacement of existing Conductor by HTLS Conductor	MSETCL	MSETCL		Subject to approval of WRDC
Under review in MOCM for the month of Deceber'22													
NIL													
Deferred in MOCM for the month of December'22													
1	500KV	HVDC	HVDC 500KV CHANDRAPUR HVDC POLE 2	03-12-2022	08:00	10-Dec-22	22:00	Continuous	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc	MSETCL	MSETCL		Annual maint. done in NOV. 22
2	500KV	HVDC	HVDC 500KV CHANDRAPUR HVDC POLE 2	03-12-2022	08:00	10-Dec-22	22:00	Continuous	Annual Maintenance work AC & DC yard equipment, valve hall, diagnostic testing, line maintenance, pole-2 base and non base filer jumper tightening and filer CT ten delta	MSETCL	MSETCL		Annual maint. done in NOV. 22
3	110KV	Bhivpuri	Bhivpuri Plant	03-12-2022	23:00	4-Dec-22	22:00	Continuous	Underwater Intake Gate Inspection	Tata power	Tata power	Hydro Generation Available 387 MW.	Deferred due to tapping outage of 400kV line
4	220kV	Trombay B	220kV Main Bus 5	07-12-2022	22:30	8-Dec-22	07:00	Continuous	Maintenance of Bus Sec-3 side GOD and TD-6 MB GOD	Tata power	Tata power	220KV Tata Trombay Carnac-5, Trombay Salsette-1, Trombay Dharavi-6 & Trombay Antop Hill-2 will remain charge from remote end. ST-7 not available. Station supply will be feed through ST-5. Transfer Breaker-2 will not be available.	Deferred due to tapping at 400KV level
5	220kV	Kharghar	220KV Kharghar- Topworth line	08-12-2022	8:00	10-Dec-22	16:00	Continuous	Gantry & Beam Erection at Proposed Panvel Timber Market GIS & Charging of 220KV EHV Cable (KK Line)	MSETCL	EHV(O&M)Circle,Panvel		Deferred due to tapping at 400KV level
6	220kV	Kharghar	220kV Kharghar- TSS Panvel line	08-12-2022	8:00	10-Dec-22	16:00	Continuous	Gantry & Beam Erection at Proposed Panvel Timber Market GIS & Charging of 221KV EHV Cable (KK Line) and Routine Maintenance Work & Diagnostic Testing of 220kV CT at 400kV Kharghar	MSETCL	EHV(O&M)Circle,Panvel		Deferred due to tapping at 400KV level
7	220kV	TSS Panvel	220kV Kharghar- TSS Panvel line	06-12-2022	8:00	6-Dec-22	16:00	Daily	Maintenance work at TSS end	MSETCL	EHV(O&M)Circle,Panvel		Deferred due to tapping at 400KV level
8	220kV	Trombay B	220kV Main Bus 3	09-12-2022	08:00	15-Dec-22	22:00	Continuous	For Breaker Replacement.	Tata power	Tata power	220kV Bus sec -1 ,2,6 will be continuous & bus 5 will be operated sectionalise. (If Unit-7 is in service , all buses will be operated continuous.)	Deferred due to tapping at 400KV level
9	110KV	Khopoli	Khopoli Plant	11-12-2022	06:00	11-Dec-22	18:00	Daily	Forbay Trash screen R/M NPH Hill tank cleaning	Tata power	Tata power	72 MW plant will not be available for generation. Hydro Generation Available to 390 MW.	Deferred due to tapping at 400KV level
10	220kv	Apta	220 kV Apta Kalwa	13-12-2022	10:00	13-Dec-22	18:00	Daily	Bay Maintenance Work and C & Tan-Delta Testing	MSETCL	EHV(O&M)Circle,Panvel		Deferred due to tapping at 400KV level
11	110KV	Bhira	25MW Set 2	14-12-2022	03:15	22-Dec-22	20:30	Daily	Annual Overhaul(GT, Generator, 11KV bus R/M and testing)	Tata power	Tata power	Hydro Generation Available to 437MW .	Deferred due to tapping at 400KV level
12	220kv	220kV Uran	220 KV Main Bus-2	14-12-2022	09:00	16-Dec-22	18:00	Daily	Insulator String Replacement	MSETCL	EHV(O&M)Circle,Panvel		Deferred due to tapping at 400KV level
13	220 kV	Ghodbunder	Dahanu - Ghodbunder Line-1	14-12-2022	05:00	28-Dec-22	20:00	Continuous	Project NHRCL: 1. Erection of Tower - LS 217, LS 218, LS 221 2. Shifting of existing conductor & OPGW between span LS 217 to LS 223. Project DFCCIL: 1. Erection of Tower - LS 223, LS 224, LS 225. 2. Shifting of existing conductor & OPGW between span LS 223 to LS 226	AEML-T	NHSRCL/DFCCIL		Deferred as Dahanu unit outage is postponed in Feb'23
14	220 kV	Ghodbunder	Dahanu - Ghodbunder Line-2	14-12-2022	05:00	28-Dec-22	20:00	Continuous		AEML-T	NHSRCL/DFCCIL		Deferred as Dahanu unit outage is postponed in Feb'23
15	220kv	Apta	220 kV Apta Talaja	16-12-2022	10:00	16-Dec-22	18:00	Daily	Bay Maintenance Work and C & Tan-Delta Testing	MSETCL	EHV(O&M)Circle,Panvel		Deferred due to tapping at 400KV level
16	500KV	HVDC	HVDC 500KV CHANDRAPUR HVDC POLE 1	17-12-2022	08:00	24-Dec-22	22:00	Continuous	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc	MSETCL	MSETCL	Pole-2 will be in service with 750 MW	annual maint done in Nov.22

Sr. No.	Voltage level	Name of Substation	Name of the Equipment	From		To		Continuous / Daily Basis	Reason	System owner	Outage requesting circle	Remark	MOCM Remark
				Date	Time	Date	Time						
17	500KV	HVDC	HVDC 500KV CHANDRAPUR HVDC POLE 1	17-12-2022	08:00	24-Dec-22	22:00	Continuous	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance, pole-1 base filter jumper replaced, pole-1 non base filter jumper tightening work, CT ten delta of filter bank	MSETCL	MSETCL	pole-2 will be in service with 750 MW, Pole-1 base and non base filter not available during this outage period	annual maint done in Nov.22
18	110KV	Bhivpuri	110 KV BS IV+V+VI	18-12-2022	08:00	18-Dec-22	16:00	Daily	110 KV Bus Cold Washing & MBS GOD R/M	Tata power	Tata power	Hydro Generation Available - 414 MW. 24 MW unit 9 & 10 not Available. 110kV Khopoli Bhivpuri-1 will remain charge from Khopoli end. Bhivpuri Neral will go on Transfer Breaker.	Deferred due to tapping at 400KV level
19	220 kV	DTPS	Dahanu - Ghodbunder Line-1	21-12-2022	09:00	23-Dec-22	18:00	Continuous	Replacement of Bay Marshaling Box Breaker Preventive Maintenance Overhauling of Iso-C & D PM & tan delta testing of Line CT / CVT	AEML-T	DTPS		Deferred in view of unit outage Postponed
20	220kv	220kV Uran	220 KV Main Bus-1	21-12-2022	09:00	23-Dec-22	18:00	Daily	Insulator String Replacement	MSETCL	EHV(O&M)Circle,Panel		Deferred due to tapping at 400KV level
21	220 kV	DTPS	Main Bus-1	24-12-2022	08:00	24-Dec-22	20:00	Daily	Bus Isolator A overhauling of Bay 06 ST 02 Bus isolator A Overhauling Bus coupler isolator A & CT-IPT PM	DTPS	DTPS		Deferred as Dahanu unit outage is postponed in Feb'23
22	220 kV	DTPS	Dahanu - Versova Line	24-12-2022	08:00	24-Dec-22	20:00	Daily	Replacement of Bay Marshaling Box Breaker Preventive Maintenance Overhauling of Iso-C & D PM & tan delta testing of Line CT / CVT	AEML-T	DTPS		Deferred as Dahanu unit outage is postponed in Feb'23
23	110KV	Khopoli	24 MW Unit 7	25-12-2022	09:30	25-Dec-22	17:30	Daily	Turbine R/M DT 7 RM inspection	Tata power	Tata power	Hydro generation available - 438MW.	Deferred in view of TATA U#8 outage
24	220KV	Kolshet	220 kV Salsette Borivali 1	25-12-2022	09:30	25-Dec-22	17:30	Daily	Line Vue inspection of conductor	Tata power	Tata power	Emergency clearance- 30 Mins	Deferred in view of TATA U#8 outage
25	220 kV	DTPS	Dahanu - MSETCL Viraj Line	26-12-2022	08:00	27-Dec-22	18:00	Continuous	Breaker Preventive Maintenance Overhauling of Iso-C & D PM & tan delta testing of Line CT / CVT Replacement of Lightning Arrestors	AEML-T	DTPS		Deferred as Dahanu unit outage is postponed in Feb'23
26	220 kV	DTPS	Dahanu - Versova Line	28-12-2022	08:00	29-Dec-22	18:00	Continuous	Breaker Preventive Maintenance Overhauling of Iso-C & D PM & tan delta testing of Line CT / CVT Replacement of Lightning Arrestors	AEML-T	DTPS		Deferred as Dahanu unit outage is postponed in Feb'23
27	220 kV	Dahanu	DTPS Main bus 2	28-12-2022	09:00	30-Dec-22	19:00	continuous	Bus 02 Maintenance	DTPS	DTPS		Deferred due to tapping at 400KV level
28	220 kV	DTPS	Dahanu - Viraj Line	29-12-2022	08:00	29-Dec-22	17:00	Daily	Overhauling of Isolator -B at DTPS end				Deferred as Dahanu unit outage is postponed in Feb'23
29	220 kV	DTPS	Dahanu - Viraj Line	30-12-2022	05:00	12-Jan-23	20:00	Continuous Basis	Project NHSRCL: 1. Erection of Tower - LS 47, 48 & 49. 2. Shifting of existing conductor & OPGW between span LS 47 to 49	AEML-T	NHSRCL	DTPS team will carry out maintenance work at their end	Deferred as Dahanu unit outage is postponed in Feb'23
30	220 kV	DTPS	Dahanu - Versova Line	30-12-2022	05:00	12-Jan-23	20:00	Continuous Basis	Project NHSRCL: 1. Erection of Tower - LS 47, 48 & 49. 2. Shifting of existing conductor & OPGW between span LS 47 to 49	AEML-T	NHSRCL	DTPS team will carry out maintenance work at their end	Deferred as Dahanu unit outage is postponed in Feb'23
31	220KV	220 kV Line Maint. S/DN-, Kalwa	220 kV Kharghar Borivali 2 Line	01-12-2022	08:00	6-Dec-22	19:00	Daily basis	Outage required for safety purpose during installation of OPGW between loc. No. 20 to 28	MSETCL	Kalwa Circle	M/s MTCIL will carry out OPGW installation work	Deferred after Tapping arrangement on 400 kV line
32	220KV	220 kV Line Maint. S/DN-, Kalwa	220 kV Kalwa Tilpi Line	01-12-2022	08:00	6-Dec-22	19:00	Daily basis	Outage required for safety purpose during installation of OPGW between loc. No. 20 to 28	MSETCL	Kalwa Circle	M/s MTCIL will carry out OPGW installation work	Deferred after Tapping arrangement on 400 kV line