

Note on**Maharashtra Power System Overview, under frequency operation, Load shedding (Planned and Distress) for the month of February-2018.****Maharashtra system Overview:-**

The overview of Maharashtra system operation for the month of February-2018 with respect to availability and shortfall is elaborated as under.

- The power supply position for **STATE** in February-2018 are given below: -

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	21641 MW (with Load shedding 0 MW)	27.02.2018	12:00 Hrs
2	Min. Demand	13303 MW	12.02.2018	03:00 Hrs
3	Max. Demand Catered	21641 MW	27.02.2018	12:00 Hrs
4	Energy Catered	11875 Mus		
5	Max. Energy Catered	455 Mus	28.02.2018	
6	Avg. Energy Catered	424 Mus		

- The power supply position for **MSEDCL** in February-2018 are given below :-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	18622 MW (with Load shedding 0 MW)	27.02.2018	12:00 Hrs
2	Min. Demand	11890 MW	12.02.2018	03:00 Hrs
3	Max. Demand Catered	18622 MW	27.02.2018	12:00 Hrs
4	Energy Catered	10393 Mus		
5	Max. Energy Catered	394 Mus	28.02.2018	
6	Avg. Energy Catered	371 Mus		

- The power supply position for **Mumbai system** in February-2018 are given below:-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	3075 MW	28.02.2018	12:00 Hrs
2	Min. Demand	1369 MW	12.02.2018	04:00 Hrs
4	Energy Catered	1482 Mus		
5	Max. Energy Catered	61 Mus	28.02.2018	
6	Avg. Energy Catered	53 Mus		

Load shedding in MSEDCL area :

- Revised Feeder wise planned load shedding protocol in MSEDCL, based on MERC Order in Case No.41 of 2012 dt.26.11.2012, is implemented w.e.f. 16/01/2013 by MSEDCL as per circular No.46 Dated 14/01/2013. The hourly load relief quantum is submitted at the end of the day, daily, by LM cell of MSEDCL, Kalwa.
 - Max. load shedding was recorded as 3 MW and Min. load shedding was recorded as 0 MW. Average load shedding quantum for the month was 0.01 MW/Hr.
 - Planned load shedding for load relief is carried out in MSEDCL area to mitigate the availability in real time if required. AG-LM load management scheme is revised as per the new load shedding circular w.e.f. 17.09.2017 vide MSEDCL letter no. ED-I/Ag Time Change/22352 dt, 15.09.2017, 3 phase supply to AG loads will be 8/8 Hrs. w.e.f. 17.09.2017.
 - There was no distress load shedding due to shortfall of supply during the month.
-

Other Highlights of Maharashtra System in February-2018.

- The RGPPL Power is scheduled to Railways only.
 - 5.843 TMC of Koyna water was utilized for February-2018.
 - Wind Generation for the month was 174 Mus. Average wind generation was 258 MW/hour.
 - The average grid frequency for the month was 49.97 Hz. The Instantaneous Maximum frequency was 50.21 Hz and Minimum frequency was 49.61 Hz.
 - There was no instance of under frequency operation during the month.
 - MSPGCL Thermal actual generation was as high as 6061 MW (hourly max) on 28/02/2018 at 22:00 hrs.
 - MSPGCL Thermal actual generation was as low as 3695 MW (hourly min) on 04/02/2018 at 24:00 hrs.
 - Max. Voltage at 765KV Substation was recorded at 765KV Ektuni substation i.e 792 KV and Min voltage was recorded at 765KV Akola substation i.e 746 KV
 - Max. Voltage at MSETCL 400 kV Substation was recorded at 400KV Kalwa i.e 442 kV and Min voltage was recorded at 400KV Lonikand i.e 388 kV
 - There was no planned load shedding in Mumbai area (i.e. BEST, R-infra-D and TPC-D) during the month.
-