

Note on**Maharashtra Power System Overview, under frequency operation, Load shedding (Planned and Distress) for the month of March - 2020****Maharashtra system Overview:-**

The overview of Maharashtra system operation for the month of March - 2020 with respect to availability and shortfall is elaborated as under;

- The power supply position for **STATE** in March - 2020 are given below: -

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	24012 MW (with Load shedding 0 MW)	17.03.2020	13:00 Hrs
2	Min. Demand	11479 MW	26.03.2020	04:00 Hrs
3	Max. Demand Catered	24012 MW	17.03.2020	13:00 Hrs
4	Energy Catered	13649 MUs		
5	Max. Energy Catered	500 MUs	17.03.2020	
6	Avg. Energy Catered	440 MUs		

- The power supply position for **MSEDCL** in March- 2020 are given below :-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	21112 MW (with Load shedding 0 MW)	17.03.2020	13:00 Hrs
2	Min. Demand	9800 MW	26.03.2020	04:00 Hrs
3	Max. Demand Catered	2112 MW	17.03.2020	13:00 Hrs
4	Energy Catered	12119 MUs		
5	Max. Energy Catered	443 MUs	17.03.2020	
6	Avg. Energy Catered	391 MUs		

- The power supply position for **Mumbai system** in March - 2020 are given below:-

Sr.No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	2962 MW	02.03.2020	12:00 Hrs
2	Min. Demand	1454 MW	14.03.2020	04:00 Hrs
3	Energy Catered	1531 MUs		
4	Max. Energy Catered	58 MUs	03.03.2020	
5	Avg. Energy Catered	49 MUs		

Load shedding in MSEDCL area :

- Revised Feeder wise planned load shedding protocol in MSEDCL, based on MERC Order in Case No.41 of 2012 dt.26.11.2012, is implemented w.e.f. 16/01/2013 by MSEDCL as per circular No.46 Dated 14/01/2013. The hourly load relief quantum is submitted at the end of the day, daily, by LM cell of MSEDCL, Kalwa.
- Max. load shedding was recorded as 0 MW and Min. load shedding was recorded as 0 MW. Average load shedding quantum for the month was 0 MW.
- Planned load shedding for load relief is carried out in MSEDCL area to mitigate the availability in real time if required. AG-LM load management scheme is revised as per the new load shedding circular w.e.f. 01.01.2019 vide MSEDCL letter no. CE(PP)/LM/30923 dt, 29.12.2018, 3 phase supply to AG loads will be 8/10 Hrs. w.e.f. 01.01.2019.

Other Highlights of Maharashtra System in March - 2020

- The RGPPL Power is scheduled to Railways only.
 - 4.598 TMC of Koyna water is utilized for March – 2020.
 - Wind Generation for the month was 381 MUs. Average wind generation was 512 MW/hour.
 - The average grid frequency for the month was 50.00 Hz. The Instantaneous Maximum frequency was 50.19 Hz and Minimum frequency was 49.56 Hz.
 - There was no instance of under frequency operation during the month.
 - MSPGCL Thermal actual generation was as high as 7582 MW (hourly max) on 07/03/2020 at 10:00 hrs.
 - MSPGCL Thermal actual generation was as low as 2510 MW (hourly min) on 31/03/2020 at 18:00 hrs.
 - Max. Voltage at 765kV Substation was recorded at 765KV Ektuni substation i.e 803 kV and Min voltage was recorded at 765kV Tirora substation i.e 743 kV.
 - Max. Voltage at MSETCL 400 kV Substation was recorded at 400KV Kalwa i.e 441 kV and Min voltage was recorded at 400KV Jejuri i.e 381 kV.
 - There was no planned load shedding in Mumbai area (BEST, AEML-D and TPC-D) during the month.
-