

Note on**Maharashtra Power System Overview, under frequency operation, Load shedding (Planned and Distress) for the month of May-2018****Maharashtra system Overview:-**

The overview of Maharashtra system operation for the month of May-2018 with respect to availability and shortfall is elaborated as under.

- The power supply position for **STATE** in May-2018 are given below: -

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	23755 MW (with Load shedding 0 MW)	30.05.2018	16:00 Hrs
2	Min. Demand	17372 MW	01.05.2018	19:00 Hrs
3	Max. Demand Catered	23755 MW	30.05.2018	16:00 Hrs
4	Energy Catered	15607 Mus		
5	Max. Energy Catered	517.3 Mus	30.05.2018	
6	Avg. Energy Catered	503.45 Mus		

- The power supply position for **MSEDCL** in May-2018 are given below :-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	20296.81 MW (with Load shedding 0 MW)	26.05.2018	16:00 Hrs
2	Min. Demand	14920.94 MW	01.05.2018	19:00 Hrs
3	Max. Demand Catered	20296.81 MW	26.05.2018	16:00 Hrs
4	Energy Catered	13487 Mus		
5	Max. Energy Catered	446 Mus	22.05.2018	
6	Avg. Energy Catered	435 Mus		

- The power supply position for **Mumbai system** in May-2018 are given below:-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	3670 MW	31.05.2018	16:00 Hrs
2	Min. Demand	2087 MW	01.05.2018	08:00 Hrs
3	Energy Catered	2119.89 Mus		
4	Max. Energy Catered	74.86 Mus	31.05.2018	
5	Avg. Energy Catered	68.4 Mus		

Load shedding in MSEDCL area :

- Revised Feeder wise planned load shedding protocol in MSEDCL, based on MERC Order in Case No.41 of 2012 dt.26.11.2012, is implemented w.e.f. 16/01/2013 by MSEDCL as per circular No.46 Dated 14/01/2013. The hourly load relief quantum is submitted at the end of the day, daily, by LM cell of MSEDCL, Kalwa.
 - Max. load shedding was recorded as 7 MW and Min. load shedding was recorded as 0 MW. Average load shedding quantum for the month was 7 MW.
 - Planned load shedding for load relief is carried out in MSEDCL area to mitigate the availability in real time if required. AG-LM load management scheme is revised as per the new load shedding circular w.e.f. 17.09.2017 vide MSEDCL letter no. ED-I/Ag Time Change/22352 dt, 15.09.2017, 3 phase supply to AG loads will be 10/8 Hrs. w.e.f. 17.09.2017.
 - There was no distress load shedding due to shortfall of supply during the month.
-

Other Highlights of Maharashtra System in May-2018

- The RGPPL Power is scheduled to Railways only.
 - 14.594 TMC of Koyna water was utilized for May-2018.
 - Wind Generation for the month was 671.86 Mus. Average wind generation was 903 MW/hour.
 - The average grid frequency for the month was 49.95 Hz. The Instantaneous Maximum frequency was 50.01 Hz and Minimum frequency was 49.77 Hz.
 - There was no instance of under frequency operation during the month.
 - MSPGCL Thermal actual generation was as high as 6586 MW (hourly max) on 14/05/2018 at 11:00 hrs.
 - MSPGCL Thermal actual generation was as low as 4854 MW (hourly min) on 01/05/2018 at 22:00 hrs.
 - Max. Voltage at 765KV Substation was recorded at 765KV Ektuni substation i.e 789 KV and Min voltage was recorded at 765KV Tirora substation i.e 746 KV
 - Max. Voltage at MSETCL 400 kV Substation was recorded at 400KV Chandrapur I i.e 434 kV and Min voltage was recorded at 400KV Jejuri i.e 371 kV
 - There was no planned load shedding in Mumbai area (BEST, R-infra-D and TPC-D) during the month.
-