

Note on

Maharashtra Power System Overview, under frequency operation, Load shedding (Planned and Distress) for the month of August-2017.

Maharashtra system Overview:-

The overview of Maharashtra system operation for the month of August-2017 with respect to availability and shortfall is elaborated as under.

- The power supply position for **STATE** in August -2017 are given below: -

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	20481 MW (with Load shedding 0 MW)	14.08.2017	12:00 Hrs
2	Min. Demand	12509 MW	21.08.2017	04:00 Hrs
3	Max. Demand Catered	20481 MW	14.08.2017	12:00 Hrs
4	Energy Catered	12552 Mus		
5	Max. Energy Catered	443 Mus	17.08.2017	
6	Avg. Energy Catered	405 Mus		

- The power supply position for **MSEDCL** in August-2017 are given below :-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	17591 MW (with Load shedding 35 MW)	18.08.2017	08:00 Hrs
2	Min. Demand	10946 MW	21.08.2017	03:00 Hrs
3	Max. Demand Catered	17556 MW	18.08.2017	08:00 Hrs
4	Energy Catered	10747 Mus		
5	Max. Energy Catered	381 Mus	17.08.2017	
6	Avg. Energy Catered	347 Mus		

- The power supply position for **Mumbai system** in August-2017 are given below:-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	3261 MW	11.08.2017	12:00 Hrs
2	Min. Demand	1528 MW	21.08.2017	04:00 Hrs
4	Energy Catered	1805 Mus		
5	Max. Energy Catered	64 Mus	11.08.2017	
6	Avg. Energy Catered	58.2 Mus		

Load shedding in MSEDCL area :

- Revised Feeder wise planned load shedding protocol in MSEDCL, based on MERC Order in Case No.41 of 2012 dt.26.11.2012, is implemented w.e.f. 16/01/2013 by MSEDCL as per circular No.46 Dated 14/01/2013. The hourly load relief quantum is submitted at the end of the day, daily, by LM cell of MSEDCL, Kalwa.
 - Max. load shedding was recorded as 41 MW and Min. load shedding was recorded as 0 MW. Average load shedding quantum for the month was 0.17 MW.
 - Planned load shedding for load relief is carried out in MSEDCL area to mitigate the availability in real time if required. AG-LM load management scheme is revised as per the new load shedding circular w.e.f. 16.12.2017 vide MSEDCL letter no. EDI/12hrs.Ag supply/37003 dt, 15.12.2017m 3 phase supply to AG loads will be 8/10 Hrs. w.e.f. 16.12.2017.
 - There was no distress load shedding due to shortfall of supply during the month.
-

Other Highlights of Maharashtra System in August-17.

- The RGPPL Power is scheduled to Railways only.
 - 3.707 TMC of Koyna water was utilized for August-2017.
 - Wind Generation for the month was 841 Mus. Average wind generation was 1130 MW/hour.
 - The average grid frequency for the month was 49.98 Hz. The Instantaneous Maximum frequency was 50.19Hz and Minimum frequency was 49.65 Hz.
 - There was no instance of under frequency operation during the month.
 - MSPGCL Thermal actual generation was as high as 7551 MW (hourly max) on 18/08/2017 at 09:00 hrs.
 - MSPGCL Thermal actual generation was as low as 3245 MW (hourly min) on 29/08/2017 at 18:00 hrs.
 - Max. Voltage at 765KV Substation was recorded at 765KV Ektuni substation i.e 792 KV and Min voltage was recorded at 765KV Tirora substation i.e 702 KV
 - Max. Voltage at MSETCL 400 kV Substation was recorded at 400KV Nanded i.e 439 kV and Min voltage was recorded at 400KV Lamboti i.e 377 kV
 - There was no planned load shedding in Mumbai area (i.e. BEST, R-infra-D and TPC-D) during the month.
-