

Note on**Maharashtra Power System Overview, under frequency operation, Load shedding (Planned and Distress) for the month of September - 2020****Maharashtra system Overview:-**

The overview of Maharashtra system operation for the month of September - 2020 with respect to availability and shortfall is elaborated as under;

- The power supply position for **STATE** in September - 2020 are given below: -

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	19356 MW (with Load shedding 0 MW)	05.09.2020	13:00 Hrs.
2	Min. Demand	13042 MW	21.09.2020	03:00 Hrs.
3	Max. Demand Catered	19356 MW	05.09.2020	13:00 Hrs.
4	Energy Catered	11897 MUs		
5	Max. Energy Catered	425 MUs	05.09.2020	
6	Avg. Energy Catered	397 MUs		

- The power supply position for **MSEDCL** in September- 2020 are given below :-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	16898 MW (with Load shedding 0 MW)	05.09.2020	13:00 Hrs.
2	Min. Demand	11327 MW	21.09.2020	03:00 Hrs.
3	Max. Demand Catered	16898 MW	05.09.2020	13:00 Hrs.
4	Energy Catered	10401 MUs		
5	Max. Energy Catered	374 MUs	05.09.2020	
6	Avg. Energy Catered	347 MUs		

- The power supply position for **Mumbai system** in September - 2020 are given below:-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	2706 MW	11.09.2020	13:00 Hrs.
2	Min. Demand	1457 MW	01.09.2020	05:00 Hrs.
3	Energy Catered	1496 MUs		
4	Max. Energy Catered	54 MUs	09.09.2020	
5	Avg. Energy Catered	50 MUs		

Load shedding in MSEDCL area :

- Revised Feeder wise planned load shedding protocol in MSEDCL, based on MERC Order in Case No.41 of 2012 dt.26.11.2012, is implemented w.e.f. 16/01/2013 by MSEDCL as per circular No.46 Dated 14/01/2013. The hourly load relief quantum is submitted at the end of the day, daily, by LM cell of MSEDCL, Kalwa.
- Max. load shedding was recorded as 0 MW and Min. load shedding was recorded as 0 MW. Average load shedding quantum for the month was 0 MW.
- Planned load shedding for load relief is carried out in MSEDCL area to mitigate the availability in real time if required. AG-LM load management scheme is revised as per the new load shedding circular w.e.f. 01.01.2019 vide MSEDCL letter no. CE(PP)/LM/30923 dt, 29.12.2018, 3 phase supply to AG loads will be 8/10 Hrs. w.e.f. 01.01.2019.

Other Highlights of Maharashtra System in September - 2020

- The RGPPL Power is scheduled to Railways only.
 - 3.331 TMC of Koyna water is utilized for September – 2020.
 - Wind Generation for the month was 369 MUs. Average wind generation was 513 MW/hour.
 - The average grid frequency for the month was 49.99 Hz. The Instantaneous Maximum frequency was 50.09 Hz and Minimum frequency was 49.78 Hz.
 - There was no instance of under frequency operation during the month.
 - MSPGCL Thermal actual generation was as high as 6176 MW (hourly max) on 09/09/2020 at 20:00 hrs.
 - MSPGCL Thermal actual generation was as low as 3731 MW (hourly min) on 23/09/2020 at 13:00 hrs.
 - Max. Voltage at 765kV Substation was recorded as 798 at 765KV Ektuni substation and Min voltage was recorded as 749kV at 765kV Tirora substation.
 - Max.Voltage at MSETCL 400 kV Substation recorded as 440kV at 400KV Kalwa and Min voltage was recorded as 392 at 400KV Chakan.
 - There was no planned load shedding in Mumbai area (BEST, AEML-D and TPC-D) during the month.
-