

**Note on****Maharashtra Power System Overview, under frequency operation, Load shedding (Planned and Distress) for the month of October - 2020****Maharashtra system Overview:-**

The overview of Maharashtra system operation for the month of October - 2020 with respect to availability and shortfall is elaborated as under;

- The power supply position for **STATE** in October - 2020 are given below: -

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	20656 MW ( with Load shedding 0 MW)	08.10.2020	12:00 Hrs.
2	Min. Demand	13671 MW	15.10.2020	04:00 Hrs.
3	Max. Demand Catered	20656 MW	08.10.2020	12:00 Hrs.
4	Energy Catered	12904 MUs		
5	Max. Energy Catered	450 MUs	08.10.2020	
6	Avg. Energy Catered	416 MUs		

- The power supply position for **MSEDCL** in October- 2020 are given below :-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	17890 MW ( with Load shedding 0 MW )	08.10.2020	12:00 Hrs.
2	Min. Demand	11794 MW	26.10.2020	02:00 Hrs.
3	Max. Demand Catered	17890 MW	08.10.2020	12:00 Hrs.
4	Energy Catered	11245 MUs		
5	Max. Energy Catered	394 MUs	08.10.2020	
6	Avg. Energy Catered	363 MUs		

- The power supply position for **Mumbai system** in October - 2020 are given below:-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	2854 MW	22.10.2020	12:00 Hrs.
2	Min. Demand	510 MW	12.10.2020	12:00 Hrs.
3	Energy Catered	1659 MUs		
4	Max. Energy Catered	58 MUs	21.10.2020	
5	Avg. Energy Catered	54 MUs		

#### **Load shedding in MSEDCL area :**

- Revised Feeder wise planned load shedding protocol in MSEDCL, based on MERC Order in Case No.41 of 2012 dt.26.11.2012, is implemented w.e.f. 16/01/2013 by MSEDCL as per circular No.46 Dated 14/01/2013. The hourly load relief quantum is submitted at the end of the day, daily, by LM cell of MSEDCL, Kalwa.
- Max. load shedding was recorded as 0 MW and Min. load shedding was recorded as 0 MW. Average load shedding quantum for the month was 0 MW.
- Planned load shedding for load relief is carried out in MSEDCL area to mitigate the availability in real time if required. AG-LM load management scheme is revised as per the new load shedding circular w.e.f. 01.01.2019 vide MSEDCL letter no. CE(PP)/LM/30923 dt, 29.12.2018, 3 phase supply to AG loads will be 8/10 Hrs. w.e.f. 01.01.2019.

### **Other Highlights of Maharashtra System in October - 2020**

- The RGPPL Power is scheduled to Railways only.
  - 2.654 TMC of Koyna water is utilized for October – 2020.
  - Wind Generation for the month was 256 MUs. Average wind generation was 344 MW/hour.
  - The average grid frequency for the month was 49.99 Hz. The Instantaneous Maximum frequency was 50.1 Hz and Minimum frequency was 49.88 Hz.
  - There was no instance of under frequency operation during the month.
  - MSPGCL Thermal actual generation was as high as 6938 MW (hourly max) on 19/10/2020 at 20:00 hrs.
  - MSPGCL Thermal actual generation was as low as 4101 MW (hourly min) on 16/10/2020 at 05:00 hrs.
  - Max. Voltage at 765kV Substation was recorded as 794 at 765KV Akola substation and Min voltage was recorded as 747kV at 765kV Koradi III substation.
  - Max.Voltage at MSETCL 400 kV Substation recorded as 440kV at 400KV Kalwa and Min voltage was recorded as 371 at 400KV Jejuri.
  - There was no planned load shedding in Mumbai area (BEST, AEML-D and TPC-D) during the month.
-