

Note on**Maharashtra Power System Overview, under frequency operation, Load shedding (Planned and Distress) for the month of November -2018****Maharashtra system Overview:-**

The overview of Maharashtra system operation for the month of November-2018 with respect to availability and shortfall is elaborated as under;

- The power supply position for **STATE** in November - 2018 are given below: -

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	23341 MW (with Load shedding 0 MW)	03.11.2018	12:00 Hrs
2	Min. Demand	15055 MW	08.11.2018	01:00 Hrs
3	Max. Demand Catered	23341 MW	03.11.2018	12:00 Hrs
4	Energy Catered	13403 Mus		
5	Max. Energy Catered	492 Mus	03.11.2018	
6	Avg. Energy Catered	447 Mus		

- The power supply position for **MSEDCL** in November-2018 are given below :-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	20231 MW (with Load shedding 0 MW)	03.11.2018	12:00 Hrs
2	Min. Demand	12767 MW	08.11.2018	01:00 Hrs
3	Max. Demand Catered	20231 MW	03.11.2018	12:00 Hrs
4	Energy Catered	11640 Mus		
5	Max. Energy Catered	427 Mus	03.11.2018	
6	Avg. Energy Catered	388 Mus		

- The power supply position for **Mumbai system** in November-2018 are given below:-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	3259MW	05.11.2018	12:00 Hrs
2	Min. Demand	1702 MW	30.11.2018	05:00 Hrs
3	Energy Catered	1763 Mus		
4	Max. Energy Catered	67 Mus	05.11.2018	
5	Avg. Energy Catered	59 Mus		

Load shedding in MSEDCL area :

- Revised Feeder wise planned load shedding protocol in MSEDCL, based on MERC Order in Case No.41 of 2012 dt.26.11.2012, is implemented w.e.f. 16/01/2013 by MSEDCL as per circular No.46 Dated 14/01/2013. The hourly load relief quantum is submitted at the end of the day, daily, by LM cell of MSEDCL, Kalwa.
- Max. load shedding was recorded as 20 MW on dt. 26.11.2018 at 14.00 hrs. and Min. load shedding was recorded as 0 MW. Average load shedding quantum for the month was 0.094 MW.
- Planned load shedding for load relief is carried out in MSEDCL area to mitigate the availability in real time if required. AG-LM load management scheme is revised as per the new load shedding circular w.e.f. 17.09.2017 vide MSEDCL letter no. ED-I/Ag Time Change/22352 dt, 15.09.2017, 3 phase supply to AG loads will be 10/8 Hrs. w.e.f. 17.09.2017.

Other Highlights of Maharashtra System in November-2018

- The RGPPL Power is scheduled to Railways only.
 - 1.267 TMC of Koyna water was utilized for November-2018.
 - Wind Generation for the month was 242 Mus. Average wind generation was 337 MW/hour.
-

- The average grid frequency for the month was 49.97 Hz. The Instantaneous Maximum frequency was 50.08 Hz and Minimum frequency was 49.85 Hz.
 - There was no instance of under frequency operation during the month.
 - MSPGCL Thermal actual generation was as high as 6771 MW (hourly max) on 30/11/2018 at 12:00 hrs.
 - MSPGCL Thermal actual generation was as low as 4512 MW (hourly min) on 05/11/2018 at 07:00 hrs.
 - Max. Voltage at 765KV Substation was recorded at 765KV Akola substation i.e 790 KV and Min voltage was recorded at 765KV Tirora substation i.e 744 KV
 - Max. Voltage at MSETCL 400 kV Substation was recorded at 400KV Kalwa i.e 439 kV and Min voltage was recorded at 400KV Jejuri i.e 384 kV
 - There was no planned load shedding in Mumbai area (BEST, R-infra-D and TPC-D) during the month.
-