

**Note on****Maharashtra Power System Overview, under frequency operation, Load shedding (Planned and Distress) for the month of November - 2019****Maharashtra system Overview:-**

The overview of Maharashtra system operation for the month of November - 2019 with respect to availability and shortfall is elaborated as under;

- The power supply position for **STATE** in November - 2019 are given below: -

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	21471 MW ( with Load shedding 0 MW)	30.11.2019	12:00 Hrs
2	Min. Demand	12830 MW	02.11.2019	03:00 Hrs
3	Max. Demand Catered	21471 MW	30.11.2019	12:00 Hrs
4	Energy Catered	12329 MUs		
5	Max. Energy Catered	445 MUs	30.11.2019	
6	Avg. Energy Catered	411 MUs		

- The power supply position for **MSEDCL** in November- 2019 are given below :-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	18477 MW ( with Load shedding 0 MW )	30.11.2019	12:00 Hrs
2	Min. Demand	10880 MW	02.11.2019	03:00 Hrs
3	Max. Demand Catered	18477 MW	30.11.2019	12:00 Hrs
4	Energy Catered	10526 MUs		
5	Max. Energy Catered	385 MUs	30.11.2019	
6	Avg. Energy Catered	351 MUs		

- The power supply position for **Mumbai system** in November - 2019 are given below:-

Sr No.	Particulars	Recorded Demand/Requirement	Date	Time
1	Max. Demand	3230 MW	05.11.2019	12:00 Hrs
2	Min. Demand	1792 MW	11.11.2019	05:00 Hrs
3	Energy Catered	1803 MUs		
4	Max. Energy Catered	64 MUs	05.11.2019	
5	Avg. Energy Catered	60 MUs		

#### **Load shedding in MSEDCL area :**

- Revised Feeder wise planned load shedding protocol in MSEDCL, based on MERC Order in Case No.41 of 2012 dt.26.11.2012, is implemented w.e.f. 16/01/2013 by MSEDCL as per circular No.46 Dated 14/01/2013. The hourly load relief quantum is submitted at the end of the day, daily, by LM cell of MSEDCL, Kalwa.
- Max. load shedding was recorded as 0 MW and Min. load shedding was recorded as 0 MW. Average load shedding quantum for the month was 0 MW.
- Planned load shedding for load relief is carried out in MSEDCL area to mitigate the availability in real time if required. AG-LM load management scheme is revised as per the new load shedding circular w.e.f. 01.01.2019 vide MSEDCL letter no. CE(PP)/LM/30923 dt, 29.12.2018, 3 phase supply to AG loads will be 8/10 Hrs. w.e.f. 01.01.2019.

### **Other Highlights of Maharashtra System in November - 2019**

- The RGPPL Power is scheduled to Railways only.
  - 5.293 TMC of Koyna water is utilized for November – 2019.
  - Wind Generation for the month was 249 MUs. Average wind generation was 346 MW/hour.
  - The average grid frequency for the month was 50.00 Hz. The Instantaneous Maximum frequency was 50.09 Hz and Minimum frequency was 49.85 Hz.
  - There was no instance of under frequency operation during the month.
  - MSPGCL Thermal actual generation was as high as 6469 MW (hourly max) on 22/11/2019 at 18:00 hrs.
  - MSPGCL Thermal actual generation was as low as 2492 MW (hourly min) on 03/11/2019 at 21:00 hrs.
  - Max. Voltage at 765kV Substation was recorded at 765KV Ektuni substation i.e 797 kV and Min voltage was recorded at 765kV Tirora substation i.e 746 kV.
  - Max. Voltage at MSETCL 400 kV Substation was recorded at 400KV Kalwa and Nandgaon i.e 439 kV and Min voltage was recorded at 400KV Lamboti i.e 388 kV.
  - There was no planned load shedding in Mumbai area (BEST, AEML-D and TPC-D) during the month.
-