

Maharashtra State Load Despatch Centre
WRPC OCCM approved Monthly Outage list for the Month of January'2019

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
1	2	400	BABHALESHWAR - PADGHE 1	01/Jan/19	08:00	10/Jan/19	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	A/R in non auto mode
2	3	400	BABHALESHWAR - PADGHE 1 ON TBC @ BABHALESHWAR	01/Jan/19	09:00	05/Jan/19	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of Isolators work	MSETCL	MSETCL	400 kv Babhaleshwar-Padghe ckt-1 Bay will be on TBC for Repairing of 29A & 29B P.G Isolator Scissors (Hanger dropper assembly of Padghe 01 bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)
3	4	400	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	01/Jan/19	08:00	12/Jan/19	17:00	Daily	PID TESTING	MSETCL	MSETCL	NA
4	5	400	KARAD - TALANDGE CKT 1 & 2	01/Jan/19	09:00	31/Jan/19	17:00	Daily	Permission for Auto Reclose to be kept OFF for PID testing & Hot Line Insulator replacement work	MSETCL	MSETCL	Permission for A/R to be kept OFF
5	7	220	PUSAD - WARDHA (PG)	01/Jan/19	07:00	31/Jan/19	17:00	Daily	PID TESTING	MSETCL	MSETCL	A/R OUT
6	8	220	220KV Bus-I at Boisar	01/Jan/19	9:00	01/Jan/19	17:30	Daily	For AMP	POWERGRID	WR-II	R
7	34	400	NEW KOYNA - DABHOL - I	01/Jan/19	08:00	02/Jan/19	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-New koyna CKT-II line
8	35	400	PARLI-SOLAPUR (LAMBOTI)	01/Jan/19	09:00	31/Jan/19	17:00	Daily	PID Work	MSETCL	MSETCL	Line will be inservice.
9	37	400	SSNL - Dhule - 1	01/Jan/19	8:00	01/Jan/19	18:00	Daily	PMM work	GETCO / MSTCL	GETCO	Auto reclose SSP- Dhule No. 2 will remain out
10	41	132	MANSAR-PENCH	02/Jan/19	09:00	02/Jan/19	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather condition.
11	43	220	SOUTH SOLAPUR (KUMBHARI)-PGCIL 1	02/Jan/19	11:00	02/Jan/19	16:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	Load can be managed on 220 kv South Solapur - PGCIL Ckt 2
12	73	400	80 MVAR Bus reactor @ Talandge	02/Jan/19	09:00	02/Jan/19	18:00	Daily	Annual maintenance work	MSETCL	MSETCL	-
13	80	400	GTR - 6 on TBC - II @ CHANDRAPUR	02/Jan/19	09:30	07/Jan/19	18:00	Continuous	1) For attending the air leakage problem from control valve. 2) Overhauling & servicing of Mechanism (Puematic drive) and Interrupter & support pole of R, Y & B-ph Breaker pole. 3) The Measurement of DCRM, CRM & Timing of breaker. 4) Maintenance & Alignments work of PG-I & PG-II Isolators.	MSETCL	MSETCL	The work will be carried out by shifting this bay on 400KV TBC-II bay
14	85	400	PARLI - LONIKAND 2 CKT 2	02/Jan/19	09:00	02/Jan/19	17:00	Daily	(1) Distance relay testing work. (2) 50 MVAR Reactor erection & Commissioning work.	MSETCL	MSETCL	-
15	86	400	SSP -Dhule - 2	02/Jan/19	8:00	02/Jan/19	18:00	Daily	PMM work	GETCO / MSTCL	GETCO	Auto reclose SSP- Dhule No.1 will remain out
16	99	400	400kv AURANGABAD(MSETCL)-PUNE(GIS) I	03/Jan/19	9:00	03/Jan/19	18:00	Daily	For AMP of Bay and non-switchable Line reactor at Pune-GIS Other ckt A/R in non-auto mode required.	WRTS-I	WRTS-I	R
17	123	765	BUS - I @ KORADI - 3	03/Jan/19	09:00	03/Jan/19	18:00	Daily	Testing & Maintenance of Bus connected Isolator and CVT	MEGPTCL	MEGPTCL	Annual Maintenance
18	124	400	BUS COUPLER @ KOLHAPUR-III (TALANDGE)-400 KV	03/Jan/19	09:00	03/Jan/19	18:00	Daily	Annual maintenance work	MSETCL	MSETCL	-
19	128	400 KV	Dhariwal- Bhadrawati 400 KV Tr. Line	03/Jan/19	8:00	03/Jan/19	18:00	Daily	For fixing line spacer cum damper, tightening bolts & nuts of suspension clamp, hardware fitting and jumper pad, other line related maintenance work and A/R of Dhariwal-Parli Ckt-II in N/A mode required.	WRTS-I	Dhariwal Infrastructure Ltd.	Planned
20	131	400	NEW KOYNA - DABHOL - II	03/Jan/19	08:00	04/Jan/19	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-New koyna CKT-I line
21	138	220	BOISAR II - TARAPUR	04/Jan/19	07:00	04/Jan/19	18:00	Daily	Routine Maintenance and diagnostic testing work	MSETCL	MSETCL	NOC required from PGCIL end
22	143	400	400kv AURANGABAD(MSETCL)-PUNE(GIS) II	04/Jan/19	9:00	04/Jan/19	18:00	Daily	For AMP of Bay / line and Non-switchable Line Reactor at Pune-GIS Other ckt A/R in non-auto mode required.	WRTS-I	WRTS-I	R
23	174	400 KV	Dhariwal- Parli 400 KV Tr. Line	04/Jan/19	8:00	04/Jan/19	18:00	Daily	For fixing line spacer cum damper, tightening bolts & nuts of suspension clamp, hardware fitting and jumper pad, other line related maintenance work and A/R of Dhariwal-Bhadrawati Ckt-II in N/A mode required.	WRTS-I	Dhariwal Infrastructure Ltd.	Planned
24	180	400	MAIN BAY (408) OF WARDHA(PG) CKT - 1 @ AKOLA	04/Jan/19	08:00	04/Jan/19	18:00	Daily	Routine Maintenance and testing work	MSETCL	MSETCL	NA
25	181	765	MAIN BAY (701) OF ICT @ TIRORA	04/Jan/19	09:00	04/Jan/19	18:00	Daily	Testing & Maintenance of Bay Breaker & CT	MEGPTCL	MEGPTCL	Annual Maintenance
26	183	400	TIE BAY (408) OF STN T/F-2 & KORADI 3 CKT-1 @ KORADI 2	04/Jan/19	10:00	04/Jan/19	17:00	Daily	DCRM, IR, Timing Measurement of 408-Q52	MSETCL	MSETCL	Station transformer-II will remain service through Main Bay 407 & Koradi-II to Koradi-III Ckt.-I will remain in service throught its Main Bay 409(full DIA)
27	200	400	400KV Kalwa Main bay (416) at Talegaon	05/Jan/19	9:00	05/Jan/19	14:00	Daily	For AMP works	WRTS-I	WRTS-I	R
28	225	400	MAIN BAY (409) OF KORADI 3 CKT- 1 @ KORADI 2	05/Jan/19	10:00	05/Jan/19	17:00	Daily	DCRM, IR, Timing Measurement of CB 409-Q52	MSETCL	MSETCL	Koradi-II-Koradi-III Ckt.-I will remain in service throught its Tie Bay 408
29	226	400	PADGHE - NAGOTHANE D/C	05/Jan/19	09:00	16/Jan/19	18:00	Continuous	1) New in line Tower Erection Work 2) New conductor stringing	MSETCL	MSETCL	Outage require for shifting & hight rising work of Padghe - Nagothane D/C at M/S Godrage Premises at Vadval.
30	228	400	BABHALESHWAR - PADGHE 2 ON TBC @ BABHALESHWAR	06/Jan/19	09:00	10/Jan/19	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of Isolators work	MSETCL	MSETCL	400 kv Babhaleshwar-Padghe ckt-2 Bay will be on TBC for Repairing of 29A & 29B P.G Isoaltor P.G Isoaltor Scissors (Hanger dropper assembly of Padghe 2 bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)
31	229	220	BOISAR II - PGCIL 2	06/Jan/19	07:00	06/Jan/19	18:00	Daily	Routine Maintenance and diagnostic testing work	MSETCL	MSETCL	NOC required from PGCIL end

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
32	240	400	400KV SOLAPUR-ALKUD	06/Jan/19	14:00	06/Jan/19	15:30	Daily	FOR LBB AND BUSBAR TESTING AT SOLAPUR	MSETCL	WRTS-I	R
33	241	400	400KV SOLAPUR-KOLHAPUR	06/Jan/19	16:00	06/Jan/19	17:30	Daily	FOR LBB AND BUSBAR TESTING AT SOLAPUR	MSETCL	WRTS-I	R
34	242	400	400KV SOLAPUR-LAMBOTI	06/Jan/19	9:00	06/Jan/19	10:30	Daily	FOR LBB AND BUSBAR TESTING AT SOLAPUR	MSETCL	WRTS-I	R
35	243	400	400KV Talegaon-Chakan Line	06/Jan/19	9:00	06/Jan/19	17:00	Daily	For AMP of Line Equipments at Talegaon	MSETCL	WRTS-I	R
36	253	220	DEOLI(PGCIL)-BADNERA	06/Jan/19	10:00	07/Jan/19	18:00	Continuous	Destrinding and restrinding of 220KV Badnera-Dhamangaon from Loc.No 03 to Loc.No 4 for Erection of inline tower between Loc. No.3 & 4 for new 220kv Badnera-Ner line ph-I	MSETCL	MSETCL	NA
37	255	765	MAIN BAY - 707 OF EKTUNI CKT - 2 @ AKOLA 2	06/Jan/19	09:00	06/Jan/19	18:00	Daily	Annual Maintenance of Bay Equipment	MEGPTCL	MEGPTCL	Annual Maintenance
38	265	400	400 KV Bus-2 along with 400 KV Warora MSETCL Line with Bays at Wardha	07/Jan/19	18:00	07/Jan/19	20:00	Daily	For Testing LBB relay of Respective Main Bay	MSETCL	WRTS-I	R
39	266	400	400 KV Bus-2 along with 400 KV Warora#1 (PG) Line with Bays at Wardha	07/Jan/19	14:00	07/Jan/19	16:00	Daily	For Testing LBB relay of Respective Main Bay	WRTS-I	WRTS-I	R
40	269	400	400 KV Bus-2 at Wardha	07/Jan/19	9:00	07/Jan/19	18:00	Daily	Alignment of newly erected bus isolator	WRTS-I	WRTS-I	C
41	270	400	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	07/Jan/19	09:00	19/Jan/19	23:53	Continuous	Replacement of ICT 3 B phase unit with repaired job	MSETCL	MSETCL	-
42	314	400	BUS COUPLER @ LONIKAND-1	07/Jan/19	10:00	07/Jan/19	17:00	Daily	Routine Dignostic testing & maintenance work	MSETCL	MSETCL	-
43	318	220	DEOLI(PGCIL)-BADNERA	07/Jan/19	09:00	12/Jan/19	17:00	Daily	PID TESTING	MSETCL	MSETCL	NA
44	320	400	DHULE - SSNNL I & AR of CKT - II IN NON-AUTO MODE @ DHULE S/S	07/Jan/19	08:00	07/Jan/19	18:00	Daily	Replacement of Suspicious Faulty insulator string found in PID at various locations	MSETCL	MSETCL	400kv Dhule SSNNI 2 A/R switch to be kept on non auto mode
45	330	765	TIE BAY (711) OF AKOLA CKT - 2 & TIRODA CKT - 1 @ KORADI - 3	07/Jan/19	09:00	07/Jan/19	18:00	Daily	Annual Maintenance of Bay Equipment	MEGPTCL	MEGPTCL	Annual Maintenance
46	349	400kv	400Kv AURANGABAD(MSETCL)-PUNE(GIS) I	08/Jan/19	9:00	08/Jan/19	13:00	Daily	Bay LBB Testing at Pune-GIS	WRTS-I	WRTS-I	R
47	350	400kv	400Kv AURANGABAD(MSETCL)-PUNE(GIS) II	08/Jan/19	14:00	08/Jan/19	18:00	Daily	Bay LBB Testing at Pune-GIS	WRTS-I	WRTS-I	R
48	388	400	DHULE - SSNNL II & AR OF CKT I IN NON-AUTO MODE @ DHULE S/S	08/Jan/19	08:00	08/Jan/19	18:00	Daily	Replacement of suspicious faulty insulator string found in PID at various locations	MSETCL	MSETCL	400kv Dhule SSNNL 1 A/R switch to be kept in non auto mode
49	394	765	MAIN BAY (707) OF KORADI CKT - 1 @ TIRODA	08/Jan/19	09:00	08/Jan/19	18:00	Daily	Testing & Maintenance of Bay Breaker & CT	MEGPTCL	MEGPTCL	Annual Maintenance
50	400	400	CHANDRAPUR - KHAPEKHEDE ON TBC - I @ CHANDRAPUR	09/Jan/19	09:00	14/Jan/19	18:00	Continuous	1) For attending the air leakage problem from control valve. 2) Overhauling & servicing of Mechanism (Pneumatic drive) and Interrupter & support pole of R, Y & B-ph Breaker pole. 3) The Measurement of DCRM, CRM & Timing of breaker. 4) Maintenance & Alignments work of PG-I & PG-II Isolators.	MSETCL	MSETCL	The work will be carried out by shifting this bay on 400KV TBC-I bay.
51	401	220	KALMESHWAR-PANDHURNA	09/Jan/19	09:00	09/Jan/19	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Outage will be availed subject to weather condition.
52	402	400	KORADI 2-WARDHA PGCIL	09/Jan/19	09:00	09/Jan/19	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	400KV WARORA-IEPL Line is in ckt
53	403	220	MAHALAXMI - AMONA	09/Jan/19	08:00	09/Jan/19	17:00	Daily	routine maintenance and diagnostic testing work	MSETCL	MSETCL	-
54	407	220	220KV Pandhurna-Kamleshwar	09/Jan/19	9:00	09/Jan/19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	R
55	437	400	DHULE - DHULE(BDTCL) CKT - 1	09/Jan/19	08:00	09/Jan/19	19:00	Daily	Bay Routine Maintenance work and diagnostic testing work	MSETCL	MSETCL	400kv Dhule BDTCL I is under BDTCL but Bay Maintenance work is to be carried out at 400kv Dhule SS so outage is proposed on Dhule BDTCL ckt 1
56	440	220	JEUR - SOLAPUR PG	09/Jan/19	10:00	09/Jan/19	17:00	Daily	Outage is required for QM work	MSETCL	MSETCL	132KVParewadi, Karmala,Karjat,Rashin & 132KV Bhairavnath Co-gen & 132KV Kurduwadi load will be affected. Partly load will be managed on 220 kv Tembhurni Line.
57	447	400	CHANDRAPUR 2 - WARORA CKT-2	10/Jan/19	08:00	10/Jan/19	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	Tightening of conductor ,Earthwire Hardware.
58	455	400	400 KV Bus-1 at Wardha	10/Jan/19	9:00	10/Jan/19	18:00	Daily	Alignment of newly erected bus isolator	WRTS-I	WRTS-I	C
59	491	400	DHULE - DHULE(BDTCL) CKT - 2	10/Jan/19	08:00	10/Jan/19	19:00	Daily	400kv Dhule BDTCL 2 Bay routine testing and diagnostic testing work at 400 kv Dhule SS	MSETCL	MSETCL	400kv Dhule BDTCL ckt 2 is under BDTCL but Bay Maintenance work is to be carried out at 400kv Dhule SS so outage is proposed on Dhule BDTCL ckt 2
60	496	765	MAIN BAY (709) OF KORADI 3 CKT-2 @ AKOLA 2	10/Jan/19	09:00	10/Jan/19	18:00	Daily	Annual Maintenance of Bay Equipment	MEGPTCL	MEGPTCL	Annual Maintenance
61	499	400	BABHALESHWAR - PADGHE 2	11/Jan/19	08:00	20/Jan/19	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	A/R in non auto mode
62	500	400	CHANDRAPUR 2 - WARORA CKT-1	11/Jan/19	08:00	11/Jan/19	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	Tightening of conductor ,Earthwire Hardware.
63	503	400	WARORA - Wardha(PG)	11/Jan/19	09:00	11/Jan/19	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	400KV WARORA-IEPL Line is in ckt
64	511	400	400/220/33 KV 600 MVA ICT - 4 @ PADGHE	11/Jan/19	09:00	13/Jan/19	18:00	Continuous	Diagnostic Testing Work. Oil Filtration Work	MSETCL	MSETCL	For Load Management Work ,220 KV Temghar-1 & Temghar-2 will remain handrip
65	540	400	BABHALESHWAR - AURANGABAD (WALUJ) ON TBC @ BABHALESHWAR	11/Jan/19	09:00	17/Jan/19	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of Isolators work	MSETCL	MSETCL	400 kv Babhaleshwar-Aurangabad Bay will be TBC for Repairing of 29A & 29B P.G Isolator P.G Isolator Scissoes (Hanger dropper assembly of Aurangabad bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)
66	543	400	Bay No-408 Tie Bay of 400kv Boisar-Padghe Line & ICT-I at Boisar	11/Jan/19	9:00	11/Jan/19	13:00	Daily	For AMP	POWERGRID	WR-II	R

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
67	554	400	MAIN BAY (418) OF 400/11.5KV Station Transformer - 5 @ Tirora	11/Jan/19	08:00	11/Jan/19	18:00	Daily	Testing & Maintenance of Bay Breaker & CT	APML	APML	Testing & Maintenance of Bay Breaker & CT
68	555	400	MAIN BUS - 1 @ DEEPNAGAR	11/Jan/19	08:00	11/Jan/19	17:00	Daily	Routine Maintenance and Diagnostic testing work	MSETCL	MSETCL	400KV Bus 2 will be in service
69	556	400	MIAN BAY-422 OF STATION TF - 1 @ KORADI -2	11/Jan/19	10:00	11/Jan/19	17:00	Daily	DCRM, IR ,Timing Measurement of CB 422-Q52	MSETCL	MSETCL	Station Transformer-I will remain in service through Tie Bay 423.
70	616	400	KHARGHAR - TALEGAON (PG)	13/Jan/19	08:00	13/Jan/19	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	-
71	618	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	14/Jan/19	10:00	31/Jan/19	17:00	Daily	PID TESTING	MSETCL	MSETCL	NA
72	619	400	CHANDRAPUR-PARLI CKT-3	14/Jan/19	10:00	31/Jan/19	17:00	Daily	PID TESTING	MSETCL	MSETCL	NA
73	620	220	MUDSHINGI - CHIKODI	14/Jan/19	10:00	14/Jan/19	17:00	Daily	routine maintenance and diagnostic testing work	MSETCL	MSETCL	-
74	640	400	BUS COUPLER @ BABHALESHWAR	14/Jan/19	09:00	15/Jan/19	17:00	Continuous	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of Isolator for 400KV Bus coupler (Hanger dropper assembly of 400KV Bus coupler Bay will be remove and connected on 400 kv bus 1 and bus 2 work carrirs work	MSETCL	MSETCL	Bus will be seperated ((Hanger dropper assembly of 400KV Bus coupler Bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)
75	641	400	BUS COUPLER @ NEW KOYNA	14/Jan/19	08:00	14/Jan/19	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	--
76	686	400	DHULE - SSNNL I & II	15/Jan/19	08:00	15/Jan/19	18:00	Daily	Online PID testing of insulators	MSETCL	MSETCL	400kv Dhule SSNNL I A/R Switch to be kept on non auto mode
77	688	400	PARLI - KUMBHARGAON (NANDED) CKT - 1	15/Jan/19	09:00	15/Jan/19	18:00	Daily	(1) C&Tan delta Measurement of Reactor Bushing (2) Line Signature (3) Bay Maint Work	MSETCL	MSETCL	-
78	691	400	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	16/Jan/19	08:00	31/Jan/19	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.
79	692	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	16/Jan/19	08:00	16/Jan/19	17:00	Daily	Replacement or broken spacer cum vibration damper	MSETCL	MSETCL	NA
80	693	220	TILARI - AMONA LINE	16/Jan/19	08:00	16/Jan/19	17:00	Daily	routine maintenance and diagnostic testing work	MSETCL	MSETCL	-
81	728	400	DHULE - SSNNL I & II	16/Jan/19	08:00	16/Jan/19	18:00	Daily	PID testing of insulators	MSETCL	MSETCL	400kv Dhule SSNNI I A/R switch to be kept on Non auto mode
82	733	400	MAIN BAY (429) OF WARORA-WARDHA(PG) @400 KV WARDHA(PG)	16/Jan/19	09:00	16/Jan/19	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolator maintainance work .	MSETCL	MSETCL	Line will be charged through Tie CB 428.
83	738	400	NAGOTHANE - DABHOL 1	17/Jan/19	08:00	18/Jan/19	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-Nagothane CKT-II line
84	753	400	400KV Kala-Kudus line ckt-1 ((Dia to be kept open and Kala-Kudus 2 to be kept in N/A mode) by Boisar	17/Jan/19	8:00	17/Jan/19	19:00	Daily	For Insulator Replacement work	POWERGRID	WR-II	R
85	764	765	765KV Tiroda Koradi III Line 2 Main Bay 704 at Tiroda SS	17/Jan/19	09:00	17/Jan/19	18:00	Daily	Testing & Maintenance of Bay Breaker & CT	MEGPTCL	MEGPTCL	
86	773	400	GTR - 4 @ CHANDRAPUR ON TBC - I BAY @ CHANDRAPUR S/S	17/Jan/19	09:00	22/Jan/19	18:00	Continuous	1) For attending the air leakage problem from control valve. 2) Overhauling & servicing of Mechanism (Pumatic drive) and Interrupter & support pole of R, Y & B-ph Breaker pole. 3) The Measurement of DCRM, CRM & Timing of breaker. 4) Maintenance & Alignments work of PG-I & PG-II Isolators.	MSETCL	MSETCL	The work will be carried out by shifting this bay on 400KV TBC-I bay.
87	779	400	MAIN BAY (413) OF KORADI 2 LINE @ WARDHA (PG)	17/Jan/19	09:00	17/Jan/19	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
88	780	400	PARLI - LONIKAND 2 CKT 1	17/Jan/19	09:00	17/Jan/19	18:00	Daily	Half yearly maintenance And diagnostic testing	MSETCL	MSETCL	Load will be managed by 400 kv Lonikand-II- Parali ckt- II, load effected NIL
89	782	400	SOLAPUR PG - ALKUD	17/Jan/19	09:30	17/Jan/19	17:30	Daily	Quarterly Maint. Work	MSETCL	MSETCL	NA
90	784	400	CHANDRAPUR-PARLI CKT-3	18/Jan/19	08:00	18/Jan/19	17:00	Daily	Replacement or broken spacer cum vibration damper	MSETCL	MSETCL	NA
91	785	400	KALWA - KHARGHAR	18/Jan/19	08:00	18/Jan/19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	...
92	792	400	400kv Aurangabad (Waluj)-2 Main bay-409 at Aurangabad	18/Jan/19	9:00	18/Jan/19	18:00	Daily	For AMP works	WRTS-I	WRTS-I	R
93	800	400	400KV Kala-Kudus line ckt-2 ((Dia to be kept open and Kala-Kudus 1 to be kept in N/A mode) by Boisar	18/Jan/19	8:00	18/Jan/19	19:00	Daily	For Insulator Replacement work	POWERGRID	WR-II	R
94	802	400	400KV PADGHE(GIS)-KUDUS(MSETCL) I and ICT1_765/400kv_PADGHE(GIS)	18/Jan/19	10:00	18/Jan/19	12:00	Daily	402 Bay LBB Testing at Padghe ICT-1 and 400 KV kudus-1 will be out of service	WRTS-I	WRTS-I	R
95	803	400	400kv PADGHE(GIS)-KUDUS(MSETCL) II and ICT2_765/400kv_PADGHE(GIS)	18/Jan/19	14:00	18/Jan/19	16:00	Daily	405 Bay LBB Testing at Padghe, Kudus Line 2 and ICT -2 will be out of service	WRTS-I	WRTS-I	R
96	828	400	MAIN BUS - 1 @ KORADI - 2	18/Jan/19	10:00	18/Jan/19	15:00	Daily	Tan delta measurement of Bus CVT	MSETCL	MSETCL	Load will be shifted to 400KV Main Bus-II
97	829	400	MAIN BUS - 2 @ DEEPNAGAR	18/Jan/19	08:00	18/Jan/19	17:00	Daily	Routine maintenance and diagnostic testing work	MSETCL	MSETCL	400kv Bus 1 will in service
98	830	220	NALASOPARA - BOISAR PG	18/Jan/19	09:00	18/Jan/19	17:00	Daily	Routine and diagnostic testing work	MSETCL	MSETCL	NOC required from PGCL end
99	833	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	19/Jan/19	08:00	19/Jan/19	17:00	Daily	Replacement or broken spacer cum vibration damper	MSETCL	MSETCL	NA
100	834	400	NAGOTHANE - DABHOL 2	19/Jan/19	08:00	20/Jan/19	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-Nagothane CKT-I line
101	848	765	706 Main Bay of Bus Reactor at Tiroda SS	19/Jan/19	09:00	19/Jan/19	18:00	Daily	Annual Maintenance of Bay Equipment	APML	APML	
102	859	400	MAIN BUS - 2 @ KORADI 2	19/Jan/19	10:00	19/Jan/19	15:00	Daily	Tan delta measurement of Bus CVT	MSETCL	MSETCL	Load will be shifted to 400KV Main Bus-I
103	862	400	400 KV BUS-1 at Padghe along with 400 KV Kudus Line 2	20/Jan/19	14:00	20/Jan/19	16:00	Daily	404 Bay LBB Testing, Kudus Line 2 and 400 KV Bus -1 will be out of service	WRTS-I	WRTS-I	R
104	863	400	400 KV BUS-1 at Padghe along with 400 KV Padghe-Kudus Line 1	20/Jan/19	10:00	20/Jan/19	12:00	Daily	401 Bay LBB Testing, at Padghe Kudus Line -1 and 400 KV Bus -1 will be out of service	WRTS-I	WRTS-I	R
105	864	220	220KV Boisar-Boisar-III line at Boisar	20/Jan/19	8:00	20/Jan/19	13:00	Daily	AMP of Line terminal Equipment	POWERGRID	WR-II	R
106	873	400	BABHALESHWAR - PADGHE 1	21/Jan/19	09:00	21/Jan/19	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400kv Babhaleshwar-Padghe-Ckt-2 will be in service

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
107	889	400	400kV KOLHAPUR (MSETCL)- KOLHAPUR (GIS) I	21/Jan/19	14:00	21/Jan/19	16:00	DAILY	407 Main bay LBB relay testing at Kolhapur	WRTS-I	WRTS-I	R
108	890	400	400kV KOLHAPUR (MSETCL)- KOLHAPUR (GIS) II	21/Jan/19	16:00	21/Jan/19	18:00	DAILY	410 Main bay LBB relay testing at Kolhapur	WRTS-I	WRTS-I	R
109	891	400	400KV KORADI-BHUSAWAL (Bhusawal end)	21/Jan/19	08:00	25/Jan/19	18:00	Continuous	Restrtring of conductor of all three phases of Koradi-Bhusawal line due to conversion of Metergauge to Broadgauge of Akot-Akola Railway line	MSETCL	MSETCL	400 kv Akola- Bhusawal, 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are in service.
110	919	400	MAIN BAY (416) OF CHANDRAPUR ckt-2 @ WARORA	21/Jan/19	09:00	21/Jan/19	17:00	Daily	Routine maintainance ,isolator maintainance work and DCRM	MSETCL	MSETCL	Line will be charged through Tie CB 415.
111	924	400	Tirora-Warora Ckt-I	21/Jan/19	08:00	21/Jan/19	18:00	Daily	Annual Maintenance Line	ATIL	ATIL	Annual Maintenance
112	926	400	BABHALESHWAR - PADGHE 2	22/Jan/19	09:00	22/Jan/19	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL	400kv Babhaleshwar-Padghe-Ckt-1 will be in service
113	928	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	22/Jan/19	08:00	22/Jan/19	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	Tightening of conductor ,Earthwire Hardware.
114	929	400	CHANDRAPUR-PARLI CKT-3	22/Jan/19	08:00	22/Jan/19	17:00	Daily	Replacement of broken spacer cum vibration Damper	MSETCL	MSETCL	NA
115	961	400	DHULE- - BABLESHWAR - I & II	22/Jan/19	08:00	22/Jan/19	18:00	Daily	PID testing of insulators	MSETCL	MSETCL	400kv Dhule Bableshtar I A/R Switch to be kept on non auto mode
116	965	400	TIE BAY (415) OF CHANDRAPUR-2 & ADANI - 2 @ WARORA	22/Jan/19	09:00	22/Jan/19	17:00	Daily	Routine maintainance ,isolater maintainance work and DCRM	MSETCL	MSETCL	Line will be charged through Main CB 416.
117	966	400	Tirora-Warora Ckt-II	22/Jan/19	08:00	22/Jan/19	18:00	Daily	Annual Maintenance Line	ATIL	ATIL	Annual Maintenance
118	969	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	23/Jan/19	08:00	23/Jan/19	17:00	Daily	Replacement of broken spacer cum vibration Damper	MSETCL	MSETCL	NA
119	970	400	LAMBOTI-SOLAPUR (PGCIL)	23/Jan/19	10:00	23/Jan/19	18:00	Daily	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on 400KV Parali line
120	971	220	SOUTH SOLAPUR (KUMBHARI)-PGCIL 2	23/Jan/19	11:00	23/Jan/19	16:00	Daily	Outage is required for QM work	MSETCL	MSETCL	Load can be managed on 220 kv South Solapur-PGCIL Ckt 1
121	1007	400	MAIN BAY (413) OF CHANDRAPUR ckt-1 @ WARORA	23/Jan/19	09:00	23/Jan/19	17:00	Daily	Routine maintainance ,isolater maintainance work and DCRM	MSETCL	MSETCL	Line will be charged through Tie CB 412.
122	1010	220	220KV Boisar-Boisar-I line at Boisar	24/Jan/19	9:00	24/Jan/19	17:30	Daily	AMP of Line terminal Equipment	POWERGRID	WR-II	R
123	1017	220	220KV Talegaon (PG)-Talegaon MSETCL Line-2	24/Jan/19	9:00	24/Jan/19	17:00	Daily	For AMP of Line Equipments at Talegaon	MSETCL	WRTS-I	R
124	1029	400	B BUS @ NAGOTHANE	24/Jan/19	08:00	24/Jan/19	18:00	Daily	various bay pg isolator overhauling	MSETCL	MSETCL	...
125	1038	400	EKTUNI - BABLESHWAR CKT 2	24/Jan/19	09:00	24/Jan/19	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL	400 kv Auragabad ,Bhusawal Dhule-Ckt-1&2, Ektuni-ckt-1 will be in service
126	1042	400	LONIKAND2-LONIKAND1 (INTERCONNECTOR - 1)	24/Jan/19	09:00	24/Jan/19	18:00	Daily	Half yearly maintenance And diagnostic testing	MSETCL	MSETCL	Load will be managed by 400 kv Lonikand-II-Lonikand-I Interconnector II, load effected NIL
127	1044	400	PARLI-SOLAPUR (LAMBOTI)	24/Jan/19	09:00	24/Jan/19	17:00	Daily	(1) Line maint. Work. (2) Bay maint.work. (3) C&Tan delta Measurement of Reactor Bushing	MSETCL	MSETCL	-
128	1046	400	TIE BAY (412) OF CHANDRAPUR-1 & ADANI - 1 @ WARORA	24/Jan/19	09:00	24/Jan/19	17:00	Daily	Routine maintainance ,isolater maintainance work and DCRM	MSETCL	MSETCL	Line will be charged through Main CB 413.
129	1047	400	CHANDRAPUR-PARLI CKT-3	25/Jan/19	08:00	25/Jan/19	17:00	Daily	Replacement of Broken Spacer cum Vibration Damper	MSETCL	MSETCL	NA
130	1061	400	KORADI 2 - KORADI 3 CKT-2	25/Jan/19	10:00	25/Jan/19	15:00	Daily	Tan delta measurement of Line CT at Bay 406 & Bus CT at Bay 405	MSETCL	MSETCL	400KV Koradi-II-Koradi-III Ckt.-I will remain service as alternate supply.
131	1063	765	Tirora-Koradi III ckt - 1	25/Jan/19	08:00	25/Jan/19	18:00	Daily	Annual Maintenance Line	MEGPTCL	MEGPTCL	Annual Maintenance
132	1068	400	MAIN BUS 'B' WITH BUS COUPLER @ CHAKAN	26/Jan/19	09:00	26/Jan/19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	Outage required along with Bus coupler
133	1070	400	KALWA - TALEGAON (PGCIL)	27/Jan/19	09:30	27/Jan/19	17:30	Daily	Routine Maintenance and diagnostic Testing Work	MSETCL	MSETCL	-
134	1071	400	PADGHE - KALWA 1	27/Jan/19	06:00	27/Jan/19	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	Diagnostic Testing work
135	1072	220	220KV Boisar-Boisar-II line at Boisar	27/Jan/19	9:00	27/Jan/19	17:30	Daily	AMP of Line terminal Equipment	POWERGRID	WR-II	R
136	1076	400	400kv Tarapur-Boisar-II at Boisar	27/Jan/19	9:00	27/Jan/19	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	POWERGRID	WR-II	R
137	1078	765	707 LR (TIRODA CKT - 2) REACTOR @ KORADI 3	27/Jan/19	09:00	27/Jan/19	18:00	Daily	Reactor & Reactor Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	Annual Maintenance
138	1084	765	Tirora-Koradi III ckt - 2	27/Jan/19	08:00	27/Jan/19	18:00	Daily	Annual Maintenance Line	MEGPTCL	MEGPTCL	Annual Maintenance
139	1085	400	CHANDRAPUR 2 - WARORA CKT-1	28/Jan/19	08:00	28/Jan/19	18:00	Daily	Routine maintainance and diaganostic testing such as CT tandelta,CRM,IR values,isolater maintainance work .	MSETCL	MSETCL	Load will be managed on 400KV Chandrapur Ckt-2
140	1086	220	TALANDAGE - CHIKODI	28/Jan/19	10:00	28/Jan/19	17:00	Daily	routine maintenance and diagnostic work	MSETCL	MSETCL	-
141	1091	220	220KV Boisar-Tarapur line at Boisar	28/Jan/19	9:00	28/Jan/19	17:30	Daily	AMP of Line terminal Equipment	POWERGRID	WR-II	R
142	1098	400	400KV Akola -A'bad#1 Main Bay 404 at Akola	28/Jan/19	9:00	28/Jan/19	18:00	Daily	For AMP work	WRTS-I	WRTS-I	R
143	1108	400	AKOLA - AURANGABAD(PG) CKT - 2	28/Jan/19	08:00	28/Jan/19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
144	1118	400	CHANDRAPUR-PARLI CKT-3	29/Jan/19	08:00	29/Jan/19	19:00	Daily	For Replacement of Damaged Earthwire Cross arms on Double Ckt Tower Hense outage on same day on both Ckt i.e CHD -II - Nanded ckt 2 & GCR Chandrapur - Parli ckt- III Line required to carry out work .	MSETCL	MSETCL	For Replacement of Damaged Earthwire Cross arms on Double Ckt Tower Hense outage on same day on both Ckt i.e CHD -II - Nanded ckt 2 & GCR Chandrapur - Parli ckt- III Line required to carry out work .
145	1119	400	KORADI 2-WARDHA PGCIL	29/Jan/19	10:00	29/Jan/19	16:00	Daily	Line maintenance work	MSETCL	MSETCL	Outage will be availed subject to weather condition.
146	1120	400	PARLI(MS) - PARLI (PG) CKT -2	29/Jan/19	09:00	29/Jan/19	17:00	Daily	(1) Distance relay testing work. (2) Bay manit. Work.	MSETCL	MSETCL	-
147	1125	400	400 KV Akola -wardha #2 Main Bay 411 at Akola	29/Jan/19	9:00	29/Jan/19	18:00	Daily	For AMP work	WRTS-I	WRTS-I	R
148	1146	400	MAIN BUS - 1 @ AKOLA	29/Jan/19	10:00	29/Jan/19	17:00	Daily	PID of insulator string of 400 kv Jack Bus-1 by PID Unit	MSETCL	MSETCL	NA
149	1148	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	30/Jan/19	08:00	30/Jan/19	17:00	Daily	For Replacement of Damaged Earthwire Cross arms on Double Ckt Tower Hense outage on same day on both Ckt i.e CHD -II - Nanded ckt 2 & GCR Chandrapur - Parli ckt- III Line required to carry out work .	MSETCL	MSETCL	For Replacement of Damaged Earthwire Cross arms on Double Ckt Tower Hense outage on same day on both Ckt i.e CHD -II - Nanded ckt 2 & GCR Chandrapur - Parli ckt- III Line required to carry out work .

Sr.No.	OCCM Sr. No	KV	Line / Element	From		To		Basis	Reason	System	Agency	Remark
				Date	Time	Date	Time					
150	1153	220	220KV Boisar-Nalasopara line at Boisar	30/Jan/19	9:00	30/Jan/19	17:30	Daily	AMP of Line terminal Equipment	POWERGRID	WR-II	R
151	1161	765	707 LR (Aurangabad-ckt-II) Reactor @ AKOLA 2	30/Jan/19	09:00	30/Jan/19	18:00	Daily	Reactor & Reactor Bay Equipments Maintenance Activity	MEGPTCL	MEGPTCL	Annual Maintenance
152	1172	400	MAIN BUS - 2 @ AKOLA	30/Jan/19	10:00	30/Jan/19	17:00	Daily	PID of insulator string of 400 kv Jack Bus-2 by PID Unit	MSETCL	MSETCL	NA
153	1173	220	Navsari - Nashik line No. 1	30/Jan/19	9:00	30/Jan/19	17:00	Daily	General bay maint.	GETCO	GETCO	
154	1174	400KV	Parli - Solapur Ckt-1	30/Jan/19	8:00	30/Jan/19	16:00	Daily	Annual Maintenance work	WTPL	WTPL	Routine
155	1175	400	PARLI-SOLAPUR (LAMBOTI)	30/Jan/19	10:00	30/Jan/19	18:00	Daily	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on 400KV PGCIL Line
156	1191	400	A BUS @ NAGOTHANE	31/Jan/19	08:00	31/Jan/19	18:00	Daily	various bay pg isolator overhauling	MSETCL	MSETCL	...
157	1197	400	LONIKAND2-LONIKAND1 (INTERCONNECTOR - 2)	31/Jan/19	10:00	31/Jan/19	17:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	-
158	1198	220	Navsari-Nashik Line No.2	31/Jan/19	9:00	31/Jan/19	17:00	Daily	General bay maintenance work.	GETCO	GETCO	

State Element Outages list for the month of January'19

Sr.No.	Voltage (KV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400	KARAD - TALANDGE CKT 1	01-Jan-19	10:00	01-Jan-19	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Load manage on 400 kV Talandge 2
2	400	CHANDRAPUR - KHAPERKHEDA	01-Jan-19	08:00	15-Jan-19	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.
3	400	AKOLA-NANDGAONPETH (RPL-AMT)	01-Jan-19	12:00	05-Jan-19	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola- Bhusawal & 400 kV Koradi-Nandgaonpeth are in service.
4	400	TBC @ KOLHAPUR(TALANDGE)	02-Jan-19	09:00	02-Jan-19	18:00	Daily	Annual maintenance work	MSETCL	MSETCL	-
5	400	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	02-Jan-19	10:00	02-Jan-19	18:00	Daily	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on 400KV ICT I
6	400	DEEPNAGAR - THAPTI TANDA	02-Jan-19	08:00	05-Jan-19	18:00	Daily	PID testing of insulators	MSETCL	MSETCL	400kV Deepnagar-Tapthi-Tanda A/R switch to be kept in non auto mode .
7	400	DEEPNAGAR AURANGABAD	02-Jan-19	06:00	05-Jan-19	18:00	Daily	PID testing of insulators	MSETCL	MSETCL	400kV Deepnagar Aurangabad Line A/R swich to be kept in non auto mode
8	400	400/220kV SPARE ICT @ JEJURI	03-Jan-19	09:00	03-Jan-19	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	-
9	400	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	04-Jan-19	09:00	04-Jan-19	18:00	Daily	Half yearly maintenance And diagnostic testing	MSETCL	MSETCL	Load will be managed by 400/220 kV 501MVA ICT - 1 ICT-I, load effected NIL
10	400	400/220/33 KV 500 MVA ICT - 1 @ NANDED	03-Jan-19	10:00	03-Jan-19	18:00	Daily	Testing Work	MSETCL	MSETCL	-
11	400	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	04-Jan-19	08:00	04-Jan-19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	...
12	400	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	03-Jan-19	09:00	03-Jan-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-
13	400	KARAD - TALANDGE CKT 2	04-Jan-19	09:00	04-Jan-19	18:00	Daily	Annual maintenance work	MSETCL	MSETCL	-
14	400	NEW KOYNA - STAGE IV CKT 1	05-Jan-19	08:00	05-Jan-19	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on 400KV New Koyna-Stage 4 CKT-II line
15	400	MAIN BAY (407) OF RPL CKT-1 @ AKOLA 2	05-Jan-19	09:00	05-Jan-19	18:00	Daily	Annual Maintenance of Bay Equipment	MEGPTC	MEGPTC	Annual Maintenance
16	400	KHADKA - BABLESHWAR ON TBC	05-Jan-19	09:00	05-Jan-19	18:00	Daily	For DCRM of Main breaker and Line will be shifted on TBC	MSETCL	MSETCL	Line will be shifted on TBC
17	400	400/220/20 KV 500MVA ICT - 1 @ KALWA	06-Jan-19	09:30	06-Jan-19	17:30	Daily	Bay Maintenance and testing work	MSETCL	MSETCL	-
18	400	NEW KOYNA - STAGE IV CKT 2	06-Jan-19	08:00	06-Jan-19	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on 400KV New Koyna-Stage 4 CKT-I line
19	400	JAIGAD-NEW KOYNA-I	07-Jan-19	08:00	07-Jan-19	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	Load can be managed on New Koyna-Jaigad ckt II line
20	400	400/220/33 KV 315MVA ICT - 2 @ AKOLA	07-Jan-19	08:00	07-Jan-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
21	400	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	07-Jan-19	08:00	07-Jan-19	17:00	Daily	Diagnostic testing work	MSETCL	MSETCL	...
22	400	KHADKA- DEEPNAGAR CKT 2	07-Jan-19	06:00	08-Jan-19	18:00	Daily	PID testing of insulators	MSETCL	MSETCL	400kV Khadka Deepnagar ckt 2 A/R switch to be kept in non auto mode
23	400	JAIGAD-NEW KOYNA-I	07-Jan-19	09:00	12-Jan-19	18:00	Daily	Hotline Insulator washing on Jaigad-Newkoyna I & II	JPTL	JPTL	
24	400	KHADKA- DEEPNAGAR CKT 1	07-Jan-19	06:00	08-Jan-19	18:00	Daily	PID testing of insulators	MSETCL	MSETCL	400kV Khadka Deepnagar ckt 1 A/R switch to be kept in non auto mode
25	400	400KV AKOLA-BHUSAWAL (Bhusawal end)	07-Jan-19	12:00	12-Jan-19	18:00	Daily	PID testing of insulator strings by PID Uint of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola- Nandgaonpeth & 400 kV Koradi-Nandgaonpeth are in service.
26	400	WARORA - IEPL	08-Jan-19	09:00	08-Jan-19	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	400KV KORADI-WARDHA Line is in ckt
27	400	JAIGAD-NEW KOYNA-II	08-Jan-19	08:00	08-Jan-19	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	Load can be managed on New Koyna-Jaigad ckt I line
28	400	SPARE LINE-1 BAY (401) @ TAPTITANDA	08-Jan-19	11:00	08-Jan-19	17:00	Daily	For CB diagnostic testing	MSETCL	MSETCL	NIL
29	400	400KV KORADI-BHUSAWAL (Koradi end)	08-Jan-19	10:00	08-Jan-19	16:00	Daily	Line maintenance work	MSETCL	MSETCL	Work carried out by MSETCL.
30	400	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	08-Jan-19	08:00	08-Jan-19	17:00	Daily	Diagnostic testing work	MSETCL	MSETCL	...
31	400	Chandrapur 2 ckt - 1 @ Chandrapur switching s/s	09-Jan-19	10:00	09-Jan-19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Routine Maintenance & Dignostic testing work
32	400	TIE BAY (402) of WALUJ @ TAPTITANDA	09-Jan-19	11:00	09-Jan-19	17:00	Daily	For Circuit breaker diagnostic testing	MSETCL	MSETCL	NII
33	400	400/220/20 KV 300 MVA ICT - 1 @ KORADI	09-Jan-19	09:00	09-Jan-19	18:00	Daily	Relay Testing work & DFRA	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
34	400	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	09-Jan-19	10:00	09-Jan-19	18:00	Daily	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on 400KV ICT II
35	400	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	10-Jan-19	10:00	10-Jan-19	17:00	Daily	MV Breaker CRM and Breaker timing & Routine Maint. Work	MSETCL	MSETCL	Work will be carried out subject to weather condition.
36	400	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	09-Jan-19	08:00	09-Jan-19	17:00	Daily	Diagnostic testing work	MSETCL	MSETCL	...
37	400	DEEPNAGAR AURANGABAD	10-Jan-19	06:00	12-Jan-19	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	Line Maintenance work

Sr.No.	Voltage (KV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.
38	400	400/220/33KV 315MVA ICT - 3 @ LONIKAND	10-Jan-19	10:00	10-Jan-19	17:00	Daily	Routine Dignostic testing & maintenance work	MSETCL	MSETCL	-
39	400	MAIN BAY (403) OF WALUJ @ TAPTITANDA	10-Jan-19	11:00	10-Jan-19	17:00	Continuous	For Circuit breaker diagnostic testing	MSETCL	MSETCL	NII
40	400	MAIN BAY (406) OF STG-4 @ JEJURI	10-Jan-19	09:00	10-Jan-19	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	-
41	400	80 MVAR REACTOR @ KHARGHAR	11-Jan-19	08:00	11-Jan-19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	...
42	400	MAIN BAY (413) OF 500MVA ICT - 2 @ TAPTITANDA	11-Jan-19	10:00	11-Jan-19	17:00	Daily	for Bushing, T/F, TanD & Relay testing work	MSETCL	MSETCL	NIL
43	400	400/220/33 KV 315 MVA ICT - 1 @ WALUJ	11-Jan-19	08:00	11-Jan-19	17:00	Daily	Routine Maintenance and Testing	MSETCL	MSETCL	Routine Maintenance and Testing of 400kV ICT-I @WALUJ End
44	400	AKOLA-NANDGAONPETH (RPL-AMT)	11-Jan-19	08:00	11-Jan-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
45	400	KHADKA- DEEPNAGAR CKT 1 ON TBC @ KHADKA	12-Jan-19	09:00	12-Jan-19	18:00	Daily	For DCRM of Main breaker and Line will be shifted on TBC	MSETCL	MSETCL	Line will be shifted on TBC
46	400	400/220 KV 3X200 MVA ICT - 2 @ KALWA	13-Jan-19	09:30	13-Jan-19	17:30	Daily	Bay Maintenance Work	MSETCL	MSETCL	-
47	400	DEEPNAGAR- AURANGABAD	14-Jan-19	06:00	19-Jan-19	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	Line Maintenance work
48	400	JAIGAD-KARAD-I	14-Jan-19	09:00	20-Jan-19	18:00	Daily	Hotline insulator washing on Jaigad-Karad line I & II.	JPTL	JPTL	
49	400	NEW KOYNA-KARAD -CKT 1	15-Jan-19	10:00	15-Jan-19	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kV Koyana 2
50	400	400KV AKOLA-BHUSAWAL (Bhusawal end)	15-Jan-19	08:00	19-Jan-19	18:00	Continuous	Restringing of conductor of all three phases of Akola- Bhusawal line due to conversion of Metergauge to Broadgauge of Akot-Akola Railway line	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola- Nandgaonpeth & 400 kV Koradi-Nandgaonpeth are in service.
51	400	KARAD - LONIKAND 1	16-Jan-19	10:00	16-Jan-19	17:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	-
52	400	400/220/33 KV 500 MVA ICT - 2 @ NANDED	17-Jan-19	10:00	17-Jan-19	18:00	Daily	Tan-d measurement	MSETCL	MSETCL	-
53	400	MAIN BAY (401) OF ICT -1 @ JEJURI	17-Jan-19	09:00	17-Jan-19	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	-
54	400	JEJURI- KOYNA STAGE-IV	17-Jan-19	08:00	17-Jan-19	18:00	Daily	Cold line washing of insulators	MSETCL	MSETCL	Jejuri-Lonikand ckt will be in service
55	400	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	17-Jan-19	09:00	17-Jan-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-
56	400	KARAD - TALANDGE CKT 1	18-Jan-19	08:00	18-Jan-19	18:00	Daily	Cold line washing of insulators	MSETCL	MSETCL	Talandge -II ckt will be in service
57	400	KHADKA - BABLESHWAR	18-Jan-19	08:00	20-Jan-19	17:00	Daily	PID testing of insulators	MSETCL	MSETCL	400kV Khadka Bableshwar Ckt A/R switch to be kept in non auto mode
58	400	400/132 KV 200 MVA ICT - 1 ON TBC @ KHADKA	19-Jan-19	09:00	19-Jan-19	18:00	Daily	For DCRM of Main breaker and ICT-I will be shifted on TBC	MSETCL	MSETCL	ICT-I will be shifted on TBC
59	400	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	19-Jan-19	08:00	19-Jan-19	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kV 315MVA ICT- I , 501 MVA ICT -III& IV will be in service
60	400	KARAD - TALANDGE CKT 2	19-Jan-19	08:00	19-Jan-19	18:00	Daily	Cold line washing of insulators	MSETCL	MSETCL	Talandge -I ckt will be in service
61	400	NEW KOYNA -KARAD - CKT 2	20-Jan-19	08:00	21-Jan-19	18:00	Daily	Cold line washing of insulators	MSETCL	MSETCL	N.Koyna-Karad ckt 1 will be in service
62	400	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	21-Jan-19	09:00	21-Jan-19	18:00	Daily	Annual Maintenance work	MSETCL	MSETCL	-
63	400	DEEPNAGAR - THAPTI TANDA	21-Jan-19	06:00	25-Jan-19	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	Line Maintenance work
64	400	400/220/33 KV 315MVA ICT - 1 @ AKOLA	21-Jan-19	08:00	21-Jan-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
65	400	JAIGAD-NEW KOYNA-I	21-Jan-19	09:00	21-Jan-19	18:00	Daily	Insulator replacement work	JPTL	JPTL	
66	400	NEW KOYNA -KARAD -CKT 2	21-Jan-19	10:00	21-Jan-19	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kV Koyana 1
67	400	BABLESHWAR- AURANGABAD (WALUJ)	21-Jan-19	08:00	31-Jan-19	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	A/R in non auto mode
68	400	DHULE- - BABLESHWAR - I & II	21-Jan-19	08:00	21-Jan-19	18:00	Daily	PID testing of insulators	MSETCL	MSETCL	400kV Dhule Bableshwar II A/R switch to be kept on non auto mode
69	400	Main bay (406) of Deepnagar line @ Taptitanda	22-Jan-19	11:00	22-Jan-19	17:00	Daily	For Circuit breaker diagnostic testing	MSETCL	MSETCL	NIL
70	400	JAIGAD-NEW KOYNA-II	22-Jan-19	09:00	22-Jan-19	18:00	Daily	INSULATOR REPLACEMENT WORK	JPTL	JPTL	
71	400	NEW KOYNA-KARAD -CKT 1	22-Jan-19	08:00	23-Jan-19	18:00	Daily	Cold line washing of insulators	MSETCL	MSETCL	NA
72	400	BABLESHWAR- AURANGABAD (WALUJ)	22-Jan-19	09:00	22-Jan-19	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kV Bhusawal,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
73	400	JAIGAD-KARAD-I	23-Jan-19	09:00	23-Jan-19	18:00	Daily	INSULATOR REPLACEMENT WORK	JPTL	JPTL	
74	400	Akola II (Yelwan) - Akola I CKT - 1	23-Jan-19	08:00	23-Jan-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
75	400	Tie bay (405) of Deepnagar line @ Taptitanda	23-Jan-19	11:00	23-Jan-19	17:00	Daily	For Circuit Breaker diagnostic testing	MSETCL	MSETCL	NIL
76	400	KHADKA - BABLESHWAR	23-Jan-19	09:00	23-Jan-19	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kV Auragabad ,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
77	400	SPARE LINE-2 BAY (404) @ TAPTITANDA	24-Jan-19	11:00	24-Jan-19	17:00	Daily	For circuit breaker diagnostic testing	MSETCL	MSETCL	NII
78	400	TIE BAY (402) OF ICT -1 AND LONIKAND 1 @ JEJURI	24-Jan-19	09:00	24-Jan-19	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	-
79	400	KHADKA-AURANGABAD	24-Jan-19	08:00	24-Jan-19	17:00	Daily	Routine Maintenance and Testing	MSETCL	MSETCL	Routine Maintenance and Testing of 400kV Bhusawal Bay @Waluj
80	400	LONIKAND 1 - KOYNA STAGE-IV	24-Jan-19	08:00	24-Jan-19	18:00	Daily	Cold line washing of insulators, Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	Koyna Satge4-Jejuri ckt will be in service
81	400	KARAD - TALANDGE CKT 1	24-Jan-19	08:00	25-Jan-19	18:00	Daily	Cold line washing of insulators	MSETCL	MSETCL	Talandge -II ckt will be in service

Sr.No.	Voltage (KV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.
82	400	JAIGAD-KARAD-II	22-Jan-19	09:00	22-Jan-19	18:00	Daily	INSULATOR REPLACEMENT WORK	JPTL	JPTL	
83	400	400/132 KV 200 MVA ICT - 2 ON TBC @ KHADKA	25-Jan-19	09:00	25-Jan-19	18:00	Daily	For DCRM of Main breaker and ICT-II will be shifted on TBC	MSETCL	MSETCL	ICT-II will be shifted on TBC
84	400	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	25-Jan-19	08:00	25-Jan-19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	...
85	400	400/220/33 KV 315 MVA ICT - 3 @ PADGHE	25-Jan-19	08:00	25-Jan-19	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Diagnostic Testing Work
86	400	MAIN BAY (416) OF 500MVA ICT - 1 @ TAPTITANDA	25-Jan-19	11:00	25-Jan-19	17:00	Daily	For Bushing , T/F, Tan D ,& relay testing work	MSETCL	MSETCL	NIL
87	400	Akola II (Yelwan) - Akola I CKT - 2	25-Jan-19	08:00	25-Jan-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NA
88	400	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	26-Jan-19	08:00	26-Jan-19	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 315MVA ICT- II , 501 MVA ICT -III& IV will be in service
89	400	KARAD - TALANDGE CKT 2	26-Jan-19	08:00	26-Jan-19	18:00	Daily	Cold line washing of insulators	MSETCL	MSETCL	Talandge -I ckt will be in service
90	400	KHADKA - BABLESHWAR	26-Jan-19	08:00	28-Jan-19	17:00	Daily	PID testing of insulators	MSETCL	MSETCL	400kv Khadka Bableshwar ckt A/R switch to be kept on non auto mode
91	400	400/220/33 KV 315 MVA ICT - 1 @ KOLHAPUR	28-Jan-19	09:00	28-Jan-19	18:00	Daily	Annual Maintenance work	MSETCL	MSETCL	-
92	400	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	28-Jan-19	08:00	28-Jan-19	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	Load can be managed on 315MVA 400/220KV ICT I
93	400	TBC @ BABHALESHWAR	28-Jan-19	09:00	30-Jan-19	17:00	Daily	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	400 kv TBC Bay is for Repairing of 29A & 29B & 29C P.G Isoaltor P.G Isoaltor Scissors (Hanger dropper assembly of TBC bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)
94	400	DEEPNAGAR - THAPTI TANDA	28-Jan-19	06:00	31-Jan-19	18:00	Daily	Replacement of Dead End & Mid Span Joint	MSETCL	MSETCL	Line Maintenance work
95	400	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	29-Jan-19	08:00	29-Jan-19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	...
96	400	MAIN BAY (403) OF LONIKAND CKT @ JEJURI	31-Jan-19	09:00	31-Jan-19	17:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	-
97	400	400/220/33 KV 500 MVA ICT - 3 @ PARLI	31-Jan-19	09:00	31-Jan-19	17:00	Daily	(1) HV CT C&Tandelta Measurement & HV CB DCRM & Timing (2) Bay maint. Work.	MSETCL	MSETCL	-
98	400	80 MVAR BUS REACTOR - 1 @ BABHALESHWAR	31-Jan-19	08:00	31-Jan-19	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	80MVAR Reactor -2 are in service