

Maharashtra State Load Despatch Centre

WRPC OCCM approved Monthly Outage list for the Month of January 2020

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	Name of Requesting Agency	D	reason
1	9	BUS COUPLER @ KARAD	01/Jan/2020	10:00	01/Jan/2020	17:00	MSETCL	Daily	Quarterly. Maint. Work
2	10	400KV-RGPPL-NAGOTHANE-1	01/Jan/2020	08:00	02/Jan/2020	18:00	MSETCL	Daily	Earth Wire replacement ,Routine maint. Work & Faulty string replacement Work & cold washing
3	19	400KV-KALWA-PADGHE-2	01/Jan/2020	09:00	09/Jan/2020	18:00	MSETCL	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
4	23	BUS COUPLER BAY - KORADI - 400KV - BUS 1 AND KORADI - 400KV - BUS 2 at Koradi - 400KV	01/Jan/2020	08:00	13/Jan/2020	18:00	MSETCL	Continuous	CB pole mechanism overhauling work
5	25	400KV-SSP-DHULE-MS-1	01/Jan/2020	08:00	15/Jan/2020	17:00	MSETCL	Daily	Online PID testing work
6	26	400KV-SSP-DHULE-MS-2	01/Jan/2020	08:00	15/Jan/2020	17:00	MSETCL	Daily	Online PID testing work
7	29	400KV-SOLAPUR-M-SOLAPUR-1	01/Jan/2020	10:00	15/Jan/2020	18:00	MSETCL	Daily	PID Testing of Insulators strings
8	47	220KV-WARDHA-PUSAD-1	01/Jan/2020	08:00	31/Jan/2020	18:00	MSETCL	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.
9	48	400KV-KARAD-NEW KOYNA-2	01/Jan/2020	09:00	31/Jan/2020	17:00	MSETCL	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
10	49	400KV-JEJURI-KOYNA STAGE IV-1	01/Jan/2020	09:00	31/Jan/2020	17:00	MSETCL	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
11	50	400KV-KOYNA STAGE IV-LONIKHAND-1	01/Jan/2020	09:00	31/Jan/2020	17:00	MSETCL	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
12	51	400KV-KARAD-NEW KOYNA-1	01/Jan/2020	09:00	31/Jan/2020	17:00	MSETCL	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
13	61	400KV-SSP-DHULE-MS-2	02/Jan/2020	9:00	02/Jan/2020	17:00	NCA	C	Insulator cleaning & jumpers checking and other preventive maintenance work & Proposed CVT testing with ERDA
14	65	MAIN BAY - KORADI-III - 765KV B/R 1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	02/Jan/2020	09:00	02/Jan/2020	18:00	MEGPTCL	Daily	Dew Point Measurement in Circuit breaker
15	66	400KV-PARLI-M-PARLI-1	02/Jan/2020	09:00	02/Jan/2020	18:00	MSETCL	Daily	Distance relay testing work and bay maintenance work
16	83	TALEGAON - 220KV - BUS 2	02/Jan/2020	9:00	02/Jan/2020	18:00	POWERGRID_WR1	D	For AMP works
17	86	400KV-BABLESHWAR-PADGHE-PG-1	02/Jan/2020	08:00	13/Jan/2020	18:00	MSETCL	Daily	PID testing work
18	88	400KV-RGPPL-NEW KOYNA-2	03/Jan/2020	10:00	14/Jan/2020	15:00	MSETCL	Daily	PID Test of insulators
19	89	LONIKHAND-II - 400KV - BUS 1	03/Jan/2020	10:00	03/Jan/2020	18:00	MSETCL	Daily	Half yearly maintenance and diagnostic testing.
20	90	400KV-RGPPL-NEW KOYNA-1	03/Jan/2020	9:00	04/Jan/2020	18:00	RGPPL	C	Disc Insulator string replacement work.
21	118	765KV-AKOLA (2)-KORADI-III-1 L/R@ KORADI-III - 765KV	03/Jan/2020	10:00	03/Jan/2020	14:00	MEGPTCL	Daily	Reactor Changeover Activity
22	130	400KV-SSP-DHULE-MS-1	04/Jan/2020	7:00	04/Jan/2020	18:00	GETCO	Daily	PMM work./ckt-2 AR off
23	137	MAIN BAY - 765KV-KORADI-III-AKOLA-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	04/Jan/2020	09:00	04/Jan/2020	18:00	MEGPTCL	Daily	Dew Point Measurement in Circuit breaker
24	151	400KV-BHUSAWAL-AKOLA-1	04/Jan/2020	08:00	15/Jan/2020	18:00	MSETCL	Continuous	Restranging of conductor of all three phases of 400 kV Akola- Bhusawal line due to conversion of Metergauge to Broadgauge of Akot-Akola Railway line and also for other maintenance works of line.

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	Name of Requesting Agency	D	reason
25	153	400KV-RGPPL-NEW KOYNA-2	05/Jan/2020	08:00	06/Jan/2020	18:00	MSETCL	Daily	Earth Wire replacement ,Routine maint. Work & Faulty string replacement Work & cold washing
26	157	400KV-RGPPL-NEW KOYNA-2	05/Jan/2020	9:00	06/Jan/2020	18:00	RGPPPL	C	Disc Insulator string replacement work.
27	158	400KV-KHARGHAR-PUNE-PG-1	05/Jan/2020	07:00	05/Jan/2020	18:00	MSETCL	Daily	Routine Maintenance & Diagnostic Testing
28	168	220KV-WARDHA-BADNERA-1	06/Jan/2020	09:00	06/Jan/2020	17:00	MSETCL	Daily	For Diagnostic testing (CT and CC tan delta measurement work)
29	172	MAIN BAY - 765KV/400KV TIRODA-ICT-1 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	06/Jan/2020	09:00	06/Jan/2020	18:00	APML	Daily	Bay Maintenance Activities
30	173	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	06/Jan/2020	09:00	06/Jan/2020	18:00	MSETCL	Daily	Annual Maintenance work
31	174	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-4 AND CHANDRAPUR - 400KV - BUS 1 at CHANDRAPUR - 400KV	06/Jan/2020	9:00	06/Jan/2020	18:00	POWERGRID_WR1	D	For AMP works
32	188	220KV-PARLI-PARLI-M-1	06/Jan/2020	13:00	06/Jan/2020	16:00	POWERGRID_WR1	D	For collecting CT oil sample
33	201	DHULE-MS - 400KV B/R 1	06/Jan/2020	9:00	12/Jan/2020	18:00	POWERGRID_WR1	C	For internal inspection due to Acetylene violation.
34	206	400KV-RGPPL-NAGOTHANE-2	07/Jan/2020	08:00	08/Jan/2020	18:00	MSETCL	Daily	Earth Wire replacement ,Routine maint. Work & Faulty string replacement Work & cold washing
35	220	MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	07/Jan/2020	09:00	07/Jan/2020	18:00	MEGPTCL	Daily	Bay Maintenance Activities
36	222	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-3 AND CHANDRAPUR - 400KV - BUS 1 at CHANDRAPUR - 400KV	07/Jan/2020	9:00	07/Jan/2020	18:00	POWERGRID_WR1	D	For AMP works
37	237	400KV/11.5KV KORADI-II-ST-2	07/Jan/2020	10:00	07/Jan/2020	16:00	MSETCL	Daily	Tan delta Measurement of Bus CT & Line CT at Bay 407.
38	239	220KV-WARDHA-BHUGAON-1	07/Jan/2020	10:00	07/Jan/2020	18:00	MSETCL	Daily	Routine maintainace work
39	243	400KV/21KV CHANDRAPUR-GT-6 ON TBC	07/Jan/2020	05:00	09/Jan/2020	18:00	MSETCL	Continuous	Permission for shifting of 400KV GTR- 6 bay on TBC-II bay.
40	244	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC- 1	07/Jan/2020	05:00	09/Jan/2020	18:00	MSETCL	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-II in HVDC- I and 400KV GTR- 6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.
41	245	CHANDRAPUR - 400KV - BUS 1	07/Jan/2020	05:00	09/Jan/2020	18:00	MSETCL	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-II in HVDC- I and 400KV GTR- 6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.
42	251	220KV-TARAPUR 1&2-BHILAD-1	08/Jan/2020	8:00	08/Jan/2020	18:00	GETCO	C	maintenance work
43	255	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	08/Jan/2020	08:00	08/Jan/2020	17:00	MSETCL	Daily	Routine Maintenance & Dignostic testing work
44	260	132KV-MANSAR-MS-PENCH-1	08/Jan/2020	09:00	08/Jan/2020	17:00	MSETCL	Daily	Routine maint work & Dignostic testing work
45	264	400KV-SSP-DHULE-MS-1	08/Jan/2020	9:00	08/Jan/2020	17:00	NCA	C	Insulator cleaning & jumpers checking and other preventive maintenance work & Proposed CVT testing with ERDA
46	265	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV B/R 1 at KORADI-III - 765KV	08/Jan/2020	09:00	08/Jan/2020	18:00	MEGPTCL	Daily	Dew Point Measurement in Circuit breaker
47	266	400KV-PARLI-M-SOLAPUR-M-1	08/Jan/2020	09:00	08/Jan/2020	18:00	MSETCL	Daily	Dist relay testing,bay maintenance,Line maintenance
48	267	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-2 AND CHANDRAPUR - 400KV - BUS 1 at CHANDRAPUR - 400KV	08/Jan/2020	9:00	08/Jan/2020	18:00	POWERGRID_WR1	D	For AMP works
49	270	220KV-SOLAPUR-KUMBARI-2	08/Jan/2020	9:00	08/Jan/2020	18:00	POWERGRID_WR1	D	CT and Line terminal equipments AMP
50	294	MAIN BAY - 400KV-WARDHA-AKOLA-1 AND AKOLA - 400KV - BUS 2 at Akola - 765KV	08/Jan/2020	9:00	14/Jan/2020	18:00	POWERGRID_WR1	C	For Replacement of BHEL CB with GE CB.
51	303	400KV-RGPPL-NEW KOYNA-1	09/Jan/2020	08:00	10/Jan/2020	18:00	MSETCL	Daily	Routine maint. Work , Faulty string replacement Work & cold washing

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	Name of Requesting Agency	D	reason
52	305	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-1	09/Jan/2020	9:00	09/Jan/2020	18:00	POWERGRID_WR1	D	LR and CB AMP works. LR shall be taken out and Load shall be shifted to TBC line taken into service with out LR during the period
53	307	400KV-KALA-KUDUS-2	09/Jan/2020	10:00	09/Jan/2020	17:00	MSETCL	Daily	Annual Maintenance of bays equipment
54	308	400KV-TARAPUR 3&4-PADGHE-2	09/Jan/2020	9:00	10/Jan/2020	18:00	NPCIL	C	CB, VT, ES, DS, CT Annual PM
55	313	220KV-TALEGAON-PUNE-PG-1	09/Jan/2020	09:00	09/Jan/2020	17:00	MSETCL	Daily	Half yearly maintenance , Diagnostic Testing
56	317	MAIN BAY - 765KV-KORADI-III-AKOLA-1 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	09/Jan/2020	09:00	09/Jan/2020	18:00	MEGPTCL	Daily	Bay Maintenance Activities
57	319	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-1 AND CHANDRAPUR - 400KV - BUS 1 at CHANDRAPUR - 400KV	09/Jan/2020	9:00	09/Jan/2020	18:00	POWERGRID_WR1	D	For AMP works
58	335	220KV-WARDHA-BHUGAON-1	09/Jan/2020	10:00	09/Jan/2020	18:00	MSETCL	Daily	Routine maintenance work
59	344	400KV-LONIKHAND-CHAKAN-1	10/Jan/2020	08:00	10/Jan/2020	18:00	MSETCL	Daily	Line Maintenance & Routine Diagnostic testing work
60	345	400KV-AURANGABAD-M (WALUJ)-PUNE-PG-2	10/Jan/2020	9:00	10/Jan/2020	18:00	POWERGRID_WR1	D	LR and CB AMP works. LR shall be taken out and Load shall be shifted to TBC line taken into service with out LR during the period
61	355	400KV-WARDHA-KORADI-II-1	10/Jan/2020	09:00	10/Jan/2020	17:00	MSETCL	Daily	Routine Maintenance & Diagnostic testing work Nut Bolt Tightening work
62	360	TIE BAY - 765KV-KORADI-III-AKOLA-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA - 765KV	10/Jan/2020	09:00	10/Jan/2020	18:00	MEGPTCL	Daily	Bay Maintenance Activities
63	379	Main Bay - 400KV-KALA-KUDUS-2 AND KUDUS - 400KV - Bus 1 at KUDUS -400KV	10/Jan/2020	10:00	10/Jan/2020	17:00	POWERGRID_WR1	D	For AMP works
64	387	400KV-KALWA-PADGHE-1	10/Jan/2020	09:00	18/Jan/2020	17:00	MSETCL	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
65	393	220KV-NASIK-NAVSARI-1	11/Jan/2020	08:00	18/Jan/2020	18:00	MSETCL	Daily	Diagnostic testing, string replacement, signature analysis, TLS fixing
66	398	220KV-TARAPUR 1&2-BOISAR-M-1	11/Jan/2020	8:00	13/Jan/2020	19:00	TAPS 1&2, NPCIL	daily	Annual maintenance Works
67	402	220KV-TARAPUR 1&2-BOISAR-M-1	11/Jan/2020	09:00	11/Jan/2020	17:00	MSETCL	Daily	POST MANSON MAINTENANCE WORK
68	404	LONIKHAND-II - 400KV - BUS 2	11/Jan/2020	10:00	11/Jan/2020	18:00	MSETCL	Daily	Half yearly maintenance and diagnostic testing.
69	405	BUS COUPLER BAY - BHUSAWAL - 400KV - BUS 1 AND BHUSAWAL - 400KV - BUS 2 at BHUSAWAL - 400KV	11/Jan/2020	06:00	11/Jan/2020	18:00	MSETCL	Daily	for taking CT Tan delta ,CB DCRM & Routine bay maintenance work
70	426	220KV-WARDHA-WARDHA-M-1	11/Jan/2020	08:00	12/Jan/2020	18:00	MSETCL	Daily	1) Bus/Line/Tie CT's, CVT Tan delta & Routine Maintenance & Dignostic testing work etc 2) Shifting and Charging of line through ERS from Loc No 15-18 due to raising the height of tower due to NHAI from Loc 16 to 17 and railway crossing from Loc No 17 to 18.and routine maintenance
71	434	BOISAR - 220KV - BUS 1	12/Jan/2020	9:00	12/Jan/2020	17:00	POWERGRID_WR2	D	FOR AMP
72	449	400KV-SSP-DHULE-MS-2	13/Jan/2020	7:00	13/Jan/2020	18:00	GETCO	Daily	PMM work./ckt-1 AR off
73	451	765KV/400KV AKOLA (2)-ICT-1	13/Jan/2020	08:00	13/Jan/2020	18:00	MEGPTCL	Daily	Annual Maintenance of ICT
74	456	AURANGABAD-M (WALUJ) - 400KV - BUS 2	13/Jan/2020	09:00	13/Jan/2020	17:00	MSETCL	Daily	Routine maintenance of Bhusawal Bay @ Main bus B/2
75	461	220KV-Pandhurna-MP-Kamleshwar	13/Jan/2020	9:00	13/Jan/2020	18:00	MP_SLDC	D	For bay equipment maintenance and testing work
76	475	220KV-WARDHA-BHUGAON-1	13/Jan/2020	10:00	13/Jan/2020	18:00	MSETCL	Daily	Routine maintenance work
77	480	NEW KOYNA - 400KV - BUS 1	13/Jan/2020	08:00	15/Jan/2020	18:00	MSETCL	Continuous	Conductor replacement work

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	Name of Requesting Agency	D	reason
78	483	400KV-KARAD-JAIGAD-1	13/Jan/2020	09:00	16/Jan/2020	18:00	JPTL	Daily	Hotline insulator washing
79	484	400KV-KARAD-JAIGAD-2	13/Jan/2020	09:00	16/Jan/2020	18:00	JPTL	Daily	Hotline insulator washing
80	488	220KV-TARAPUR 1&2-BORIVALI-1	14/Jan/2020	09:00	14/Jan/2020	17:00	MSETCL	Daily	Routine Maintenance and Dignostic testing work
81	493	400KV-BABLESHWAR-PADGHE-PG-1	14/Jan/2020	08:00	14/Jan/2020	18:00	MSETCL	Daily	PID testing work
82	507	400KV-BABLESHWAR-PADGHE-PG-1	14/Jan/2020	09:00	16/Jan/2020	18:00	MSETCL	Daily	PID Faulty String replacement work & Relay Testing
83	513	220KV-BOISAR-BOISAR-M-3	15/Jan/2020	09:00	15/Jan/2020	17:00	MSETCL	Daily	POST MANSON MAINTENANCE WORK
84	519	220KV-TILLARI-AMONA-1	15/Jan/2020	08:00	15/Jan/2020	17:00	MSETCL	Daily	Routine Maintenance & Dignostic testing work
85	520	220KV-PANDURNA-KALMESHVAR-1	15/Jan/2020	08:00	15/Jan/2020	18:00	MSETCL	Daily	Routine Maintenance & Diagnostic testing work
86	523	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	15/Jan/2020	09:00	15/Jan/2020	17:00	MSETCL	Daily	Routine Maintenance & Dignostic testing work .
87	524	132KV-PENCH-MP-KANHAN-1	15/Jan/2020	09:00	15/Jan/2020	17:00	MSETCL	Daily	Routine maint work & Diagnostic testing work
88	525	220KV-PARLI-OSMANABAD-M-1	15/Jan/2020	09:00	15/Jan/2020	18:00	MSETCL	Daily	Line maintenance
89	540	MAIN BAY - 404 OF SOLAPUR PG @ ALKUD	15/Jan/2020	10:00	15/Jan/2020	17:30	MSETCL	Daily	Quarterly Maint. Work & Diagnostic Testing Work
90	541	TIE BAY - 405 OF SOLAPUR PG @ ALKUD	15/Jan/2020	10:00	15/Jan/2020	17:30	MSETCL	Daily	Quarterly Maint. Work & Diagnostic Testing Work
91	542	400KV-ALKUD-SOLAPUR-1	15/Jan/2020	10:00	15/Jan/2020	17:30	MSETCL	Daily	Quarterly Maint. Work & Diagnostic Testing Work
92	543	220KV-WARDHA-PUSAD-1	15/Jan/2020	10:00	15/Jan/2020	18:00	MSETCL	Daily	Routine maintenance work
93	553	400KV-CHAKAN-PUNE-PG-1	16/Jan/2020	09:00	16/Jan/2020	17:00	MSETCL	Daily	Half yearly testing and maintenance activities
94	559	ALKUD - 400KV - BUS 1	16/Jan/2020	10:00	16/Jan/2020	17:30	MSETCL	Daily	Quarterly Maint. Work
95	561	220KV-WARDHA-PUSAD-1	16/Jan/2020	08:00	16/Jan/2020	18:00	ATIL	Daily	For routine maintenance work
96	564	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	16/Jan/2020	09:00	16/Jan/2020	17:00	MSETCL	Daily	Routine Maintenance & Dignostic testing work .
97	570	765KV-AKOLA (2)-EKTUNI-2 L/R@ AKOLA (2) - 765KV	16/Jan/2020	09:00	16/Jan/2020	18:00	MEGPTCL	Daily	Annual Maintenance of Reactor Bay Equipments
98	571	400KV-PARLI-M-PARLI-2	16/Jan/2020	09:00	16/Jan/2020	18:00	MSETCL	Daily	Distance relay testing,bay maintenance work
99	586	400KV-KORADI-II-KORADI-III-1	16/Jan/2020	10:00	16/Jan/2020	18:00	MSETCL	Daily	Tan delta measurement of Line CT & CVT at Bay 409
100	590	NEW KOYNA - 400KV - BUS 2	16/Jan/2020	08:00	18/Jan/2020	18:00	MSETCL	Continuous	Conductor replacement work
101	597	400KV-DHULE-MS-BABLESHWAR-1	16/Jan/2020	08:00	29/Jan/2020	17:00	MSETCL	Daily	online PID testing work
102	598	400KV-DHULE-MS-BABLESHWAR-2	16/Jan/2020	08:00	29/Jan/2020	18:00	MSETCL	Daily	PID testing work
103	601	400KV-CHANDRAPUR-GCR-PARLI-M-3	16/Jan/2020	08:00	31/Jan/2020	17:00	MSETCL	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.
104	602	400KV-CHANDRAPU-II-NANDED-2	16/Jan/2020	08:00	31/Jan/2020	17:00	MSETCL	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.
105	603	400KV-PARLI-M-SOLAPUR-M-1	16/Jan/2020	10:00	31/Jan/2020	18:00	MSETCL	Daily	PID Testing of Insulator strings
106	608	PADGHE - 400KV - BUS 1	17/Jan/2020	05:00	19/Jan/2020	23:55	MSETCL	Continuous	400kV A bus Partial Bus Outage for Bus Conductor replacement
107	609	400KV-LONIKHAND-PUNE-PG-1	17/Jan/2020	08:00	17/Jan/2020	18:00	MSETCL	Daily	Line Maintenance & Routine Diagnostic testing work
108	610	KORADI-III - 765KV - BUS 1	17/Jan/2020	09:00	17/Jan/2020	18:00	MEGPTCL	Daily	Maintenance of Bus Related Equipments
109	618	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	17/Jan/2020	09:00	17/Jan/2020	17:00	MSETCL	Daily	Routine Maintenance & Dignostic testing work .
110	641	400KV-KORADI-II-KORADI-III-2	17/Jan/2020	10:00	17/Jan/2020	17:00	MSETCL	Daily	Tan delta measurement of & CVT at Bay 406

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	Name of Requesting Agency	D	reason
111	646	400KV-JAIGAD-NEW KOYNA-1	17/Jan/2020	09:00	18/Jan/2020	18:00	JPTL	Daily	Hotline insulator washing
112	647	400KV-JAIGAD-NEW KOYNA-2	17/Jan/2020	09:00	18/Jan/2020	18:00	JPTL	Daily	Hotline insulator washing
113	660	220KV-BOISAR-NALASOPARA-1	18/Jan/2020	09:00	18/Jan/2020	17:00	MSETCL	Daily	POST MANSON MAINTENANCE WORK
114	670	KORADI-III - 765KV - BUS 2	18/Jan/2020	09:00	18/Jan/2020	18:00	MEGPTCL	Daily	Maintenance of Bus Related Equipments
115	677	220KV-WARDHA-PUSAD-1	18/Jan/2020	9:00	18/Jan/2020	18:00	POWERGRID_WR1		For AMP Work
116	682	220KV-WARDHA-PUSAD-1	18/Jan/2020	10:00	18/Jan/2020	18:00	MSETCL	Daily	Routine maintenance work
117	689	220KV-NASIK-NAVSARI-2	19/Jan/2020	08:00	26/Jan/2020	18:00	MSETCL	Daily	Diagnostic testing, string replacement, signature analysis
118	696	220KV-BOISAR-BOISAR-M-1	19/Jan/2020	09:00	19/Jan/2020	17:00	MSETCL	Daily	POST MANSON MAINTENANCE WORK
119	697	400KV-RGPPL-NAGOTHANE-1	19/Jan/2020	10:00	26/Jan/2020	15:00	MSETCL	Daily	PID Test of insulators
120	702	TIE BAY - 400KV-PARLI-PUNE-PG-2 AND 400KV-WARORA-PG-PARLI-2 at PARLI - 400KV	20/Jan/2020	9:00	20/Jan/2020	18:00	POWERGRID_WR1	D	For AMP works
121	703	Main Bay - 400KV-TARAPUR 3&4-PADGHE-1 AND PADGHE - 400KV - Bus 1	20/Jan/2020	10:00	20/Jan/2020	17:00	POWERGRID_WR1	D	For AMP of Tarapur Padghe 1 Line CVT at MSETCL Padghe SS.
122	708	400KV-BABLESHWAR-PADGHE-PG-2	20/Jan/2020	08:00	22/Jan/2020	18:00	MSETCL	Daily	PID Faulty String replacement work & Relay Testing
123	709	BOISAR - 220KV - BUS 2	20/Jan/2020	06:00	21/Jan/2020	18:00	MSETCL	Continuous	Routine Maintenance & Dignostic testing works.
124	717	KORADI-III - 765KV - BUS 1	20/Jan/2020	09:00	20/Jan/2020	18:00	MEGPTCL	Daily	Maintenance of Bus Related Equipments
125	732	220KV-WARDHA-PUSAD-1	20/Jan/2020	10:00	20/Jan/2020	18:00	MSETCL	Daily	Routine maintenance work
126	744	400KV-KALWA-PUNE-PG-1	20/Jan/2020	09:00	25/Jan/2020	17:00	MSETCL	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
127	747	400KV-KHARGHAR-PUNE-PG-1	20/Jan/2020	09:00	31/Jan/2020	17:00	MSETCL	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
128	779	MAIN BAY - 400KV-KORADI-II-KORADI-III-1 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV	21/Jan/2020	10:00	21/Jan/2020	12:00	MSETCL	Daily	Tan delta measurement of Bus CT at Bay 409
129	781	220KV-WARDHA-WARDHA-M-1	21/Jan/2020	08:00	22/Jan/2020	18:00	MSETCL	Daily	1) Routine Maintenance & Diagnostic testing work Nut Bolt Tightening work 2) Restoration of line from ERS to new erected tower from Loc No 15-18 due to raising the height of tower due to NHAI from Loc 16 to 17 and railway crossing from Loc No 17 to 18.and routine maintenance
130	786	TIE BAY - 400KV-WARDHA-AURANGABAD-1 AND 400KV/220KV WARDHA-ICT-2 at Wardha - 400KV	21/Jan/2020	9:00	30/Jan/2020	18:00	POWERGRID_WR1	C	For Replacement of BHEL CB with GE CB.
131	789	220KV-TARAPUR 1&2-BORIVALI-1	22/Jan/2020	8:00	28/Jan/2020	19:00	TAPS 1&2, NPCIL	continuous	Zone-II main bus outage
132	796	AKOLA (2) - 400KV - BUS 1	22/Jan/2020	09:00	22/Jan/2020	18:00	MEGPTCL	Daily	Maintenance of Bus Related Equipments
133	800	400KV-SSP-DHULE-MS-1 and Ckt - 2 AR In Non-auto mode	22/Jan/2020	08:00	22/Jan/2020	18:00	MSETCL	Daily	PID work will be carried out on 01 to 15 Jan 2019. if any strings found suspicious, it will be replaced in this proposed outages
134	803	MAIN BAY (419) OF FUTURE CKT - 1 @ WARORA	22/Jan/2020	09:00	22/Jan/2020	17:00	MSETCL	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .
135	824	400KV-KALA-KUDUS-1	22/Jan/2020	10:00	22/Jan/2020	17:00	MSETCL	Daily	Annual Maintenance of bays equipment
136	835	400KV-RGPPL-NAGOTHANE-2	22/Jan/2020	9:00	25/Jan/2020	18:00	RGPPL	C	Tie bkr (407-52 T) SF6 gas leakage to be attended.
137	838	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	23/Jan/2020	10:00	23/Jan/2020	17:00	MSETCL	Daily	Routine Maintenance & testing work

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	Name of Requesting Agency	D	reason
138	840	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at Akola - 765KV	23/Jan/2020	9:00	30/Jan/2020	18:00	POWERGRID_WR1	C	For Replacement of BHEL CB with GE CB.
139	841	220KV-TALEGAON-PUNE-PG-2	23/Jan/2020	09:00	23/Jan/2020	17:00	MSETCL	Daily	Half yearly maintenance , Diagnostics Testing
140	860	AKOLA (2) - 400KV - BUS 2	23/Jan/2020	09:00	23/Jan/2020	18:00	MEGPTCL	Daily	Maintenance of Bus Related Equipments
141	873	TIE BAY - 400KV/11.5KV KORADI-II-ST-2 AND 400KV-KORADI-II-KORADI-III-1 at KORADI-II - 400KV	23/Jan/2020	10:00	23/Jan/2020	12:00	MSETCL	Daily	Tan delta measurement of Bus CT at Bay 408
142	882	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AKOLA - 400KV - BUS 1 at Akola - 765KV	23/Jan/2020	9:00	30/Jan/2020	18:00	POWERGRID_WR1	C	For Replacement of BHEL CB with GE CB.
143	883	400KV-KALWA-KHARGHAR-1	24/Jan/2020	09:00	24/Jan/2020	18:00	MSETCL	Daily	Bus maint. and CVT testing work Routine Maintenance & Diagnostic Testing
144	886	KORADI-III - 400KV - BUS 1	24/Jan/2020	09:00	24/Jan/2020	18:00	MEGPTCL	Daily	Maintenance of Bus Related Equipments
145	890	400KV-SSP-DHULE-MS-2 and Ckt -1 AR required in Non-auto mode	24/Jan/2020	08:00	24/Jan/2020	18:00	MSETCL	Daily	PID work will be carried out on 1 to 15 Jan 2019. If any strings found suspicious, it will be replaced in this proposed outages
146	895	220KV-TARAPUR 1&2-BORIVALI-1	24/Jan/2020	09:00	24/Jan/2020	17:00	MSETCL	Daily	POST MANSON MAINTENANCE WORK
147	916	PADGHE - 400KV - BUS 2	24/Jan/2020	04:00	26/Jan/2020	23:59	MSETCL	Continuous	400KV B bus outage for Partial Bus Conductor Replacement work
148	924	KORADI-III - 400KV - BUS 2	25/Jan/2020	09:00	25/Jan/2020	18:00	MEGPTCL	Daily	Maintenance of Bus Related Equipments
149	928	220KV-BOISAR-BOISAR-M-2	25/Jan/2020	09:00	25/Jan/2020	17:00	MSETCL	Daily	POST MANSON MAINTENANCE WORK
150	938	220KV-TALEGAON-PUNE-PG-1	25/Jan/2020	9:00	25/Jan/2020	18:00	POWERGRID_WR1	D	For line equipments AMP work & Relay Testing,
151	947	MAIN BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	26/Jan/2020	09:00	26/Jan/2020	18:00	MEGPTCL	Daily	Dew Point Measurement in Circuit breaker
152	950	WARDHA - 765KV - BUS 2	27/Jan/2020	9:00	27/Jan/2020	18:00	POWERGRID_WR1	D	For AMP work, Phase CVT Errection.
153	954	TIE BAY - 765KV-KORADI-III-AKOLA-1 AND 765KV-TIRODA-KORADI-III-2 at KORADI-III - 765KV	27/Jan/2020	08:00	27/Jan/2020	18:00	MEGPTCL	Daily	Attending SF6 gas leakage
154	962	400KV-EKTUNI-BABLESHWAR-1	27/Jan/2020	09:00	27/Jan/2020	18:00	MSETCL	Daily	Quarterly maintenance work & Relay Testing
155	967	400KV-RGPPL-NAGOTHANE-1	27/Jan/2020	9:00	27/Jan/2020	18:00	RGPPL	D	Tie bkr (406-52 T) Mechanism drive maintenance work.
156	986	400KV-KALWA-KHARGHAR-1	27/Jan/2020	09:00	31/Jan/2020	17:00	MSETCL	Daily	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
157	997	WARORA - 400KV - BUS 2	28/Jan/2020	09:00	28/Jan/2020	17:00	MSETCL	Daily	Routine maintainance and diagonastic testing such as CVT tandelta,IR values,isolater maintainance work etc
158	1028	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	28/Jan/2020	08:00	28/Jan/2020	18:00	MEGPTCL	Daily	Bay Maintenance Activities
159	1036	PUNE-PG - 400KV - BUS 1	29/Jan/2020	9:00	29/Jan/2020	18:00	POWERGRID_WR1	D	For Replacement of Clamp & connectors
160	1074	400KV-KALWA-PUNE-PG-1	30/Jan/2020	08:00	30/Jan/2020	18:00	MSETCL	Daily	Maintenance and Diagnostic testing work and CB Overhauling work
161	1075	TIE BAY - 400KV-KALWA-PUNE-PG-1 AND 400KV/220KV PUNE-PG-ICT-3 at PUNE-PG - 400KV	30/Jan/2020	9:00	30/Jan/2020	18:00	POWERGRID_WR1	D	For AMP works
162	1084	400KV-EKTUNI-BABLESHWAR-2	30/Jan/2020	09:00	30/Jan/2020	17:00	MSETCL	Daily	Quarterly Maintenance work & Relay Testing
163	1087	MAIN BAY - 765KV-TIRODA-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	30/Jan/2020	09:00	30/Jan/2020	18:00	MEGPTCL	Daily	Dew Point Measurement in Circuit breaker
164	1092	220KV-WARDHA-WARDHA-M-1	30/Jan/2020	9:00	30/Jan/2020	18:00	POWERGRID_WR1	D	Line Impedance Kit commissioning & AMP WORK.
165	1099	400KV-BABLESHWAR-PADGHE-PG-2	30/Jan/2020	08:00	31/Jan/2020	18:00	MSETCL	Daily	PID testing work
166	1106	MAIN BAY - 765KV-KORADI-III-AKOLA-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	31/Jan/2020	08:00	31/Jan/2020	18:00	MEGPTCL	Daily	Attending SF6 gas leakage
167	1107	TALEGAON - 220KV - BUS 1	31/Jan/2020	9:00	31/Jan/2020	18:00	POWERGRID_WR1	D	For Replacement of Clamp & connectors

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	Name of Requesting Agency	D	reason
168	1109	400KV-DHULE-MS-BABLESHWAR-2 and Ckt - 1 AR required in Non-auto mode	31/Jan/2020	08:00	31/Jan/2020	18:00	MSETCL	Daily	PID work will be carried out on 16 to 29 Jan 2019. if any strings found suspicious, it will be replaced in this proposed outages
169	1119	220KV-WARDHA-BADNERA-1	31/Jan/2020	9:00	31/Jan/2020	18:00	POWERGRID_WR1	D	Line Impedance Kit commissioning

Maharashtra State Load Despatch Centre												
State Element Outages list for the month of January 2020												
Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	
1	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	01-Jan-20	08:00	15-Jan-20	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.	
2	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	02-Jan-20	08:00	02-Jan-20	18:00	Daily	Maintenance and Diagnostic testing work	MSETCL	MSETCL	-	
3	400 KV	KHADKA-AURANGABAD	02-Jan-20	06:00	04-Jan-20	18:00	Daily	For replacement of conductor H/W & other AMC works	MSETCL	MSETCL	NIL	
4	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	03-Jan-20	09:00	03-Jan-20	17:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work	
5	400 KV	125 MVAR BUS REACTOR @ TALANDGE	03-Jan-20	09:00	03-Jan-20	18:00	Daily	Quarterly Maintenance	MSETCL	MSETCL	Quarterly Maintenance	
6	400 KV	KARAD - LONIKAND 1	03-Jan-20	09:00	03-Jan-20	19:00	Daily	Quarterly, Maint. Work & 80 MVAR BHEL reactor Line re-commissioning work	MSETCL	MSETCL	Load manage on other ckt.	
7	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	03-Jan-20	09:00	03-Jan-20	17:00	Daily	Diagnostic Testing of Circuit Breaker & Routine Maintenance Work	MSETCL	MSETCL	--	
8	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	04-Jan-20	09:00	04-Jan-20	17:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work	
9	400 KV	400/220/33KV SPARE ICT @ KORADI 2	04-Jan-20	10:00	04-Jan-20	15:00	Daily	DCRM of CB 431-Q52	MSETCL	MSETCL	Spare ICT is on No-Load	
10	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	04-Jan-20	08:00	04-Jan-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	-	
11	400 KV	400220KV 167MVA SPARE ICT @ DEEPNAGAR	04-Jan-20	09:00	04-Jan-20	17:00	Daily	Spare ICT Bay For Bushing & Winding Tan Delta of ICT Bus CT Tan delta Testing and quarterly Bay Maintenance.	MSETCL	MSETCL	Spare ICT bay	
12	400 KV	TBC @ KOLHAPUR(TALANDGE)	04-Jan-20	09:00	04-Jan-20	18:00	Daily	Annual Maintenance	MSETCL	MSETCL	Annual Maintenance	
13	400 KV	KARAD - TALANDGE CKT 2	06-Jan-20	10:00	06-Jan-20	17:00	Daily	Quarterly, Maint. Work	MSETCL	MSETCL	Load manage on 400 kv Karad-Talandage I	
14	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	06-Jan-20	09:00	06-Jan-20	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL	
15	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	07-Jan-20	09:00	08-Jan-20	18:00	Daily	Spike Bird Guard Fixing	MSETCL	MSETCL	Spike Bird Guard Fixing	
16	400 KV	KARAD - TALANDGE CKT 2	07-Jan-20	09:00	07-Jan-20	18:00	Daily	C and Tan delta Testing work	MSETCL	MSETCL	Testing and QM work	
17	400 KV	TIE BAY (406) OF ICT -2 @ WARORA	07-Jan-20	09:00	07-Jan-20	17:00	Daily	Bus/Line/Tie CT's,Syn CVT Tan delta & Routine Maintenance & Dignostic testing work etc	MSETCL	MSETCL	400KV ICT No -2handed over to 400kv PADGHA	
18	400 KV	400/220 125MVAR BUS REACTOR @ LAMBOTI	08-Jan-20	10:00	08-Jan-20	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Diagnostic testing work	
19	400 KV	TIE BAY (417) OF ST - 3 AND ST-5 @ TIRORA	08-Jan-20	09:00	08-Jan-20	18:00	Daily	Bay Maintenance Activities	APML	APML	Bay Maintenance Activities	
20	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	08-Jan-20	09:00	08-Jan-20	17:00	Daily	Diagnostic Testing of CT's & Routine Maintenance Work	MSETCL	MSETCL	--	
21	400 KV	BUS REACTOR AT 400 KV KORADI 5/5	08-Jan-20	09:00	08-Jan-20	18:00	Daily	Relay testing Differential and LBB	MSETCL	MSETCL	Outages will be availed subject to weather conditions.	
22	400 KV	DHULE - BABLESHWAR - I	08-Jan-20	09:00	08-Jan-20	18:00	Daily	Quarterly maintenance work and relay testing	MSETCL	MSETCL	-	
23	400 KV	WARORA - IEPL	09-Jan-20	09:00	09-Jan-20	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt	
24	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	09-Jan-20	09:00	09-Jan-20	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-	
25	400 KV	JAIGAD-KARAD-II	09-Jan-20	10:00	09-Jan-20	17:00	Daily	Quarterly, Maint. Work	MSETCL	MSETCL	Load manage on 400 kv Karad-jaigad I	
26	400 KV	400/220KV SPARE ICT @ JEJURI	09-Jan-20	09:00	09-Jan-20	17:00	Daily	Annual testing & maint.	MSETCL	MSETCL	-	
27	400 KV	NEW KOYNA - STAGE IV CKT 1	09-Jan-20	08:00	10-Jan-20	18:00	Daily	Routine maint. Work , Faulty string replacement Work & cold washing	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 Ckt-II line	
28	400 KV	TIE BAY (423) OF STATION TF - 1 @ KORADI 2	09-Jan-20	10:00	09-Jan-20	15:00	Daily	DCRM of CB 423-Q52	MSETCL	MSETCL	1)Station Transformer -I will remain in service through Main Bay 422	
29	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	09-Jan-20	08:00	09-Jan-20	18:00	Daily	For routine maintenance work	MSETCL	MSETCL	Nil	
30	400 KV	THAPTI TANDA - WALUJ	10-Jan-20	09:00	11-Jan-20	18:00	Daily	Chemical Washing of Lines	MSETCL	MSETCL	Chemical Washing of lines	
31	400 KV	400KV RPL LINE REACTOR @ 400KV KORADI	10-Jan-20	09:00	10-Jan-20	18:00	Daily	Differential Relay testing	MSETCL	MSETCL	Outages will be availed subject to weather conditions.	
32	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	10-Jan-20	08:00	10-Jan-20	18:00	Daily	R&M and Diagnostic testing work	MSETCL	MSETCL	-----	
33	400 KV	400/220/33 KV 315 MVA ICT - 1 @ WALUJ	10-Jan-20	09:00	10-Jan-20	17:00	Daily	Routine maintenance of ICT I Bay @ waluj end	MSETCL	MSETCL	Routine maintenance	
34	400 KV	NEW KOYNA - STAGE IV CKT 2	11-Jan-20	08:00	12-Jan-20	18:00	Daily	Routine maint. Work , Faulty string replacement Work & cold washing	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 Ckt-I line	
35	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	11-Jan-20	08:00	11-Jan-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	-	
36	400 KV	CHANDRAPUR - KHAPERKHEDA	11-Jan-20	08:00	11-Jan-20	18:00	Daily	Line maintenance work	MSETCL	MSETCL	--	
37	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	11-Jan-20	09:00	11-Jan-20	17:00	Daily	1.Main Bus CT Tan delta testing. 2.LV CB Timing measurment CRM & LV CT Tan delta testing work 3. Quarterly Bay Maintenance work	MSETCL	MSETCL	Load will be managed on 501MVA ICT- II during outage.	
38	400 KV	400/220/33 KV 315 MVA ICT - 1 @ KOLHAPUR	13-Jan-20	09:00	13-Jan-20	23:59	Daily	Oil leakage Attending, QM work	MSETCL	MSETCL	Oil leakage Attending, QM work	
39	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	13-Jan-20	09:00	13-Jan-20	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL	
40	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	14-Jan-20	09:00	15-Jan-20	18:00	Daily	1) For measurement of tan delta & capacitance of Bushings. 2) Arresting oil leakages. 3) Maintenance & alignment of isolators.	MSETCL	MSETCL	During outage, ICT-2 will be in service.	

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
41	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	15-Jan-20	09:00	16-Jan-20	18:00	Continuous	PG isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
42	400 KV	KHADKA- DEEPNAGAR CKT 1	15-Jan-20	09:00	15-Jan-20	13:00	Daily	For Tie CB DCRM Testing work.	MSETCL	MSETCL	Opportunity
43	400 KV	KHADKA- DEEPNAGAR CKT 1	15-Jan-20	06:00	18-Jan-20	18:00	Daily	For replacement of Faulty String Detected in PID	MSETCL	MSETCL	NIL
44	400 KV	KHADKA - BABLESHWAR	16-Jan-20	06:00	18-Jan-20	18:00	Daily	For replacement of conductor H/W & Other AMC Works	MSETCL	MSETCL	NIL
45	400 KV	TIE BAY (409) OF FUTURE BAY AND ICT - 3 @ JEJURI	16-Jan-20	09:00	16-Jan-20	17:00	Daily	Annual testing & maint.	MSETCL	MSETCL	-
46	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	16-Jan-20	08:00	16-Jan-20	17:00	Daily	For Replacement of Disc Insulator if found During PID Testing & Line Signature Test	MSETCL	MSETCL	For Replacement of Disc Insulator if found During PID Testing & Line Signature Test
47	400 KV	400/220kv 500MVA ICT-1 @ TAPTITANDA	16-Jan-20	10:00	16-Jan-20	18:00	Daily	ICT testing work	MSETCL	MSETCL	Nil
48	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	16-Jan-20	10:00	16-Jan-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	One and half breaker system , Load will manage on Interconnector I Bay
49	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	16-Jan-20	08:00	16-Jan-20	18:00	Daily	Maintenance and Diagnostic testing work	MSETCL	MSETCL	-
50	400 KV	CHANDRAPUR - KHAPERKHEDA	16-Jan-20	08:00	18-Jan-20	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.
51	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 2)	16-Jan-20	10:00	16-Jan-20	18:00	Daily	Half yearly maintenance and diagnostic testing.	MSETCL	MSETCL	One and half breaker system , Load will manage on Interconnector I Bay
52	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	16-Jan-20	12:00	26-Jan-20	18:00	Daily	PID testing of insulator strings by PID Uint Akola of O&M Circle Akola.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Bhusawal & 400 kv Koradi-Nandgaonpeth are in service.
53	400 KV	400 KV WALLUJ (400 KV) - BABHALESHWAR CKT	16-Jan-20	10:00	16-Jan-20	16:00	Daily	PID works	MSETCL	MSETCL	PID works
54	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	17-Jan-20	09:00	18-Jan-20	18:00	Continuous	PG isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
55	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	17-Jan-20	10:00	17-Jan-20	18:00	Daily	ICT-II testing work	MSETCL	MSETCL	Nil
56	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	18-Jan-20	08:00	18-Jan-20	17:00	Daily	For Conductor & Earthwire Hardware tightening work	MSETCL	MSETCL	For Conductor & Earthwire Hardware tightening work
57	400 KV	CHANDRAPUR - KHAPERKHEDA ON TBC @ CHANDRAPUR	18-Jan-20	09:00	18-Jan-20	18:00	Daily	1) For measurement of Timing, CRM & DCRM of CB. 2) Maintenance & alignment of PG-1 & PG-2 Isolators.	MSETCL	MSETCL	Permission to shift the 400KV Chandrapur - Khaparkheda Bay on TBC-1 bay.
58	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	18-Jan-20	09:00	18-Jan-20	17:00	Daily	1. Main Bus CT Tan delta testing. 2. LV CB Timing measurnment CRM & LV CT Tan delta testing work 3. Quarterly Bay Maintenance work	MSETCL	MSETCL	Load will be managed on 501MVA ICT-I during outage.
59	400 KV	KORADI-KHAPERKHEDA I	19-Jan-20	09:00	20-Jan-20	18:00	Continuous	PG isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
60	400 KV	CHANDRAPUR - KHAPERKHEDA	19-Jan-20	08:00	31-Jan-20	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.
61	400 KV	JAIGAD-NEW KOYNA-I	20-Jan-20	09:00	20-Jan-20	18:00	Daily	Insulator replacement work	JPTL	JPTL	Jaigad-New koyna line II will be in service
62	400 KV	KARAD - TALANDGE CKT 1	20-Jan-20	08:00	24-Jan-20	18:00	Daily	Replacement of Disc Insulator String by Porcelain Insulator (LE Scheme)	MSETCL	MSETCL	400KV Karad - Talandge ckt-2 will be in service
63	400 KV	105 MVA SPARE ICT @ AKOLA	20-Jan-20	09:00	20-Jan-20	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
64	400 KV	KHADKA- DEEPNAGAR CKT 2	20-Jan-20	09:00	20-Jan-20	13:00	Daily	For Main CB DCRM Testing work	MSETCL	MSETCL	Opportunity Outage
65	400 KV	KHADKA- DEEPNAGAR CKT 2	20-Jan-20	06:00	22-Jan-20	18:00	Daily	For replacement of Faulty Insulator string detected in PID	MSETCL	MSETCL	NIL
66	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	20-Jan-20	09:00	20-Jan-20	23:59	Daily	Oil Leakage Attending, QM work	MSETCL	MSETCL	Oil Leakage Attending, QM work
67	400 KV	JAIGAD-NEW KOYNA-II	21-Jan-20	09:00	21-Jan-20	18:00	Daily	Insulator replacement works	JPTL	JPTL	Jaigad-New koyna line I will be in service
68	400 KV	GT - 7 @ KORADI-1	21-Jan-20	09:00	22-Jan-20	18:00	Continuous	PG isolators alignment , testing and setting work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
69	400 KV	400 KV FUTURE BAY II @ WARORA	21-Jan-20	09:00	21-Jan-20	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	400KV Bay No 422 charged on No Load
70	400 KV	GTR - 5 ON TBC @ CHANDRAPUR SS	21-Jan-20	09:00	22-Jan-20	18:00	Continuous	For servicing & overhauling of R, Y & B-ph PG-1 (Main Bus Isolators). By replacing the scissor assembly.	MSETCL	MSETCL	Permission to shift the 400KV GTR-5 Bay on TBC-2 bay.
71	400 KV	400 KV WALLUJ (400 KV) - BABHALESHWAR CKT	21-Jan-20	10:00	21-Jan-20	16:00	Daily	PID WORKS	MSETCL	MSETCL	PID WORKS
72	400 KV	JAIGAD-KARAD-I	22-Jan-20	09:00	22-Jan-20	18:00	Daily	Insulator replacement works	JPTL	JPTL	Jaigad-karad line-II will be in service
73	400 KV	MAIN BAY (410) OF FUTURE BAY @ JEJURI	23-Jan-20	09:00	23-Jan-20	17:00	Daily	Annual testing & maint.	MSETCL	MSETCL	-
74	400 KV	DEEPNAGAR - THAPTI TANDA	23-Jan-20	06:00	25-Jan-20	18:00	Daily	For replacement faulty string detected in PID	MSETCL	MSETCL	NIL
75	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	23-Jan-20	09:00	23-Jan-20	18:00	Daily	Reactor backup relay testing work, Bay Maintenance & Line maintainance work	MSETCL	MSETCL	-
76	400 KV	JAIGAD-KARAD-II	23-Jan-20	09:00	23-Jan-20	18:00	Daily	Insulator replacement works	JPTL	JPTL	Jaigad-Karad line II will be service
77	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	23-Jan-20	08:00	23-Jan-20	18:00	Daily	Maintenance and Diagnostic testing work	MSETCL	MSETCL	-
78	400 KV	400 KV WALLUJ (400 KV) - BABHALESHWAR CKT	23-Jan-20	10:00	23-Jan-20	16:00	Daily	PID WORKS	MSETCL	MSETCL	PID WORKS
79	400 KV	GT - 6 @ KORADI-1	24-Jan-20	09:00	24-Jan-20	18:00	Daily	CB Timing DCRM & CRM	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
80	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	24-Jan-20	08:00	24-Jan-20	18:00	Daily	R&M and Diagnostic Testing Work	MSETCL	MSETCL	ICT-1 and ICT-2 will be in service
81	400 KV	KORADI-NANDGAONPETH (RPL)	25-Jan-20	08:00	25-Jan-20	18:00	Daily	Line maintenance work	MSETCL	MSETCL	-
82	400 KV	AKOLA - KHADKA (BHUSAWAL)	25-Jan-20	08:00	25-Jan-20	18:00	Daily	for taking CT Tan delta ,CB DCRM & Routine bay maintenance work	MSETCL	MSETCL	Max load-302 MW & Min load-270 MW
83	400 KV	400 KV WALLUJ (400 KV) - BABHALESHWAR CKT	25-Jan-20	10:00	25-Jan-20	16:00	Daily	PID WORKS	MSETCL	MSETCL	PID WORKS

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
84	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	27-Jan-20	08:00	30-Jan-20	18:00	Daily	Work of replacement of faulty strings having 03 & above no. of punctured discs detected in PID by agency by availing outages (cold line).	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Bhusawal & 400 kv Koradi-Nandgaonpeth are in service.
85	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	27-Jan-20	09:00	27-Jan-20	17:00	Daily	For Quarterly Bay Maintenance	MSETCL	MSETCL	Opportunity Outage
86	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	27-Jan-20	06:00	31-Jan-20	18:00	Daily	For replacement of faulty string & dead end & Mid span joint	MSETCL	MSETCL	NIL
87	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	27-Jan-20	09:00	27-Jan-20	23:59	Daily	Oil Leakage Attending, Qm work	MSETCL	MSETCL	Oil Leakage Attending, Qm work
88	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	27-Jan-20	08:00	27-Jan-20	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	Load can be managed on 315MVA ICT I
89	400 KV	KARAD - TALANDGE CKT 2	27-Jan-20	08:00	31-Jan-20	18:00	Daily	Replacement of Disc Insulator String by Porcelain Insulator (LE Scheme)	MSETCL	MSETCL	400KV Karad - Talandge ckt-I will be in service
90	400 KV	80 MVar BUS REACTOR - 1 @ BABHALESHWAR	28-Jan-20	09:00	28-Jan-20	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	-
91	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	28-Jan-20	08:00	28-Jan-20	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	Load can be managed on 315MVA ICT II
92	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	28-Jan-20	10:00	28-Jan-20	16:00	Daily	PID WORKS	MSETCL	MSETCL	PID WORKS
93	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	30-Jan-20	09:00	30-Jan-20	17:00	Daily	Annual testing & maint.	MSETCL	MSETCL	-
94	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	30-Jan-20	10:00	30-Jan-20	16:00	Daily	PID WORKS	MSETCL	MSETCL	PID WORKS