

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of JANUARY' 2023

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|---------------------------|--|--------------------|--|----------|-------|-----------|-------|--|
| 1 | 1 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KALWA-PADGHE-2 | C | Replacement of existing Conductor by HTLS Conductor | 1-Jan-23 | 06:00 | 1-Jan-23 | 19:00 | Replacement of existing Conductor by HTLS Conductor |
| 2 | 4 | PLANNED | OCC_562 | WTPL | 400KV-PUNE-GIS-PARLI-1 | D | AR is to be disable due to annual maintenance work is to be done on 400KV-PUNE-GIS-PARLI-2 | 1-Jan-23 | 8:00 | 1-Jan-23 | 18:00 | AR to be disable |
| 3 | 7 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-CHAKAN-PUNE-PG-1 | D | PID scanning of insulator strings | 1-Jan-23 | 08:00 | 3-Jan-23 | 18:00 | - |
| 4 | 9 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-TALEGAON-PUNE-PG-1 | D | Pilot Wire Protection Scheme(Only AR out) line will be in service. | 1-Jan-23 | 09:00 | 8-Jan-23 | 17:00 | Total 8 days required for both the lines |
| 5 | 10 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-TALEGAON-PUNE-PG-2 | D | Pilot Wire Protection Scheme(Only AR out) line will be in service. | 1-Jan-23 | 09:00 | 8-Jan-23 | 17:00 | Total 8 days required for both the lines |
| 6 | 14 | PLANNED | OCC_562 | APML-ADANI | 765KV/22KV TIRODA-GT-5 | C | For bay equipment maintenance and testing work. | 1-Jan-23 | 9:00 | 10-Jan-23 | 18:00 | TRANSFORMER OUTAGE |
| 7 | 16 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-1 | D | For Carrying PID Work | 1-Jan-23 | 08:00 | 15-Jan-23 | 18:00 | AR required out of service |
| 8 | 36 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-TAPTHITHANDA-EKTUNI-1 | D | OPGW Stringing and removal of Earthwire work on Ektuni-Thapatitanda Ckt-1 by MTCL | 1-Jan-23 | 08:00 | 31-Jan-23 | 18:00 | Work will be carried out by MTCL |
| 9 | 37 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-TAPTHITHANDA-EKTUNI-2 | D | OPGW stringing and removal of Earthwire work on 400 KV Thapatitanda-Ektuni line by MTCL | 1-Jan-23 | 08:00 | 31-Jan-23 | 18:00 | Work will be carried out by MTCL |
| 10 | 38 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-II-NADED-2 | D | For PID Work, Shifting of auto reclose switch to non auto mode. | 1-Jan-23 | 08:00 | 31-Jan-23 | 18:00 | Permission for Auto Reclose to be kept in Non auto mode for PID testing work |
| 11 | 39 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-GCR-PARLI-M-3 | D | For PID Work, Shifting of auto reclose switch to non auto mode. | 1-Jan-23 | 08:00 | 31-Jan-23 | 18:00 | - |
| 12 | 40 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-PUSAD-1 | D | For PID Work/Fixing bird guard, Shifting of auto reclose switch to non auto mode. | 1-Jan-23 | 08:00 | 31-Jan-23 | 18:00 | - |
| 13 | 41 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-BHUGAON-1 | D | for PID work outage will be required on daily basis (Only AR out) | 1-Jan-23 | 08:00 | 31-Jan-23 | 18:00 | NA |
| 14 | 45 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-JEJURI-KOYNA STAGE IV-1 | D | Permission for Auto Reclose to be kept in Non auto mode for PID testing work | 1-Jan-23 | 09:00 | 31-Jan-23 | 17:00 | Permission for Auto Reclose to be kept in Non auto mode for PID testing work |
| 15 | 46 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KOYNA STAGE IV-LONIKHAND-1 | D | Permission for Auto Reclose to be kept in Non auto mode for PID testing work | 1-Jan-23 | 09:00 | 31-Jan-23 | 17:00 | Permission for Auto Reclose to be kept in Non auto mode for PID testing work |
| 16 | 47 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARAD-NEW KOYNA-1 | D | Permission for Auto Reclose to be kept in Non auto mode for PID testing work | 1-Jan-23 | 09:00 | 31-Jan-23 | 17:00 | Permission for Auto Reclose to be kept in Non auto mode for PID testing work |
| 17 | 48 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARAD-NEW KOYNA-2 | D | Permission for Auto Reclose to be kept in Non auto mode for PID testing work | 1-Jan-23 | 09:00 | 31-Jan-23 | 17:00 | Permission for Auto Reclose to be kept in Non auto mode for PID testing work |
| 18 | 49 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARAD-KOLHAPUR-MS-1 | D | Permission for Auto Reclose to be kept in Non auto mode for PID testing work | 1-Jan-23 | 09:00 | 31-Jan-23 | 17:00 | Permission for Auto Reclose to be kept in Non auto mode for PID testing work |
| 19 | 50 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARAD-KOLHAPUR-MS-2 | D | Permission for Auto Reclose to be kept in Non auto mode for PID testing work | 1-Jan-23 | 09:00 | 31-Jan-23 | 17:00 | Permission for Auto Reclose to be kept in Non auto mode for PID testing work |
| 20 | 51 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-PARLI-PARLI-M-2 | D | PID Testing Hotline Work | 1-Jan-23 | 09:00 | 31-Jan-23 | 17:30 | - |
| 21 | 52 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-PARLI-OSMANABAD-M-1 | D | PID Testing Hotline Work | 1-Jan-23 | 09:00 | 31-Jan-23 | 17:30 | - |
| 22 | 53 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-PARLI-M-SOLAPUR-M-1 | D | PID testing work | 1-Jan-23 | 09:00 | 31-Jan-23 | 18:00 | - |
| 23 | 56 | PLANNED | OCC_562 | WTPL | 400KV-PUNE-GIS-PARLI-2 | D | Annual Maintenance | 2-Jan-23 | 8:00 | 2-Jan-23 | 18:00 | Line outage |
| 24 | 57 | PLANNED | OCC_562 | POWERGRID_WR1 | TIE BAY - 765KV-WARDHA-AURANGABAD-4 AND FUTURE at AURANGABAD - 765KV | D | 720 Bay AMP Work at Aurangabad | 2-Jan-23 | 7:00 | 2-Jan-23 | 18:00 | Element name to be changed as TIE BAY - 765KV-WARDHA-AURANGABAD-4 AND |
| 25 | 68 | PLANNED | OCC_562 | WTPL | 400KV-KARAD-SOLAPUR-1 | D | On line insulator replacement. | 2-Jan-23 | 9:00 | 2-Jan-23 | 14:00 | AR to be disable |
| 26 | 86 | PLANNED | OCC_562 | RGPL | 400KV-RGPP-L Nagothane Line-1 | D | Replacement of Surge Arrestor for Y & B poles | 2-Jan-23 | 8:00 | 3-Jan-23 | 18:00 | - |
| 27 | 88 | PLANNED | OCC_562 | MSLDC_OUTAGE | CHAKAN - 400KV - TRANSFER BUS 1 (ELEMENT NOT FOUND) | C | For Replacement of old scissprs of of Bus A 89A Rph, Yph, Bph PG Isolators along with Routine Testing and Maintenance Work. 400KV 89A PG Isolators Rph , Yph and B ph Hanger rods will be replaced by Hotline method. For the same permission is required to work online on 400KV Bus A. | 2-Jan-23 | 10:00 | 3-Jan-23 | 21:00 | 400KV 89A PG Isolators Rph , Yph and B ph Hanger rods will be replaced by Hotline method. For the same permission is required to work online on 400KV Bus A. |
| 28 | 89 | PLANNED | OCC_562 | MSLDC_OUTAGE | CHAKAN - 400KV - BUS 1 | C | For Replacement of old scissprs of of Bus A 89A Rph, Yph, Bph PG Isolators along with Routine Testing and Maintenance Work. 400KV 89A PG Isolators Rph , Yph and B ph Hanger rods will be replaced by Hotline method. For the same permission is required to work online on 400KV Bus A. | 2-Jan-23 | 10:00 | 3-Jan-23 | 21:00 | 400KV 89A PG Isolators Rph , Yph and B ph Hanger rods will be replaced by Hotline method. For the same permission is required to work online on 400KV Bus A. |
| 29 | 91 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARIAT-LONIKHAND-II-1 | D | PID Testing work A/R switch will be put on Non Auto Mode. | 2-Jan-23 | 08:00 | 4-Jan-23 | 18:00 | Line will be in service A/R switch will be put on Non Auto Mode. |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|---------------------------|---|--------------------|---|-------------|-------|-------------|-------|--|
| 30 | 92 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV/220KV KARAD-ICT-2 | C | Oil filtration work of ICT-II Y ph 105 MVA Unit having abnormal DGA reports & partial Discharge. SE, TCC Karad recommended to carry out filtration of oil for monitoring purpose. | 2-Jan-23 | 08:00 | 4-Jan-23 | 20:00 | SE, TCC Karad recommended to carry out filtration of oil for monitoring purpose as letter No-248 Dtd 18.11.2022. Load will be managed on other two bays. |
| 31 | 93 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-TARAPUR 1&2-BOISAR-M-1 | D | 1) Replacement of rusted hardware under R&M Scheme. 2) Line Maintenance work. 3) Bay maintenance at 220KV Boisar-II 5/stn | 2-Jan-23 | 07:00 | 5-Jan-23 | 17:00 | 1) Replacement of rusted hardware under R&M Scheme. 2) Line Maintenance work. 3) Bay maintenance at 220KV Boisar-II 5/stn |
| 32 | 95 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KALWA-PADGHE-1 | D | PID Testing Auto-Restore function to be out of service. | 2-Jan-23 | 09:00 | 7-Jan-23 | 18:00 | PID Testing Auto-Restore function to be out of service. |
| 33 | 101 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-SOLAPUR-M-SOLAPUR-1 | D | PID testing work A/R switch will be put on Non Auto Mode. | 2-Jan-23 | 09:00 | 31-Jan-23 | 18:00 | Line will be in service A/R switch will be put on Non Auto Mode. |
| 34 | 102 | PLANNED | OCC_562 | MSLDC_OUTAGE | 20KV-SOLAPUR-JEUR-1 | D | PID testing work | 2-Jan-23 | 09:00 | 31-Jan-23 | 18:00 | Line will be in service |
| 35 | 103 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-SSP-DHULE-MS-2 | D | For ON LINE PID Testing Work. | 2-Jan-23 | 11:00 | 31-Jan-23 | 15:00 | 400 KV DHL-SSNNL CKT 1 A/R switch will be put on Non Auto Mode. |
| 36 | 104 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-SSP-DHULE-MS-1 | D | For On Line PID Testing Work. | 2-Jan-23 | 11:00 | 31-Jan-23 | 15:00 | 400 KV DHL-SSNNL CKT 2 A/R switch will be put on Non Auto Mode. |
| 37 | 105 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-BADNERA-1 | D | For PID work, Shifting of auto reclose switch to non auto mode | 2-Jan-23 | 11:00 | 31-Jan-23 | 15:00 | . |
| 38 | 106 | PLANNED | OCC_562 | NPCL, TAPS 1&2 | 220KV - TAPS - Boisar | C | Continuous Line outage is required | 2-Jan-23 | 07:00 | 3-Jan-23 | 17:00 | Continuous Line outage is required |
| 39 | 111 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV | D | 404 Bay AMP Work at Waluj SS | 3-Jan-23 | 7:00 | 2-Jan-23 | 18:00 | |
| 40 | 120 | PLANNED | OCC_562 | GETCO | 400KV-SSP-DHULE-MS-1 | D | Maintenance work. Auto reclose of 400 kV SSP - Dhule 2 will remain out | 3-Jan-23 | 8:00 | 3-Jan-23 | 18:00 | Non auto reclose code for 400KV SSP Dhule No 2 |
| 41 | 124 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-GCR-CHANDRAPUR-II-2 | D | "1) Measurement Circuit Breaker timing, CRM & DCRM. 2) Measurement of tandelta of CVT. 3) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators." | 3-Jan-23 | 08:00 | 3-Jan-23 | 18:00 | During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No. - 1, 400KV KHAPARKHEDA ckt. 400KV CHANDRAPUR-PGCIL Bhadravati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be in service. |
| 42 | 129 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-EKTUNI-BABLESHWAR-2 | D | MTAMC work & Quarterly Bay Maintenance Work. | 3-Jan-23 | 09:00 | 3-Jan-23 | 15:00 | 400KV Ektuni ckt-II, 400KV Bhusawal, 400KV Aurangabad and Dhule I&II will be in service |
| 43 | 157 | PLANNED | OCC_562 | MEGPTCL | MAIN BAY - 765KV-AKOLA (2)-EKTUNI-2 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV | D | OEM Inspection of CB | 3-Jan-23 | 09:30 | 4-Jan-23 | 18:30 | OEM Inspection of CB |
| 44 | 158 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY OF 400KV-KOYNA STAGE IV-NEW KOYNA-2 AND NEW KOYNA - 400KV - BUS 1 @NEW KOYNA - 400KV at NEW KOYNA - 400KV | C | Y Pole C.B SF6 gas leakage attending work | 3-Jan-23 | 08:00 | 6-Jan-23 | 17:00 | TBC Shifting |
| 45 | 164 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-LONIKHAND-PUNE-PG-1 | C | O/H & Servicing of 29C PG Isolator & Replacement of PGI mechanism box. | 4-Jan-23 | 08:00 | 4-Jan-23 | 18:00 | - |
| 46 | 175 | PLANNED | OCC_562 | ATIL | 400KV-TIRODA-WARORA-2 | D | Annual Maintenance of line | 4-Jan-23 | 8:00 | 4-Jan-23 | 18:00 | Line Outage |
| 47 | 184 | PLANNED | OCC_562 | MSLDC_OUTAGE | 132KV-DHARNI-NEPANAGAR-1 | D | 1. For Replacement of Flashover Discs. 2. For Diagnostic Testing of Line Bay. | 4-Jan-23 | 09:00 | 4-Jan-23 | 17:00 | . |
| 48 | 188 | PLANNED | OCC_562 | POWERGRID_WR2 | 400KV/220KV BOISAR-ICT-3 | D | AMP WORKS. DIA TO BE KEPT OPEN. | 04-Jan-2023 | 9:00 | 04-Jan-2023 | 17:30 | PG-WR2-BOISAR |
| 49 | 189 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-PARLI-OSMANABAD-M-1 | D | LINE/ s/s maintenance | 4-Jan-23 | 09:00 | 4-Jan-23 | 17:30 | - |
| 50 | 196 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-PARLI-M-SOLAPUR-M-1 | D | (1) C & Tan delta measurement of CTs (2) Line Maintenance Work for Hardware tightening & fitting work. (3) Bay maintenance work. (4) Hardware Tightening & Fitting Work | 4-Jan-23 | 09:00 | 4-Jan-23 | 18:00 | - |
| 51 | 197 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-PARLI-M-SOLAPUR-M-1 | D | string replacement | 4-Jan-23 | 09:00 | 4-Jan-23 | 18:00 | Load managed on 400kv lamboti-PGCIL(solapur) |
| 52 | 198 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-MAHALAXMI(KONALKATTA)-AMONA-1 | D | Annual maintenance work | 4-Jan-23 | 09:00 | 4-Jan-23 | 18:00 | The said work is very important |
| 53 | 202 | PLANNED | OCC_562 | MEGPTCL | 765KV-AKOLA (2)-EKTUNI-1 L/R@ AKOLA (2) - 765KV | D | Taking Spare Reactor in Service in place of B-ph Reactor as per CEA guideline | 4-Jan-23 | 09:30 | 4-Jan-23 | 15:30 | Switchable Reactor-Akola(2) - Ektuni-ckt-1 will remain in service. (No changeover in LR 1) |
| 54 | 203 | PLANNED | OCC_562 | MEGPTCL | 765KV-AKOLA (2)-EKTUNI-1 | D | Taking Spare Reactor in Service in place of B-ph Reactor as per CEA guideline | 4-Jan-23 | 09:30 | 4-Jan-23 | 15:30 | Switchable Reactor-Akola(2) - Ektuni-ckt-1 will remain in service. (No changeover in LR 1) |
| 55 | 208 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-SOLAPUR-KUMBARI-1 | D | Outage is required for Quarterly Maintenance | 4-Jan-23 | 11:00 | 4-Jan-23 | 17:00 | Quarterly Maintenance |
| 56 | 209 | PLANNED | OCC_562 | MSLDC_OUTAGE | KUMBARI - 220KV - BUS 1 | D | Outage is required for Quarterly Maintenance | 4-Jan-23 | 11:00 | 4-Jan-23 | 17:00 | Quarterly Maintenance |
| 57 | 215 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-LONIKHAND-PUNE-PG-1 | D | PID scanning of insulator strings | 4-Jan-23 | 08:00 | 6-Jan-23 | 18:00 | - |
| 58 | 216 | PLANNED | OCC_562 | RGPLL | 400KV-RGPLL-NewKoyna-Line-2 | D | Replacement of Surge Arrestor for all the three poles | 4-Jan-23 | 8:00 | 6-Jan-23 | 18:00 | |
| 59 | 226 | PLANNED | OCC_562 | POWERGRID_WR1 | WARDHA - 400KV - BUS 1 | D | Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators. | 5-Jan-23 | 8:00 | 5-Jan-23 | 19:00 | 4B81A |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|---------------------------|--|--------------------|---|-------------|-------|-------------|-------|---|
| 60 | 242 | PLANNED | OCC_562 | GETCO | 400KV-SSP-DHULE-MS-2 | D | Maintenance work. Auto reclose of 400 kV SSP - Dhule 1 will remain out | 5-Jan-23 | 8:00 | 5-Jan-23 | 18:00 | Non auto reclose code for 400KV SSP Dhule No 1 |
| 61 | 243 | PLANNED | OCC_562 | MSLDC_OUTAGE | LONIKHAND-II - 400KV - BUS 2 | D | Diagnostic testing and Maintenance | 5-Jan-23 | 08:00 | 5-Jan-23 | 18:00 | - |
| 62 | 244 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-PUSAD-1 | D | For routine maintenance work. | 5-Jan-23 | 08:00 | 5-Jan-23 | 18:00 | - |
| 63 | 246 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV AKOLA (MSETCL) BUS-2 | D | Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators at Akola (MSETCL) station. | 5-Jan-23 | 8:00 | 5-Jan-23 | 18:00 | - |
| 64 | 256 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-WARDHA-CHANDRAPU-II-2 | D | Line CT, CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work . | 5-Jan-23 | 09:00 | 5-Jan-23 | 17:00 | Load manage on 400KV Chandrapur 2 Ckt 1, parallel ckt |
| 65 | 271 | PLANNED | OCC_562 | MSLDC_OUTAGE | CHANDRAPU-II - 400KV - BUS 1 | D | Diagnostic testing and allied bay maintenance work | 5-Jan-23 | 09:00 | 5-Jan-23 | 18:00 | Diagnostic testing and allied bay maintenance work |
| 66 | 272 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-PARLI-M-KARIAT-2 | D | (1) Reactor testing work. (2) Bay maintenance work. | 5-Jan-23 | 09:00 | 5-Jan-23 | 18:00 | - |
| 67 | 273 | PLANNED | OCC_562 | MP_SLDC | 220KV-PANDURNA-KALMESHWAR-1 | D | FOR LINE MAINTENANCE WORK | 5/Jan/23 | 9:00 | 5/Jan/23 | 18:00 | - |
| 68 | 284 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARIAT-LONIKHAND-II-1 | D | Cold line washing of insulator strings | 5-Jan-23 | 08:00 | 7-Jan-23 | 18:00 | Chemical cleaning of insulators is necessary in view of sugarcane harvesting season and last year tripping scenario |
| 69 | 285 | PLANNED | OCC_562 | WTPL | 400KV-AURANGABAD-M (WALLUJ)-PUNE-GIS-1 | D | On line isolator replacement. | 5-Jan-23 | 9:00 | 11-Jan-23 | 18:00 | AR to be disable |
| 70 | 308 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV AKOLA (MSETCL) BUS-2 | D | Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators at Akola (MSETCL) station. | 6-Jan-23 | 8:00 | 6-Jan-23 | 18:00 | - |
| 71 | 311 | PLANNED | OCC_562 | MEGPTCL | KORADI-III - 765KV B/R 1 | D | For Reactor changeover Activity as per CEA guideline B- Ph reactor taken into service in place of Spare Reactor. | 6-Jan-23 | 09:00 | 6-Jan-23 | 14:00 | Reactor outage Required. (Discharged on 21.02.2017 as spare was taking into service in place of B-Ph) |
| 72 | 314 | PLANNED | OCC_562 | POWERGRID_WR2 | 220KV-BOISAR-BOISAR-M-3 | D | AMP WORKS OF LTE EQUIPMENT. LINE OUTAGE IS REQUIRED. | 06-Jan-2023 | 9:00 | 06-Jan-2023 | 17:30 | PG-WR2-BOISAR |
| 73 | 323 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-KHARGHAR-PUNE-PG-1 | D | For AMP WORK | 6-Jan-23 | 9:00 | 6-Jan-23 | 18:00 | - |
| 74 | 333 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY OF 220KV-BOISAR-BOISAR-M-3 AND BOISAR - 220KV - BUS 1 @BOISAR - 220KV at BOISAR - 220KV | C | CB Overhauling Work by shifting the line on TBC. | 6-Jan-23 | 09:00 | 7-Jan-23 | 17:00 | BOISAR II - BOISAR (PG) CKT - 3 will be in service through the TBC. |
| 75 | 334 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-DHULE-MS-BABLESHWAR-1 | D | Online PID work | 6-Jan-23 | 09:00 | 7-Jan-23 | 17:00 | Only A/R out of service required |
| 76 | 335 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-DHULE-MS-BABLESHWAR-2 | D | on line PID work | 6-Jan-23 | 09:00 | 7-Jan-23 | 17:00 | Only A/R switch required out of service |
| 77 | 340 | PLANNED | OCC_562 | MSLDC_OUTAGE | BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV | C | Bus Maintenance work and for replacement of Damaged Bus conductor | 6-Jan-23 | 08:00 | 8-Jan-23 | 18:00 | To avoid breaking of Bus conductor and to avoid Bus fault |
| 78 | 341 | PLANNED | OCC_562 | MSLDC_OUTAGE | KHARGHAR - 400KV - BUS 2 | D | Bus Maintenance Work and for replacement of Damaged Bus conductor | 6-Jan-23 | 08:00 | 8-Jan-23 | 18:00 | All Lines & ICT's will be on A bus, Load will be shifted Via TBC |
| 79 | 342 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARIAT-LONIKHAND-II-1 | D | PID Testing work | 6-Jan-23 | 08:00 | 10-Jan-23 | 18:00 | Line will be in service |
| 80 | 343 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-BOISAR-BOISAR-M-3 | D | Bay Maintenance Work | 06-Jan-2023 | 9:00 | 06-Jan-2023 | 17:30 | Bay Maintenance Work |
| 81 | 344 | PLANNED | OCC_562 | MEGPTCL | MAIN BAY - 765KV-AKOLA (2)-EKTUNI-1 L/R at EKTUNI - 765KV | D | Taking Spare line Reactor in Service in place of Y-ph Reactor at Ektuni as per CEA guideline | 7-Jan-23 | 09:30 | 7-Jan-23 | 15:30 | Non-Switchable Reactor at Ektuni.Hence line outage required for change over. (Discharged on 25.07.2022 as spare was taking into service in place of Y-Ph) |
| 82 | 345 | PLANNED | OCC_562 | MEGPTCL | 765KV-AKOLA (2)-EKTUNI-2 | D | Taking Spare line Reactor in Service in place of Y-ph Reactor at Ektuni as per CEA guideline | 7-Jan-23 | 09:30 | 7-Jan-23 | 15:30 | Non-Switchable Reactor at Ektuni.Hence line outage required for change over. (Discharged on 25.07.2022 as spare was taking into service in place of Y-Ph) |
| 83 | 349 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-2 | D | 1) Bay Maint works 2) MTAMC work 3) Diagnostic Testing work 4) Replacement of C Bus PG isolator under LES scheme | 7-Jan-23 | 09:00 | 7-Jan-23 | 20:00 | Weather condition should be clear |
| 84 | 359 | PLANNED | OCC_562 | POWERGRID_WR2 | 220KV-BOISAR-BORIVALI-1 | D | AMP WORKS OF LTE EQUIPMENT. LINE OUTAGE IS REQUIRED. | 07-Jan-2023 | 9:00 | 07-Jan-2023 | 17:30 | PG-WR2-BOISAR |
| 85 | 369 | PLANNED | OCC_562 | MEGPTCL | AKOLA (2) - 765KV B/R 1 | D | Taking Y-ph Reactor in Service in place of Spare Reactor as per CEA guideline | 7-Jan-23 | 09:30 | 7-Jan-23 | 15:30 | Reactor outage Required. (Discharged on 13.11.2017 as spare was taking into service in place of Y-Ph) |
| 86 | 376 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-1 | D | Chemical Cleaning of Insulator string and Routine Line maintenance work, CB Timing DCRM and Quarterly Bay Maintenance Work. | 7-Jan-23 | 08:00 | 8-Jan-23 | 18:00 | 400KV Padghe I will be in in service |
| 87 | 377 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KHARGHAR-PUNE-PG-1 | D | PID scanning of insulator strings | 7-Jan-23 | 08:00 | 9-Jan-23 | 18:00 | - |
| 88 | 380 | PLANNED | OCC_562 | POWERGRID_WR1 | 765KV-PUNE-GIS-SOLAPUR-1 | D | For Spare Reactor Changeover | 8-Jan-23 | 9:00 | 8-Jan-23 | 14:00 | - |
| 89 | 381 | PLANNED | OCC_562 | POWERGRID_WR1 | 765KV-PUNE-PG-SOLAPUR-1 L/R@ PUNE-PG - 765KV | D | For Spare Reactor Changeover | 8-Jan-23 | 9:00 | 8-Jan-23 | 14:00 | For Spare Reactor Changeover |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | To | Remarks | |
|--------|-------------|--------------|------------|---------------------------|--|--------------------|--|-------------|-------|-------------|---------|--|
| 90 | 385 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-BOISAR-BOISAR-M-1 | D | Bay Maintenance Work | 8-Jan-23 | 07:00 | 8-Jan-23 | 17:00 | Bay Maintenance Work |
| 91 | 387 | PLANNED | OCC_562 | MSLDC_OUTAGE | BUS COUPLER BAY OF NAGOTHANE - 400KV - BUS 1 AND NAGOTHANE - 400KV - BUS 2 @NAGOTHANE - 400KV at NAGOTHANE - 400KV | D | Regular Maint work and Dignostic testing work | 8-Jan-23 | 08:00 | 8-Jan-23 | 17:00 | nil |
| 92 | 388 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 220KV-FUTURE AND WARDHA - 220KV - BUS 1 at Wardha - 220KV | D | Amp work of 209bay. 400kv ICT-3, 220kv side to be shifted to TBC bay. | 8-Jan-23 | 8:00 | 8-Jan-23 | 18:00 | 209 |
| 93 | 391 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KALWA-PADGHE-1 | D | 1) Bay Maint works 2) MTAMC work 3) Diagnostic Testing work 4) Replacement of C Bus PG Isolator under LES scheme | 8-Jan-23 | 09:00 | 8-Jan-23 | 20:00 | Weather condition should be clear |
| 94 | 393 | PLANNED | OCC_562 | MEGPTCL | MAIN BAY OF AKOLA (2) - 765KV B/R 1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV | D | OEM Inspection of CB | 8-Jan-23 | 09:30 | 9-Jan-23 | 18:00 | OEM Inspection of CB |
| 95 | 395 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-KORADI-SATPURA-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV | C | Overhauling of Sami Line CGL CB at Koradi SS, Line to be shifted on TBC for 4 days. | 8-Jan-23 | 8:00 | 12-Jan-23 | 18:00 | SRN |
| 96 | 396 | PLANNED | OCC_562 | POWERGRID_WR2 | 220KV-BOISAR-BOISAR-M-1 | D | AMP WORKS OF LTE EQUIPMENT. LINE OUTAGE IS REQUIRED. | 8-Jan-23 | 07:00 | 8-Jan-23 | 17:00 | PG-WR2-BOISAR |
| 97 | 399 | PLANNED | OCC_562 | POWERGRID_WR1 | TIE BAY - 400KV-WARDHA-KORADI-II-1 AND 400KV-RAIPUR-WARDHA-1 at Wardha - 400KV | C | Isolator upgradation work of 41489B, 41589R, 41589 Rph FSC Isolators & By Pass Isolator and 41589 Bph FSC Isolators & By Pass Isolator under substation package 5511 (Construction outage) | 9-Jan-23 | 7:00 | 15-Jan-23 | 20:00 | |
| 98 | 400 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-WARDHA-AKOLA-2 | D | Replacement of BHEL insulators from Gantries in Switchyard with CLR insulators at Akola (MSETCL) station. | 9-Jan-23 | 8:00 | 9-Jan-23 | 18:00 | 411L |
| 99 | 403 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-EKTUNI-BABLESHWAR-1 | D | CT Tan D, LBB & MTAMC work, Quarterly Bay Maintenance Work. | 9-Jan-23 | 09:00 | 9-Jan-23 | 17:00 | 400kv Ektuni ckt-ii,400kv Bhusawal,400kv Aurangabad and Dhule I&II will be in service |
| 100 | 408 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV/220KV SOLAPUR-ICT-3 AND SOLAPUR - 220KV - BUS 1 at Solapur - 220KV | D | Bay AMP works Note : 400/220KV ICT#3 shall be in service via TBC | 9-Jan-23 | 7:00 | 9-Jan-23 | 18:00 | |
| 101 | 420 | PLANNED | OCC_562 | POWERGRID_WR1 | WARORA-PG - 400KV - BUS 1 | D | FOR 400 KV BUS-1 AMP WORK | 9-Jan-23 | 8:30 | 9-Jan-23 | 18:00 | |
| 102 | 421 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-BADNERA-1 | D | 1. For Replacement of Flashover Discs. 2. For Diagnostic Testing of Line Bay | 9-Jan-23 | 09:00 | 9-Jan-23 | 17:00 | |
| 103 | 431 | PLANNED | OCC_562 | POWERGRID_WR2 | 400KV-KHANDWA-DHULE-MS-2 | D | Line Isolator arm retrofitting work and line amp works. A/R OFF OF CKT # 1 IS REQUIRED AND DIA TO BE KEPT OPEN AT BOTH ENDS. | 09-Jan-2023 | 9:00 | 09-Jan-2023 | 18:00 | PG-WR2-KHANDWA |
| 104 | 433 | PLANNED | OCC_562 | MEGPTCL | AKOLA (2) - 765KV - BUS 1 | D | Annual maintenance of Bus-1 Equipments | 9-Jan-23 | 09:00 | 9-Jan-23 | 18:00 | Annual maintenance of Bus-1 Equipments |
| 105 | 436 | PLANNED | OCC_562 | POWERGRID_WR1 | 220KV-PUNE-PG-CHAKAN-1 | D | For AMP WORK | 9-Jan-23 | 9:00 | 9-Jan-23 | 18:00 | |
| 106 | 442 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY - 400KV-KORADI-III-KORADI-III-2 AND KORADI-II - 400KV - BUS 2 at KORADI-II - 400KV | D | Diagnostic Testing of CB and routine bay maintenance work | 9-Jan-23 | 10:00 | 9-Jan-23 | 17:00 | 400kv Koradi-II -Koradi-III Ckt2 will remain in service through Tie bay 405 |
| 107 | 448 | PLANNED | OCC_562 | POWERGRID_WR1 | 220KV-TALANGADE(MS)-CHIKKODI-II-1 | D | For Reconductoring work of Kolhapur(PG)-Kolhapur(MSETCL)#1 (Crossing 64-65) | 9-Jan-23 | 7:00 | 10-Jan-23 | 18:00 | Crossing 64-65 |
| 108 | 449 | PLANNED | OCC_562 | POWERGRID_WR1 | 220KV-MUDSHINGI-CHIKKODI-II-1 | D | For Reconductoring work of Kolhapur(PG)-Kolhapur(MSETCL)#1 (Crossing 64-65) | 9-Jan-23 | 7:00 | 10-Jan-23 | 18:00 | Crossing 64-65 |
| 109 | 452 | PLANNED | OCC_562 | MSLDC_OUTAGE | KHARGHAR - 400KV - TRANSFER BUS 1(ELEMENT NOT FOUND) | C | 400KV CB mechanism Overhauling work | 9-Jan-23 | 08:00 | 11-Jan-23 | 18:00 | Healthiness of CB Mechanism |
| 110 | 453 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-LONIKHAND-JEJURI-1 | C | O/H & Servicing of 29C PG Isolator & Replacement of PGI mechanism box. | 9-Jan-23 | 08:00 | 11-Jan-23 | 18:00 | - |
| 111 | 456 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-TARAPUR 1&2-BORIVALI-1 | D | Scheme work of replacement of rusted Hardware/earthwire & conductor and Routine maintenance work. | 9-Jan-23 | 07:00 | 12-Jan-23 | 17:00 | Scheme work of replacement of rusted Hardware/earthwire & conductor and Routine maintenance work. |
| 112 | 457 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-PARLI-PARLI NEW-1 | C | Conintgency Bypass works of old Parli SS under WRES-XXX. Ckt-2 A/R in N/A | 09/Jan/2023 | 7:00 | 11/Jan/2023 | 18:00 | |
| 113 | 458 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-PARLI-M-PARLI-2 | C | Conintgency Bypass works of old Parli SS under WRES-XXX.Ckt-1 A/R in N/A | 09/Jan/2023 | 7:00 | 11/Jan/2023 | 18:00 | |
| 114 | 462 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-RGPPL-NEW KOYNA-2 | C | Dismantling of existing tilted old tower at location no 94 and erection of new tower (B-9ST) with foundation and stringing of conductor. | 9-Jan-23 | 08:00 | 9-Jan-23 | 18:00 | Planned outage |
| 115 | 471 | PLANNED | OCC_562 | RGPL | 400KV-RGPPL-NewKoyna Line-1 | D | Replacement of Surge Arrestor for all the three poles | 10-Jan-23 | 8:00 | 12-Jan-23 | 18:00 | |
| 116 | 474 | PLANNED | OCC_562 | POWERGRID_WR1 | BUS COUPLER BAY - SOLAPUR - 220KV - BUS 1 AND SOLAPUR - 220KV - BUS 2 at Solapur - 220KV | D | Bay AMP works | 10-Jan-23 | 7:00 | 10-Jan-23 | 18:00 | |
| 117 | 487 | PLANNED | OCC_562 | MSLDC_OUTAGE | WARORA - 400KV - BUS 2 | D | BUS CVT Tan Delta & Isolator Maintenance work thorough Agency. | 10-Jan-23 | 08:00 | 10-Jan-23 | 18:00 | 400KV C'pur 2 Ckt1, 400KV C'pur 2 Ckt 1, 400KV Future 1 & Future 2, 400KV ICT 1 remain Charged through respective Tie CB's connected on busbars. |
| 118 | 494 | PLANNED | OCC_562 | WRTS-1 | 400KV-PADGHE-PG-KUDUS-1 | D | B PH Line CT Replacement of Padghe Kudus Line 1 at Kudus SS. | 10-Jan-2023 | 9:00 | 10-Jan-2023 | 17:00 | 400 KV Padghe Kudus Line 1 will be out of service. |
| 119 | 509 | PLANNED | OCC_562 | POWERGRID_WR1 | 220KV-PUNE-PG-CHAKAN-2 | D | For AMP WORK | 10-Jan-23 | 9:00 | 10-Jan-23 | 18:00 | |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|---------------------------|---|--------------------|---|-------------|-------|-------------|-------|--|
| 120 | 510 | PLANNED | OCC_562 | MEGPTCL | 765KV/400KV KORADI-III-ICT-1 | D | For ICT changeover Activity as per CEA guideline Sapre Ph. ICT taken into service in place of R-Ph . | 10-Jan-23 | 09:00 | 10-Jan-23 | 19:00 | ICT Outage Required. (Common spare ICT not charged till date) |
| 121 | 515 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-WARDHA-M-1 | D | Routine line maintenance work | 10-Jan-23 | 10:00 | 10-Jan-23 | 18:00 | NA |
| 122 | 518 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-BHUGAON-1 | D | Routine line maintenance work | 10-Jan-23 | 08:00 | 11-Jan-23 | 18:00 | NA |
| 123 | 526 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KALWA-PUNE-PG-1 | D | PID scanning of insulator strings | 10-Jan-23 | 08:00 | 12-Jan-23 | 18:00 | - |
| 124 | 533 | PLANNED | OCC_562 | MSLDC_OUTAGE | KORADI - 400KV - BUS 2 | D | FOR ATTENDING 400KV KHAPERKHEDA CKT-2 BUS-2 PG ISOLATOR Y PHASE ROTARY PROBLEM BY AGENCY | 11-Jan-23 | 06:00 | 11-Jan-23 | 21:00 | FOR ATTENDING 400KV KHAPERKHEDA CKT-2 BUS-2 PG ISOLATOR Y PHASE ROTARY PROBLEM BUS-2 FEEDER REQUIRED TO BE SHIFTED ON BUS-1.Outages will be availed subject to weather |
| 125 | 547 | PLANNED | OCC_562 | MSLDC_OUTAGE | TIE BAY - 400KV-WARORA-CHANDRAPUR-II-2 AND 400KV-TIRODA-WARORA-1 at WARORA - 400KV | D | Routine maintenance and DCRM/CRM/CB Timings Testing works and Isolater maintenance work. | 11-Jan-23 | 09:00 | 11-Jan-23 | 17:00 | only Tie CB 412 is in OFF condition, respective ckt charged through its own main CB. |
| 126 | 550 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-PARLI-OSMANABAD-M-1 | D | LINE/ s/s maintenance | 11-Jan-23 | 09:00 | 11-Jan-23 | 17:30 | - |
| 127 | 561 | PLANNED | OCC_562 | MEGPTCL | AKOLA (2) - 765KV - BUS 2 | D | Annual maintenance of Bus-2 Equipments | 11-Jan-23 | 09:00 | 11-Jan-23 | 18:00 | Annual maintenance of Bus-2 Equipments |
| 128 | 562 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-PANDURNA-KALMESHWAR-1 | D | Routine Maintenance Work | 11-Jan-23 | 09:00 | 11-Jan-23 | 18:00 | - |
| 129 | 563 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-TILLARI-AMONA-1 | D | Annual maintenance work | 11-Jan-23 | 09:00 | 11-Jan-23 | 18:00 | The said work is very important |
| 130 | 564 | PLANNED | OCC_562 | MSLDC_OUTAGE | 132KV-PENCH-KANHAN-1 | D | Routine Maintenance. Work | 11-Jan-23 | 09:00 | 11-Jan-23 | 18:00 | - |
| 131 | 565 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-KALWA-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV | D | For AMP WORK | 11-Jan-23 | 9:00 | 11-Jan-23 | 18:00 | - |
| 132 | 571 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-BADNERA-1 | D | Routine line maintenance work | 11-Jan-23 | 10:00 | 11-Jan-23 | 18:00 | NA |
| 133 | 574 | PLANNED | OCC_562 | POWERGRID_WR1 | 220KV Talandage-Sawantwadi (D/C) | D | For Reconductoring work of Kolhapur(PG)-Kolhapur(MSETCL)#1 | 11-Jan-23 | 7:00 | 12-Jan-23 | 18:00 | U26-LI27 |
| 134 | 579 | PLANNED | OCC_562 | MSLDC_OUTAGE | CHANDRAPUR-GCR - 400KV - AUXILIARY BUS 1 | D | For PID testing work of Aux bus section-2 | 11-Jan-23 | 08:00 | 14-Jan-23 | 18:00 | 400KV STN TF-3 will be Shifted on TBC-2 in order to carry out PID testing work on Aux Bus (Section-2) |
| 135 | 580 | Planned | OCC_562 | MSLDC_OUTAGE | MAIN BAY OF 400KV/11.5KV CHANDRAPUR-GCR-ST-3 AND CHANDRAPUR-GCR - 400KV - BUS 1 @CHANDRAPUR-GCR - 400KV at CHANDRAPUR-GCR - 400KV | C | For PID testing work of Aux bus section-2 | 11-Jan-23 | 08:00 | 14-Jan-23 | 18:00 | 400KV STN TF-3 will be in service via TBC-2 in order to carry out PID testing work on Aux Bus (Section-2) |
| 136 | 581 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARJAT-LONIKHAND-II-2 | D | PID Testing work | 11-Jan-23 | 08:00 | 14-Jan-23 | 18:00 | Line will be in service |
| 137 | 585 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-PARLI-PARLI NEW-2 | C | Conintgency Bypass works of old Parli 5S under WRES-XXX. Ckt-1 A/R in N/A | 12/Jan/2023 | 7:00 | 13/Jan/2023 | 18:00 | - |
| 138 | 586 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-PARLI-M-PARLI-1 | C | Conintgency Bypass works of old Parli 5S under WRES-XXX. Ckt-2 A/R in N/A | 12/Jan/2023 | 7:00 | 13/Jan/2023 | 18:00 | - |
| 139 | 592 | PLANNED | OCC_562 | POWERGRID_WR1 | SOLAPUR - 220KV - BUS 2 | D | 220KV Bus#2 AMP Works Note1: Before shutdown, All the elements connected with 220KV Bus#2 shall be shifted to 220KV Bus#1 Note 2: Each element shall be shifted to TBC one by one for maintenance of Bus#2 Isolators. | 12-Jan-23 | 7:00 | 12-Jan-23 | 18:00 | - |
| 140 | 597 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARJAT-LONIKHAND-II-2 | D | Cold line washing of insulator strings | 12-Jan-23 | 08:00 | 12-Jan-23 | 18:00 | Chemical cleaning of insulators is necessary in view of sugarcane harvesting season and last year tripping scenario |
| 141 | 598 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARJAT-LONIKHAND-II-1 | D | Diagnostic testing and Maintenance | 12-Jan-23 | 08:00 | 12-Jan-23 | 18:00 | - |
| 142 | 599 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-PUSAD-1 | D | Routine line maintenance work | 12-Jan-23 | 08:00 | 12-Jan-23 | 18:00 | NA |
| 143 | 600 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-PUSAD-1 | D | Routine Maintenance work. | 12-Jan-23 | 08:00 | 12-Jan-23 | 18:00 | - |
| 144 | 610 | PLANNED | OCC_562 | WRTS-1 | 400KV-TARAPUR 3&4-PADGHE-2 | D | AMP of Line Equipment. | 12-Jan-2023 | 9:00 | 12-Jan-2023 | 17:00 | 400 KV Padghe Tarapur 2 will be out of service. |
| 145 | 611 | PLANNED | OCC_562 | POWERGRID_WR2 | 400KV-PADGHE-BOISAR-1 | D | AMP WORKS OF LTE EQUIPMENT. LINE OUTAGE IS REQUIRED. | 12-Jan-2023 | 9:00 | 12-Jan-2023 | 17:30 | PG-WR2-BOISAR |
| 146 | 623 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-SSP-DHULE-MS-1 | D | For Replacement of PID Suspecious Insulator Strings & Maintenance Work. | 12-Jan-23 | 09:00 | 12-Jan-23 | 18:00 | 400 KV DHL-SSNNL CKT 2 A/R switch will be put on Non Auto mode. |
| 147 | 624 | Planned | OCC_562 | MSLDC_OUTAGE | JEJURI - 400KV - BUS 2 | D | Annual testing & maintenance.(Bus 1 and Bus 2 bus bar protection will be out) | 12-Jan-23 | 09:00 | 12-Jan-23 | 18:00 | During outage Busbar testing will be carried out.During Testing 400 kv Main Bus 1 & 2 will be in service.Busbar protection will be out of service during testing.Distance protection Z4 will act as backup to busbar protection. |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|---------------------------|--|--------------------|---|-------------|-------|-------------|-------|--|
| 148 | 625 | PLANNED | OCC_562 | MSLDC_OUTAGE | JEJURI - 400KV - BUS 1 | D | Annual testing & maintenance.(Bus 1 and Bus 2 bus bar protection will be out) | 12-Jan-23 | 09:00 | 12-Jan-23 | 18:00 | During outage Busbar testing will be carried out.During Testing 400 kv Main Bus 1 & 2 will be in service.Busbar protection will be out of service during testing.Distance protection 24 will act as backup to busbar protection. |
| 149 | 628 | PLANNED | OCC_562 | POWERGRID_WR1 | 220KV-TALEGAON-PUNE-PG-1 | D | IPS Tube Clamp replacment work | 12-Jan-23 | 9:00 | 12-Jan-23 | 18:00 | |
| 150 | 633 | PLANNED | OCC_562 | MSLDC_OUTAGE | CHANDRAPUR SWITCHING STATION - 400KV - BUS 2 | D | Diagnostic testing and allied bay maintenance work | 12-Jan-23 | 10:00 | 12-Jan-23 | 18:00 | Diagnostic testing and allied bay maintenance work |
| 151 | 637 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-LONIKHAND-CHAKAN-1 | C | Retrofitting work of Main 1 distance relay under MTAMC project. O/H & Servicing of 29C PG Isolator & Replacement of PGI mechanism box. DT & Bay Maintenance Work. | 12-Jan-23 | 08:00 | 13-Jan-23 | 22:00 | - |
| 152 | 640 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-WARDHA-KORADI-II-1 | D | Isolator upgradation work of 41489A isolator under substation package SS11 (Construction outage) | 12-Jan-23 | 7:00 | 14-Jan-23 | 20:00 | |
| 153 | 641 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1B at Wardha - 400KV | D | Isolator upgradation work of 41489A isolator under substation package SS11 (Construction outage) | 12-Jan-23 | 7:00 | 14-Jan-23 | 20:00 | |
| 154 | 642 | PLANNED | OCC_562 | POWERGRID_WR1 | TIE BAY - 400KV-WARDHA-KORADI-II-1 AND 400KV-RAIPUR-WARDHA-1 at Wardha - 400KV | D | Isolator upgradation work of 41489A isolator under substation package SS11 (Construction outage) | 12-Jan-23 | 7:00 | 14-Jan-23 | 20:00 | |
| 155 | 643 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KOYNA STAGE IV-LONIKHAND-1 | C | Restinging of conductor Between Loc No 89-92 to achieve Ground clearance | 12-Jan-23 | 08:00 | 14-Jan-23 | 18:00 | Restinging of conductor Between Loc No 89-92 to achieve Ground clearance |
| 156 | 646 | PLANNED | OCC_562 | WRTS-1 | 400KV-PADGHE-BOISAR-1 | D | Relay Replacement of Bosar Line/AMC of Line Equipment | 12-Jan-2023 | 9:00 | 12-Jan-2023 | 17:30 | 400 KV Padghe Boisar LINE along with Line Reactor will be out of service. |
| 157 | 649 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - SEONI-PG - 400KV B/R 1 AND SEONI-PG - 400KV - BUS 1 at SEONI-PG - 400KV | D | AMP work@Seoni | 13-Jan-23 | 9:00 | 13-Jan-23 | 18:00 | |
| 158 | 650 | PLANNED | OCC_562 | POWERGRID/ODISHA | 400KV-JHARSUGUDA-RAIGARH-4 | D | TLA installation work at loc.no.- 362, 441, 492, 421 | 13/Jan/2023 | 7:00 | 13/Jan/2023 | 17:00 | |
| 159 | 651 | PLANNED | OCC_562 | POWERGRID/ODISHA | A/R of 400KV-JHARSUGUDA-RAIGARH-2 | D | For facilitating the SD of 400KV-JHARSUGUDA-RAIGARH-4 | 13/Jan/2023 | 7:00 | 13/Jan/2023 | 17:00 | |
| 160 | 652 | PLANNED | OCC_562 | POWERGRID_WR1 | SOLAPUR - 220KV - BUS 1 | D | 220KV Bus#1 AMP Works Note : Before shutdown , All the elements connected with 220kv Bus#1 shall be shifted to 220KV Bus#2 | 13-Jan-23 | 7:00 | 13-Jan-23 | 18:00 | |
| 161 | 653 | PLANNED | OCC_562 | POWERGRID_WR2 | 220KV-VAPI-MAGARWADA-2 | D | LTE AMP WORKS and line amp works.A/R OFF of ckt # 1 is required. | 13-Jan-2023 | 8:00 | 13-Jan-2023 | 17:30 | PG-WR2-VAPI |
| 162 | 654 | PLANNED | OCC_562 | POWERGRID_WR2 | 400KV/220KV BHUJ-ICT-7 | D | AMP OF 400KV/220KV BHUJ-ICT-7 AND CT OIL SAMPLING.Dia to be kept open. | 13-Jan-2023 | 8:00 | 13-Jan-2023 | 18:00 | PG-WR2-BHUJ P5 |
| 163 | 655 | PLANNED | OCC_562 | POWERGRID_WR2 | 400KV-KHANDWA-BETUL-2 | D | Line Outage for attending SD nature defect.A/R OFF OF CKT # 1 IS REQUIRED AND DIA TO BE KEPT OPEN AT BOTH ENDS. | 13-Jan-2023 | 8:00 | 13-Jan-2023 | 18:00 | PG-WR2-KHANDWA |
| 164 | 656 | PLANNED | OCC_562 | MSLDC_OUTAGE | WARORA - 400KV - BUS 1 | D | Isolator Maintenance work thorough Agency. | 13-Jan-23 | 08:00 | 13-Jan-23 | 18:00 | 400KV PGCIL LINE, 400KV IEP/L LINE, 400KV ADANI-1 & ADANI-2 remain Charged through respective Tie CB's connected on MAIN BUS 2 and 432ANVAR Bus Reactor is off. |
| 165 | 657 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-PUSAD-1 | D | Routine line maintainance work | 13-Jan-23 | 08:00 | 13-Jan-23 | 18:00 | NA |
| 166 | 658 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - RAIGARH - 400KV B/R 2 AND RAIGARH - 400KV - BUS 2 at Raigarh - 400KV | D | AMP | 13-Jan-23 | 8:00 | 13-Jan-23 | 18:00 | Annual Maintenance Plan |
| 167 | 659 | PLANNED | OCC_562 | POWERGRID_WR1 | 765KV-GADARWARA-WARORA-PG-2 | D | FOR Line Bay equipment AMP, Line maintenance and Relay testing works. Diameter to be kept open. A/R Ckt-1 to be kept in Non-Auto mode. | 13-Jan-23 | 8:00 | 13-Jan-23 | 18:00 | |
| 168 | 660 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 765KV/400KV TAMNAR-ICT-4 AND TAMNAR - 400KV - BUS 3 at TAMNAR - 400KV | D | AMP Work | 13-Jan-2023 | 8:30 | 13-Jan-2023 | 17:30 | AMP Work |
| 169 | 661 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-PARLI-PARLI NEW-1 AND PARLI - 400KV - BUS 2 at PARLI - 400KV | D | AMP OF BAY | 13-Jan-2023 | 8:30 | 13-Jan-2023 | ##### | AMP OF BAY |
| 170 | 662 | PLANNED | OCC_562 | POWERGRID_WR2 | 400KV-VAPI-BOISAR-1 | D | AMP WORKS, DIA TO BE KEPT OPEN AT BOTH ENDS. | 13-Jan-2023 | 9:00 | 13-Jan-2023 | 17:30 | PG-WR2-BOISAR |
| 171 | 663 | PLANNED | OCC_562 | POWERGRID_WR2 | TIE BAY - 765KV-SATNA-VINDHYACHAL(PS)-1 AND 765KV-SATNA-GWALIOR-2 at SATNA - 765KV | D | AMP | 13-Jan-2023 | 9:00 | 13-Jan-2023 | 18:00 | PG-WR2-SATNA |
| 172 | 664 | PLANNED | OCC_562 | POWERGRID_WR2 | 765KV-SASAN-VINDHYACHAL(PS)-2 | D | Line Terminal equipment AMP work at Vindhychal(PS) | 13-Jan-2023 | 9:00 | 13-Jan-2023 | 18:00 | PG-WR2-VINDHYACHAL P5 |
| 173 | 665 | PLANNED | OCC_562 | POWERGRID_WR2 | TIE BAY - 765KV-BANASKANTHA-CHITTORGARH-1 AND 765KV/400KV BANASKANTHA-ICT-2 at Banaskantha - 765KV | D | Yearly AMP | 13-Jan-2023 | 9:00 | 13-Jan-2023 | 18:00 | PG-WR2-BANASKANTHA |
| 174 | 666 | PLANNED | OCC_562 | POWERGRID_WR2 | MAIN BAY - 400KV/220KV BACHAU-ICT-2 AND BACHAU - 400KV - BUS 2 at BACHAU - 400KV | D | Bay AMP | 13-Jan-2023 | 9:00 | 13-Jan-2023 | 18:00 | PG-WR2-BHACHAU |
| 175 | 667 | PLANNED | OCC_562 | POWERGRID_WR2 | MAIN BAY - 400KV-INDORE-KHANDWA-1 AND KHANDWA - 400KV - BUS 1 at KHANDWA - 400KV | D | Annual Maintenance | 13-Jan-2023 | 9:00 | 13-Jan-2023 | 18:00 | PG-WR2-KHANDWA |
| 176 | 668 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-SSP-DHULE-MS-1 | D | For Replacement of PID Suspecious Insulator Strings & Maintenance Work. | 13-Jan-23 | 09:00 | 13-Jan-23 | 18:00 | 400 KV DHL-SSNNL CKT 2 A/R switch will be put on Non Auto mode. |
| 177 | 669 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-PUNE-GIS-PARLI-1 | D | For AMP | 13-Jan-23 | 9:00 | 13-Jan-23 | 18:00 | For attending TLM defects, 400 Kv Pune-Aurangabad Ckt#2 is to be required in Non auto mode. |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|-----------------------------|---|--------------------|--|-------------|-------|-------------|-------|--|
| 178 | 670 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 220KV-RAIPUR-BHATAPARA-CG-1 AND RAIPUR - 220KV - BUS 1 at RAIPUR - 220KV | D | AMP at Raipur SS | 13-Jan-2023 | 9:00 | 13-Jan-2023 | 18:00 | AMP at Raipur SS |
| 179 | 671 | PLANNED | OCC_562 | POWERGRID_WR2 | KALA - 400KV B/R 1 | D | AMP WORKS. DIA TO BE KEPT OPEN. | 13-Jan-2023 | 9:00 | 13-Jan-2023 | 19:00 | PG-WR2-KALA |
| 180 | 672 | PLANNED | OCC_562 | POWERGRID_WR2 | JABALPUR-PS - 765KV - BUS 2 | D | FOR AMP WORK | 13-Jan-2023 | 9:30 | 13-Jan-2023 | 15:30 | PG-WR2-JABALPUR PS |
| 181 | 673 | PLANNED | OCC_562 | SLDC.CG | 220KV-RAIPUR-DOMA-2 | D | Post Monsoon Maintenance | 13/Jan/2023 | 10:00 | 13/Jan/2023 | 16:00 | -- |
| 182 | 674 | PLANNED | OCC_562 | POWERGRID_WR2 | RAIGARH - 400KV - BUS 1 | D | BUS MAINTENANCE | 13-Jan-2023 | 10:00 | 13-Jan-2023 | 17:00 | PG-WR2-RAIGARH |
| 183 | 675 | PLANNED | OCC_562 | POWERGRID_WR2 | MAIN BAY - 400KV-INDORE-MP-ASOJ-2 AND INDORE-MP - 400KV - BUS 1 at INDORE-MP - 400KV | D | AMP WORK | 13-Jan-2023 | 10:00 | 13-Jan-2023 | 18:00 | PG-WR2-INDORE |
| 184 | 676 | PLANNED | OCC_562 | POWERGRID_WR1 | 110KV Mudshingi-Dudhganga (S/C) | D | For Reconductoring work of Kolhapur(PG)-Kolhapur(MSETCL)#1 | 13-Jan-23 | 7:00 | 14-Jan-23 | 18:00 | U16-U17 |
| 185 | 677 | PLANNED | OCC_562 | MSLDC_OUTAGE | BOISAR-M - 220KV - BUS 1 | C | Bus Isolator R/M & R/M Work. | 13-Jan-23 | 07:00 | 14-Jan-23 | 20:00 | Bus Isolator R/M & R/M Work. |
| 186 | 678 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-DHULE-MS-BABLESHWAR-1 | D | on line PID work | 13-Jan-23 | 09:00 | 14-Jan-23 | 17:00 | only A/R with required out of service |
| 187 | 679 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-DHULE-MS-BABLESHWAR-2 | D | On line PID work | 13-Jan-23 | 09:00 | 14-Jan-23 | 17:00 | A/R switch will be on non auto mode |
| 188 | 680 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 765KV-RAIGARH-PS-TAMNAR-1 AND RAIGARH-PS - 765KV - BUS 2 at RAIGARH-PS - 765KV | C | CT Cleaning | 13-Jan-23 | 9:00 | 14-Jan-23 | 17:30 | CT Cleaning |
| 189 | 681 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY OF 400KV/220KV KHARGHAR-ICT-3 AND KHARGHAR - 400KV - BUS 1 @KHARGHAR - 400KV at KHARGHAR - 400KV | C | 400KV CB mechanism Overhauling work | 13-Jan-23 | 08:00 | 15-Jan-23 | 18:00 | ICT will be in service via TBC |
| 190 | 682 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-BHILAI-KORADI-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV | C | Overhauling of Bhilai Line CGL CB at Koradi SS, Line to be shifted on TBC for 4 days. | 13-Jan-23 | 8:00 | 17-Jan-23 | 18:00 | BHI |
| 191 | 683 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-WARDHA-WARORA-PG-2 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV | C | Overhauling of 409 CGL CB | 13-Jan-23 | 8:00 | 18-Jan-23 | 18:00 | 409 |
| 192 | 684 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY - 400KV/220KV PADGHE-ICT-3 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV | C | 315 MVA ICT-03 on TBC FOR CB Replacement work under LES scheme | 13-Jan-23 | 08:00 | 22-Jan-23 | 23:00 | 1) Weather condition should be clear |
| 193 | 685 | PLANNED | OCC_562 | MSLDC_OUTAGE | PADGHE - 400KV - BUS 2 | C | B bus PG Isolator Replacement of 315 MVA ICT-3. All other elements on B bus in service. | 13-Jan-23 | 10:00 | 22-Jan-23 | 16:00 | 1)Hot line team will be present on site 2) Weather condition should be clear |
| 194 | 686 | PLANNED | OCC_562 | POWERGRID_WR2 | BOISAR-M - 220KV - BUS 1 | D | AMP WORKS | 13-Jan-23 | 9:00 | 13-Jan-23 | 17:30 | PG-WR2-BOISAR |
| 195 | 687 | PLANNED | OCC_562 | POWERGRID/ODISHA/JHARSUGUDA | 400KV-JHARSUGUDA-RAIGARH-4 | D | TLA installation work at loc.no - 362, 441, 492, 421 | 13-Jan-2023 | 7:00 | 13-Jan-2023 | 17:00 | |
| 196 | 688 | PLANNED | OCC_562 | POWERGRID/ODISHA/JHARSUGUDA | A/R of 400KV-JHARSUGUDA-RAIGARH-2 | D | For facilitating the SD of 400KV-JHARSUGUDA-RAIGARH-4 | 13-Jan-2023 | 7:00 | 13-Jan-2023 | 17:00 | |
| 197 | 689 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV/220KV SOLAPUR-ICT-1 AND SOLAPUR - 220KV - BUS 1 at Solapur - 220KV | D | Bay AMP works Note : 400/220KV ICT#1 shall be in service via TBC | 14-Jan-23 | 7:00 | 14-Jan-23 | 18:00 | |
| 198 | 690 | PLANNED | OCC_562 | POWERGRID_WR1 | 765KV-DHULE-AURANGABAD-1 | D | AMP Work | 14-Jan-23 | 8:00 | 14-Jan-23 | 16:00 | |
| 199 | 691 | PLANNED | OCC_562 | POWERGRID_WR_1 | MAIN BAY - 765KV-DHARAMJYAGARH-JHARSUGUDA-2 AND DHARAMJYAGARH - 765KV - BUS 4 at DHARAMJYAGARH - 765KV | D | For AMP works | 14-Jan-23 | 8:00 | 14-Jan-23 | 18:00 | |
| 200 | 692 | PLANNED | OCC_562 | POWERGRID_WR2 | TIE BAY - 765KV-SASAN-VINDHYACHAL(PS)-1 AND 765KV/400KV VINDHYACHAL(PS)-ICT-1 at Vindhyachal(PS) - 765KV | D | Bay AMP work at Vindhyachal(PS) | 14-Jan-2023 | 9:00 | 14-Jan-2023 | 18:00 | PG-WR2-VINDHYACHAL PS |
| 201 | 693 | PLANNED | OCC_562 | POWERGRID_WR1 | TIE BAY - 400KV/220KV RAIPUR-ICT-1 AND RAIPUR - 400KV B/R 1 at RAIPUR - 400KV | D | AMP at Raipur SS | 14-Jan-2023 | 9:00 | 14-Jan-2023 | 18:00 | AMP at Raipur SS |
| 202 | 694 | PLANNED | OCC_562 | POWERGRID_NR3 | 765KV-VINDHYACHAL(PS)-VARANASI-1 | D | Bay and Line Reactor AMP Work at Varanasi end | 14-Jan-2023 | 9:30 | 14-Jan-2023 | 18:00 | PG-WR2-RTAMC NR3 |
| 203 | 695 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-2 | D | TO ATTEND DEFECTS IDENTIFIED IN MONKEY PATROLLING UNDER PADGHE AND JUNNER SD:-1. TO FIX REPAIR SLEEVE AT BROKEN CONDUCTOR STRANDS.2. REPLACEMENT OF BROKEN AND FLASHOVER DISC INSULATORS STRINGS.3. CHEMICAL AND COLD WASHING OF DUST/BIRD SHIT POLLUTED INSULATOR STRING.4. FIX OF BIRD GUARD AT INSULATORS STRING AT BIRD SHIT LOCATIONS.5. FIXING OF MISSING/DAMAGED HARDWARE.6. TIGHTENING LOOSE OF NUT BOLTS OF CONDUCTOR JUMPER AND EARTH WIRE HARDWARE. | 14-Jan-23 | 08:00 | 15-Jan-23 | 18:00 | 400KV Babhaleshwar-Padghe Ckt -1 will be available. THIS OUTAGE IS REQUIRED FOR UNINTERRUPTED OPERATION IN SUMMER PEAK LOAD. |
| 204 | 696 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KALWA-PADGHE-2 | C | Removal of Tapping of 400KV Kalwa-Padghe-2 line on 400KV Kharghar-Talegaon Line to normalise the Network. | 14-Jan-23 | 22:00 | 15-Jan-23 | 08:00 | 400KV Kalwa-Padghe@ line tapping was carried out on 400KV Kharghar-Talegaon line in Dec-2022 to form Temporary 400KV Kharghar-Padghe-Talegaon Line for HTLS of 400KV |
| 205 | 697 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KHARGHAR-PUNE-PG-1 | C | Removal of Tapping of 400KV Kalwa-Padghe-II line on 400KV Kharghar-Talegaon Line to normalise the network. | 14-Jan-23 | 22:00 | 15-Jan-23 | 08:00 | 400KV Kalwa-Padghe@ line tapping was carried out on 400KV Kharghar-Talegaon line in Dec-2022 to form |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|---------------------------|---|--------------------|--|-------------|-------|-------------|-------|---|
| 206 | 698 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-2 | D | For Carrying PID Work | 15-Jan-23 | 09:00 | 31-Jan-23 | 18:00 | 400KV Babhaleshwar-Padghe Ckt -1 will be available. |
| 207 | 700 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-BOISAR-NALASOPARA-1 | D | Bay Maintenance Work | 15-Jan-23 | 07:00 | 15-Jan-23 | 17:00 | Bay Maintenance Work |
| 208 | 701 | PLANNED | OCC_562 | POWERGRID_WR1 | 220KV-MAPUSA-AMONA-1 | D | AMP Works | 15-Jan-23 | 7:00 | 15-Jan-23 | 18:00 | |
| 209 | 702 | PLANNED | OCC_562 | MSLDC_OUTAGE | NAGOTHANE - 400KV - BUS 1 | D | Regular Maint work and Dignostic testing work | 15-Jan-23 | 08:00 | 15-Jan-23 | 18:00 | nil |
| 210 | 703 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARJAT-LONIKHAND-II-2 | D | Cold line washing of insulator strings | 15-Jan-23 | 08:00 | 15-Jan-23 | 18:00 | Chemical cleaning of insulators is necessary in view of sugarcane harvesting season and last year tripping scenario |
| 211 | 704 | PLANNED | OCC_562 | POWERGRID_WR1 | TIE BAY - 400KV-AKOLA-AURANGABAD-2 AND 400KV/220KV-AKOLA-ICT-2 at AKOLA - 400KV | D | AMP of 406 Bay at Akola | 15-Jan-23 | 8:00 | 15-Jan-23 | 18:00 | 406A |
| 212 | 705 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KALWA-PADGHE-2 | D | 1) Bay Maint work 2) MTAMC work 3) Diagnostic Testing work 4) | 15-Jan-23 | 09:00 | 15-Jan-23 | 20:00 | Weather condition should be clear |
| 213 | 706 | PLANNED | OCC_562 | MEGPTCL | MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV | D | OEM Inspection of CB | 15-Jan-23 | 09:00 | 16-Jan-23 | 18:00 | OEM Inspection of CB |
| 214 | 709 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-1 | D | Chemical Cleaning of Insulator string and Routine Line maintenance work | 15-Jan-23 | 08:00 | 15-Jan-23 | 18:00 | 400KV Padghe II will be in in service |
| 215 | 714 | PLANNED | OCC_562 | WRTS-1 | 765KV-PUNE-PADGHE-PG-1 | C | Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. | 16-Jan-2023 | 9:00 | 31-Jan-2023 | 18:00 | 765 KV PUNE PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE |
| 216 | 715 | PLANNED | OCC_562 | WRTS-1 | 765KV-AURANGABAD-PADGHE-PG-2 | C | Diversion of 765 KV Aurangabad Padghe Line for Nagpur Mumbai Samridhi Express Highway. | 16-Jan-2023 | 9:00 | 31-Jan-2023 | 18:00 | 765 KV AURANGABAD PADGHE LINE ALONG WITH LINE REACTOR WILL BE OUT OF SERVICE |
| 217 | 717 | PLANNED | OCC_562 | WTPL | 400KV-PUNE-GIS-PUNE-PG-1 | D | On line isolator replacement. | 16-Jan-23 | 9:00 | 31-Jan-23 | 18:00 | AR to be disable |
| 218 | 718 | PLANNED | OCC_562 | WTPL | 400KV-PUNE-GIS-PUNE-PG-2 | D | On line isolator replacement. | 16-Jan-23 | 9:00 | 31-Jan-23 | 18:00 | AR to be disable |
| 219 | 719 | PLANNED | OCC_562 | WTPL | 400KV-PUNE-GIS-PUNE-PG-3 | D | On line isolator replacement. | 16-Jan-23 | 9:00 | 31-Jan-23 | 18:00 | AR to be disable |
| 220 | 720 | PLANNED | OCC_562 | WTPL | 400KV-PUNE-GIS-PUNE-PG-4 | D | On line isolator replacement. | 16-Jan-23 | 9:00 | 31-Jan-23 | 18:00 | AR to be disable |
| 221 | 721 | PLANNED | OCC_562 | POWERGRID_WR1 | KOLHAPUR-MS - 400KV - BUS 1 | D | For stringing of jack bus and erection of PG isolator in bay augmentation work of Kolhapur(PG)-Kolhapur(MSETCL)#1 Bay at MSETCL, Talandage(Kolhapur) | 16-Jan-23 | 10:00 | 16-Jan-23 | 12:00 | Bus-1 |
| 222 | 722 | PLANNED | OCC_562 | POWERGRID_WR1 | KOLHAPUR-MS - 400KV - BUS 2 | D | For erection of jack bus and PG isolator in bay augmentation work of Kolhapur(PG)-Kolhapur(MSETCL)#1 Bay at MSETCL, Talandage(Kolhapur) | 16-Jan-23 | 14:00 | 16-Jan-23 | 16:00 | Bus-2 |
| 223 | 725 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-RGPPL-NAGOTHANE-1 | D | Dignostic testing work and Earthwire restringing work | 16-Jan-23 | 08:00 | 16-Jan-23 | 17:00 | NIL |
| 224 | 730 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV | D | AMP of 407 Bay at Akola | 16-Jan-23 | 8:00 | 16-Jan-23 | 18:00 | 407A |
| 225 | 735 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-BADNERA-1 | D | For Replacement of Flashover Disc by Hot Line Method. Shifting of auto reclose switch to non auto mode. | 16-Jan-23 | 09:00 | 16-Jan-23 | 17:00 | |
| 226 | 737 | PLANNED | OCC_562 | WRTS-1 | MAIN BAY OF 400KV-KUDUS-PADGHE-1 AND KUDUS - 400KV - BUS 2 @KUDUS - 400KV at KUDUS - 400KV | D | AMP of 415 Bay | 16-Jan-2023 | 9:00 | 16-Jan-2023 | 17:00 | 400 KV Padghe Kudus Line 1 will be in service through Tie Bay 414. |
| 227 | 738 | PLANNED | OCC_562 | POWERGRID_WR2 | MAIN BAY - 400KV-AURANGABAD-BOISAR-2 AND BOISAR - 400KV - BUS 1 at BOISAR - 400KV | D | AMP WORKS | 16-Jan-2023 | 9:00 | 16-Jan-2023 | 17:30 | PG-WR2-BOISAR |
| 228 | 745 | PLANNED | OCC_562 | MEGPTCL | MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV | D | Annual Maintenance of Bay equipment | 16-Jan-23 | 09:00 | 16-Jan-23 | 18:00 | Annual Maintenance of Bay equipment |
| 229 | 746 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-PARLI-M-PARLI-2 | D | (1) Relay testing work (2) Bay maintenance work. | 16-Jan-23 | 09:00 | 16-Jan-23 | 18:00 | - |
| 230 | 757 | PLANNED | OCC_562 | MSLDC_OUTAGE | KORADI - 400KV - BUS 1 | D | ON LINE PID TESTING WORK | 16-Jan-23 | 09:30 | 17-Jan-23 | 17:30 | Outages will be availed subject to weather conditions. |
| 231 | 759 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV/220KV KHARGHAR-ICT-1 ON TBC @ KHARGHAR (Element not found in Outage software) | C | 400KV CB mechanism Overhauling work | 16-Jan-23 | 08:00 | 18-Jan-23 | 18:00 | ICT-1 will be in service Via 400KV TBC |
| 232 | 760 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KOYNA STAGE IV-LONIKHAND-1 | C | O/H & Servicing of 29C PG Isolator & Replacement of PGI mechanism box. | 16-Jan-23 | 08:00 | 18-Jan-23 | 18:00 | - |
| 233 | 765 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARJAT-LONIKHAND-II-2 | D | PID Testing work | 16-Jan-23 | 08:00 | 20-Jan-23 | 18:00 | Line will be in service |
| 234 | 768 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KALWA-PUNE-PG-1 | D | PID Testing Auto-Reclose function to be out of service. | 16-Jan-23 | 09:00 | 21-Jan-23 | 18:00 | PID Testing Auto-Reclose function to be out of service. |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|---------------------------|---|--------------------|---|-------------|-------|-------------|-------|--|
| 235 | 773 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV/220KV PADGHE-ICT-4 | C | 1) MTAMC work 2) Bay Maint work 3) Replacement of B-PH Unit due to PD and increasing key gases presence of theme fault. 4) filtration of Y ph. unit 5) attending Oil leakage R & Y-ph. unit from various point. 6) If outage not approved for replacement, TBC charging permission required for four days for CB mechanism overhauling work on HV side | 16-Jan-23 | 00:28 | 26-Jan-23 | 23:59 | 1) Weather condition should be clear 2) if Outage not approved on 30Nov to 13 dec 22 |
| 236 | 779 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-CHANDRAPUR-BHADRAWATI-1 | D | For AMP works at GCR end | 17-Jan-2023 | 7:00 | 17-Jan-2023 | 18:00 | For AMP works at GCR end |
| 237 | 796 | PLANNED | OCC_562 | MEGPTCL | 765KV-AKOLA (2)-KORADI-III-1 | D | For Reactor changeover Activity as per CEA guideline B- Ph reactor taken into service in place of Spare Reactor. | 17-Jan-23 | 09:00 | 17-Jan-23 | 14:00 | 765KV-AKOLA (2)-KORADI-III-1 will remain in service without LR. (Discharged on 09.01.2020 as spare was taking into service in place of B-Ph) |
| 238 | 797 | PLANNED | OCC_562 | MEGPTCL | 765KV-AKOLA (2)-KORADI-III-1 L/R@ KORADI-III - 765KV | D | For Reactor changeover Activity as per CEA guideline B- Ph reactor taken into service in place of Spare Reactor. | 17-Jan-23 | 09:00 | 17-Jan-23 | 14:00 | 765KV-AKOLA (2)-KORADI-III-1 will remain in service without LR. (Discharged on 09.01.2020 as spare was taking into service in place of B-Ph) |
| 239 | 800 | PLANNED | OCC_562 | WRTS-1 | MAIN BAY OF 400KV-PADGHE-PG-KUDUS-2 AND KUDUS - 400KV - BUS 2 @KUDUS - 400KV at KUDUS - 400KV | D | AMP of 418 Bay | 17-Jan-2023 | 9:00 | 17-Jan-2023 | 17:00 | 400 KV Padghe Kudus Line 1 will be in service through Tie Bay 414. |
| 240 | 811 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-KHARGHAR-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV | D | For AMP WORK | 17-Jan-23 | 9:00 | 17-Jan-23 | 18:00 | |
| 241 | 823 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-KOLHAPUR GIS-Mapusa-2 | D | For Reconducting work of Kolhapur(PG)-Kolhapur(MSETCL)#1 | 17-Jan-23 | 7:00 | 24-Jan-23 | 18:00 | Multi ckt |
| 242 | 825 | PLANNED | OCC_562 | WKTL | 400KV-WARDHA-WARORA-PG-1 | D | 765KV Wraora Warangal T/L,Line (Construction) | 17-Jan-23 | 08:00 | 24-Jan-23 | 18:30 | Construction |
| 243 | 826 | PLANNED | OCC_562 | WKTL | 400KV-WARDHA-WARORA-PG-2 | D | 765KV Wraora Warangal T/L,Line (Construction) | 17-Jan-23 | 08:00 | 24-Jan-23 | 18:30 | Construction |
| 244 | 832 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-CHANDRAPUR-BHADRAWATI-2 | D | For AMP works at GCR end | 18-Jan-2023 | 7:00 | 18-Jan-2023 | 18:00 | For AMP works at GCR end |
| 245 | 834 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-RGPP-L-NAGOTHANE-2 | D | Jumper tightening and cold washing work | 18-Jan-23 | 08:00 | 18-Jan-23 | 17:00 | nil |
| 246 | 847 | PLANNED | OCC_562 | MSLDC_OUTAGE | BABLESHWAR - 400KV - BUS 1 | D | ZIV BUS BAR Testing(Allelements will be in service through Bus 1 and 2) | 18-Jan-23 | 08:00 | 18-Jan-23 | 20:00 | ZIV BUS BAR to be taken out of Service during the outage period Outage required for 400 KV ZIV BUS BAR |
| 247 | 848 | PLANNED | OCC_562 | MSLDC_OUTAGE | BABLESHWAR - 400KV - BUS 2 | D | ZIV BUS BAR Testing(Allelements will be in service through Bus 1 and 2) | 18-Jan-23 | 08:00 | 18-Jan-23 | 20:00 | ZIV BUS BAR to be taken out of Service during the outage period Outage required for 400 KV ZIV BUS BAR |
| 248 | 851 | PLANNED | OCC_562 | MSLDC_OUTAGE | TIE BAY OF 400KV-KALA-KUDUS-1 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV | D | Annual Maintenance of bays equipment & Diagnostics Testing Work | 18-Jan-23 | 09:00 | 18-Jan-23 | 17:00 | Simultaneously outage is required on Main Bay 404 kudas-kala ckt-1 @ Kudus |
| 249 | 852 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY - 400KV-KALA-KUDUS-1 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV | D | Annual Maintenance of bays equipment & Diagnostics Testing Work | 18-Jan-23 | 09:00 | 18-Jan-23 | 17:00 | Simultaneously outage is required on Tie Bay 405 of kudas-kala ckt-1 @ Kudus. |
| 250 | 853 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-WARORA-CHANDRAPU-II-1 | D | Relay testing work & routine maintenance work. | 18-Jan-23 | 09:00 | 18-Jan-23 | 17:00 | Load manage on 400KV Chandrapur 2 Ckt 2, parallel ckt |
| 251 | 854 | PLANNED | OCC_562 | MSLDC_OUTAGE | 132KV-DHARNI-NEPANAGAR-1 | D | "1. For Replacement of Flashover Discs. 2. For Diagnostic Testing of Line Bay." | 18-Jan-23 | 09:00 | 18-Jan-23 | 17:00 | - |
| 252 | 855 | PLANNED | OCC_562 | WRTS-1 | TIE BAY OF 400KV-PADGHE-PG-KUDUS-2 AND FUTURE @KUDUS - 400KV at KUDUS - 400KV | D | R PH CT Replacement of 417 Bay and Bay AMP at Kudus SS. | 18-Jan-2023 | 9:00 | 18-Jan-2023 | 17:00 | 400 KV Padghe Kudus Line 1 will be in service through Main Bay 415. |
| 253 | 858 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-PARLI-PARLI-M-2 | D | LINE/ s/s maintenance | 18-Jan-23 | 09:00 | 18-Jan-23 | 17:30 | - |
| 254 | 867 | PLANNED | OCC_562 | MSETCL | 220KV-MUDSHINGI-CHIKKODI-II-1 | D | Annual maintenance work | 18-Jan-23 | 09:00 | 18-Jan-23 | 18:00 | The said work is very important |
| 255 | 868 | PLANNED | OCC_562 | ATIL | TIRODA - 400KV B/R 1 | D | For bay equipment maintenance and testing work | 18-Jan-23 | 09:00 | 18-Jan-23 | 18:00 | BUS REACTOR OUTAGE |
| 256 | 871 | PLANNED | OCC_562 | POWERGRID_WR1 | KOLHAPUR-MS - 400KV B/R 2 | D | Bay AMP | 18-Jan-23 | 9:00 | 18-Jan-23 | 18:00 | Outage required on CB only. Bus reactor can be kept in service through TBC. |
| 257 | 872 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-LONIKHAND-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV | D | For AMP WORK | 18-Jan-23 | 9:00 | 18-Jan-23 | 18:00 | |
| 258 | 879 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-TALEGAON-PUNE-PG-2 | D | Half yearly maintenance | 18-Jan-23 | 10:00 | 18-Jan-23 | 18:00 | - |
| 259 | 886 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY - 400KV-KHARGHAR-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 2 at KHARGHAR - 400KV(ELEMENT NOT FOUND) | C | 400KV CB mechanism Overhauling work | 18-Jan-23 | 08:00 | 20-Jan-23 | 18:00 | Line will be in Service Via 400KV TBC |
| 260 | 891 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-LONIKHAND-CHAKAN-1 | C | For Overhauling of Bus A 89A & BUS C 89 C Rph, Yph, Bph PG Isolators along with Routine Testing and Maintenance Work. | 19-Jan-23 | 10:00 | 20-Jan-23 | 21:00 | - |
| 261 | 892 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-DHULE-MS-BABLESHWAR-2 | D | work of cold line washing of insulator string and routine Line maintenance work on Dhule-BBLR ckt. I A/R in N/A of ckt-1 | 19-Jan-23 | 08:00 | 19-Jan-23 | 18:00 | 400KV Ektuni ckt I&II,400KV Bhusawal,400kv Aurangabad and Dhule II will be in service |
| 262 | 902 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARJAT-LONIKHAND-II-1 | D | Cold line washing of insulator strings | 19-Jan-23 | 08:00 | 19-Jan-23 | 18:00 | Chemical cleaning of insulators is necessary in view of sugarcane harvesting season and last year tripping scenario |
| 263 | 903 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-PUSAD-1 | D | For routine maintenance work. | 19-Jan-23 | 08:00 | 19-Jan-23 | 18:00 | - |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|---------------------------|---|--------------------|--|-------------|-------|-------------|-------|---|
| 264 | 915 | PLANNED | OCC_562 | WRTS-1 | MAIN BAY - 400KV-KALA-KUDUS-2 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV | D | AMP of 401 Bay | 19-Jan-2023 | 9:00 | 19-Jan-2023 | 17:00 | 400 KV Padghe Kudus Line 1 will be in service through Main Bay 415. |
| 265 | 921 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-PARLI-M-KARIAT-1 | D | (1) Main-1 Distance relay testing work. (2) Bay maintenance work. | 19-Jan-23 | 09:00 | 19-Jan-23 | 18:00 | - |
| 266 | 922 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-SSP-DHULE-MS-2 | D | For Replacement of PID Suspecious Insulator strings & Maintenance work. | 19-Jan-23 | 09:00 | 19-Jan-23 | 18:00 | 400 KV DHL-SSNNL CKT 1 A/R Switch will be put on Non Auto Mode. |
| 267 | 928 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-WARDHA-KORADI-II-1 | D | Routine line maintenance work | 19-Jan-23 | 10:00 | 19-Jan-23 | 18:00 | 400 KV WARDHA - DEOLI 2 Line is in ckt |
| 268 | 929 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-CHAKAN-PUNE-PG-1 | D | Routine Testing and Maintenance Work. & Installation of spacers and routine maintenance work. | 19-Jan-23 | 10:00 | 19-Jan-23 | 18:00 | - |
| 269 | 935 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-JEJURI-KOYNA STAGE IV-1 | C | Restinging of conductor Between Loc No 89-92 to achieve Ground clearance | 19-Jan-23 | 08:00 | 21-Jan-23 | 17:00 | Restinging of conductor Between Loc No 89-92 to achieve Ground clearance |
| 270 | 942 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY OF 765KV/400KV SOLAPUR-M-ICT-2 AND SOLAPUR-M - 400KV - BUS 1 @SOLAPUR-M - 400KV at SOLAPUR-M - 400KV | C | 404-52 CB Overhauling work. | 19-Jan-23 | 10:00 | 24-Jan-23 | 18:00 | Without Load interruption. ICT II will be in service via 405-52CB. |
| 271 | 950 | PLANNED | OCC_562 | POWERGRID_WR1 | 220KV-SOLAPUR-KUMBARI-2 | D | Line side equipments AMP | 20-Jan-23 | 7:00 | 20-Jan-23 | 18:00 | - |
| 272 | 975 | PLANNED | OCC_562 | APML-ADANI | 400KV/11.5KV TIRODA-ST-3 | D | For bay equipment maintenance and testing work. | 20-Jan-23 | 9:00 | 20-Jan-23 | 18:00 | TRANSFORMER OUTAGE |
| 273 | 976 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-SSP-DHULE-MS-2 | D | For Replacement of PID Suspecious Insulator strings & Maintenance work. | 20-Jan-23 | 09:00 | 20-Jan-23 | 18:00 | 400 KV DHL-SSNNL CKT 1 A/R Switch will be put on Non Auto Mode. |
| 274 | 979 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - KOLHAPUR GIS - 400KV B/R 1 AND KOLHAPUR GIS - 400KV - BUS 2 at Kolhapur GIS - 400KV | D | Bay AMP | 20-Jan-23 | 9:00 | 20-Jan-23 | 18:00 | 412 Bay |
| 275 | 980 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV/220KV PUNE-PG-ICT-3 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV | D | For AMP WORK | 20-Jan-23 | 9:00 | 20-Jan-23 | 18:00 | - |
| 276 | 981 | PLANNED | OCC_562 | MEGPTCL | 765KV-AKOLA (2)-KORADI-III-2 | D | Taking Spare line Reactor in Service in place of B-ph Reactor at Akola as per CEA guideline | 20-Jan-23 | 09:30 | 20-Jan-23 | 15:30 | Non-Switchable Reactor. Hence line outage required for change over. (No changeover in LR 2) |
| 277 | 987 | PLANNED | OCC_562 | MEGPTCL | 765KV-AKOLA (2)-KORADI-III-2 | C | To attend the sag corection in tower no. 534, to stop the deforming of tower members in the first section. | 20-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | Outage can be upload in WRDLC outage management portal in account of MEGPTCL for D-3 readiness. |
| 278 | 988 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-BHADRAWATI-3 | C | Required for Main Bus -1 outage work. | 20-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are faulty. |
| 279 | 989 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-BHADRAWATI-4 | C | Required for Main Bus -1 outage work. | 20-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are faulty. |
| 280 | 990 | PLANNED | OCC_562 | MSLDC_OUTAGE | BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV | C | Required for Main Bus -1 outage work. | 20-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | 400KV PGCL Ckt-1 to Ckt-4, 400KV HVDC CKT-1 & CKT-2, 400KV CHD-2 CKT-1 & CKT-2 will be in service. (act as a Bus-coupler) |
| 281 | 991 | PLANNED | OCC_562 | MSLDC_OUTAGE | CHANDRAPUR - 400KV - BUS 1 | C | "1. Tan delta measurement of Bus CVT. 2. Replacement of faulty disc insulator string of Main Bus-1 3. Nut Bolts and hardware tightening work." | 20-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | Bays/feeders/Circuits connected to Main Bus-1 will be shifted on Main Bus-2 via TBC-1 and TBC-2 bay. |
| 282 | 992 | PLANNED | OCC_562 | MEGPTCL | 400KV-AKOLA (2)-NANDGAONPETH-1 | C | To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deforming of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line. | 20-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | Outage can be upload in WRDLC outage management portal in account of MEGPTCL for D-3 readiness. |
| 283 | 993 | PLANNED | OCC_562 | MEGPTCL | 400KV-AKOLA (2)-NANDGAONPETH-2 | C | To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deforming of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line. | 20-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | Outage can be upload in WRDLC outage management portal in account of MEGPTCL for D-3 readiness. |
| 284 | 994 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-DHULE-MS-BABLESHWAR-1 | D | On line PID test | 20-Jan-23 | 09:00 | 21-Jan-23 | 18:00 | A/R switch required on non auto mode |
| 285 | 995 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KHARGHAR-PUNE-PG-1 | C | Maintenance work in span between loc no. 33 & 34 w.r.to conductor replacement and insulator replacement | 20-Jan-23 | 07:00 | 23-Jan-23 | 18:00 | - |
| 286 | 999 | PLANNED | OCC_562 | POWERGRID_WR2 | 400KV-AURANGABAD-BOISAR-2 | C | Damaged Conductor replacement work in between location 753-754 (610 Mtrs). A/R OFF OF CKT # 1 IS REQUIRED AND DIA TO BE KEPT OPEN AT BOTH ENDS. | 21-Jan-2023 | 9:00 | 22-Jan-2023 | 17:30 | PG-WR2-BOISAR |
| 287 | 1000 | PLANNED | OCC_562 | MSLDC_OUTAGE | BOISAR - 220KV - BUS 2 | C | Bus Iso. R/M & R/M Work | 21-Jan-23 | 07:00 | 22-Jan-23 | 20:00 | Bus iso. R/M & R/M Work |
| 288 | 1007 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-1 | D | Chemical Cleaning of Insulator string and Routine Line maintenance work | 21-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | 400KV Padghe II will be in in service |
| 289 | 1010 | PLANNED | OCC_562 | MSLDC_OUTAGE | LONIKHAND - 400KV - BUS 2 | D | Numerical Bus Bar Testing. Make- NR(All elements will be in service through main bus 1 and 2) | 21-Jan-23 | 08:00 | 21-Jan-23 | 20:00 | - |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|---------------------------|---|--------------------|---|-------------|-------|-------------|-------|---|
| 290 | 1011 | PLANNED | OCC_562 | MSLDC_OUTAGE | LONIKHAND - 400KV - BUS 1 | D | Numerical Bus Bar Testing. Make- NR(All elements will be in service through main bus 1 and 2) | 21-Jan-23 | 08:00 | 21-Jan-23 | 20:00 | |
| 291 | 1019 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-LONIKHAND-PUNE-PG-1 | D | For AMP WORK | 21-Jan-23 | 9:00 | 21-Jan-23 | 18:00 | |
| 292 | 1026 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-1 | D | TO ATTEND DEFECTS IDENTIFIED IN MONKEY PATROLLING UNDER PADGHE AND JUNNER S-DN-1. TO FIX REPAIR SLEEVE AT BROKEN CONDUCTOR STRANDS.2. REPLACEMENT OF BROKEN AND FLASHOVER DISC. INSULATORS STRINGS.3. CHEMICAL AND COLD WASHING OF DUST/BIRD SHIT POLLUTED INSULATOR STRING.4. FIX OF BIRD GUARD AT INSULATORS BIRD SHIT LOCATIONS.5. TIGHTENING OF NUT BOLTS OF CONDUCTOR JUMPER AND EARTHWIRE HARDWARE.6. STRINGING OF EARTHWIRE AND LOC 919-920.7. FIXING OF MISSING/DAMAGED HARDWARE. | 21-Jan-23 | 08:00 | 22-Jan-23 | 18:00 | 400KV Babhaleshwar-Padghe Ckt-2 will be available. THIS OUTAGE IS REQUIRED FOR UNINTERRUPTED OPERATION IN SUMMER PEAK LOAD. |
| 293 | 1027 | PLANNED | OCC_562 | MEGPTCL | TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA (2) - 765KV | D | OEM Inspection of CB | 21-Jan-23 | 09:00 | 22-Jan-23 | 18:00 | OEM Inspection of CB |
| 294 | 1032 | PLANNED | OCC_562 | WTPL | 400KV-KHARGHAR-PUNE-PG-1 | C | Line diversion work due to expansion of MIDC road at Talegaon | 22-Jan-23 | 8:00 | 31-Jan-23 | 18:00 | Line shut down required for dismantling, erection & stringing work. |
| 295 | 1033 | Planned | OCC_562 | MSLDC_OUTAGE | BABLESHWAR - 400KV - BUS 1 | D | Bus CVT Testing | 22-Jan-23 | 08:00 | 22-Jan-23 | 17:00 | 400 KV BUS -1 feeders and ICTs to be shifted on 400 KV Bus-II |
| 296 | 1036 | PLANNED | OCC_562 | MSLDC_OUTAGE | NAGOTHANE - 400KV - BUS 2 | D | Regular Maint work and Dignostic testing work | 22-Jan-23 | 08:00 | 22-Jan-23 | 17:00 | nil |
| 297 | 1038 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KARIAT-LONIKHAND-II-2 | D | Cold line washing of insulator strings | 22-Jan-23 | 08:00 | 22-Jan-23 | 18:00 | Chemical cleaning of insulators is necessary in view of sugarcane harvesting season and last year tripping scenario |
| 298 | 1042 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KALWA-PUNE-PG-1 | D | Routine Maintenance Activity | 22-Jan-23 | 09:00 | 22-Jan-23 | 18:00 | Routine Maintenance Activity |
| 299 | 1044 | PLANNED | OCC_562 | MSLDC_OUTAGE | KOLHAPUR-MS - 400KV - BUS 2 | D | Replacement of Bph Bus CVT PID faulty string replacement work | 23-Jan-23 | 07:00 | 23-Jan-23 | 23:59 | Monday is load staggering day. All bays will be shifted online through TBC |
| 300 | 1045 | PLANNED | OCC_562 | POWERGRID_WR1 | CHANDRAPUR-GCR - 400KV - BUS 1 | C | Retrofitting of PG-1 pantograph Isolators of MSEB ckt-1 and MSEB ckt-2 at GCR end | 23-Jan-2023 | 7:00 | 31-Jan-2023 | 18:00 | Retrofitting of PG-1 Isolators of MSEB ckt-1 and MSEB ckt-2 |
| 301 | 1055 | PLANNED | OCC_562 | MEGPTCL | 765KV-TIRODA-KORADI-III-1 | D | Annual Maintenance of line | 23-Jan-23 | 08:00 | 23-Jan-23 | 18:00 | Annual Maintenance of line |
| 302 | 1058 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 220KV-WARDHA-WARDHA-M-1 AND WARDHA - 220KV - BUS 1 at Wardha - 220KV | D | AMP of Bay | 23-Jan-23 | 8:00 | 23-Jan-23 | 18:00 | 206 |
| 303 | 1059 | PLANNED | OCC_562 | POWERGRID_WR1 | 220KV-WARDHA-WARDHA-M-1 | D | AMP of Line Bay | 23-Jan-23 | 8:00 | 23-Jan-23 | 18:00 | 206L |
| 304 | 1063 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-BADNERA-1 | D | 1. For Replacement of Flashover Discs. 2. For Diagnostic Testing of Line Bay. | 23-Jan-23 | 09:00 | 23-Jan-23 | 17:00 | |
| 305 | 1076 | PLANNED | OCC_562 | MEGPTCL | 765KV/400KV AKOLA (2)-ICT-1 | D | Taking Spare ICT in Service in place of B-ph ICT as per CEA guideline | 23-Jan-23 | 09:00 | 23-Jan-23 | 18:00 | ICT Outage Required (Discharged on 05.02.2015 as B-ph was taking into service in place of Spare) |
| 306 | 1077 | PLANNED | OCC_562 | MSLDC_OUTAGE | CHANDRAPUR-II - 400KV - BUS 2 | D | Diagnostic testing and allied bay maintenance work | 23-Jan-23 | 09:00 | 23-Jan-23 | 18:00 | Diagnostic testing and allied bay maintenance work |
| 307 | 1078 | PLANNED | OCC_562 | MP_SLDC | 220KV-DAMOH-SAGAR-2 | D | FOR LINE MAINTENANCE WORK | 23/Jan/23 | 9:00 | 23/Jan/23 | 18:00 | |
| 308 | 1079 | PLANNED | OCC_562 | POWERGRID_WR1 | TIE BAY - 400KV-KOLHAPUR GIS-NARENDRA KUDGI-1 AND 400KV-KOLHAPUR GIS-MAPUSA-2 at Kolhapur GIS - 400KV | D | Bay AMP | 23-Jan-23 | 9:00 | 23-Jan-23 | 18:00 | 402 Bay |
| 309 | 1080 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV/220KV PUNE-PG-ICT-1 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV | D | For AMP WORK | 23-Jan-23 | 9:00 | 23-Jan-23 | 18:00 | ICT_1 Load shifted to Transfer Bus by charging the Transfer Bus Bay, Transfer Bus Bay Taken into service before S/D of bay |
| 310 | 1087 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY OF 400KV-LONIKHAND-JEJURI-1 AND LONIKHAND - 400KV - BUS 2 @JEJURI - 400KV at LONIKHAND - 400KV(ELEMENT NOT FOUND | C | PID Testing work & O/H & Serviceing of 29B PG Isolator & Replacement of PGI mechanism box. Line will be shifted on TBC | 23-Jan-23 | 08:00 | 25-Jan-23 | 18:00 | Line will be in service |
| 311 | 1094 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KALWA-KHARGHAR-1 | D | PID Testing Auto-Reclose function to be out of service. | 23-Jan-23 | 09:00 | 28-Jan-23 | 18:00 | PID Testing Auto-Reclose function to be out of service. |
| 312 | 1095 | PLANNED | OCC_562 | POWERGRID_WR1 | CHANDRAPUR-GCR - 400KV - BUS 2 | C | Retrofitting of PG-2 pantograph Isolators of MSEB ckt-1 and MSEB ckt-2 at GCR end | 23-Jan-2023 | 7:00 | 30-Jan-2023 | 18:00 | Retrofitting of PG-2 Isolators of MSEB ckt-1 and MSEB ckt-2 |
| 313 | 1096 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-WARORA-CHANDRAPUR-II-2 | D | For PID Testing Work,shifting autoreclose switch to Non auto Mode . | 23-Jan-23 | 09:00 | 31-Jan-23 | 17:00 | For PID Testing Work,shifting autoreclose switch to Non auto Mode . |
| 314 | 1097 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-WARORA-CHANDRAPUR-II-1 | D | For PID Testing Work,shifting autoreclose switch to Non auto Mode . | 23-Jan-23 | 09:00 | 31-Jan-23 | 17:00 | For PID Testing Work,shifting autoreclose switch to Non auto Mode . |
| 315 | 1099 | PLANNED | OCC_562 | MSLDC_OUTAGE | KOLHAPUR-MS - 400KV - BUS 1 | D | Annual Maintenance and Annual Testing work | 24-Jan-23 | 07:00 | 24-Jan-23 | 23:59 | Monday is load staggering day. All bays will be shifted online through TBC |
| 316 | 1104 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-CHANDRAPUR-BHADRAWATI-3 | D | For AMP works at GCR end | 24-Jan-2023 | 7:00 | 24-Jan-2023 | 18:00 | For AMP works at GCR end |
| 317 | 1105 | PLANNED | OCC_562 | POWERGRID_WR1 | 765KV-AURANGABAD-SOLAPUR-1 | D | For Taking Spare out of Service | 24-Jan-23 | 8:00 | 24-Jan-23 | 11:00 | |
| 318 | 1106 | PLANNED | OCC_562 | POWERGRID_WR1 | 765KV-AURANGABAD-SOLAPUR-1 U/R@ AURANGABAD - 765KV | D | For Taking Spare out of Service | 24-Jan-23 | 8:00 | 24-Jan-23 | 11:00 | |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|---------------------------|--|--------------------|--|-------------|-------|-------------|-------|---|
| 319 | 1110 | PLANNED | OCC_562 | MEGPTCL | 765KV-TIRODA-KORADI-III-2 L/R@ KORADI-III - 765KV | D | For Reactor changeover Activity as per CEA guideline Spare reactor taken into service in place of Y ph. | 24-Jan-23 | 08:00 | 24-Jan-23 | 18:00 | 765KV-TIRODA-KORADI-III-2 will remain in service without LR (Common Spare Reactor discharged 17.06.2019) |
| 320 | 1111 | PLANNED | OCC_562 | MEGPTCL | 765KV-TIRODA-KORADI-III-2 | D | For Reactor changeover Activity as per CEA guideline Spare reactor taken into service in place of Y ph. & annual line maintenance | 24-Jan-23 | 08:00 | 24-Jan-23 | 18:00 | 765KV-TIRODA-KORADI-III-2 will remain in service without LR (Common Spare Reactor discharged 17.06.2019) |
| 321 | 1113 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-WARDHA-AKOLA-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV | D | AMP of Bay | 24-Jan-23 | 8:00 | 24-Jan-23 | 18:00 | 419 |
| 322 | 1119 | PLANNED | OCC_562 | WRTS-1 | MAIN BAY - 400KV-KALA-KUDUS-1 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV | D | AMP of 404 Bay | 24-Jan-2023 | 9:00 | 24-Jan-2023 | 17:00 | 400 KV Padghe Kudus Line 1 will be in service through Main Bay 415. |
| 323 | 1129 | PLANNED | OCC_562 | GETCO | 220KV-TARAPUR 1&2-BHILAD-1 | D | PMM work | 24-Jan-23 | 9:00 | 24-Jan-23 | 18:00 | |
| 324 | 1137 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-WARORA-PG-WARORA-M-1(ELEMENT NOT FOUND) | D | Routine line maintenance work | 24-Jan-23 | 10:00 | 24-Jan-23 | 18:00 | 400KV WARORA-IEPL Line is in ckt |
| 325 | 1144 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 | C | For attending SF6 Gas Leakage | 24-Jan-23 | 9:00 | 28-Jan-23 | 18:00 | For attending TLM defects, 400 Kv Pune-Parli Ckt#1 is to be required in Non auto mode. |
| 326 | 1147 | PLANNED | OCC_562 | POWERGRID_WR1 | SOLAPUR - 400KV - BUS 1 | D | 400KV Bus#1 AMP works | 25-Jan-23 | 7:00 | 25-Jan-23 | 18:00 | |
| 327 | 1149 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-CHANDRAPUR-BHADRAWATI-4 | D | For AMP works at GCR end | 25-Jan-2023 | 7:00 | 25-Jan-2023 | 18:00 | For AMP works at GCR end |
| 328 | 1150 | PLANNED | OCC_562 | POWERGRID_WR2 | VAPI - 220KV - BUS 2 | D | AMP Works | 25-Jan-2023 | 8:00 | 25-Jan-2023 | 17:30 | PG-WR2-VAPI |
| 329 | 1156 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-WARDHA-PUSAD-1 | D | For routine maintenance work. | 25-Jan-23 | 08:00 | 25-Jan-23 | 18:00 | - |
| 330 | 1161 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-PARLI-PARLI-M-2 | D | LINE/ s/s maintenance | 25-Jan-23 | 09:00 | 25-Jan-23 | 17:30 | - |
| 331 | 1166 | PLANNED | OCC_562 | MSETCL | 220KV-TALANGADE(MS)-CHIKKODI-II-1 | D | Annual maintenance work | 25-Jan-23 | 09:00 | 25-Jan-23 | 18:00 | The said work is very important |
| 332 | 1167 | PLANNED | OCC_562 | MSLDC_OUTAGE | 132KV-MANSAR-MS-PENCH-1 | D | Routine Maintenance. Work | 25-Jan-23 | 09:00 | 25-Jan-23 | 18:00 | - |
| 333 | 1171 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-TALEGAON-PUNE-PG-1 | D | Half yearly maintenance | 25-Jan-23 | 10:00 | 25-Jan-23 | 18:00 | - |
| 334 | 1172 | PLANNED | OCC_562 | MSLDC_OUTAGE | KUMBARI - 220KV - BUS 2 | D | Outage is required for Quarterly Maintenance | 25-Jan-23 | 11:00 | 25-Jan-23 | 17:00 | Quarterly Maintenance |
| 335 | 1173 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-SOLAPUR-KUMBARI-2 | D | Outage is required for Quarterly Maintenance | 25-Jan-23 | 11:00 | 25-Jan-23 | 17:00 | Quarterly Maintenance |
| 336 | 1174 | PLANNED | OCC_562 | MEGPTCL | TIE BAY - AKOLA (2) - 765KV B/R 1 AND 765KV/400KV AKOLA (2)-ICT-1 at AKOLA (2) - 765KV | D | OEM Inspection of CB | 25-Jan-23 | 09:00 | 26-Jan-23 | 18:00 | OEM Inspection of CB |
| 337 | 1175 | PLANNED | OCC_562 | POWERGRID_WR1 | MAIN BAY - 400KV-RAIPUR-WARDHA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV | C | Overhauling of 415 CGL CB | 25-Jan-23 | 8:00 | 30-Jan-23 | 18:00 | 415 |
| 338 | 1176 | PLANNED | OCC_562 | POWERGRID_WR2 | 400KV-KALA-KUDUS-1 | D | For shutdown nature defects rectification works in line and LINE AMP Works.A/R OFF of ckt # 2 is required. | 26-Jan-2023 | 8:00 | 26-Jan-2023 | 17:30 | PG-WR2-VAPI |
| 339 | 1182 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KALWA-PADGHE-1 | D | All diagnostic testing work, and Bay maintenance work. | 26-Jan-23 | 08:00 | 26-Jan-23 | 18:00 | All diagnostic testing work, and Bay maintenance work. |
| 340 | 1184 | PLANNED | OCC_562 | POWERGRID_WR1 | 220KV-TALEGAON-PUNE-PG-2 | D | For AMP WORK | 26-Jan-23 | 9:00 | 26-Jan-23 | 18:00 | |
| 341 | 1188 | PLANNED | OCC_562 | MSLDC_OUTAGE | BUS COUPLER BAY OF CHAKAN - 400KV - BUS 1 AND CHAKAN - 400KV - BUS 2 @CHAKAN - 400KV at CHAKAN - 400KV | C | For Overhauling of Bus A 89A Rph, Yph, Bph PG Isolators and Routine Testing and Maintenance Work. | 26-Jan-23 | 10:00 | 27-Jan-23 | 21:00 | - |
| 342 | 1193 | PLANNED | OCC_562 | MSLDC_OUTAGE | 220KV-BOISAR-BOISAR-M-2 | D | Bay Maintenance Work | 27-Jan-23 | 07:00 | 27-Jan-23 | 17:00 | Bay Maintenance Work |
| 343 | 1194 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-WARDHA-WARORA-PG-1 | D | Earth wire Peak Strengthening work for Diamond Crossing of Earthwire / OPGW over 400kv Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme | 27-Jan-23 | 7:00 | 27-Jan-23 | 18:00 | |
| 344 | 1196 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY - 400KV-TARAPUR 3&4-PADGHE-2 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV | D | 1)400kv Tarapur-II shifted on TBC for removing IPS tube between A& B bus PG isolator.2) Tarapur-II will be charge on B bus for next 3 days. | 27-Jan-23 | 08:00 | 27-Jan-23 | 10:00 | Weather condition should be clear |
| 345 | 1216 | PLANNED | OCC_562 | MEGPTCL | MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV | D | OEM Inspection of CB | 27-Jan-23 | 09:00 | 27-Jan-23 | 18:00 | OEM Inspection of CB |
| 346 | 1217 | PLANNED | OCC_562 | MP_SLDC | 220KV-ANNUPUR-KOTMIKALA-2 | D | FOR LINE MAINTENANCE WORK | 27/Jan/23 | 9:00 | 27/Jan/23 | 18:00 | |
| 347 | 1219 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY - 400KV-TARAPUR 3&4-PADGHE-1 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV | D | 1) 400kv Tarapur -1 shifted on TBC for safety purposed for removing jumper between Gantry of 400kv Trapur I & II by Hot line method. 2) Once work completed line will be charged on own CB & Bus | 27-Jan-23 | 10:00 | 27-Jan-23 | 12:30 | 1) Hot line team will be present on site for the work |
| 348 | 1224 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-BHADRAWATI-2 | C | Required for Main Bus -2 outage work. | 27-Jan-23 | 08:00 | 28-Jan-23 | 18:00 | This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are faulty. |
| 349 | 1225 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-CHANDRAPUR-BHADRAWATI-1 | C | Required for Main Bus -2 outage work. | 27-Jan-23 | 08:00 | 28-Jan-23 | 18:00 | This circuits/bays can not be shifted on 400KV Main Bus-1, as the Bus-1 isolators are faulty. |
| 350 | 1226 | PLANNED | OCC_562 | MSLDC_OUTAGE | CHANDRAPUR - 400KV - BUS 2 | C | "1. Tan delta measurement of Bus CVT. 2. Replacement of faulty disc insulator string of Main Bus-2 3. Nut Bolts and hardware tightening work." | 27-Jan-23 | 08:00 | 28-Jan-23 | 18:00 | "This circuits/bays which are connected to 400KV MainBUS-2 will be shifted on 400KV Main Bus-1, as the Bus-1 isolators are faulty." |

| Sr.No. | OCCM Sr. No | Request Type | OCC Number | Name of Requesting Agency | Line / Element | Daily / Continuous | Reason | From | To | Remarks | | |
|--------|-------------|--------------|------------|---------------------------|---|--------------------|---|-------------|-------|-------------|-------|---|
| 351 | 1227 | PLANNED | OCC_562 | MSLDC_OUTAGE | BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV | C | "1. During outage on Main Bus-2 , Bus-coupler will be in out of service. 2. Measurement of CB timing, CRM, DCRM." | 27-Jan-23 | 08:00 | 28-Jan-23 | 18:00 | 400KV PGCL Ckt-1 to Ckt-4, 400KV HVDC CKT-1 & CKT-2, 400KV CHD-2 CKT-1 & CKT-2 will be in service. (act as a Bus-coupler) |
| 352 | 1229 | PLANNED | OCC_562 | MSLDC_OUTAGE | PADGHE - 400KV - BUS 1 | C | A Bus Conductor Replacement of Section -1 between 400KV Tarapur II & 500MVA ICT -5. 1) 500MVA ICT-5 & 400KV Tarapur -2 on TBC for 3hrs for removing IPS tube between A & B Bus PG Isolator one by one and later on will be charged on B bus for 3 days. 2) 400KV Tarapur I on TBC for removing jumper by Hot line method. | 27-Jan-23 | 05:00 | 29-Jan-23 | 23:00 | 1)Details plan will be submitted later 2) Weather condition should be clear |
| 353 | 1232 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KALWA-PUNE-PG-1 | C | Maintenance work in span between loc no. 33 & 34 w.r.to conductor replacement and insulator replacement | 27-Jan-23 | 07:00 | 30-Jan-23 | 18:00 | - |
| 354 | 1240 | PLANNED | OCC_562 | NPCL, TAPS 1&2 | 220KV - Tarapur 1&2 - Borivali-1 | Continuous | Zone-II outage for PM of main bus related equipments. | 27-Jan-2023 | 8:00 | 02-Feb-2023 | 20:00 | 1) Continuous line outage is required |
| 355 | 1244 | PLANNED | OCC_562 | POWERGRID_WR1 | 400KV-WARORA-WARORA-PG-2 | D | Earth wire Peak Strengthening work for Diamond Crossing of Earthwire / OPGW over 400KV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme | 28-Jan-23 | 7:00 | 28-Jan-23 | 18:00 | |
| 356 | 1249 | PLANNED | OCC_562 | MSLDC_OUTAGE | BUS COUPLER BAY - KALWA - 400KV - BUS 1 AND KALWA - 400KV - BUS 2 at KALWA - 400KV | D | All diagnostic testing work, and Bay maintenance work. | 28-Jan-23 | 08:00 | 28-Jan-23 | 18:00 | All diagnostic testing work, and Bay maintenance work. |
| 357 | 1250 | PLANNED | OCC_562 | MSLDC_OUTAGE | LONIKHAND - 400KV - BUS 2 | D | Numerical Bus Bar Testing. Make- NR | 28-Jan-23 | 08:00 | 28-Jan-23 | 18:00 | - |
| 358 | 1251 | PLANNED | OCC_562 | MSLDC_OUTAGE | LONIKHAND - 400KV - BUS 1 | D | Numerical Bus Bar Testing. Make- NR | 28-Jan-23 | 08:00 | 28-Jan-23 | 18:00 | - |
| 359 | 1259 | PLANNED | OCC_562 | MEGPTCL | MAIN BAY - 400KV-AKOLA (2)-FUTURE-5 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV | D | Annual Maintenance of Bay Equipment | 28-Jan-23 | 09:00 | 28-Jan-23 | 18:00 | Annual Maintenance of Bay Equipment |
| 360 | 1262 | PLANNED | OCC_562 | MSLDC_OUTAGE | KHARGHAR - 400KV - BUS 1 | D | For replacement of R&B phase Bus CVT and Bus Maintenance work and Replacement of Damaged Bus conductor Span | 28-Jan-23 | 07:00 | 30-Jan-23 | 18:00 | All Lines & ICT's will be on B bus. Load will be shifted Via TBC |
| 361 | 1267 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-2 | D | cold line washing of insulator string and routine Line maintenance work | 29-Jan-23 | 08:00 | 29-Jan-23 | 18:00 | 400KV Padghe I will be in in service |
| 362 | 1271 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-KHARGHAR-PUNE-PG-1 | D | Routine Maintenance Activity | 29-Jan-23 | 09:00 | 29-Jan-23 | 23:30 | Weather condition should be clear |
| 363 | 1272 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY - 400KV-TARAPUR 3&4-PADGHE-1 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV | D | 1) Tarapur -I on TBC for safety purpose for re connection of A bus gantry jumper between Tarapur -I & II by hot line method. 2) after work Tarapur -I will be charge on own CB. | 29-Jan-23 | 15:00 | 29-Jan-23 | 18:00 | PG-WR2-ITARSI |
| 364 | 1273 | PLANNED | OCC_562 | MSLDC_OUTAGE | MAIN BAY - 400KV-TARAPUR 3&4-PADGHE-2 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV | D | 1) Tarapur -II on TBC for re connection of IPS tube between A& B bus PG Isolator. 2) after work Tarapur -II will be charge on own CB. | 29-Jan-23 | 21:00 | 29-Jan-23 | 18:00 | |
| 365 | 1285 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-BABLESHWAR-PADGHE-1 | D | Chemical Cleaning of Insulator string and Routine Line maintenance work | 30-Jan-23 | 08:00 | 30-Jan-23 | 20:00 | Annual Maintenance & Testing & RTV Coating. |
| 366 | 1288 | PLANNED | OCC_562 | MSLDC_OUTAGE | 132KV-DHARNI-NEPANAGAR-1 | D | For Replacement of Flashover Disc by Hot Line Method Shifting of auto reclose switch to non auto mode | 30-Jan-23 | 09:00 | 30-Jan-23 | 18:00 | PG-WR2-PIRANA |
| 367 | 1291 | PLANNED | OCC_562 | MEGPTCL | 765KV/400KV AKOLA (2)-ICT-1 | D | Annual Maintenance of ICT | 30-Jan-23 | 09:00 | 30-Jan-23 | 18:00 | |
| 368 | 1292 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-SSP-DHULE-MS-1 | D | For Replacement of PID Suspecious Insulator Strings & Maintenance work. | 30-Jan-23 | 09:00 | 30-Jan-23 | 17:30 | |
| 369 | 1296 | PLANNED | OCC_562 | POWERGRID_WR2 | MAIN BAY - 765KV-INDORE-VADODARA-1 AND INDORE - 765KV - BUS 2 at INDORE - 765KV | D | AMP WORK | 30-Jan-2023 | 9:00 | 31-Jan-2023 | 20:00 | - |
| 370 | 1297 | PLANNED | OCC_562 | MEGPTCL | MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV | D | OEM Inspection of CB | 30-Jan-23 | 09:00 | 31-Jan-23 | 18:00 | Line with SLR outage is required. |
| 371 | 1298 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-LONIKHAND-JEJURI-2 | C | O/H & Servicing of 29C PG Isolator & Replacement of PGI mechanism box. | 30-Jan-23 | 08:00 | 1-Feb-23 | 15:00 | |
| 372 | 1309 | PLANNED | OCC_562 | MSLDC_OUTAGE | 400KV-SSP-DHULE-MS-1 | D | For Replacement of PID Suspecious Insulator Strings & Maintenance work. | 31-Jan-23 | 09:00 | 31-Jan-23 | 18:00 | |

State Element outage list for the month of JANUARY'2023

| Sr.No. | Line Equipment | From Date | From Time | To Date | To Time | Basis | Reason | System | Agency | Remark .If any. | |
|--------|----------------|--|-----------|---------|-----------|-------|-------------|--|--------|-----------------|---|
| 1 | 400 KV | CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2 | 01-Jan-23 | 08:00 | 31-Jan-23 | 18:00 | Daily | For PID Work, Shifting of auto reclose switch to non auto mode. | MSETCL | MSETCL | |
| 2 | 400 KV | AKOLA - KHADKA (BHUSAWAL) | 01-Jan-23 | 10:00 | 31-Jan-23 | 17:00 | Daily | PID of 400 kv Akola- Bhusawal line will be carried out by PID unit Akola & Hot line Unit Akola. | MSETCL | MSETCL | PID of 400 kv Akola- Bhusawal line will be carried out by PID unit Akola & Hot line Unit Akola. |
| 3 | 400 KV | AKOLA-NANDGAONPETH (RPL-AMT) | 01-Jan-23 | 10:00 | 31-Jan-23 | 17:00 | Daily | PID of 400 kv Akola- Nandgaonpeth line will be carried out by PID unit Akola & Hot line Unit Akola. | MSETCL | MSETCL | PID of 400 kv Akola- Nandgaonpeth line will be carried out by PID unit Akola & Hot line Unit Akola. |
| 4 | 400 KV | CHANDRAPUR - KHAPERKHEDA | 01-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | Daily | ONLINE PID WORK | MSETCL | MSETCL | PID WITH AR IN NON AUTO MODE |
| 5 | 400 KV | WARORA - IEPL | 03-Jan-23 | 09:00 | 03-Jan-23 | 17:00 | Daily | Line CT, CVT Tan delta, IR values & Routine maintenance and and Isolator maintenance work | MSETCL | MSETCL | Both Main & Tie Bay is in OFF condition. |
| 6 | 400 KV | 400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA | 04-Jan-23 | 10:00 | 04-Jan-23 | 17:00 | Daily | RTV Coating of 33 kv Tertiary Side Equipments | MSETCL | MSETCL | - |
| 7 | 400 KV | BABLESHWAR- AURANGABAD (WALUJ) | 04-Jan-23 | 09:00 | 04-Jan-23 | 17:00 | Daily | Main I & Main II distance relay Testing Quarterly Bay Maintenance Work. | MSETCL | MSETCL | 400kv Ektuni ckt I&II, 400kv Bhusawal, and Dhule I&II will be in service |
| 8 | 400 KV | KHADKA - BABLESHWAR | 05-Jan-23 | 06:00 | 06-Jan-23 | 18:00 | Daily | Chemical Cleaning of Insulator string and Routine Line maintenance work | MSETCL | MSETCL | 400kv Ektuni ckt I&II, 400kv Aurangabad , Dhule I&II will be in service |
| 9 | 400 KV | JEJURI- KOYNA STAGE-IV | 05-Jan-23 | 08:00 | 05-Jan-23 | 17:00 | Daily | PID Faulty disc insulator replacement work & Cold & Chemical line washing work | MSETCL | MSETCL | PID Faulty disc insulator replacement work & Cold & Chemical line washing work |
| 10 | 400 KV | TIE BAY (405) OF ICT -2 AND STG-4 @ JEJURI | 05-Jan-23 | 09:00 | 05-Jan-23 | 18:00 | Daily | Annual testing & maintenance. | MSETCL | MSETCL | 400 kv Jejuri-Koyna St IV line will be in service through 406 CB |
| 11 | 400 KV | MIAN BAY-422 OF STATION TF - 1 @ KORADI-2 | 05-Jan-23 | 10:00 | 05-Jan-23 | 17:00 | Daily | Diagnostic Testing of CB and routine bay maintenance work | MSETCL | MSETCL | Station transformer-1 will remain in service through Tie Bay 423 |
| 12 | 400 KV | 400/220/33 KV 315MVA ICT - 2 @ CHAKAN | 05-Jan-23 | 10:00 | 05-Jan-23 | 21:00 | Daily | For Overhauling of Bus A 89A Rph, Yph, Bph PG Isolators along with Routine Testing and Maintenance Work. | MSETCL | MSETCL | ICT-2 will be in service through 400 kv TBC. |
| 13 | 400 KV | 400/220/33KV 315MVA ICT - 3 @ LONKAND | 05-Jan-23 | 08:00 | 06-Jan-23 | 20:00 | Continuou s | DT & Bay Maintenance Work & O/H & Servicing of 29B PG Isolator & Replacement of PGI mechanism box. | MSETCL | MSETCL | - |
| 14 | 400 KV | 400/220/33 KV 500MVA ICT - 1 @ WARORA | 06-Jan-23 | 09:00 | 06-Jan-23 | 17:00 | Daily | Line CT, Sync CVT Tan delta, IR values & Routine maintenance and and isolator maintenance work . | MSETCL | MSETCL | 400KV, 125MVAR Bus reactor charged on own main CB (Bay no.402) |
| 15 | 400 KV | 400/220/33 KV 315 MVA ICT - 1 @ WALUJ | 06-Jan-23 | 10:00 | 06-Jan-23 | 18:00 | Daily | Diagnostic Testing & Routine Maintenance work | MSETCL | MSETCL | NIL |
| 16 | 400 KV | GTR - 9 @ CHANDRAPUR SWITCHING SS | 06-Jan-23 | 09:00 | 06-Jan-23 | 17:00 | Daily | Diagnostic testing and allied bay maintenance work | MSETCL | MSETCL | Diagnostic testing and allied bay maintenance work |
| 17 | 400 KV | LONKAND I - KOYNA STAGE-IV | 06-Jan-23 | 08:00 | 06-Jan-23 | 17:00 | Daily | PID Faulty disc insulator replacement work & Cold & Chemical line washing work | MSETCL | MSETCL | PID Faulty disc insulator replacement work & Cold & Chemical line washing work |
| 18 | 400 KV | CHANDRAPUR - KHAPERKHEDA | 06-Jan-23 | 08:00 | 06-Jan-23 | 18:00 | Daily | 1) Measurement Circuit Breaker timing, CRM & DCRM. 2) Maintenance and alignments of PG-1 & PG-2 Isolator. | MSETCL | MSETCL | This circuit will be in service via 400KV TBC-1 |
| 19 | 400 KV | NEW KOYNA-KARAD CKT - 1 | 07-Jan-23 | 08:00 | 07-Jan-23 | 17:00 | Daily | PID Faulty disc insulator replacement work & Cold & Chemical line washing work | MSETCL | MSETCL | PID Faulty disc insulator replacement work & Cold & Chemical line washing work |
| 20 | 400 KV | 400/220kv 500MVA ICT-1 @ TAPTITANDA | 07-Jan-23 | 10:00 | 07-Jan-23 | 18:00 | Daily | Diagnostic testing work, SFRA, DFR of ICT, IV CB Testing work, quarterly maintenance work. | MSETCL | MSETCL | Load can be managed on ICT-II |
| 21 | 400 KV | CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1 | 08-Jan-23 | 08:00 | 08-Jan-23 | 18:00 | Daily | Routine maintenance work. | MSETCL | MSETCL | . |
| 22 | 400 KV | CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2 | 09-Jan-23 | 08:00 | 11-Jan-23 | 18:00 | Daily | For replacement of polymer Insulator to antifog Long ROD Porcelain Insulator | MSETCL | MSETCL | . |
| 23 | 400 KV | KARAD - TALANDGE CKT - 1 | 09-Jan-23 | 08:00 | 09-Jan-23 | 18:00 | Daily | PID Faulty disc insulator replacement work & Cold line washing work | MSETCL | MSETCL | PID Faulty disc insulator replacement work & Cold line washing work |
| 24 | 400 KV | TBC @ PARLI | 09-Jan-23 | 09:00 | 09-Jan-23 | 18:00 | Daily | (1) Breaker testing work. (2) Bay maintenance work. | MSETCL | MSETCL | - |
| 25 | 400 KV | 400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE | 09-Jan-23 | 08:00 | 09-Jan-23 | 17:00 | Daily | Regular Maint work and Dignostic testing work | MSETCL | MSETCL | nil |
| 26 | 400 KV | 500 MVA 400/220 KV ICT -I @ CHANDRAPUR 2 | 09-Jan-23 | 09:00 | 10-Jan-23 | 18:00 | Continuou s | Diagnostic testing and allied bay maintenance work | MSETCL | MSETCL | Diagnostic testing and allied bay maintenance work |
| 27 | 400 KV | KARAD - TALANDGE CKT - 2 | 10-Jan-23 | 08:00 | 10-Jan-23 | 18:00 | Daily | PID Faulty disc insulator replacement work & Cold line washing work | MSETCL | MSETCL | PID Faulty disc insulator replacement work & Cold line washing work |
| 28 | 400 KV | GTR - 3 @ CHANDRAPUR SS | 10-Jan-23 | 08:00 | 10-Jan-23 | 18:00 | Continuou s | "1) Measurement Circuit Breaker timing, CRM & DCRM. 3) Maintenance and alignments of PG-1 & PG-2 Isolator." 4) This circuit will be in service via 400KV TBC-1 | MSETCL | MSETCL | This circuit will be in service via 400KV TBC-1 |
| 29 | 400 KV | PADGHE - NAGOTHANE CKT - 1 | 10-Jan-23 | 08:00 | 10-Jan-23 | 17:00 | Daily | string replacement and earthwire stringing work | MSETCL | MSETCL | nil |
| 30 | 400 KV | KHADKA-AURANGABAD (WALUJ) | 10-Jan-23 | 10:00 | 10-Jan-23 | 18:00 | Daily | Diagnostic Testing & Routine Maintenance work | MSETCL | MSETCL | NIL |

| Sr.No. | Line Equipment | From Date | From Time | To Date | To Time | Basis | Reason | System | Agency | Remark .If any. | |
|--------|----------------|--|-----------|---------|-----------|-------|-------------|--|--------|-----------------|---|
| 31 | 400 KV | KARAD - TALANDGE CKT - 1 | 11-Jan-23 | 08:00 | 11-Jan-23 | 20:00 | Daily | C bus PG isolator overhauling work. Quarterly maintenance work | MSETCL | MSETCL | Tuesday is load staggering day at Karad. 400KV Karad 2 will be in service |
| 32 | 400 KV | 400KV RPL-AKOLA2 CKT 1 | 11-Jan-23 | 08:00 | 11-Jan-23 | 17:00 | Daily | Outage required for routine maintenance of 400KV RPL to Akola II Line I. | APTCL | APTCL | Outage required for routine maintenance of 400KV RPL to Akola II Line I. |
| 33 | 400 KV | 400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA | 11-Jan-23 | 10:00 | 11-Jan-23 | 17:00 | Daily | Diagnostic Testing of CBs | MSETCL | MSETCL | - |
| 34 | 400 KV | 400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE | 11-Jan-23 | 08:00 | 11-Jan-23 | 17:00 | Daily | Regular Maint work and Dignostic testing work | MSETCL | MSETCL | nil |
| 35 | 400 KV | 80 MVA BUS REACTOR - 1 @ BABHALESHWAR | 11-Jan-23 | 09:00 | 11-Jan-23 | 17:00 | Daily | CT Tan D, Winding Tan D, SFRA, DFRA and bay maintenance work | MSETCL | MSETCL | Reactor will be taken in service after 18:00 hrs i.e at peak voltage hours |
| 36 | 400 KV | KORADI - KHAPARKHEDA CKT - 2 | 11-Jan-23 | 10:00 | 11-Jan-23 | 20:00 | Daily | FOR ATTENDING BUS-2 PG ISOLATOR Y PHASE ROTARY PROBLEM BY AGENCY | MSETCL | MSETCL | After removing faulty scissor of PG isolator , 400KV Khaperkheda Ckt-2 shifted on 400KV TBC. Outages will be availed subject to weather conditions. |
| 37 | 400 KV | NEW KOYNA-KARAD CKT - 2 | 12-Jan-23 | 08:00 | 12-Jan-23 | 17:00 | Daily | PID Faulty disc insulator replacement work & Cold line washing work | MSETCL | MSETCL | PID Faulty disc insulator replacement work & Cold line washing work |
| 38 | 400 KV | KHADKA - BABLESHWAR | 12-Jan-23 | 08:00 | 13-Jan-23 | 18:00 | Daily | Chemical Cleaning of Insulator string and Routine Line maintenance work | MSETCL | MSETCL | 400kv Ektuni ckt I&II 400kv Aurangabad , Dhule I&II will be in service |
| 39 | 400 KV | CHANDRAPUR-PARLI CKT-3 | 12-Jan-23 | 08:00 | 12-Jan-23 | 18:00 | Daily | For replacement of polymer Insulator to antifog Long ROD Porcelain Insulator | MSETCL | MSETCL | . |
| 40 | 400 KV | PARLI - KUMBHARGAON(NANDED) CKT - 2 | 12-Jan-23 | 09:00 | 12-Jan-23 | 18:00 | Daily | (1) Relay testing work (2) Line Maintenance Work for Hardware tightening & fitting work. (3) Bay maintenance work. | MSETCL | MSETCL | - |
| 41 | 400 KV | PADGHE - NAGOTHANE CKT - 2 | 12-Jan-23 | 08:00 | 12-Jan-23 | 17:00 | Daily | String replacement and earth wire restringing work | MSETCL | MSETCL | NIL |
| 42 | 400 KV | TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA | 12-Jan-23 | 09:00 | 12-Jan-23 | 17:00 | Daily | Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work . | MSETCL | MSETCL | only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB. |
| 43 | 400 KV | 400KV KORADI-BHUSAWAL (Koradi end) | 12-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | Daily | ONLINE PID WORK | MSETCL | MSETCL | PID WITH AR IN NON AUTO MODE |
| 44 | 400 KV | 400KV RPL-AKOLA 2 CKT 2 | 13-Jan-23 | 08:00 | 13-Jan-23 | 17:00 | Daily | Outage required for routine maintenance of 400KV RPL to Akola II Line II. | APTCL | APTCL | Outage required for routine maintenance of 400KV RPL to Akola II Line II. |
| 45 | 400 KV | STATION TF 8B @ CHANDRAPUR SWITCHING | 13-Jan-23 | 10:00 | 13-Jan-23 | 18:00 | Daily | Diagnostic testing and allied bay maintenance work | MSETCL | MSETCL | Diagnostic testing and allied bay maintenance work |
| 46 | 400 KV | CHANDRAPUR-PARLI CKT-3 | 13-Jan-23 | 08:00 | 13-Jan-23 | 18:00 | Daily | For replacement of polymer Insulator to antifog Long ROD Porcelain Insulator | MSETCL | MSETCL | . |
| 47 | 400 KV | CHANDRAPUR-PARLI CKT-3 | 13-Jan-23 | 09:00 | 13-Jan-23 | 18:00 | Daily | Hardware tightening & fitting work. | MSETCL | MSETCL | - |
| 48 | 400 KV | 400/220/33 KV 500MVA ICT - 1 @ KORADI 2 | 13-Jan-23 | 10:00 | 13-Jan-23 | 17:00 | Daily | Diagnostic Testing of ICT and routine bay maintenance work | MSETCL | MSETCL | 501 MVA 400/220/33 KV ICT-1 will remain in service as alternate source of supply |
| 49 | 400 KV | 400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE | 13-Jan-23 | 08:00 | 13-Jan-23 | 17:00 | Daily | Regular Maint work and Dignostic testing work | MSETCL | MSETCL | nil |
| 50 | 400 KV | 400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR | 14-Jan-23 | 09:00 | 14-Jan-23 | 17:00 | Daily | CB Timing,DCRM,REF,NDR,SFRA and bay maintenance work | MSETCL | MSETCL | ICT 1, 3 and 4 will be in service |
| 51 | 400 KV | CHANDRAPUR-PARLI CKT-3 | 14-Jan-23 | 08:00 | 14-Jan-23 | 18:00 | Daily | For replacement of polymer Insulator to antifog Long ROD Porcelain Insulator | MSETCL | MSETCL | . |
| 52 | 400 KV | LONIKAND - JEJURI CKT - 2 | 15-Jan-23 | 08:00 | 17-Jan-23 | 18:00 | Daily | PID scanning of insulator strings | MSETCL | MSETCL | - |
| 53 | 400 KV | 400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR | 16-Jan-23 | 08:00 | 16-Jan-23 | 20:00 | Daily | C bus PG isolator overhauling work. | MSETCL | MSETCL | Monday is load staggering day. 501 MVA ICT 1 and 501MVA ICT 3 will be in service |
| 54 | 400 KV | 500 MVA 400/220 KV ICT - II @ CHANDRAPUR 2 | 16-Jan-23 | 09:00 | 17-Jan-23 | 18:00 | Continuou s | Diagnostic testing and allied bay maintenance work | MSETCL | MSETCL | Diagnostic testing and allied bay maintenance work |
| 55 | 400 KV | 400/220/33 KV 500MVA ICT - 2 @ KORADI 2 | 17-Jan-23 | 11:00 | 17-Jan-23 | 17:00 | Daily | Diagnostic Testing of ICT and routine bay maintenance work | MSETCL | MSETCL | 502 MVA 400/220/33 KV ICT-I will remain in service as alternate source of supply |
| 56 | 400 KV | 400/220/33 KV 315MVA ICT - 1 @ AKOLA | 17-Jan-23 | 10:00 | 17-Jan-23 | 17:00 | Daily | DCRM, Tandella CT, CRM CB, Breaker Timing Tower Erection work for new ICT -03 | MSETCL | MSETCL | Load shifted on ICT-02 |
| 57 | 400 KV | WARORA - IEPL | 17-Jan-23 | 10:00 | 17-Jan-23 | 18:00 | Daily | Routine line maintenance work | MSETCL | MSETCL | 400 KV KORADI 2-WARDHA PGCL Line is in ckt |
| 58 | 400 KV | KARAD - TALANDGE CKT - 2 | 17-Jan-23 | 08:00 | 17-Jan-23 | 20:00 | Daily | C bus PG isolator overhauling work. | MSETCL | MSETCL | Tuesday is load staggering day at Karad. 400kv Karad 1 will be in service. |
| 59 | 400 KV | 125MVA BUS REACTOR @ WARORA | 17-Jan-23 | 09:00 | 17-Jan-23 | 17:00 | Daily | Maintenance work | MSETCL | MSETCL | Reactor kept in OFF position. |
| 60 | 400 KV | KORADI - KHAPARKHEDA CKT - 2 | 18-Jan-23 | 10:00 | 18-Jan-23 | 17:00 | Daily | Diagnostic Testing of CBs | MSETCL | MSETCL | - |
| 61 | 400 KV | JEJURI - KARAD | 18-Jan-23 | 08:00 | 18-Jan-23 | 18:00 | Daily | PID Faulty disc insulator replacement work & Cold line washing work | MSETCL | MSETCL | PID Faulty disc insulator replacement work & Cold line washing work |

| Sr.No. | Line Equipment | From Date | From Time | To Date | To Time | Basis | Reason | System | Agency | Remark .If any. | |
|--------|----------------|--|-----------|---------|-----------|-------|-------------|---|--------|-----------------|---|
| 62 | 400 KV | JEJURI - KARAD | 18-Jan-23 | 08:00 | 22-Jan-23 | 18:00 | Daily | PID scanning of insulator strings | MSETCL | MSETCL | - |
| 63 | 400 KV | 400/220/33KV 315MVA ICT - 2 @ LONIKAND | 19-Jan-23 | 08:00 | 20-Jan-23 | 20:00 | Continuou s | DT & Bay Maintenance Work &O/H & Servicing of 29A PG Isolator & Replacement of PGI mechanism box. | MSETCL | MSETCL | - |
| 64 | 400 KV | 400/220/33 KV 500 MVA ICT - 3 @ JEJURI | 19-Jan-23 | 09:00 | 19-Jan-23 | 18:00 | Daily | Annual testing & maintenance. | MSETCL | MSETCL | During outage ICT 1 & ICT 2 will be service. |
| 65 | 400 KV | FUTURE CKT - 1 @ WARORA | 19-Jan-23 | 09:00 | 19-Jan-23 | 17:00 | Daily | Relay testing work & routine maintenance work. | MSETCL | MSETCL | In Dia the 400KV IEPCL ckt charged on its Main Bay CB |
| 66 | 400 KV | KORADI-NANDGAONPETH (RPL) | 20-Jan-23 | 09:00 | 20-Jan-23 | 18:00 | Daily | CB CRM/DCRM/TIMING WORK | MSETCL | MSETCL | Outages will be availed subject to weather conditions. |
| 67 | 400 KV | 400/220KV 105 MVA SPARE ICT - 1 @ BABHALESHWAR | 20-Jan-23 | 09:00 | 20-Jan-23 | 17:00 | Daily | CT Tan D Bushing Winding Tan D Excitation current | MSETCL | MSETCL | 105 MVA Spare ICT-1 not charged |
| 68 | 400 KV | 400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 1(CHPR1 END) | 20-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | Continuou s | Required for Main Bus -1 outage work. | MSETCL | MSETCL | Required for replacement of faulty string of 400KV Main Bus-1 this bay section |
| 69 | 400 KV | 400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 2 (CHPR 1 1END) | 20-Jan-23 | 08:00 | 21-Jan-23 | 18:00 | Continuou s | Required for Main Bus -1 outage work, Howeve this feeder will be in service via 400KV TBC-1. | MSETCL | MSETCL | Required for Main Bus -1 outage work, Howeve this feeder will be in service via 400KV TBC-1. |
| 70 | 400 KV | 400/220/33 KV 315MVA ICT - 2 @ AKOLA | 20-Jan-23 | 10:00 | 20-Jan-23 | 17:00 | Daily | DCRM, Tandelta CT, CRM CB, Breaker Timing Tower Erection work for new ICT -03 | MSETCL | MSETCL | Load shifed on ICT-01 |
| 71 | 400 KV | 400 KV FUTURE BAY II @ WARORA | 20-Jan-23 | 09:00 | 20-Jan-23 | 17:00 | Daily | Relay testing work & routine maintenance work. | MSETCL | MSETCL | In Dia the 400KV PGCL (NAGRI) ckt charged on its Main Bay CB. |
| 72 | 400 KV | DHULE - BABLESHWAR - II | 20-Jan-23 | 08:00 | 20-Jan-23 | 18:00 | Daily | cold line washing of insulator string and routine Line maintenance work | MSETCL | MSETCL | 400kv Ektuni ckt I&II,400kv Bhusawal,400kv Aurangabad and Dhule I will be in in service |
| 73 | 400 KV | DHULE - BABLESHWAR - I | 20-Jan-23 | 08:00 | 20-Jan-23 | 18:00 | Daily | work of cold line washing of insulator string and routine Line maintenance work on 400kv Dhule-BBLR line II | MSETCL | MSETCL | 400kv Ektuni ckt I&II,400kv Bhusawal,400kv Aurangabad and Dhule I will be in in service |
| 74 | 400 KV | 400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR | 21-Jan-23 | 09:00 | 21-Jan-23 | 17:00 | Daily | MTAMC Work and bay maintenance work | MSETCL | MSETCL | ICT 1, 2, 4 will be in service |
| 75 | 400 KV | 400/220kv 500MVA ICT-2 @ TAPTITANDA | 21-Jan-23 | 10:00 | 21-Jan-23 | 18:00 | Daily | ICT Diagnostic testing work, Quarterly maintenance work | MSETCL | MSETCL | Load Can be managed on ICT-I |
| 76 | 400 KV | 400/220KV 315MVA ICT - 3 @ CHAKAN | 21-Jan-23 | 10:00 | 21-Jan-23 | 21:00 | Daily | For Overhauling of Bus B 89B Rph, Yph, Bph PG Isolators and Routine Testing and Maintenance Work. | MSETCL | MSETCL | ICT-3 will be in service through 400 kv TBC. |
| 77 | 400 KV | LONIKAND - JEJURI CKT - 1 | 21-Jan-23 | 08:00 | 31-Jan-23 | 18:00 | Daily | PID Testing work | MSETCL | MSETCL | Line will be in service |
| 78 | 400 KV | KORADI-NANDGAONPETH (RPL) | 22-Jan-23 | 08:00 | 30-Jan-23 | 18:00 | Daily | ONLINE PID WORK | MSETCL | MSETCL | PID WITH AR IN NON AUTO MODE |
| 79 | 400 KV | 400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR | 23-Jan-23 | 08:00 | 23-Jan-23 | 20:00 | Daily | C bus PG isolator overhauling work. | MSETCL | MSETCL | Monday is load staggering day. 315MVA ICT 2 and 501 MVA ICT 3 will be in service. |
| 80 | 400 KV | CHANDRAPUR - KHAPERKHEDA | 23-Jan-23 | 08:00 | 23-Jan-23 | 18:00 | Daily | Conductor & Earthwire Hardware tightening work & Replacement disc Insulator if found during PID | MSETCL | MSETCL | Conductor & Earthwire Hardware tightening work & Replacement disc Insulator if found during PID |
| 81 | 400 KV | 400/220/33 KV 500 MVA ICT - 3 @ PARLI | 23-Jan-23 | 09:00 | 23-Jan-23 | 18:00 | Daily | (1)HV backup relay & IV CT testing work. (2) Bay maintenance work. | MSETCL | MSETCL | - |
| 82 | 400 KV | Akola II (Yelwan) - Akola I CKT - 2 | 24-Jan-23 | 10:00 | 24-Jan-23 | 17:00 | Daily | DCRM, Tandelta, CRM, Breaker Timing & routine maintenance | APTCL | APTCL | Yelwan Ckt-01 Will be in service |
| 83 | 400 KV | DHULE - BABLESHWAR - I | 24-Jan-23 | 09:00 | 24-Jan-23 | 18:00 | Daily | For replacement of PID suspicious insulator strings & maintenance work | MSETCL | MSETCL | 400 kv DHL-BBLR-II /A/R switch willbe put on non auto mode |
| 84 | 400 KV | 400 /7.6KV Station T/F-5 A @ KHAPERKHEDA | 25-Jan-23 | 10:00 | 25-Jan-23 | 17:00 | Daily | Diagnostic Testing of CBs | MSETCL | MSETCL | - |
| 85 | 400 KV | DHULE - BABLESHWAR - II | 25-Jan-23 | 09:00 | 25-Jan-23 | 18:00 | Daily | for replacement of PID suspicious insulator strings & maintenance work. | MSETCL | MSETCL | 400 kv DHL-BBLR -I /A/R switch will be kept on non auto mode |
| 86 | 400 KV | 400/220/33 KV 315 MVA ICT - 1 @ LONIKAND | 26-Jan-23 | 08:00 | 27-Jan-23 | 20:00 | Continuou s | DT & Bay Maintenance Work. O/H & Serviceing of 29A PG Isolator & Replacement of PGI mechanism box. | MSETCL | MSETCL | - |
| 87 | 400 KV | 400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 1(CHPR1 END) | 27-Jan-23 | 08:00 | 28-Jan-23 | 18:00 | Continuou s | Required for Main Bus -2 outage work. | MSETCL | MSETCL | Required for replacement of faulty string of 400KV Main Bus-2. |
| 88 | 400 KV | 400/220 KV 500 MVA ICT - 5 @ PADGHE | 27-Jan-23 | 06:00 | 27-Jan-23 | 08:00 | Daily | 1) 500MVA ICT-5 HV side on TBC for 2 hrs for removing IPS tube between A & B bus PG isolator 2)ICT -5 will be charged on B bus | MSETCL | MSETCL | 1) Agency will be present on site |
| 89 | 400 KV | DHULE - BABLESHWAR - II | 27-Jan-23 | 08:00 | 27-Jan-23 | 18:00 | Daily | cold line washing of insulator string and routine Line maintenance work | MSETCL | MSETCL | 400kv Ektuni ckt I&II,400kv Bhusawal,400kv Aurangabad and Dhule I will be in in service |
| 90 | 400 KV | DHULE - BABLESHWAR - I | 27-Jan-23 | 08:00 | 27-Jan-23 | 18:00 | Daily | work of cold line washing of insulator string and routine Line maintenance work on Dhule -BBLR ckt II | MSETCL | MSETCL | 400kv Ektuni ckt I&II,400kv Bhusawal,400kv Aurangabad and Dhule I will be in in service |
| 91 | 400 KV | 400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR | 28-Jan-23 | 09:00 | 28-Jan-23 | 17:00 | Daily | LV CB Timing DCRM , DFRA and Quarterly Bay Maintenance work | MSETCL | MSETCL | ICT 1, 2, 3 will be in service |

| Sr.No. | Line Equipment | From Date | From Time | To Date | To Time | Basis | Reason | System | Agency | Remark .If any. | |
|--------|----------------|---------------------------------------|-----------|---------|-----------|-------|--------|---|--------|-----------------|--|
| 92 | 400 KV | 400/220 KV 500 MVA ICT - 5 @ PADGHE | 29-Jan-23 | 18:00 | 29-Jan-23 | 20:00 | Daily | 1) ICT-5 HV side on TBC for re connection of IPS to tube between A & B bus PG Isolator. 2) after work ICT -5 will be charge on own CB. | MSETCL | MSETCL | Weather condition should be clear |
| 93 | 400 KV | 400/220/33 KV 315 MVA ICT - 2 @ PARLI | 30-Jan-23 | 09:00 | 30-Jan-23 | 18:00 | Daily | (1)HV backup relay & IV CT testing work. (2) Bay maintenance work. | MSETCL | MSETCL | - |
| 94 | 400 KV | 400/220/33 KV 315MVA ICT - 1 @ CHAKAN | 31-Jan-23 | 10:00 | 31-Jan-23 | 21:00 | Daily | For Overhauling of Bus B 89B Rph, Yph, Bph PG Isolators and Routine Testing and Maintenance Work. | MSETCL | MSETCL | ICT-1 will be in service through 400 KV TBC. |