

Maharashtra State Load Despatch Centre													
Monthly Outage list approved in WRLDC OCCM for the Month of January 2024													
Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks	
1	2	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	Bunching at Loc.No.03 & Loc.No132 of 400kv padghe kharghar line (Dead line) for HTLS in dead portion of PADGHE - KALWA CKT - 1	11/12/2023	08:30	25/01/2024	18:00	After above arrangement Tapping of 400KV Kharghar - Talegoan line at Loc no.9 will be done with 400KV Padgha-Kharghar line to form Temporary 400kv Padghe - kharghar-Talegoan line.	
2	19	PLANNED	OCC_574	MSLDC_OUTAGE	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV - BUS 2 at BABLESHWAR - 400KV	C	CB pole overhauling work	01/01/2024	09:00	04/01/2024	18:00	400 KV Main Bus I and II will be separated	
3	20	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY (402) of WALUJ @ TAPTITANDA (Element not found)	C	CB mechanism Overhauling Work through M/s CGL	01/01/2024	11:00	04/01/2024	18:00	Continuous outage required for CB Mechanism overhauling work.	
4	26	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	PID work. only A/R out of service during PID work.	01/01/2024	08:00	15/01/2024	18:00	only A/R out of service during PID work.	
5	27	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	PID work. only A/R out of service during PID work.	01/01/2024	08:00	15/01/2024	18:00	only A/R out of service during PID work.	
6	31	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY - 400KV-AKOLA (2)-NANDGAONPETH-2 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	D	Replacement of earthwire & Routine Maint. Work	01/01/2024	09:00	16/01/2024	18:00	NA	
7	32	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing work. only A/R out of service during PID work.	01/01/2024	09:00	16/01/2024	18:00	-	
8	33	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing work. only A/R out of service during PID work.	01/01/2024	09:00	16/01/2024	18:00	-	
9	36	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	Outage is required for Insulator String PID Testing.	01/01/2024	10:00	24/01/2024	18:00	work will be carried out by hot line method. Only A/R at Jeur & PGCIL end required out of service during outage	
10	37	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-2	D	FOR PID WORK (JAIGAD-KARAD CKT2 AR OUT)	01/01/2024	09:00	27/01/2024	18:00	FOR PID WORK (JAIGAD-KARAD CKT2 AR OUT)	
11	38	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KARAD-JAIGAD-1	D	FOR PID WORK (JAIGAD-KARAD CKT1 AR OUT)	01/01/2024	09:00	27/01/2024	18:00	FOR PID WORK (JAIGAD-KARAD CKT1 AR OUT)	
12	40	PLANNED	OCC_574	APML	400KV/21KV TIRODA-GT-3	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	01/01/2024	00:00	31/01/2024	18:00		
13	63	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	AR disable for replacement of insulator in live line method.	01/01/2024	08:00	15/01/2024	18:00	AR disable	
14	64	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	AR disable for replacement of insulator in live line method.	01/01/2024	08:00	15/01/2024	18:00	AR disable	
15	65	PLANNED	OCC_574	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for replacement of insulator in live line method.	01/01/2024	08:00	15/01/2024	18:00	AR disable	
16	77	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Auto reclose OFF required for OPGW stringing work by replacement of existing Earthwire in Live line condition	01/01/2024	08:00	31/01/2024	18:00	400kv Babhaleshwar-Padghe Ckt -1 Auto reclose OFF is also required for OPGW stringing work on 400kV Babhaleshwar-Padghe Double circuit tower line section from loc 1 to 59.	
17	78	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	01/01/2024	08:00	31/01/2024	18:00	--	
18	80	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For Online PID (Puncture insulation Detection)Work of 400 KV Dhule-SSNNL CKT 1. Auto Reclose switch will be kept on Non Auto mode during Outage period.	01/01/2024	09:00	31/01/2024	15:00	400 KV Dhule-SSNNL CKT 1 Auto Reclose switch will be kept on Non Auto mode during Outage period	
19	81	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/01/2024	09:00	31/01/2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
20	82	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/01/2024	09:00	31/01/2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
21	83	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/01/2024	09:00	31/01/2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
22	84	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/01/2024	09:00	31/01/2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
23	85	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID testing work only A/R out of service during PID work.	01/01/2024	09:00	31/01/2024	17:00	-
24	86	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For Online PID (Puncture insulation Detection)Work of 400 KV Dhule-SSNNL CKT 2. Auto Reclose switch will be kept on Non Auto mode during Outage period.	01/01/2024	09:00	31/01/2024	18:00	400 KV Dhule-SSNNL CKT 2 Auto Reclose switch will be kept on Non Auto mode during Outage period
25	87	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-JEJURI-KOYNA STAGE IV-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/01/2024	09:00	31/01/2024	18:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
26	88	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KOYNA STAGE IV-LONIKHAND-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01/01/2024	09:00	31/01/2024	18:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
27	89	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID testing work . only A/R out of service during PID work.	01/01/2024	09:00	31/01/2024	18:00	-
28	90	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY - 400KV-AKOLA-AKOLA (2)-2 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	D	For PID work, shifting of auto reclose switch to non auto mode	01/01/2024	11:00	31/01/2024	15:00	.
29	143	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY - 400KV-WARORA-CHANDRAPU-II-2 AND 400KV-TIRODA-WARORA-1 at WARORA - 400KV	D	Routine maintenance and IR Values, Testing works and isolator maintenance work .	02/01/2024	09:00	02/01/2024	17:00	only Tie CB 412 is in OFF condition, respective ckt charged through its own main CB.
30	144	PLANNED	OCC_574	MEGPTCL	TIE BAY - 765KV-AKOLA (2)-KORADI-III-1 AND 765KV-TIRODA-KORADI-III-2 at KORADI-III - 765KV	D	Annual maintenance of CB at Koradi- III SS.	02/01/2024	09:00	02/01/2024	18:00	Bay Outage
31	149	PLANNED	OCC_574	MSLDC_OUTAGE	KARAD - 400KV - BUS 1	D	for Hot line work for installation of pilot string at Bus gantry near Jaigad Bay & 125 MVAR reactor.	02/01/2024	10:00	04/01/2024	17:00	Hot line method
32	203	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY - 765KV-AKOLA (2)-KORADI-III-1 AND 765KV-TIRODA-KORADI-III-2 at KORADI-III - 765KV	D	Routine Maintenance & Diagnostic Testing Work	03/01/2024	08:00	03/01/2024	17:00	Routine Maintenance & Diagnostic Testing Work
33	205	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY - 400KV-AKOLA (2)-FUTURE-5 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	D	Routine Maintenance & Dignostic testing work .	03/01/2024	09:00	03/01/2024	17:00	400KV WARORA-IEPL Line is in ckt
34	206	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	03/01/2024	09:00	03/01/2024	18:00	-
35	207	PLANNED	OCC_574	MEGPTCL	AKOLA (2) - 400KV - BUS 1	D	For Annual Testing of Bus CVT & LED light installation.	03/01/2024	09:30	03/01/2024	18:30	Bus Outage
36	208	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-SOLAPUR-BALE-1	D	Outage is required for Quarterly Maintenance	03/01/2024	10:00	03/01/2024	18:00	Quarterly Maintenance
37	211	PLANNED	OCC_574	MUML-Sterlite	400kv Bhableswar - Padghe Ckt I & II	D	For hot-line stringing of 400kv D/C Padghe - Kharghar Transmission line	03/01/2024	09:00	04/01/2024	18:00	For hot-line stringing of 400kv D/C Padghe - Kharghar Transmission line
38	212	PLANNED	OCC_574	MSLDC_OUTAGE	400KV/220KV CHANDRAPU-II-ICT-1	D	Diagnostic testing & allied bay maintenance work	03/01/2024	10:00	04/01/2024	18:00	Diagnostic testing & allied bay maintenance work
39	269	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	D	PID detected weak strings replacement. Cold line washing of insulator strings and DT Work & Bay Maintenance	04/01/2024	08:00	04/01/2024	18:00	Nil
40	270	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	04/01/2024	08:00	04/01/2024	18:00	--
41	271	PLANNED	OCC_574	MSLDC_OUTAGE	220 KV-WARDHA-YAWATMAL-1	D	Maintenance work	04/01/2024	08:00	04/01/2024	18:00	--
42	273	PLANNED	OCC_574	MSLDC_OUTAGE	765KV-AKOLA (2)-EKTUNI-1	D	Half yearly maintenance	04/01/2024	09:00	04/01/2024	17:00	-

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
43	274	PLANNED	OCC_574	MEGPTCL	AKOLA (2) - 400KV - BUS 2	D	For Annual Testing of Bus CVT & LED light installation.	04/01/2024	09:30	04/01/2024	18:30	Bus Outage
44	347	PLANNED	OCC_574	MSLDC_OUTAGE	AKOLA (2) - 765KV - BUS 1	D	For connecting the new bus sectionaliser jumper to 220kV Bus	05/01/2024	08:00	05/01/2024	18:00	220kV half bus outage is required for carrying out the above work.
45	348	PLANNED	OCC_574	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Connection of 501 MVA ICT V isolator jumps to Main Bus I by Hotline method	05/01/2024	09:00	05/01/2024	13:00	Work will be done online through Hotline method
46	349	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Dignostic testing work .	05/01/2024	09:00	05/01/2024	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
47	350	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY OF 400KV-TAPTHITHANDA-EKTUNI-1 AND EKTUNI - 400KV - BUS 1 @EKTUNI - 400KV at EKTUNI - 400KV	D	Routine Maintenance & Diagnostic Testing Work	05/01/2024	09:00	05/01/2024	18:00	Routine Maintenance & Diagnostic Testing Work (404 MAIN BAY)
48	351	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Connection of 501 MVA ICT V isolator jumps to Main Bus II by Hotline method	05/01/2024	13:00	05/01/2024	18:00	Work will be done online through Hotline method
49	357	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY OF 220KV-BOISAR-BOISAR-M-3 AND BOISAR-M - 220KV - BUS 1 @BOISAR-M - 220KV at BOISAR-M - 220KV	C	CB overhauling work after shifting the line on TBC.	05/01/2024	07:00	06/01/2024	18:00	Line Will be in service through TBC.
50	358	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Cold Washing Work	05/01/2024	08:00	06/01/2024	18:00	---
51	359	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV PADGHE-ICT-4 AND PADGHE - 400KV - BUS 1 @PADGHE - 400KV at PADGHE - 400KV	C	1.HV CB Overhauling Work. 2.A & B Bus PG Isolator Maintenance Work. 3.ICT-04 in service Through TBC.	05/01/2024	08:00	08/01/2024	22:00	Weather condition should be clear.
52	360	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	Replacement of existing conductor by HTLS conductor.	05/01/2024	22:00	08/01/2024	06:00	Replacement of existing conductor by HTLS conductor.
53	406	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Outage required for attending defects identified in PID testing, Monkey/Drone Patrolling and Cold washing of Dust polluted Insulator Strings.	06/01/2024	08:00	06/01/2024	18:00	400kV Babhaleshwar -Padghe Ckt -2 will be available.
54	407	PLANNED	OCC_574	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	BUS PT Capacitance and tan D testing	06/01/2024	09:00	06/01/2024	18:00	All feeders and ICTs on Main Bus I will be shifted on Main Bus II through TBC
55	408	PLANNED	OCC_574	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	D	Six monthly changeover of Spare -Ph Reactor to taken in service in place of B- Ph reactor as per CEA regulation at Akola- II SS. Last changeover date 15.07.2023. Non-Switchable Reactor at Akola SS.	06/01/2024	09:30	06/01/2024	18:30	Line Outage
56	409	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	For safety purpose only. Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).	06/01/2024	07:00	07/01/2024	18:00	For safety purpose only. Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).
57	410	PLANNED	OCC_574	MSLDC_OUTAGE	POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ PADGHE HVDC (Element not forund)	C	400 kV Ciruit Breaker B-ph Pole overhauling work.  CB Mechanisum box overhauling work. Filter jumper replacement work with new.	06/01/2024	08:00	07/01/2024	08:00	CB Pole & Mechanisum overhauling is due hence it need to be done. and Filter jumper aged and rusted so need to be replaced on urgent basis.

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
58	413	PLANNED	OCC_574	MSLDC_OUTAGE	KALWA - 400KV - BUS 1	C	For stub bus HTLS conductor stringing work of 400kV Kalwa-Padgha-2 line above live 400kV B-Bus by Partial outage on 400kV Main Bus-1 at 400kV RS Kalwa. For carrying out the work following operations will be carried out: 1) 400 KV Kharghar line  shifted to B Bus through TBC 2) Removing of A bus Quadera jumper (R,Y & B ph) to make A bus partially dead By hot line unit. 3) On 07.01.2023 @00:00 Hrs to 08.01.2024 till 24:00 Hrs Stringing of HTLS conductor in Stub bus of 400 KV Padgha II line will be carried out. 4) Quadra A bus jumper (R,Y & B ph) connection work by hot line unit	06/01/2024	06:00	08/01/2024	18:00	For stub bus HTLS conductor stringing work of 400kV Kalwa-Padgha-2 line above live 400kV B-Bus by Partial outage on 400kV Main Bus-1 at 400kV RS Kalwa. For carrying out the work following operations will be carried out: 1) 400 KV Kharghar line  shifted to B Bus through TBC 2) Removing of A bus Quadera jumper (R,Y & B ph) to make A bus partially dead By hot line unit. 3) On 07.01.2023 @00:00 Hrs to 08.01.2024 till 24:00 Hrs Stringing of HTLS conductor in Stub bus of 400 KV Padgha II line will be carried out. 4) Quadra A bus jumper (R,Y & B ph) connection work by hot line unit
59	424	PLANNED	OCC_574	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 1	D	Regular Maint work and Dignostic testing work	07/01/2024	08:00	07/01/2024	17:00	NA
60	425	PLANNED	OCC_574	MSLDC_OUTAGE	AKOLA - 765KV - BUS 2	D	Outage required for attending defects identified in PID testing, Monkey/Drone Patrolling and Cold washing of Dust polluted Insulator Strings.	07/01/2024	08:00	07/01/2024	18:00	400kV Babhaleshwar -Padghe Ckt -1 will be available.
61	426	PLANNED	OCC_574	MEGPTCL	765KV-AKOLA (2)-KORADI-III-1 L/R@ KORADI-III - 765KV	D	Six monthly changeover of B-Ph Reactor to be taken in service in place of Spare Ph Reactor as per CEA regulation at Koradi- III SS. Last changeover date 09.07.2023.	07/01/2024	09:00	07/01/2024	14:00	Line Reactor Outage. Last changeover date 09.07.2023.
62	427	PLANNED	OCC_574	MEGPTCL	AKOLA - 765KV - BUS 2	D	Six monthly changeover of B-PH Reactor to be taken in service in place of Spare Ph Reactor as per CEA regulation at Koradi- III SS. Last changeover date 09.07.2023.	07/01/2024	09:00	07/01/2024	14:00	KORADI III - AKOLA II Ckt - 1 will remain in service without LR.
63	428	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	(1) CT testing. (2) Bay maintenance work. (3) String cold washing & spacer replacement work	07/01/2024	09:00	07/01/2024	18:00	-
64	429	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	D	1.Bay Maintenance Work. 2.MTAMC Work. 3.Diagnostic Testing Work. 4.Replacement of 29 C Bus PG Isolator under LES Scheme. 5.Replacement of all phase CT with new Ratio of 3000/1 A. 6.Distance Relay & Over Voltage Relay.	07/01/2024	09:30	07/01/2024	18:30	Weather condition should be clear.
65	430	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	C	For stub bus HTLS conductor stringing work of 400kV Kalwa-Padgha-2 line above live 400kV B-Bus by Partial outage on 400kV Main Bus-1 at 400kV RS Kalwa. For carrying out the work following operations will be carried out: 1) 400 KV Kharghar line  shifted to B Bus through TBC 2) Removing of A bus Quadera jumper (R,Y & B ph) to make A bus partially dead By hot line unit. 3) On 07.01.2023 @00:00 Hrs to 08.01.2024 till 24:00 Hrs Stringing of HTLS conductor in Stub bus of 400 KV Padgha II line will be carried out. 4) Quadra A bus jumper (R,Y & B ph) connection work by hot line unit	07/01/2024	00:00	08/01/2024	23:59	For stub bus HTLS conductor stringing work of 400kV Kalwa-Padgha-2 line above live 400kV B-Bus by Partial outage on 400kV Main Bus-1 at 400kV RS Kalwa. For carrying out the work following operations will be carried out: 1) 400 KV Kharghar line  shifted to B Bus through TBC 2) Removing of A bus Quadera jumper (R,Y & B ph) to make A bus partially dead By hot line unit. 3) On 07.01.2023 @00:00 Hrs to 08.01.2024 till 24:00 Hrs Stringing of HTLS conductor in Stub bus of 400 KV Padgha II line will be carried out. 4) Quadra A bus jumper (R,Y & B ph) connection work by hot line unit
66	432	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	A/R off for PID Testing work.	08/01/2024	09:00	20/01/2024	18:00	A/R off for PID Testing work
67	494	PLANNED	OCC_574	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For Replacement of Flashover Disc by Hot Line Method. Shifting of auto reclose switch to non auto mode	08/01/2024	09:00	08/01/2024	17:00	.
68	496	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintenance work	08/01/2024	10:00	08/01/2024	18:00	NA
69	504	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Cold Washing Work	08/01/2024	08:00	09/01/2024	18:00	---

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
70	505	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	08/01/2024	08:00	09/01/2024	18:00	NA
71	518	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV BABLESHWAR-ICT-2 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work. 400/220 KV ICT II HV will be in service through TBC	08/01/2024	09:00	11/01/2024	18:00	400/220 KV ICT II HV will be in service through TBC
72	519	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY OF 765KV-TIRODA-KORADI-III-1 AND KORADI-III - 765KV - BUS 1 @KORADI-III - 765KV at KORADI-III - 765KV	C	CB mechanism Overhauling work through M/s CGL service Engineer.	08/01/2024	11:00	11/01/2024	18:00	Continuous Outage required for CB mechanism overhauling work.
73	522	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	08/01/2024	08:00	13/01/2024	17:00	---
74	586	PLANNED	OCC_574	MEGPTCL	765KV-TIRODA-KORADI-III-1	D	Annual maintenance of line equipment's at Tiroda 765KV.	09/01/2024	08:00	09/01/2024	18:00	Metering CT Testing to be done.
75	587	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	Routine Maintenance & Diagnostic Testing Work	09/01/2024	08:00	09/01/2024	18:00	Routine Maintenance & Diagnostic Testing Work (BBLR-1)
76	588	PLANNED	OCC_574	MSLDC_OUTAGE	CHANDRAPUR SWITCHING STATION - 400KV - BUS 1	D	Bus-1 CVT Testing & Maintenance work	09/01/2024	09:00	09/01/2024	18:00	Bus-1 CVT Testing & Maintenance work
77	590	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintenance work	09/01/2024	10:00	09/01/2024	18:00	NA
78	597	PLANNED	OCC_574	MUML-Sterlite	500kV Chandrapur-Padghe HVDC Ckt I & II	D	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line	09/01/2024	09:00	10/01/2024	18:00	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line
79	673	PLANNED	OCC_574	MEGPTCL	765KV-TIRODA-KORADI-III-2 L/R@ KORADI-III - 765KV	D	Six monthly changeover of Spare Ph Reactor to be taken in service in place of Y-Ph Reactor as per CEA regulation at Koradi- III SS. Last changeover date 16.07.2023.	10/01/2024	08:00	10/01/2024	18:00	Line Reactor Outage. Last changeover date 16.07.2023.
80	674	PLANNED	OCC_574	MEGPTCL	765KV-TIRODA-KORADI-III-2	D	Annual maintenance of line equipment's & Six monthly changeover of Spare-PH Reactor to be taken in service in place of Y-Ph Reactor as per CEA regulation at Koradi- III SS. Last changeover date 16.07.2023.	10/01/2024	08:00	10/01/2024	18:00	Metering CT testing to be done.
81	675	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	10/01/2024	08:00	10/01/2024	18:00	NA
82	680	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-TIRODA-KORADI-III-1 at KORADI-III - 765KV	D	Maintenance work	10/01/2024	09:00	10/01/2024	17:00	The said work is very important
83	681	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KORADI-II-KORADI-III-2	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	10/01/2024	09:00	10/01/2024	18:00	During 400KV Busbar Protection Relay testing works Outage, (1) 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work (2)The 400KV Busbar Relay will be tested Online by taking necessary precautions of 400KV Bus-I/Bus-II Bays, respective Bays CT shorting arrangement and isolation of respective 400KV Bays Busbar Relays trippings etc. as per requirement prior to testing. (3) During the outage, On 400KV Bus I, Ckt's connected on Bus I i.e., 400KV Adani ckt. 1 & 2, PGCIL-Nagari, IEPL and 400KV Bus Reactor remains charged through their respective Main CBs. No any CB or Isolator will be isolated /opened during the said outage . (4) During the outage, On 400KV Bus II, Ckt's connected on Bus II i.e., 400KV Cpur-II ckt-1 & 2, 400KV Future Line-1/2 and ICT-1 remains charged through their respective Main CBs. No any CB or Isolator will be isolated /opened during the outage . (5) All 400KV Bays Tie CBs/Isolators will be in service. No any Load affected nil, load will be managed on Bus A & B
84	682	PLANNED	OCC_574	MSLDC_OUTAGE	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	D	Quarterly maintenance work	10/01/2024	09:00	10/01/2024	18:00	NA
85	683	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHWAR-I	D	Routine Maint. Work	10/01/2024	09:00	10/01/2024	18:00	NA

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
86	684	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	10/01/2024	09:00	10/01/2024	18:00	-
87	686	PLANNED	OCC_574	MSLDC_OUTAGE	KUMBARI - 220KV - BUS 1	D	Outage is required for Quarterly Maintenance	10/01/2024	10:00	10/01/2024	18:00	Quarterly Maintenance
88	687	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-SOLAPUR-KUMBARI-1	D	Outage is required for Quarterly Maintenance	10/01/2024	10:00	10/01/2024	18:00	Quarterly Maintenance
89	694	PLANNED	OCC_574	MSLDC_OUTAGE	400KV/220KV KHAPARKHEDA-ICT-2	C	Replacement of Neutral Bushing of R & Y Ph Unit	10/01/2024	08:00	12/01/2024	18:00	NA
90	747	PLANNED	OCC_574	ATIL	400KV-TIRODA-WARORA-1	D	Annual maintenance of line equipment.	11/01/2024	08:00	11/01/2024	18:00	Line outage
91	748	PLANNED	OCC_574	ATIL	400KV-TIRODA-WARORA-1	D	Annual maintenance of line equipment's at Tiroda.	11/01/2024	08:00	11/01/2024	18:00	Metering CT Testing to be done.
92	749	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintainace work	11/01/2024	08:00	11/01/2024	18:00	NA
93	750	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	11/01/2024	08:00	11/01/2024	18:00	--
94	751	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	11/01/2024	08:00	11/01/2024	18:00	--
95	752	PLANNED	OCC_574	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	For conductor stringing work between tower loc no. 271 to 280.	11/01/2024	09:00	11/01/2024	17:00	Other lines at 220 KV Mudshingi s/s will be in service .Also 220 kV Talandge-Chikodi line will be in service.
96	753	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	For conductor stringing work between tower loc no. 271 to 280.	11/01/2024	09:00	11/01/2024	17:00	Other lines at 220 KV Mudshingi s/s will be in service .Also 220 kV Talandge-Chikodi line will be in service.
97	755	PLANNED	OCC_574	MEGPTCL	MAIN BAY - 400KV-AKOLA (2)-NANDGAONPETH-2 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	D	For Annual maintenance of CT & CB.	11/01/2024	10:00	11/01/2024	18:00	Bay Outage
98	758	PLANNED	OCC_574	MSLDC_OUTAGE	POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ PADGHE HVDC (Element not found)	C	1. R-ph CB Pole alongwith interrupter & operating mechanism overhauling work. 2. Filter jumper replacement work between capacitor.	11/01/2024	08:00	12/01/2024	08:00	1. CB Pole alongwith interrupter & mechanism box is due for overhauling work. 2. Filter jumper old aged need to replace for avoiding hot spots.
99	759	PLANNED	OCC_574	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 1	C	1. Tan delta measurement of Bus CVT. 2. Nut Bolts and hardware tightening work.	11/01/2024	08:00	12/01/2024	18:00	"This circuits/bays which are connected to 400KV MainBUS-1 will be shifted on 400KV Main Bus-2 one by one via TBC-1 & TBC-2
100	760	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-3	C	Required for Main Bus -1 outage work.	11/01/2024	08:00	12/01/2024	18:00	This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service.
101	761	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-4	C	Required for Main Bus -1 outage work.	11/01/2024	08:00	12/01/2024	18:00	This circuits/bays can not be shifted on 400KV Main Bus-2, as the Bus-2 isolators are not in service.
102	762	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	PID detected weak strings replacement.	11/01/2024	22:00	12/01/2024	06:00	-
103	767	PLANNED	OCC_574	MSLDC_OUTAGE	KARAD - 400KV - BUS 2	D	for Hot line work for installation of pilot string at Bus gantry near Jaigad Bay & 125 MVAR reactor.	11/01/2024	10:00	13/01/2024	17:00	hot line method
104	790	PLANNED	OCC_574	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Annual Maintenance	12/01/2024	08:00	12/01/2024	18:00	Outage
105	791	PLANNED	OCC_574	WTPL	400KV-ALKUD-SOLAPUR-1	D	AR disable for annual maintenance in 400KV Kolhapur - MS- Solapur Line -2	12/01/2024	08:00	12/01/2024	18:00	AR disable
106	792	PLANNED	OCC_574	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	AR disable for annual maintenance in 400KV Kolhapur - MS- Solapur Line -2	12/01/2024	08:00	12/01/2024	18:00	AR disable
107	814	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Routine Maintenance & Diagnostic Testing Work	12/01/2024	08:00	12/01/2024	18:00	Routine Maintenance & Diagnostic Testing Work (BBLR-2)
108	815	PLANNED	OCC_574	ATIL	400KV-TIRODA-WARORA-2	D	Annual maintenance of line equipment's.	12/01/2024	08:00	12/01/2024	18:00	Line outage.
109	818	PLANNED	OCC_574	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	For conductor stringing work between tower loc no. 271 to 280.	12/01/2024	09:00	12/01/2024	17:00	Other lines at 220 KV Mudshingi s/s will be in service .Also 220 kV Talandge-Chikodi line will be in service.
110	819	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY OF 400KV-TIRODA-WARORA-2 AND 400KV-WARORA-CHANDRAPU-II-2 @WARORA - 400KV at WARORA - 400KV	D	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	12/01/2024	09:00	12/01/2024	17:00	only Tie CB 415 is in OFF condition, respective ckt charged through its own main CB.

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
111	820	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	For conductor stringing work between tower loc no. 271 to 280.	12/01/2024	09:00	12/01/2024	17:00	Other lines at 220 KV Mudshingi s/s will be in service .Also 220 kV Talandge-Chikodi line will be in service.
112	824	PLANNED	OCC_574	MUML-Sterlite	400kV D/C Padghe - Nagothane Ckt I & II	D	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line	12/01/2024	09:00	13/01/2024	18:00	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line
113	829	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY - 400KV-KORADI-II-KORADI-III-3 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	C	Rapid Restoration Scheme work;DFRA;Quarterly bay maintenance work	12/01/2024	09:00	14/01/2024	18:00	315 MVA ICT I and II and 501 MVA ICT IV will be in service
114	831	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	Replacement of existing conductor by HTLS conductor	12/01/2024	22:00	15/01/2024	06:00	Replacement of existing conductor by HTLS conductor
115	850	PLANNED	OCC_574	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	Annual Manitenance	13/01/2024	08:00	13/01/2024	18:00	Outage
116	851	PLANNED	OCC_574	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for annual maintenance in 400KV Kolhapur - MS- Alkud Line -1	13/01/2024	08:00	13/01/2024	18:00	AR disable
117	859	PLANNED	OCC_574	APML	TIE BAY - TIRODA - 400KV B/R 1 AND TIRODA - 400KV B/R 2 at TIRODA - 400KV	D	Annual testing of bay equipments	13/01/2024	09:00	13/01/2024	18:00	BR-1 & BR-2 will be in service with main bay
118	868	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Routine Line maintenance work;LBB relay and Distance Main I and II relay testing	13/01/2024	08:00	13/01/2024	18:00	400kV Padghe II will be in service
119	869	PLANNED	OCC_574	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	D	For changeover of Y-Ph LR with R-Ph LR at Ektuni SS for mechanical protection cable replacement & cable tray installation work.	13/01/2024	10:00	13/01/2024	15:30	Line Outage
120	870	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	For safety purpose only. Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).	13/01/2024	07:00	14/01/2024	18:00	For safety purpose only. Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).
121	871	PLANNED	OCC_574	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 1	C	220kV A-Bus Isolator r/m works.	13/01/2024	07:00	14/01/2024	20:00	220kV A-Bus has following elements: 220kV Tarapur Line 220kV Borivali Line 220kV Viraj Line 220kV PGCIL Line 2 200MVA , 220/132kV ICT No.2 80MVA, 220/33-33kV PTR 150MVA , 220/132kV ICT No.2  During the outage, all elements/lines will be in service through 220kV B-Bus
122	872	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	For restoration of 400kV Kalwa-Kharghar & 400kV Kalwa-Padgha-1 line after HTLS work on 400kV Kalwa-Padgha-1 line (work proposed from 16.12.2023) by removing the T-connection of 400kV Kalwa-Padgha-1 line on KALWA - KHARGHAR.	13/01/2024	22:00	14/01/2024	06:00	For restoration of 400kV Kalwa-Kharghar & 400kV Kalwa-Padgha-1 line after HTLS work on 400kV Kalwa-Padgha-1 line (work proposed from 16.12.2023) by removing the T-connection of 400kV Kalwa-Padgha-1 line on KALWA - KHARGHAR.
123	873	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	C	For restoration of 400kV Kalwa-Kharghar & 400kV Kalwa-Padgha-1 line after HTLS work on 400kV Kalwa-Padgha-1 line (work proposed from 16.12.2023) by removing the T-connection of 400kV Kalwa-Padgha-1 line on KALWA - KHARGHAR.	13/01/2024	22:00	14/01/2024	06:00	For restoration of 400kV Kalwa-Kharghar & 400kV Kalwa-Padgha-1 line after HTLS work on 400kV Kalwa-Padgha-1 line (work proposed from 16.12.2023) by removing the T-connection of 400kV Kalwa-Padgha-1 line on KALWA - KHARGHAR.

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
124	875	PLANNED	OCC_574	MSLDC_OUTAGE	KALWA - 400KV - BUS 2	C	For stub bus HTLS conductor stringing work of 400kV Kalwa-Padgha-1 line above live 400kV Bus-2 by Partial outage on 400kV Main Bus-2 at 400kV RS Kalwa. For carrying out the work following operations will be carried out: 1) 400 KV Talegaon line  shifted to Bus-1 through TBC 2) Removing of Bus-2 Quadera jumper (R,Y & B ph) to make A bus partially dead By hot line unit. 3) On 14.01.2023 @00:00 Hrs to 15.01.2024 till 24:00 Hrs Stringing of HTLS conductor in Stub bus of 400 KV Padgha I line will be carried out. 4) Quadra Bus jumper (R,Y & B ph) connection work by hot line unit	13/01/2024	06:00	15/01/2024	23:59	For stub bus HTLS conductor stringing work of 400kV Kalwa-Padgha-1 line above live 400kV Bus-2 by Partial outage on 400kV Main Bus-2 at 400kV RS Kalwa. For carrying out the work following operations will be carried out: 1) 400 KV Talegaon line  shifted to Bus-1 through TBC 2) Removing of Bus-2 Quadera jumper (R,Y & B ph) to make A bus partially dead By hot line unit. 3) On 14.01.2023 @00:00 Hrs to 15.01.2024 till 24:00 Hrs Stringing of HTLS conductor in Stub bus of 400 KV Padgha I line will be carried out. 4) Quadra Bus jumper (R,Y & B ph) connection work by hot line unit
125	880	PLANNED	OCC_574	WTPL	400KV-ALKUD-SOLAPUR-1	D	Annual Manitenance	14/01/2024	08:00	14/01/2024	18:00	Outage
126	881	PLANNED	OCC_574	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for annual maintenance in 400KV Alkud -MS- Solapur Line - I	14/01/2024	08:00	14/01/2024	18:00	AR disable
127	884	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance work;CVT tan D,Distance Main II relay testing	14/01/2024	08:00	14/01/2024	18:00	400kV Padghe I will be in service
128	885	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	(1) CT & CVT testing. (2) Bay maintenance work. (3) String cold washing & spacer replacement work	14/01/2024	09:00	14/01/2024	18:00	-
129	886	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	For stub bus HTLS conductor stringing work of 400kV Kalwa-Padgha-1 line above live 400kV B-Bus by Partial outage on 400kV Main Bus-2 at 400kV RS Kalwa. For carrying out the work following operations will be carried out: 1) 400 KV Talegaon line  shifted to A Bus through TBC 2) Removing of B bus Quadera jumper (R,Y & B ph) to make B bus partially dead By hot line unit. 3) On 14.01.2023 @00:00 Hrs to 15.01.2024 till 24:00 Hrs Stringing of HTLS conductor in Stub bus of 400 KV Padgha I line will be carried out. 4) Quadra B bus jumper (R,Y & B ph) connection work by hot line unit	14/01/2024	00:00	15/01/2024	23:59	For stub bus HTLS conductor stringing work of 400kV Kalwa-Padgha-1 line above live 400kV B-Bus by Partial outage on 400kV Main Bus-2 at 400kV RS Kalwa. For carrying out the work following operations will be carried out: 1) 400 KV Talegaon line  shifted to A Bus through TBC 2) Removing of B bus Quadera jumper (R,Y & B ph) to make B bus partially dead By hot line unit. 3) On 14.01.2023 @00:00 Hrs to 15.01.2024 till 24:00 Hrs Stringing of HTLS conductor in Stub bus of 400 KV Padgha I line will be carried out. 4) Quadra B bus jumper (R,Y & B ph) connection work by hot line unit
130	898	PLANNED	OCC_574	WTPL	220KV-SOLAPUR-JEUR-1	D	Annual Manitenance	15/01/2024	08:00	15/01/2024	18:00	Outage
131	899	PLANNED	OCC_574	WTPL	400KV-SOLAPUR-M-SOLAPUR-1	D	AR disable for annual maintenance in 220 KV Solapur - Jeur -1	15/01/2024	08:00	15/01/2024	18:00	AR disable
132	919	PLANNED	OCC_574	MEGPTCL	765KV/400KV TIRODA-ICT-1	C	Annual maintenance & testing transformer. Annual maintenance of main bay & tie bay equipment's.	15/01/2024	09:00	16/01/2024	18:00	ICT Outage
133	927	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	C	CB pole overhauling work. 400 KV Padghe I will be in service through TBC	15/01/2024	08:00	18/01/2024	18:00	400 KV Padghe I will be in service through TBC
134	928	PLANNED	OCC_574	MSLDC_OUTAGE	AKOLA (2) - 400KV - BUS 1	C	CB mechanism Overhauling work through M/s CGL service Engineer	15/01/2024	11:00	18/01/2024	18:00	Continuous outage required for CB mechanism overhauling work
135	931	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	A/R off for PID Testing work	15/01/2024	09:00	19/01/2024	18:00	A/R off for PID Testing work
136	933	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	15/01/2024	08:00	20/01/2024	17:00	---
137	935	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY OF 400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2 AND CHANDRAPUR-GCR - 400KV - BUS 1 @CHANDRAPUR-GCR - 400KV at CHANDRAPUR-GCR - 400KV	C	1. Pole Overhauling of Bhel make CB of 400KV HVDC CKT-2 bay. 2. Diagnostic testing of Circuit breaker. 3. 400KV HVDC CKT-2 will be in service via TBC-2.	15/01/2024	08:00	22/01/2024	18:00	400KV HVDC CKT-2 will be in service via TBC-2. There will not be any power restriction on HVDC Bipole during outage from 400KV GCR-1 SS Chandrapur.



Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
138	941	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	16/01/2024	08:00	31/01/2024	18:00	AR disable
139	942	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	16/01/2024	08:00	31/01/2024	18:00	AR disable
140	943	PLANNED	OCC_574	WTPL	400KV-ALKUD-SOLAPUR-1	D	AR disable for replacement of insulator in live line method.	16/01/2024	08:00	31/01/2024	18:00	AR disable
141	944	PLANNED	OCC_574	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	AR disable for replacement of insulator in live line method.	16/01/2024	08:00	31/01/2024	18:00	AR disable
142	963	PLANNED	OCC_574	WTPL	400KV-SOLAPUR-M-SOLAPUR-1	D	Annual Manitenance	16/01/2024	08:00	16/01/2024	18:00	Outage
143	964	PLANNED	OCC_574	WTPL	220KV-SOLAPUR-JEUR-1	D	AR disable for annual maintenance in 400KV Solapur-M-Solapur -1	16/01/2024	08:00	16/01/2024	18:00	AR disable
144	986	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	1.For Replacement of Flashover Disc 2.Diagnostic testing of Line Bay at Badnera S/s	16/01/2024	09:00	16/01/2024	17:00	.
145	990	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY - 400KV-KORADI-II-KORADI-III-2 AND FUTURE at KORADI-III - 400KV	C	1. Y-ph CB Pole alongwith interrupter & operating mechanism overhauling work. 2. Filter jumper replacement work between capacitor.	16/01/2024	08:00	17/01/2024	08:00	1. Y-ph CB Pole alongwith interrupter & mechanisum box is due for overhauling work. 2. Filter jumper old aged need to replace for avoiding hot spots.
146	1014	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual Maintenance	17/01/2024	08:00	17/01/2024	18:00	Outage
147	1015	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual Manitenance	17/01/2024	08:00	17/01/2024	18:00	Outage
148	1035	PLANNED	OCC_574	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-1	D	Routine Maintenance & Diagnostic Testing Work	17/01/2024	07:00	17/01/2024	18:00	Routine Maintenance & Diagnostic Testing Work (ICT-1 Units)
149	1036	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-2	D	Diagnostic testing & Relay testing work , Routine maint. Work	17/01/2024	08:00	17/01/2024	17:00	---
150	1038	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY - 400KV-KORADI-II-KORADI-III-2 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	D	Maintenance work	17/01/2024	09:00	17/01/2024	17:00	The said work is very important
151	1039	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	17/01/2024	09:00	17/01/2024	17:00	-
152	1040	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3)String replacement work.	17/01/2024	09:00	17/01/2024	18:00	-
153	1041	PLANNED	OCC_574	MSLDC_OUTAGE	AKOLA (2) - 400KV - BUS 2	D	Quarterly maintenance work	17/01/2024	09:00	17/01/2024	18:00	Load affected nil
154	1042	PLANNED	OCC_574	MEGPTCL	MAIN BAY - 400KV-AKOLA-AKOLA (2)-2 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	D	Annual maintenance of CT & CB.	17/01/2024	10:00	17/01/2024	18:00	Bay Outage
155	1043	PLANNED	OCC_574	MSLDC_OUTAGE	KUMBARI - 220KV - BUS 2	D	Outage is required for Quarterly Maintenance	17/01/2024	10:00	17/01/2024	18:00	Quarterly Maintenance
156	1044	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY - 400KV-AKOLA (2)-NANDGAONPETH-1 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	D	Outage is required for Quarterly Maintenance	17/01/2024	10:00	17/01/2024	18:00	Quarterly Maintenance
157	1073	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual Manitenance	18/01/2024	08:00	18/01/2024	18:00	Outage
158	1074	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual Manitenance	18/01/2024	08:00	18/01/2024	18:00	Outage
159	1075	PLANNED	OCC_574	APML	TIRODA - 400KV - BUS 2	D	Annual Maintenance of Bus equipment's	18/01/2024	08:00	18/01/2024	18:00	All equipments will be in service through BUS-1
160	1106	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-AKOLA-AKOLA (2)-2	D	Maintenance work	18/01/2024	08:00	18/01/2024	18:00	--
161	1107	PLANNED	OCC_574	MSLDC_OUTAGE	220 KV-WARDHA-YAWATMAL-1	D	Maintenance work	18/01/2024	08:00	18/01/2024	18:00	--

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
162	1108	PLANNED	OCC_574	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	18/01/2024	09:00	18/01/2024	17:00	The said work is very important
163	1109	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	Relay testing work & routine maintenace work.	18/01/2024	09:00	18/01/2024	17:00	Load manage on 400KV Chandrapur 2 Ckt 2, parallel ckt
164	1110	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	18/01/2024	09:00	18/01/2024	17:00	The said work is very important
165	1112	PLANNED	OCC_574	MUML-Sterlite	400kV D/C Talegaon-Kargar-Kalwa Ckt I & II	D	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line	18/01/2024	09:00	19/01/2024	18:00	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line
166	1116	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-1	D	For Replacement of Missing Hardware , Cold line washing & Other maintenance work.	18/01/2024	08:00	20/01/2024	18:00	400 KV Dhule-SSNNL CKT 2 Auto Reclose switch will be kept on Non Auto mode during Outage period
167	1141	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual Manitenance	19/01/2024	08:00	19/01/2024	18:00	Outage
168	1142	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual Manitenance	19/01/2024	08:00	19/01/2024	18:00	Outage
169	1171	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY - 400KV-EKTUNI-BABLESHWAR-1 AND EKTUNI - 400KV - BUS 1 at EKTUNI - 400KV	D	Routine Maintenance & Diagnostic Testing Work	19/01/2024	08:00	19/01/2024	17:00	Routine Maintenance & Diagnostic Testing Work (411 MAIN BAY)
170	1174	PLANNED	OCC_574	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	For conductor stringing work between tower loc no. 271 to 280.	19/01/2024	09:00	19/01/2024	17:00	220 KV Talandge- Mudshingi ckt-2, 220kV Peth - Mudshingi, 220 KV Karad-Mudshingi Ckt-2, 220 KV Wathar-Mudshingi & 220 KV Karad-Mudshingi Ckt-IV lines will be in service.
171	1175	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	For conductor stringing work between tower loc no. 271 to 280.	19/01/2024	09:00	19/01/2024	17:00	220 KV Talandge- Mudshingi ckt-2, 220kV Peth - Mudshingi, 220 KV Karad-Mudshingi Ckt-2, 220 KV Wathar-Mudshingi & 220 KV Karad-Mudshingi Ckt-IV lines will be in service.
172	1177	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-I	D	1.Bay Maintenance work. 2.Diagonostic Testing work. 3.Replacement of over voltage distance relay. 4.MTAMC work. 5.Replacement of 29C Isolator under LES Scheme.	19/01/2024	09:30	19/01/2024	18:30	Weather Condition should be clear.
173	1178	PLANNED	OCC_574	MEGPTCL	MAIN BAY - 400KV-AKOLA (2)-FUTURE-5 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	D	Annual maintenance of CT & CB	19/01/2024	10:00	19/01/2024	18:00	Bay Outage
174	1187	PLANNED	OCC_574	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-4	C	Rapid Restoration Scheme work; LV LBB relay,LV CT tan D, Bushing tan D, DFRA;Quarterly bay maintenance work	19/01/2024	09:00	21/01/2024	18:00	315 MVA ICT I and II and 501 MVA ICT III will be in service
175	1188	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY - 400KV-KORADI-II-KORADI-III-1 AND FUTURE at KORADI-III - 400KV	C	Replacement of existing conductor by HTLS conductor.	19/01/2024	22:00	22/01/2024	06:00	Replacement of existing conductor by HTLS conductor.
176	1189	PLANNED	OCC_574	MSLDC_OUTAGE	BUS COUPLER BAY OF NAGOTHANE - 400KV - BUS 1 AND NAGOTHANE - 400KV - BUS 2 @NAGOTHANE - 400KV at NAG	C	for 400 kv CB replacement work	19/01/2024	08:00	25/01/2024	17:00	nil
177	1201	PLANNED	OCC_574	APML	TIRODA - 400KV - BUS 1	D	Annual Maintenance of Bus equipment's	20/01/2024	08:00	20/01/2024	18:00	All equipments will be in service through BUS-2
178	1224	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY OF 400KV-KARJAT-LONIKHAND-II-2 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Maintenance	20/01/2024	08:00	20/01/2024	18:00	-
179	1225	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-1	D	Cold washing of Insulator Strings	20/01/2024	08:00	20/01/2024	18:00	-
180	1227	PLANNED	OCC_574	MEGPTCL	765KV/400KV AKOLA (2)-ICT-1	D	For annual maintenance & Testing of ICT at Akola SS.	20/01/2024	09:30	20/01/2024	19:30	ICT Outage
181	1238	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	For Bay maintenance & equipment testing.	21/01/2024	07:00	21/01/2024	19:00	Also outage is required Outage required for safety purpose during Hot spot attending work on PGCIL-Panchali line at loc No.DP Between Loc No.12-13

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
182	1239	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	Outage required for Hot spot attending work at loc No.DP Between Loc No.12-13	21/01/2024	07:00	21/01/2024	19:00	Simultaneously outage required on 220KV Boisar-PGCIL Ckt-2 for safety purpose.
183	1240	PLANNED	OCC_574	MEGPTCL	765KV-AKOLA (2)-KORADI-III-1	D	Annual maintenance of line.	21/01/2024	08:00	21/01/2024	18:00	Line Outage
184	1241	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	1.Bay Maintenance Work. 2.MTAMC Work. 3.Diagnostic Testing Work. 4.Replacement of 29 C Bus PG Isolator under LES Scheme. 5.Replacement of all phase CT with new Ratio of 3000/1 A. 6.Distance Relay & Over Voltage Relay.	21/01/2024	09:30	21/01/2024	18:30	Weather condition should be clear.
185	1242	PLANNED	OCC_574	MSLDC_OUTAGE	765KV-AKOLA (2)-EKTUNI-2	C	1. B-ph CB Pole alongwith interrupter & operating mechanism overhauling work. 2. Filter jumper replacement work between capacitor.	21/01/2024	08:00	22/01/2024	08:00	1. B-ph CB Pole alongwith interrupter & mechanism box is due for overhauling work. 2. Filter jumper old aged need to replace for avoiding hot spots.
186	1280	PLANNED	OCC_574	APML	400KV/11.5KV TIRODA-ST-3	D	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	22/01/2024	09:00	22/01/2024	18:00	ST-5 will be in service with main bay
187	1292	PLANNED	OCC_574	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	D	Annual maintenance of line.	22/01/2024	08:00	22/01/2024	18:00	Line Outage
188	1293	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV LONIKHAND-ICT-3 AND LONIKHAND - 400KV - BUS 1 @LONIKHAND - 400KV at LONIKHAND - 400KV	D	HV CB Maintenance Work. ICT-3 will be in service through TBC.	22/01/2024	08:00	22/01/2024	18:00	Load On TBC
189	1294	PLANNED	OCC_574	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	22/01/2024	09:00	22/01/2024	17:00	The said work is very important
190	1295	PLANNED	OCC_574	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	Routine maintenance and diagnostic testing such as CVT tan delta & maintenance work	22/01/2024	09:00	22/01/2024	17:00	1) 400KV MAIN BUS-2 will be service. 2) 400KV, 125MVAR reactor kept off position during outage.
191	1296	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	22/01/2024	09:00	22/01/2024	17:00	The said work is very important
192	1297	PLANNED	OCC_574	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	1.For Replacement of Flashover Disc 2.Diagnostic testing & Routine Maintenance of Line Bay at 132kV Dharni S/Stn	22/01/2024	09:00	22/01/2024	17:00	.
193	1304	PLANNED	OCC_574	MUML-Sterlite	220kV Padghe - Jindal TL	D	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line	22/01/2024	09:00	23/01/2024	18:00	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line
194	1305	PLANNED	OCC_574	MUML-Sterlite	220kV Padghe - Nasik TL	D	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line	22/01/2024	09:00	23/01/2024	18:00	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line
195	1310	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-1	D	For carrying out routine maintenance work and defects observed during monkey patrolling work	22/01/2024	08:00	23/01/2024	18:00	wORK TO BE CARRIED OUT BY amc aGENCY
196	1311	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Cold Washing Work, Diagnostic testing & Relay testing work , Routine maint. Work	22/01/2024	08:00	23/01/2024	18:00	---
197	1317	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-SSP-DHULE-MS-2	D	For Replacement of Missing Hardware , Cold line washing & Other maintenance work.	22/01/2024	08:00	24/01/2024	18:00	400 KV Dhule-SSNNL CKT 1 Auto Reclose switch will be kept on Non Auto mode during Outage period
198	1323	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	C	CB pole overhauling work. 400 KV Padghe II will be in service through TBC	22/01/2024	09:00	25/01/2024	18:00	400 KV Padghe II will be in service through TBC
199	1326	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	22/01/2024	08:00	27/01/2024	17:00	----
200	1377	PLANNED	OCC_574	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV B/R 1 at KORADI-III - 765KV	D	Annual maintenance of CB at Koradi- III SS.	23/01/2024	09:00	23/01/2024	18:00	Bay Outage

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
201	1378	PLANNED	OCC_574	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	23/01/2024	09:00	23/01/2024	18:00	During 400KV Busbar Protection Relay testing works (1) 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work (2)The 400KV Busbar Relay will be tested Online by taking necessary precautions of 400KV Bus-1/Bus-II Bays .respective Bays CT shorting arrangement and isolation of respective 400KV Bays Busbar Relays trippings etc. as per requirement prior to testing. (3) During the outage , On 400KV Bus I , Ckt's connected on Bus I i.e.,400KV Adani ckt. 1 & 2 ,PGCIL-Nagari, IEPL and 400KV Bus Reactor remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened during the said outage . (4) During the outage , On 400KV Bus II , Ckt's connected on Bus II i.e.,400KV Cpur-II ckt-1 & 2 , 400KV Future Line-1/2 and ICT-1 remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened during the outage . (5) All 400KV Bays Tie CBs/Isolators will be in service. No any 400KV Tie Bus.
202	1427	PLANNED	OCC_574	MSLDC_OUTAGE	EKTUNI - 400KV - BUS 2	D	Routine Maintenance & Diagnostic Testing Work	24/01/2024	07:00	24/01/2024	18:00	Routine Maintenance & Diagnostic Testing Work (400KV MAIN BUS-2)
203	1428	PLANNED	OCC_574	MSLDC_OUTAGE	KORADI - 400KV - BUS 1	D	Busbar Scheme Testing. Configuration of signal in MTAMC SCADA .During testing busbar protection is out of service.	24/01/2024	07:00	24/01/2024	20:00	NA
204	1429	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	24/01/2024	09:00	24/01/2024	17:00	-
205	1435	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-TAPTHITHANDA-EKTUNI-2	D	For carrying out routine maintenance work and defects observed during monkey patrolling work	24/01/2024	08:00	25/01/2024	18:00	Work to be carried out by AMC Agency
206	1436	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY - 400KV-KORADI-II-KORADI-III-1 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	D	Cold Washing Work, Diagnostic testing & Relay testing work , Routine maint. Work	24/01/2024	08:00	25/01/2024	18:00	---
207	1462	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-2	D	Cold washing of Insulator Strings	25/01/2024	08:00	25/01/2024	18:00	-
208	1463	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	25/01/2024	08:00	25/01/2024	18:00	--
209	1464	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	25/01/2024	08:00	25/01/2024	18:00	--
210	1465	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	Routine Line maintenance work	25/01/2024	08:00	25/01/2024	18:30	400KV Ektuni ckt II will be in service
211	1466	PLANNED	OCC_574	MEGPTCL	765KV/400KV KORADI-III-ICT-1	D	Annual maintenance of ICT-1 at Koradi- III SS.	25/01/2024	09:00	25/01/2024	18:00	ICT Outage
212	1467	PLANNED	OCC_574	MSLDC_OUTAGE	BUS COUPLER BAY OF CHAKAN - 400KV - BUS 1 AND CHAKAN - 400KV - BUS 2 @CHAKAN - 400KV at CHAKAN - 400	D	Replacement of 89A and 89B 400kv PG Isolator scissors, Routine maintenance and DT.	25/01/2024	10:00	25/01/2024	18:00	-
213	1468	PLANNED	OCC_574	MUML-Sterlite	220kv D/C GCR Eklahare - Kalwa Ckt I & II	D	For hot-line stringing of 400kv D/C Padghe - Kharghar Transmission line	25/01/2024	09:00	26/01/2024	18:00	For hot-line stringing of 400kv D/C Padghe - Kharghar Transmission line
214	1469	PLANNED	OCC_574	MSLDC_OUTAGE	Pole-1 Non base AC filter Z3 (120 MVAR) @PADGHE HVDC (Element not found)	C	1. Rph CB Pole alongwith interrupter & operating mechanism overhauling work. 2. Filter jumper replacement work between capacitor.	25/01/2024	08:00	26/01/2024	08:00	1. R-ph CB Pole alongwith interrupter & mechanism box is due for overhauling work. 2. Filter jumper old aged need to replace for avoiding hot spots.
215	1472	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Manitenance	26/01/2024	08:00	26/01/2024	18:00	Outage
216	1473	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Manitenance	26/01/2024	08:00	26/01/2024	18:00	Outage
217	1483	PLANNED	OCC_574	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-5	D	1) Shifting from B bus to A bus for partial Bus outage	26/01/2024	05:00	26/01/2024	11:00	Weather condition should be clear.
218	1484	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-TARAPUR 3-4-PADGHE-1	D	1) Shifting from B bus to A bus for partial Bus outage	26/01/2024	05:00	26/01/2024	12:00	Weather condition should be clear.

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
219	1485	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	D	1) shifting from B bus to A bus for partial Bus outage 2) H/T required for 2 to 3 hrs. for jumper removing work by cold line method between Nagothane 2&1 in afternoon hrs.	26/01/2024	05:00	26/01/2024	15:00	Weather condition should be clear.
220	1486	PLANNED	OCC_574	MSLDC_OUTAGE	LONIKHAND - 400KV - BUS 1	D	CVT DT & Maintenance Work	26/01/2024	08:00	26/01/2024	18:00	-
221	1487	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Routine Line maintenance work	26/01/2024	08:00	26/01/2024	18:30	400kV Ektuni ckt I will be in service
222	1488	PLANNED	OCC_574	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-1	D	1.Shifting from B Bus to A Bus for load management during partial bus outage.	26/01/2024	09:00	26/01/2024	11:00	Weather condition should be clear.
223	1489	PLANNED	OCC_574	MEGPTCL	765KV/400KV KORADI-III-ICT-1	D	Testing of Metering CT of ICT	26/01/2024	09:00	26/01/2024	18:00	ICT Outage
224	1490	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-1	D	1) H/T required for safety proposed for removing jumper between HVDC 1&2 gantry by Hot line method. 2) power restriction of 750 MW for 3Hrs.	26/01/2024	10:00	26/01/2024	13:00	Weather condition should be clear.
225	1493	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-KALWA-PADGHE-1	C	Replacement of existing conductor by HTLS conductor.	26/01/2024	22:00	29/01/2024	06:00	Replacement of existing conductor by HTLS conductor.
226	1503	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Manitenance	27/01/2024	08:00	27/01/2024	18:00	Outage
227	1504	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Manitenance	27/01/2024	08:00	27/01/2024	18:00	Outage
228	1526	PLANNED	OCC_574	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	Bus CVT tan D testing	27/01/2024	08:00	27/01/2024	18:00	All feeders and ICT on Main Bus I will be shifted on Main Bus II through TBC
229	1527	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY - 400KV-EKTUNI-BABLESHWAR-2 AND 765KV/400KV EKTUNI-ICT-1 at EKTUNI - 400KV	D	Routine Maintenance & Diagnostic Testing Work	27/01/2024	09:00	27/01/2024	17:00	Routine Maintenance & Diagnostic Testing Work
230	1528	PLANNED	OCC_574	MEGPTCL	765KV/400KV KORADI-III-ICT-2	D	Annual maintenance of ICT at Koradi - III SS.	27/01/2024	09:00	27/01/2024	18:00	ICT Outage
231	1529	PLANNED	OCC_574	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	D	For changeover of B-Ph LR with Y-Ph LR at Ektuni SS for mechanical protection cable replacement & cable tray installation work.	27/01/2024	10:00	27/01/2024	15:30	Line Outage.
232	1531	PLANNED	OCC_574	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	For safety purpose only. Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).	27/01/2024	07:00	28/01/2024	18:00	For safety purpose only. Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line).
233	1532	PLANNED	OCC_574	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 2	C	220kV B-Bus Isolator r/m works.	27/01/2024	07:00	28/01/2024	20:00	220KV B-Bus has following elements: 220kV Ghodbunder Line 220kV PGCIL Line 1 220kV Versova Line 200MVA , 220/132kV ICT No.1 100MVA, 220/33-33kV PTR 220kV PGCIL Line 3  During the outage, all elements/lines will be in service through 220kV A-Bus.
234	1541	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Manitenance	28/01/2024	08:00	28/01/2024	18:00	Outage
235	1542	PLANNED	OCC_574	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Manitenance	28/01/2024	08:00	28/01/2024	18:00	Outage
236	1546	PLANNED	OCC_574	MSLDC_OUTAGE	NAGOTHANE - 400KV - BUS 2	D	Regular Maint work and Dignostic testing work	28/01/2024	08:00	28/01/2024	17:00	NA
237	1547	PLANNED	OCC_574	MEGPTCL	765KV/400KV KORADI-III-ICT-2	D	Testing of metering CT of ICT	28/01/2024	09:00	28/01/2024	18:00	ICT Outage

Sr. No.	OCCM Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
238	1548	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	D	1) H/t requires for safety purposed for re connection of jumper by cold line method between Nago I & II . 2) shifting from A bus to B bus after Bus conductor replacement work.	28/01/2024	12:00	28/01/2024	22:00	Weather condition should be clear.
239	1549	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-PADGHE HVDC-PADGHE-1	D	1) H/T requires for safety purposed for re connection of jumper between HVDC 1 & II gantry of B bus by Hot line METHOD.	28/01/2024	14:00	28/01/2024	17:30	1) weather condition should be clear for Hot line method
240	1550	PLANNED	OCC_574	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-5	D	1) Shifting from A bus to B bus for partial Bus outage.	28/01/2024	18:00	28/01/2024	23:30	1) weather condition should be clear.
241	1551	PLANNED	OCC_574	MSLDC_OUTAGE	400KV-TARAPUR 3-4-PADGHE-1	D	1) Shifting from A bus to B bus for partial Bus outage restoration.	28/01/2024	18:00	28/01/2024	23:30	Weather condition should be clear
242	1552	PLANNED	OCC_574	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	C	OPGW repairing work. AR in Non-auto mode	28/01/2024	08:00	29/01/2024	18:00	AR IN NON-AUTO
243	1554	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work. 400 KV Aurangabad will be in service through TBC	28/01/2024	09:00	31/01/2024	18:00	400 KV Aurangabad will be in service through TBC
244	1592	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	29/01/2024	09:00	29/01/2024	17:00	Line will be charged through Tie CB 428.
245	1632	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY - 400KV/220KV AKOLA-ICT-1 AND 400KV-AKOLA-AURANGABAD-1 at AKOLA - 400KV	D	Routine Maintenance & testing work	30/01/2024	09:00	30/01/2024	13:00	both ICT-01 & Aunrgabad Ct-01 will be in service through main Bay
246	1633	PLANNED	OCC_574	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	30/01/2024	09:00	30/01/2024	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
247	1634	PLANNED	OCC_574	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	Routine Maint. Work	30/01/2024	09:00	30/01/2024	18:00	NA
248	1635	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-AKOLA-1 AND 400KV-BHUSAWAL-AKOLA-1 at AKOLA - 400KV	D	Routine maintenance & testing work	30/01/2024	14:00	30/01/2024	18:00	Wardha ckt-01 & bhusawal Ckt will remain charged through main bay
249	1637	PLANNED	OCC_574	MUML-Sterlite	400kV D/C Bablesar - Kudus Ckt I & II	D	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line	30/01/2024	09:00	31/01/2024	18:00	For hot-line stringing of 400kV D/C Padghe - Kharghar Transmission line
250	1640	PLANNED	OCC_574	MSLDC_OUTAGE	Pole-1 Non base AC filter Z3 (120 MVAR) @PADGHE HVDC (Element not found)	C	1.Y-ph CB Pole alongwith interrupter & operating mechanism overhauling work. 2. Filter jumper replacement work between capacitor.	30/01/2024	08:00	31/01/2024	08:00	1. Y-ph CB Pole alongwith interrupter & mechanism box is due for overhauling work. 2. Filter jumper old aged need to replace for avoiding hot spots.
251	1665	PLANNED	OCC_574	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-2	D	Routine Maintenance & Diagnostic Testing Work	31/01/2024	07:00	31/01/2024	18:00	Routine Maintenance & Diagnostic Testing Work (ICT-2 Units)
252	1666	PLANNED	OCC_574	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	31/01/2024	09:00	31/01/2024	17:00	Line will be charged through Main CB 429.

**Additional Monthly Outage list approved in WRLDC OCCM for the Month of January 2024**

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continous	Reason	From Date	From Time	To Date	To Time
1	70	ADDITIONAL	OCC_574	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-1	C	Bullet Train Diversion works. Simultaneous outage of 400KV Tarapur- Boisar # 1 & 2 are required. Dia to be kept open at both ends.	11-Jan-24	8:00	19-Jan-24	18:00
2	71	ADDITIONAL	OCC_574	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-2	C	Bullet Train Diversion works. Simultaneous outage of 400KV Tarapur- Boisar # 1 & 2 are required. Dia to be kept open at both ends.	11-Jan-24	9:00	19-Jan-24	19:00
3	110	ADDITIONAL	OCC_574	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-1	C	Bullet Train Diversion works. Simultaneous outage of 400KV Tarapur- Padghe # 1 & 2 are required. Dia to be kept open at both ends.	20-Jan-24	8:00	29-Jan-24	18:00
4	111	ADDITIONAL	OCC_574	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-2	C	Bullet Train Diversion works. Simultaneous outage of 400KV Tarapur- Padghe # 1 & 2 are required. Dia to be kept open at both ends.	20-Jan-24	8:00	29-Jan-24	18:00

**State Element outage list for the month of January 2024**

Sr.No .	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	BUS REACTOR (125MVA <sub>r</sub> ) @ WARORA	1/1/2024	09:00	1/1/2024	17:00	Daily	Routine Maintenance & Dignostic testing work ,Bushing & Winding Tan delta, IR etc.	MSETCL	MSETCL	During outage reactor is in off condition
2	400 KV	DHULE- - BABLESHWAR CKT - 1	1/2/2024	08:00	1/2/2024	18:00	Daily	Routine line maintenance work & cold line wash.	MSETCL	MSETCL	400 kV DHL-BBLR -2 AR switch required in non auto mode.
3	400 KV	NEW KOYNA-KARAD CKT - 2	1/2/2024	08:00	1/2/2024	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
4	400 KV	TBC @ PADGHE	1/3/2024	08:00	1/3/2024	23:00	Daily	1.400kV TBC of All R, Y, B Phase CT Replacement with New Ratio of 3000/1 Amp. 2. Bay Maintenance Work.	MSETCL	MSETCL	Weather Condition should be clear.
5	400 KV	TBC @ BABHALESHWAR	1/3/2024	09:00	1/3/2024	16:00	Daily	CB DCRM/Timing testing work	MSETCL	MSETCL	TBC will be free for availing outage
6	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	1/3/2024	10:00	1/3/2024	17:00	Daily	RRS Scheme Work of ICT	MSETCL	MSETCL	NA
7	400 KV	LONIKAND I - KOYNA STAGE-IV	1/4/2024	08:00	1/4/2024	18:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
8	400 KV	NEW KOYNA-KARAD CKT - 1	1/4/2024	09:00	1/4/2024	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Quarterly maintenance work
9	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	1/4/2024	09:00	1/4/2024	18:00	Daily	1) HV Backup relay & IV CT testing work.2) Bay Maintenance work.3) Rapid restoration scheme work	MSETCL	MSETCL	-
10	400 KV	400/220 KV 105 MVA SPARE ICT	1/4/2024	09:00	1/4/2024	18:00	Daily	Rapid restoration scheme work	MSETCL	MSETCL	-
11	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	1/4/2024	10:30	1/4/2024	18:00	Daily	Bay Maintenance, CT Tan D & Relay Testing Work	MSETCL	MSETCL	Routine Maintenance work
12	400 KV	KHADKA- DEEPNAGAR CKT 1	1/4/2024	08:00	1/5/2024	20:00	Continuous	For M2 relay retrofitting work under MTAMC Project by agency Engineer.	MSETCL	MSETCL	Urgent MTAMC Project work.
13	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	1/4/2024	09:30	1/4/2024	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-2 & ICT-3 will continue to remain in service
14	400 KV	TIE BAY 418 OF ICT-1 @ LONIKAND 2	1/4/2024	08:00	1/4/2024	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
15	400 KV	WARORA - IEPL	1/4/2024	09:00	1/4/2024	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
16	400 KV	JEJURI- KOYNA STAGE-IV	1/4/2024	08:00	1/4/2024	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
17	400 KV	MAIN BAY (419) OF 400/220/33kV 500MVA ICT-I @ LONIKAND 2	1/4/2024	08:00	1/4/2024	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
18	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	1/5/2024	09:00	1/6/2024	18:00	Daily	maintenance work. (3) String replacement wotk at loc no-843	MSETCL	MSETCL	-



Sr.No .	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
19	400 KV	NEW KOYNA-KARAD CKT - 1	1/5/2024	08:00	1/5/2024	18:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
20	400 KV	400/220KV 105 MVA SPARE ICT @ DHULE	1/5/2024	09:00	1/5/2024	18:00	Daily	For Diagnostic testing and Routine maintenance work	MSETCL	MSETCL	105 MVA Spare ICT-1 is on NO Load.
21	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	1/5/2024	08:00	1/5/2024	18:00	Daily	1) Routine Line Maintenance work. 2) Diagnostic Testing and routine maintenance work at Ss.	MSETCL	MSETCL	NIL
22	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 1	1/6/2024	10:00	1/6/2024	18:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
23	400 KV	NEW KOYNA-KARAD CKT - 2	1/6/2024	08:00	1/6/2024	18:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
24	400 KV	400/220KV 167 MVA SPARE ICT @ DHULE	1/6/2024	09:00	1/6/2024	18:00	Daily	For Diagnostic testing and Routine maintenance work	MSETCL	MSETCL	167 MVA Spare ICT-2 is on NO Load.
25	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	1/6/2024	10:00	1/6/2024	18:00	Daily	Replacement of R phase 220kV IV CT due to higher tan delta,Inspection of SERGI NIFPS Fire system for ICT No.1 in the view of overhauling, Repairing and Overhauling of 89B PG isolators, Routine Maintenance and DT.	MSETCL	MSETCL	-
26	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	1/8/2024	09:00	1/8/2024	23:59	Daily	Quarterly Maintenance work, Diagnostic testing work.	MSETCL	MSETCL	Load will be managed on ICT - 1 & 2.
27	400 KV	KARAD - TALANDGE CKT - 1	1/8/2024	09:00	1/8/2024	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Quarterly maintenance work
28	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	1/8/2024	08:00	1/8/2024	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
29	400 KV	400/220/33 KV 315 MVA ICT - 1 @ DHULE	1/8/2024	09:00	1/8/2024	18:00	Daily	For Diagnostic testing and Routine maintenance work	MSETCL	MSETCL	501 MVA ICT-2 and 501 MVA ICT-3 are in service.
30	400 KV	CHANDRAPUR-PARLI CKT-3	1/8/2024	09:00	1/8/2024	18:00	Daily	Nut bolt hardware tightning work/ Spacer Repalcement	MSETCL	MSETCL	-
31	400 KV	KARAD - TALANDGE CKT - 2	1/9/2024	08:00	1/9/2024	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
32	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	1/9/2024	09:00	1/9/2024	18:00	Daily	Nut bolt hardware tightning work & Earthwire Stringing Work loc.no.497-500/ Spacer Replacement	MSETCL	MSETCL	-
33	400 KV	WARORA - IEPL	1/9/2024	09:00	1/9/2024	17:00	Daily	Line CT,CVT Tan delta ,IR values & Routine maintainance and and isolater maintainance work .	MSETCL	MSETCL	Both Main & Tie Bay is in OFF condition.
34	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	1/9/2024	10:00	1/9/2024	17:00	Daily	Diagnostic testing of Bushing & winding	MSETCL	MSETCL	501MVA 400/220/33kV ICT-II will in service

Sr.No .	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
35	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	1/9/2024	08:00	1/9/2024	18:00	Daily	Routine Line maintenance work;CB DCRM and timing	MSETCL	MSETCL	400kV Bhusawal,400kV Dhule ckt I&II, Ektuni I&II will be in service
36	400 KV	400/220/33 KV 500 MVA ICT - 2 @ DHULE	1/9/2024	09:00	1/9/2024	18:00	Daily	For Diagnostic testing and Routine maintenance work	MSETCL	MSETCL	315 MVA ICT-1 and 501 MVA ICT-3 are in service.
37	400 KV	PADGHE - NAGOTHANE CKT - 2	1/10/2024	09:30	1/10/2024	18:00	Daily	1.Replacement of Distance & Over Voltage Relay. 2.Bay Maintenance work. 3.Diagnostic Testing work. 4.MTAMC Work	MSETCL	MSETCL	Weather Condition should be clear.
38	400 KV	NEW KOYNA - STAGE IV CKT - 1	1/10/2024	08:00	1/10/2024	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
39	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	1/10/2024	10:00	1/10/2024	17:00 D	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
40	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	1/10/2024	10:00	1/10/2024	17:00	Daily	Diagnostic testing of Bushing & winding	MSETCL	MSETCL	501MVA 400/220/33kV ICT-II will in service
41	400 KV	400/220/33 KV 500 MVA ICT - 3 @ DHULE	1/10/2024	09:00	1/10/2024	18:00	Daily	For Diagnostic testing and Routine maintenance work	MSETCL	MSETCL	315 MVA ICT-1 and 501 MVA ICT-2 are in service
42	400 KV	BUS REACTOR (80 MVAr) - 1 @ BABHALESHWAR	1/10/2024	10:00	1/10/2024	15:00	Daily	CB DCRM/Timing testing	MSETCL	MSETCL	Reactor is out of service during day hours
43	400 KV	JEJURI - KARAD	1/11/2024	08:00	1/11/2024	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
44	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	1/11/2024	10:30	1/11/2024	18:00	Daily	Bay Maintenance, CT Tan D & Relay Testing Work	MSETCL	MSETCL	Routine Maintenance Work
45	400 KV	MAIN BAY - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	1/11/2024	08:00	1/11/2024	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
46	400 KV	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	1/11/2024	08:00	1/11/2024	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
47	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	1/11/2024	10:00	1/11/2024	17:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
48	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	1/11/2024	09:00	1/11/2024	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.
49	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	1/11/2024	09:30	1/11/2024	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-1 & ICT-3 will continue to remain in service
50	400 KV	JAIGAD - NEW KOYNA CKT - 1	1/12/2024	08:00	1/12/2024	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
51	400 KV	KHADKA-AURANGABAD (WALUJ)	1/12/2024	10:00	1/12/2024	18:00	Daily	Diagnostic Testing and routine maintenance work	MSETCL	MSETCL	Outage on 400kV Waluj-Khadka (Bhusawal) Line through TBC Bay
52	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	1/13/2024	09:00	1/13/2024	18:00	Daily	Earthwire broken strands repairing work at Loc.6-7. and Jumper repairing at Loc.53	MSETCL	MSETCL	-
53	400 KV	JEJURI- KOYNA STAGE-IV	1/13/2024	08:00	1/13/2024	18:00	Daily	Cold washing of Insulator Strings	MSETCL	MSETCL	-

Sr.No .	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
54	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	1/15/2024	08:00	1/15/2024	18:00	Daily	HV CB Maintenance Work. ICT-1 will be in service through TBC.	MSETCL	MSETCL	Load On TBC
55	400 KV	NEW KOYNA - STAGE IV CKT - 2	1/15/2024	08:00	1/15/2024	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
56	400 KV	FUTURE CKT - 1 @ WARORA	1/16/2024	09:00	1/16/2024	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV IEPL ckt charged on its Main Bay CB
57	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	1/16/2024	10:00	1/16/2024	17:00	Daily	Diagnostic testing of Bushing & winding	MSETCL	MSETCL	501MVA 400/220/33kV ICT-I will in service
58	400 KV	400KV TBC @ KHADKA	1/16/2024	09:00	1/16/2024	18:00	Daily	For C& tan delta Measurement and routine bay maintenance work	MSETCL	MSETCL	As per annual outage plan.
59	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	1/16/2024	09:00	1/16/2024	18:00	Daily	Diagnostic testing work & Routine maintenance work	MSETCL	MSETCL	Bhusawal ckt will be in service
60	400 KV	400 KV FUTURE BAY II @ WARORA	1/17/2024	09:00	1/17/2024	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV PGCIL (NAGRI) ckt charged on its Main Bay CB.
61	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	1/17/2024	10:00	1/17/2024	17:00	Daily	Diagnostic testing of Bushing & winding	MSETCL	MSETCL	501MVA 400/220/33kV ICT-I will in service
62	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	1/17/2024	09:00	1/31/2024	18:00	Daily	PID testing work	MSETCL	MSETCL	-
63	400 KV	LONIKAND I - KOYNA STAGE-IV	1/18/2024	08:00	1/18/2024	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
64	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	1/18/2024	10:30	1/18/2024	18:00	Daily	Bay Maintenance, CT Tan D & Relay Testing Work	MSETCL	MSETCL	Routine Maintenance Work
65	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR ) - 1	1/18/2024	08:00	1/18/2024	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
66	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	1/18/2024	08:00	1/18/2024	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
67	400 KV	JEJURI- KOYNA STAGE-IV	1/18/2024	08:00	1/18/2024	17:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
68	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR ) - 1	1/18/2024	08:00	1/18/2024	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
69	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	1/18/2024	10:00	1/18/2024	18:00	Daily	For Overhauling of SERGI NIFPS Fire system for ICT No.2, Repairing and Overhauling of 89A PG isolators, Routine Maintenance and DT.	MSETCL	MSETCL	-
70	400 KV	BUS REACTOR (125 MVAr) - 2 @ KOLHAPUR (TALANDGE)	1/19/2024	09:00	1/19/2024	18:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Load affected nil
71	400 KV	CHANDRAPUR - KHAPERKHEDA	1/19/2024	07:00	1/19/2024	18:00	Daily	REPALCEMENT OF FAULTY STRINGS AND LINES MAINT WPRKS	MSETCL	MSETCL	NA
72	400 KV	WARORA - IEPL	1/19/2024	09:00	1/19/2024	17:00	Daily	Routine maintenance and diagnostic testing such as CVT/ CT tan delta, and, isolator maintenance work	MSETCL	MSETCL	Load will be managed on 400KV PGCIL Ckt .
73	400 KV	400/220/33 KV 315 MVA ICT - 1 @ WALUJ	1/19/2024	10:00	1/19/2024	18:00	Daily	Diagnostic Testing and routine maintenance work	MSETCL	MSETCL	NIL

Sr.No	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
74	400 KV	AKOLA 2 (YELWAN) - AKOLA 1 CKT - 2	1/19/2024	09:00	1/19/2024	18:00	Daily	Metering CT tan delta & diagnostic testing and routine maintenance work	APTCL	APTCL	Yelwan Ckt-01 will be in service
75	400 KV	CHANDRAPUR-PARLI CKT-3	1/19/2024	09:00	1/19/2024	18:00	Daily	Nut bolt hardware tightning work/ Spacer Replacement	MSETCL	MSETCL	-
76	400 KV	KHADKA - BABLESHWAR	1/20/2024	08:00	1/20/2024	18:00	Daily	Routine Line maintenance work;CVT tan D testing work	MSETCL	MSETCL	400KV Karangadgaon, 400KV Dhule ckt I&II, Ektuni I&II will be in service
77	400 KV	WARORA - IEPL	1/20/2024	07:00	1/20/2024	18:00	Daily	LINE MAINT. WORKS	MSETCL	MSETCL	NA
78	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	1/20/2024	08:00	1/20/2024	20:00	Daily	For preventative maintenance and dignostic testing works.	MSETCL	MSETCL	As per annual,outage plan.
79	400 KV	TBC @ CHAKAN	1/20/2024	10:00	1/20/2024	18:00	Daily	Replacement of 89A 400kV PG Isolator scissors, Routine maintenance and DT.	MSETCL	MSETCL	-
80	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	1/22/2024	09:00	1/22/2024	18:00	Daily	broken conductor strand replair at loc 45 to 46	MSETCL	MSETCL	kind of emergency work
81	400 KV	TBC @ KOLHAPUR(TALANDGE)	1/22/2024	09:00	1/22/2024	18:00	Daily	Quarterly maintenance work, Relay testing work	MSETCL	MSETCL	Load affected nil
82	400 KV	CHANDRAPUR-PARLI CKT-3	1/22/2024	09:00	1/22/2024	18:00	Daily	(1) Reactor testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work	MSETCL	MSETCL	(1) Reactor testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work
83	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	1/23/2024	09:00	1/23/2024	18:00	Daily	Diagnostic testing & routine maintenance work	MSETCL	MSETCL	load will be shifted on ICT-02 & 03
84	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	1/23/2024	08:00	1/24/2024	18:00	Continuous	1.Maintenance and alignment of HV Side CB, PG Isolators. 2. Routine maintenance of ICT	MSETCL	MSETCL	During outage, 400/220/33KV ICT-1, 220KV CHD-2 will be in service.
85	400 KV	400/220 KV 315MVA ICT - 1 @ KARAD	1/24/2024	09:00	1/24/2024	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Quarterly maintenance work
86	400 KV	400/220KV 500MVA ICT 3 @ AKOLA	1/25/2024	09:00	1/25/2024	18:00	Daily	Diagnostic testing CT tan delta, bushing Tan delta winding resistance & routine ,maintenance work	MSETCL	MSETCL	load will be shifted on ICT-01 & 02
87	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	1/25/2024	09:00	1/25/2024	18:00	Daily	Spacer replacement/Nut bolt Hardware tightning/ loc.no.497-500 Earthwire stringing work	MSETCL	MSETCL	-
88	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	1/25/2024	09:00	1/25/2024	18:00	Daily	(1) Reactor testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work Hardware tightening & fitting work (1) Reactor testing work. (2) Bay maintenance work. (3)	MSETCL	MSETCL	-
89	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR ) - 2	1/25/2024	08:00	1/25/2024	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
90	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	1/25/2024	10:30	1/25/2024	18:00	Daily	Bay Maintenance, CT Tan D & Relay Testing Work	MSETCL	MSETCL	Routine Maintenance Work

Sr.No .	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
91	400 KV	DHULE- - BABLESHWAR CKT - 1	1/27/2024	08:00	1/27/2024	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Bhusawal,400kV Dhule ckt II, 400kV Aurangabad ,Ektuni I&II will be in service
92	400 KV	DHULE- - BABLESHWAR CKT - 2	1/28/2024	08:00	1/28/2024	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Bhusawal,400kV Dhule ckt I, 400kV Aurangabad ,Ektuni I&II will be in service
93	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	1/29/2024	08:00	1/29/2024	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
94	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	1/29/2024	09:00	1/29/2024	18:00	Daily	Nut bolt hardware tightning work & Earthwire Stringing Work loc.no.497-500/ Spacer Replacement	MSETCL	MSETCL	-
95	400 KV	KARAD - TALANDGE CKT - 1	1/29/2024	09:00	1/29/2024	18:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Load will be managed on 400kV Talandge Karad Ckt -II Monday is load staggering day
96	400 KV	KHADKA-AURANGABAD (WALUJ)	1/30/2024	08:00	1/30/2024	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Bhusawal,400kV Dhule ckt I&II, 400kV Aurangabad ,Ektuni I&II will be in service
97	400 KV	JEJURI - KARAD	1/30/2024	09:00	1/30/2024	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	Quarterly maintenance work
98	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	1/30/2024	08:00	1/30/2024	18:00	Daily	1.Maintenance and alignment of CBI, PG Isolators. 2. Routine maintenance of ICT	MSETCL	MSETCL	During outage, 400/220/33KV ICT-2, 220KV CHD-2 will be in service.
99	400 KV	400/220/33 KV 315 MVA ICT - 1 @ CHANDRAPUR	1/31/2024	08:00	1/31/2024	18:00	Daily	1.Maintenance and alignment of CBI, PG Isolators. 2. Routine maintenance of ICT	MSETCL	MSETCL	During outage, 400/220/33KV ICT-2, 220KV CHD-2 will be in service.