

Outage planning of transmission elements for the month of Feb 2018

Sr.No.	503rd OCCM Sr. No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS
				Date	Time	Date	Time					
1	5	220	Wardha PG-Pusad line	01/Feb/18	7:00	28/Feb/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	
2	6	400	400kV New Koyna- Karad Ckt I&II	01/Feb/18	7:00	28/Feb/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	
3	7	400	400kV Jejuri - Lonikand S/c line	01/Feb/18	7:00	28/Feb/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	
4	14	400	Dabhol-Nagonathane Ckt 2 Line@Dabhol	01/Feb/18	8:00	07/Feb/18	18:00	Daily	For Cold washing , insulator replacement ,Earth wire replacement	MSETCL	MSETCL	Remaing all lines from RGPPL to be inservice along with AR
5	15	400	400kV WARDHA-AKOLA I & II	01/Feb/18	8:00	15/Feb/18	18:30	Daily	Both circuit-I & II, A/R to keep in Non-Auto mode for carry out Hotline maintenance.	POWERGRID	WRTS-I	
6	23	400	400kV Chakan -Talegaon line @ 400kV Chakan SS	01/Feb/18	9:00	01/Feb/18	18:00	Daily	Half Yearly Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
7	27	220	220kV Bus # 1 & 220kV Badnera line at wardha	01/Feb/18	9:00	01/Feb/18	18:00	Daily	Bay Amp work, Hotspot on Bus1 side Isolator.	POWERGRID	WRTS-I	SLDC Maharasgtra consent required
8	37	400	400kV Kalwa-Talegaon Line & Talegaon-Kharghar Line	01/Feb/18	9:00	09/Feb/18	18:00	Daily	PID Testing work of 400 Kalwa-Talegaon & 400Talegaon-Kharghar (D/C) line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	
9	55	400	Chandrapur 2 - Kumbhargaoon (Nanded) Ckt-II	01/Feb/18	6:00	15/Feb/18	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	
10	56	400	GCR Chandrapur - Parli Ckt -III	01/Feb/18	6:00	15/Feb/18	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	
11	65	220	Chitegaon - Chittepimpalgaon (PGCIL) Ckt. -II @Chitegaon	02/Feb/18	8:00	02/Feb/18	18:00	Daily	Maintenance of Isolators and routine maintenance work.	MSETCL	MSETCL	
12	66	400	400kV DGEN ICT-1 (BAY 408) WITH 400kV DGEN BUS 2	02/Feb/18	8:00	02/Feb/18	19:00	Daily	Annual PM of 408 89B isolator. Bus B outage and ICT-1 bay outage required.	TPL	TPL	
13	75	400	315 MVA ICT-II at Boisar	02/Feb/18	09:00	02/Feb/18	18:00	Daily	AMP	POWERGRID	WRTS-II	SLDC Maharashtra consent required
14	83	220	PGCIL -Shendra Ckt 1 @ Shendra	02/Feb/18	10:00	02/Feb/18	17:00	Daily	Maintenance Work	MSETCL	MSETCL	
15	85	765	765kV Ektuni-Akola Ckt-I @Ektuni	02/Feb/18	10:00	02/Feb/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	NLDC consent required
16	86	400	400kV KOLHAPUR (MSETCL)- KOLHAPUR (GIS) II	02/Feb/18	10:00	02/Feb/18	18:00	Daily	For Line side equipment & Line AMP works.	POWERGRID	WRTS-I	
17	89	400	400kV Waluj-2 & ICT-3 Tie bay-408 at Aurangabad	02/Feb/18	11:00	02/Feb/18	13:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
18	90	400	400kV Waluj-2 Main bay-409 at Aurangabad	02/Feb/18	14:00	02/Feb/18	16:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
19	91	400	400kV Wardha-2 Main bay-410 at Aurangabad	02/Feb/18	16:00	02/Feb/18	18:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
20	92	400	410Main Bay &411Tie Bay (Main Bay of 400kV Girwali ckt-1) at 400kV Nanded	03/Feb/18	11:00	03/Feb/18	18:00	Daily	Quarterly Maint. Of Bay's Equipments	MSETCL	MSETCL	
21	101	400	400kV Waluj-1 & Wardha-2 Ttie bay-411 at Aurangabad	03/Feb/18	9:00	03/Feb/18	11:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
22	110	400	400kV Waluj-1 Main bay-412 at Aurangabad	03/Feb/18	11:00	03/Feb/18	13:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
23	111	400	400kV Wardha-1 Main bay-413 at Aurangabad	03/Feb/18	14:00	03/Feb/18	16:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
24	112	400	400kV Akola-1 & Wardha-1Ttie bay-414 at Aurangabad	03/Feb/18	16:00	03/Feb/18	18:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
25	113	400	Bus-I at Boisar	04/Feb/18	09:00	04/Feb/18	18:00	Daily	AMP	POWERGRID	WRTS-II	SLDC Maharasgtra consent required/To be availed on Sunday
26	126	400/220	Kharghar @ Kalwa	05/Feb/18	6:00	05/Feb/18	20:00	Daily	29B isolator replacement work , 29 C,D,E work and Bay maintenance and testing Work	MSETCL	MSETCL	
27	128	400	400kV Khadka-Akola	05/Feb/18	6:00	06/Feb/18	18:00	Daily	Permission for carrying out PID . During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL	
28	131	400	400kV Dhule-SSNNL Ckt-I &II	05/Feb/18	8:00	05/Feb/18	17:00	Daily	On Line PID Testing	MSETCL	MSETCL	
29	134	400	400kV Girwali-Lonikhand(II) D/c line	05/Feb/18	6:00	05/Feb/18	20:00	Continuous	Construction of 400D/C Old Parli - New Parli TL	MSETCL	WRTS-I	Hot line method , due to high demand and high loading .
30	139	400	Babhaleshwar-Aurangabad - @BBLR	05/Feb/18	9:00	05/Feb/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Bhusawal,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
31	140	400	400kV Akola-1 Main bay-415 at Aurangabad	05/Feb/18	9:00	05/Feb/18	11:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	

Sr.No.	503rd OCCM Sr. No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS
				Date	Time	Date	Time					
32	142	400	400KV WARORA-WARDHA Ckt @ Warora	05/Feb/18	9:00	05/Feb/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
33	145	400	400KV Alkud (Kolhapur-1) Main bay (415) at Solapur.	05/Feb/18	9:00	05/Feb/18	18:00	DAILY	AMP	POWERGRID	WRTS-I	
34	152	220	220KV Bus-I at Boisar	05/Feb/18	09:00	05/Feb/18	18:00	Daily	AMP	POWERGRID	WRTS-II	SLDC Maharashtra to be informed
35	160	400	Babhaleshwar-Padgha 2	05/Feb/18	9:00	28/Feb/18	9:00	Daily	PID testing of insulator strings by Hot line Uint A/R shall be kept in non auto mode.	MSETCL	MSETCL	
36	161	220	220KV Talegaon MSETCL -1 Main bay (202)) at Pune (Talegaon)	05/Feb/18	9:30	05/Feb/18	17:00	Daily	For AMP works	POWERGRID	WRTS-I	Line to be inservice with TBC bay
37	169	400	400KV Akola-2 & Future tie bay-417 at Aurangabad	05/Feb/18	11:00	05/Feb/18	13:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
38	170	400	400KV Akola-2 Main bay-418 at Aurangabad	05/Feb/18	14:00	05/Feb/18	16:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
39	172	765	712LR- Akola Line 2 Reactor at Koradi-III SS (Switchable)	05/Feb/18	8:00	05/Feb/18	18:00	Daily	For Maintenance of Reactor and related equipments	MEGPTCL	MEGPTCL	
40	175	400	400kv Main Bus-I @ 400kv S/S Chandrapur	06/Feb/18	6:00	07/Feb/18	18:00	Continuous	1) For checking the healthiness of R, Y & B-ph 400Main BUS-I CVTs. At present there, is a difference of around 7-8 kV on primary side. 2) As per Partial Discharge test report , it is also necessary to confirm healthiness of 400Main Bus-1 CVTs.	MSETCL	MSETCL	
41	177	400	Akola - Bhusawal Ckt with Bay 409 & 410 at 400KV Akola	06/Feb/18	9:00	06/Feb/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
42	178	400	400KV Parli-2 Main Bay (409) at Wardha	06/Feb/18	9:00	06/Feb/18	18:00	Daily	Bay Amp work	POWERGRID	WRTS-I	
43	179	220	TAPS-3&4 to Boisar S/c line	06/Feb/18	9:00	07/Feb/18	18:00	Continuous	preventive maintenance of CB, LA, CVT, DS, ES, CT, relays & outdoor tightness and inspection	POWERGRID	NPCIL	
44	183	400	400KV Dhule-SSNNL Ckt-I &II	06/Feb/18	8:00	06/Feb/18	17:00	Daily	On Line PID Testing	MSETCL	MSETCL	
45	186	400	400KV Dhule-SSNNL Ckt-II	06/Feb/18	8:00	10/Feb/18	17:00	Daily	STRING Work Replacement	MSETCL	B N Chaudhari ltd	
46	197	400	428- Bay (Tie Bay of Warora- Wardha ckt at PGCIL Boisar Ckt)	06/Feb/18	9:00	10/Feb/18	17:00	Continuous	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
47	206	400	400KV Boisar-2 LR bay-427R at Aurangabad	06/Feb/18	14:00	06/Feb/18	16:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
48	220	400	765KV /400KV ICT-1 Main bay-428 at Aurangabad	07/Feb/18	9:00	07/Feb/18	11:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
49	234	220	220kv Kalmeshwar-Pandhurna ckt	07/Feb/18	10:00	07/Feb/18	18:00	Daily	For maintenance work	MSETCL	MSETCL	
50	235	400	400kv , 1500MVA ICT-I (410) Bay @ Ektuni	07/Feb/18	10:00	07/Feb/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	
51	243	400	400KV Chandrapur-Parli-III & 400KV Parli-Nanded-II	08/Feb/18	6:00	08/Feb/18	20:00	Continuous	Construction of 765D/C Warora-Parli Part-III TL	MSETCL	WRTS-I	SLDC Maharashtra consent required / Explore the possibility of hot line method. SLDC Remark:Hot line method , due to high demand and high loading .
52	248	400	400KV SOLAPUR PGCIL@ Karad	08/Feb/18	10:00	08/Feb/18	17:00	Daily	Quarterly. Maint. Work / Replacement of Disc Insulators.	MSETCL	MSETCL	
53	252	400	400KV Parli -Lonikand-II	08/Feb/18	8:00	08/Feb/18	17:00	Daily	Maintenance work By Lamboti Sdn	MSETCL	MSETCL	
54	254	220	Talegaon M - Talegaon PG Ckt I @Talegaon M	08/Feb/18	8:00	08/Feb/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL	
55	256	400	400KV BHADRAVATI-CHANDRAPUR III	08/Feb/18	8:00	08/Feb/18	18:00	Daily	For Tighning of Loose C C rings in Loc.No.07 , A/R to be keep in Non-Auto mode for Ckt-IV.	POWERGRID	WRTS-I	
56	259	400	400kv Chakan - Lonikand line @ 400kv Chakan &Lonikand ends	08/Feb/18	9:00	08/Feb/18	18:00	Daily	Half Yearly Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
57	276	400	400KV Akola- Bhusawal Line	08/Feb/18	12:00	10/Feb/18	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 Koradi- Bhusawal, 400 Akola- Nandgaonpeth & 400 Koradi- Nandgaonpeth are in service.
58	287	220	220kv Boisar-Boisar-I Line at Boisar	09/Feb/18	09:00	09/Feb/18	17:00	Daily	Line Equipment AMP	POWERGRID	WRTS-II	To be availed on Friday
59	289	765/400	400kv , 1500MVA ICT-II (406) Bay @Ektuni	09/Feb/18	10:00	09/Feb/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	
60	292	400	400KV Koradi -Bhusawal ckt	09/Feb/18	8:00	09/Feb/18	17:00	Daily	Restrining work between tower loction 5-6 &111-112	MSETCL	MSETCL	
61	294	220	TAPS -Borivali (M) @ Borivali (M)	09/Feb/18	8:00	09/Feb/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL	
62	295	400	400KV BHADRAVATI-CHANDRAPUR IV	09/Feb/18	8:00	09/Feb/18	18:00	Daily	Tighning of Loose C C rings in Loc.No.07, A/R to be keep in NonAuto mode for ckt-III	POWERGRID	WRTS-I	

Sr.No.	503rd OCCM Sr. No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS
				Date	Time	Date	Time					
63	296	400	400kV Aurangabad-Aurangabad-1 along with Main Bus-2 at Msetcl, Waluj SS	09/Feb/18	8:00	09/Feb/18	18:00	Daily	line AMP works and for repairing of damaged strands of Bus conductors & CT drop jumpers replacement. Note:400Aurangabad-Aurangabad-1 along with Main Bus-2 at Waluj SS (MSETCL).Bus conductor strands got cut near pantograph Isolator and it needs to repair and alignment of Bus Isolator	POWERGRID	WRTS-I	
64	300	400	Babhaleshwar-Ektuni-Ckt-1 @BBLR	09/Feb/18	9:00	09/Feb/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Bhusawal, Auranagabad Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
65	301	220	Mudshingi -Chikodi @ Mudshingi	09/Feb/18	9:00	09/Feb/18	17:00	Daily	Half yearly maintenance of 220 kV Main Bus section II & III & Routine Quarterly Maintenance work of chikodi bay equipments.	MSETCL	MSETCL	NLDC Consent required
66	302	400	Kharghar-Kalwa @ 400kV Kharghar	09/Feb/18	9:00	09/Feb/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	400Kharghar-Talegaon will be in service
67	303	220	Nasik - Navsari Ckt 1 @ Nasik	09/Feb/18	9:00	09/Feb/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL	
68	326	400	400kV Girwali-Solapur ckt @ Girwali	10/Feb/18	9:00	10/Feb/18	18:00	Daily	Bay maintenance work	MSETCL	MSETCL	
69	329	400	Parli-Nanded-I	10/Feb/18	8:00	11/Feb/18	18:00	Continuous	Construction of 765D/C Warora-Parli Part-III TL	MSETCL	WRTS-I	
70	330	400	Akola - Yelawan Ckt- 1 with Bay 414 & 415 at 400kV Akola	10/Feb/18	9:00	10/Feb/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
71	332	500	Pole-I of Chandrapur-Padghe HVDC Line	10/Feb/18	6:00	11/Feb/18	17:00	Daily	For Repairing of damaged OPGW wire above Pole-I of Chandrapur-Padghe HVDC Line	MSETCL	MSETCL	
72	333	400	400kV Bus Bar @ Khadka ss	10/Feb/18	8:00	10/Feb/18	17:00	Daily	400 Bus Bar ABB RADSS Relay Testing	MSETCL	MSETCL	
73	334	400	400kV Kalwa-Padgha Line-2	10/Feb/18	8:00	10/Feb/18	18:00	Daily	Insulator Replacement work	MSETCL	MSETCL	
74	335	400	Parli MS-Lamboti	10/Feb/18	6:00	10/Feb/18	20:00	Continuous	Construction of 400D/C Old Parli - New Parli TL	MSETCL	WRTS-I	Hot line method , due to high demand and high loading .
75	336	765	765kV AURANGABAD(PG)-SOLAPUR I & II	10/Feb/18	8:00	11/Feb/18	18:00	Continuous	Construction of 765D/C Parli - Solapur TL	POWERGRID	WRTS-I	NLDC Consent required / ATC/TTC revision in WR-SR path, Saturday and Sunday
76	338	220	Nasik - Navsari Ckt 2 @ Nasik	10/Feb/18	9:00	10/Feb/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL	
77	339	400	ICT2_400kV /220kV _SOLAPUR	10/Feb/18	9:00	10/Feb/18	18:00	DAILY	STATCOM COMMISSIONING WORKS	POWERGRID	WRTS-I	
78	341	400	400kV Kalwa-Talegaon Line, (2) 400kV K V Kalwa-Kharghar Line	10/Feb/18	9:00	17/Feb/18	18:00	Daily	PID Testing work of 400 Kalwa-Talegaon & 400Kalwa-Kharghar (D/C) line insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	
79	354	400	400kV SSNL-Dhule-2	10/Feb/18	8:00	10/Feb/18	18:00	Daily	Line Maintenance Work	MSETCL	GETCO	Auto reclose of SSP - Dhule line No. 1 will remain out
80	360	400	Dhule- Dhule BDTCL Ckt-1 @ Dhule	11/Feb/18	8:00	11/Feb/18	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL	
81	364	765	765kV S/C Tirora-Koradi line ckt-1	11/Feb/18	7:00	11/Feb/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L ,part 2 at power line crossing section	MEGPTL	WRTS-II	SPS to be inservcie at Tirora/MEGPTCL NOC . No.gen backdown for APML gen.
82	368	400	400kV ALKUD - KOLHAPUR LINE @ ALKUD	11/Feb/18	9:30	11/Feb/18	17:30	DAILY	Quarterly Maint. Work	MSETCL	MSETCL	
83	370	765	765kV S/C Tirora-Koradi line ckt-1	11/Feb/18	7:00	11/Feb/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L ,part 2 at power line crossing section	MEGPTL	WRTS-II	MEGPTCL NOC . No.gen backdown for APML gen.
84	372	765	765kV Tiroda-Koradi-III Ckt-I	11/Feb/18	8:00	11/Feb/18	18:00	Daily	For Maintenance of Transmission Line	MEGPTCL	MEGPTCL	Preponed and Clubbed with other utility request
85	374	400	Babhaleshwar-Padghe -Ckt-2 @BBLR	12/Feb/18	9:00	12/Feb/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	Chandrapur-Padghe-HVDC bipole to be inservcie with full transfer capacity
86	377	400	Dhule- Dhule BDTCL Ckt-2 @Dhule	12/Feb/18	8:00	12/Feb/18	17:00	Daily	Routine Maintenance work	MSETCL	MSETCL	
87	379	400/220	Padgha II @ Kalwa	12/Feb/18	6:00	12/Feb/18	20:00	Daily	29D isolator replacement work and Bay maintenance and testing Work	MSETCL	MSETCL	
88	382	400	400kV Khadka-Koradi	12/Feb/18	6:00	13/Feb/18	18:00	Daily	Permission for carrying out PID by Special PID Gang under EHV (O&M) Circle.Bhusawal. During the PID only Auto-reclose of the ckt will be made Off from both side of the ckt.The Ckt will be in live condition. No outage required.	MSETCL	MSETCL	
89	404	400	411 (Main Bay Wardha Ckt- 2) at 400kV Akola	12/Feb/18	10:00	12/Feb/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	

Sr.No.	503rd OCCM Sr. No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS
				Date	Time	Date	Time					
90	417	400	Babhaleshwar-Padghe-Ckt-1 @BBLR	13/Feb/18	9:00	13/Feb/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	Chandrapur-Padghe-HVDC bipole to be inservice with full transfer capacity
91	420	765	765kV S/C Tirora-Koradi line ckt-2	13/Feb/18	7:00	13/Feb/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L ,part 2 at power line crossing section	MEGPTL	WRTS-II	MEGPTCL NOC : No.gen backdown for APML gen.
92	422	400	400kV Kharghar Main bay (403) at Pune (Talegaon)	13/Feb/18	9:30	13/Feb/18	17:00	Daily	For AMP works	POWERGRID	WRTS-I	
93	424	765	765kV S/C Tirora-Koradi line ckt-2	13/Feb/18	7:00	13/Feb/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L ,part 2 at power line crossing section	MEGPTL	WRTS-II	SPS at Tirora to be inservice/MEGPTCL NOC . No.gen backdown for APML gen.
94	451	765	765kV Tiroda-Koradi-III CKT-II	13/Feb/18	8:00	13/Feb/18	18:00	Daily	For Maintenance of Transmission Line	MEGPTCL	MEGPTCL	Preponed and Clubbed with other utility request
95	455	765	765kV Ektuni-Akola Ckt-II @ Ektuni	14/Feb/18	10:00	14/Feb/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	
96	456	400	400kV AURANGABAD(PG)-AURANGABAD(MSETCL) II	14/Feb/18	8:00	14/Feb/18	18:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
97	457	400	Babhaleshwar-Bhusawal -@BBLR	14/Feb/18	9:00	14/Feb/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Auranagabad Dhule-Ckt-1&2, Ektuni-ckt-1&2, will be in service
98	468	500	500kV HVDC Chandrapur-Padghe	14/Feb/18	6:00	14/Feb/18	20:00	Continuous	Construction of 765D/C Warora-Parli TL	MSETCL	WRTS-I	Already approved on 10.02 - 11.02 and explore the possibility of hot line method/Hot line method , due to high demand and high loading .
99	472	220	South Solapur - Solapur PGCIL @South Solapur	14/Feb/18	9:00	14/Feb/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL	
100	481	220	220kV PGCIL- Badnera Line	14/Feb/18	10:00	14/Feb/18	17:00	Daily	For measurment of CRM at 220 kv Bhugaon S/Strn	MSETCL	MSETCL	
101	486	400	400kV Koyna Stage 4- Jejuri ckt	14/Feb/18	10:00	15/Feb/18	17:00	Daily	Cold line Washing work	MSETCL	Ramelex Pvt Ltd,Pune	400Jejuri-Lonikand ckt should be in service
102	490	400	400kV Wardha-2 Main Bay (404) at Parli	14/Feb/18	9:00	14/Feb/18	18:00	Daily	For AMP works at Parli	POWERGRID	WRTS-I	
103	492	400	Babhaleshwar-Ektuni-Ckt-2 @BBLR	15/Feb/18	9:00	15/Feb/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	Chandrapur-Padghe-HVDC bipole to be inservice with full transfer capacity
104	495	400	400kV SSNL - Dhule - 1	15/Feb/18	8:00	15/Feb/18	18:00	Daily	Line Maintenance Work	MSETCL	GETCO	Auto reclose of SSP - Dhule line No. 2 will remain out
105	500	220	Talegaon M - Talegaon PG Ckt II@Talegaon M	15/Feb/18	8:00	15/Feb/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL	
106	503	400	400kV WARDHA-MAUDA I & II	15/Feb/18	8:00	16/Feb/18	18:00	Continuous	Power line crossing of under Construction 765D/C Gadawara-Warora TL.	POWERGRID	WRTS-I	Subject to mouda generation
107	505	400	400kV KORADI-WARDHA Ckt	15/Feb/18	9:00	15/Feb/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
108	518	400	400kV KOLHAPUR (MSETCL)- KOLHAPUR (GIS) I	15/Feb/18	10:00	15/Feb/18	18:00	Daily	For Line side equipment & Line AMP works.	POWERGRID	WRTS-I	
109	522	400	404-Bay (Main Bay of 501MVA 400kV /220kV ICT-1) at 400kV Nanded Substation	15/Feb/18	11:00	15/Feb/18	18:00	Daily	Quarterly Maint. Of Bay's Equipments	MSETCL	MSETCL	
110	523	400	400kV Akola- Nandgaonpeth Line	15/Feb/18	12:00	17/Feb/18	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 Koradi- Bhusawal, 400 Akola- Bhusawal & 400 Koradi- Nandgaonpeth are in service.
111	524	400	400kV Vapi-Boisar at Boisar	15/Feb/18	14:00	15/Feb/18	17:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	POWERGRID	WRTS-II	
112	528	400	400kV WARDHA-PARLI I	16/Feb/18	6:00	28/Feb/18	18:00	Daily	A/R to be kept in Non auto mode for Online OPGW work.	POWERGRID	WRTS-I	
113	529	400	400kV Aurangabad-Aurangabad-1 along with Main Bus-1 at Msetcl, Waluj SS	16/Feb/18	8:00	16/Feb/18	18:00	Daily	for repairing of damaged strands of Bus conductors & CT drop jumpers replacement. Note: 400Aurangabad-Aurangabad-1 along with Main Bus-1 at Waluj SS (Msetcl).Bus conductor strands got cut near pantograph Isolator and it needs to repair and alignment of Bus Isolator	POWERGRID	WRTS-I	To be availed on Friday
114	530	220	220kV Boisar-Boisar-III Line at Boisar	16/Feb/18	09:00	16/Feb/18	17:00	Daily	Line Equipment AMP	POWERGRID	WRTS-II	
115	533	400	400kV PARLI(PG)-PARLI(MSETCL) I & II	16/Feb/18	6:00	16/Feb/18	20:00	Continuous	Construction of 400D/C Old Parli - New Parli TL	POWERGRID	WRTS-I	Hot line method , due to high demand and high loading .
116	534	400	400kV Lonikand 2 ckt 1 @Girwali	16/Feb/18	9:00	16/Feb/18	18:00	Daily	Testing of M-1 & M-2 Numerical distance prot. Relay.	MSETCL	MSETCL	

Sr.No.	503rd OCCM Sr. No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS
				Date	Time	Date	Time					
117	536	400	403-Bay (Tie Bay of ICT-1 & 400kV Chandrapur ckt-2) at 400kV Nanded Substation	16/Feb/18	11:00	16/Feb/18	18:00	Daily	Quarterly Maint. Of Bay's Equipments	MSETCL	MSETCL	
118	541	400	400kV KOLHAPUR-MAPUSA II	16/Feb/18	8:00	16/Feb/18	18:30	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for other ckt will be required during above period.	POWERGRID	WRTS-I	SLDC Goa to be informed / All interconnector lines between Maharashtra and Goa to be inservice
119	553	400	400kV JAIGAD -I @ Karad	16/Feb/18	10:00	16/Feb/18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	
120	554	400	408 (Main Bay of Wardha Ckt-1) at 400kV Akola	16/Feb/18	10:00	16/Feb/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
121	557	220	220kV Chittegaon-1 Main bay-207 at Aurangabad	16/Feb/18	14:00	16/Feb/18	18:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	Line to be inservice with TBC bay
122	558	400	400kV CHD-I CHD-II CKT No.I Bay @400kV S/S Chandrapur	16/Feb/18	8:00	16/Feb/18	18:00	Daily	1)Measurement of Tan delta & capacitance of CTV's. 2) For attending the Hot spot. 3) Routine maintenance of the bay.	MSETCL	MSETCL	
123	561	220	TAPS - Boisar M @ Boisar (M)	17/Feb/18	8:00	17/Feb/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL	
124	567	400	400kV WARORA-PGCIL CKT BAY NO 420 & 421 (421 is tie bay of 400kV pgcil and 400kV future-2)@ 400kV s/s warora end	17/Feb/18	8:00	17/Feb/18	17:00	Daily	Rotuine bay maintenance and relay testing	MSETCL	MSETCL	Load will be managed on 400IEPL Ckt
125	568	400	400kV Bus I @ Khadka S/S	17/Feb/18	8:00	17/Feb/18	17:00	Daily	New Reactor Bay PG Isolator errection work	MSETCL	BNC Power Project	
126	572	220	220kV Shendra-1 Main bay-208 at Aurangabad	17/Feb/18	9:00	17/Feb/18	13:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	Line to be inservice with TBC bay
127	582	220	220kV Shendra-2 Main bay-209 at Aurangabad	17/Feb/18	14:00	17/Feb/18	18:00	Daily	For intigration of NTAMC & Trail operations to improment the system smooth operations.	POWERGRID	WRTS-I	
128	583	400	Padgh-Kalwa-I @ Padghe	17/Feb/18	8:00	17/Feb/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL	
129	588	220	220kV Bus-II at Boisar	18/Feb/18	09:00	18/Feb/18	18:00	Daily	AMP	POWERGRID	WRTS-II	SLDC Maharashtra to be informed/To be availed on Sunday
130	589	400	400kV Bus Coupler @ Padghe	18/Feb/18	8:00	18/Feb/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL	Can be Facilitated on Sunday
131	590	400	400kV Bus # 1 at Wardha	18/Feb/18	9:00	19/Feb/18	18:00	Continuous	Bus Extension for 400 Aurangabad 1 & 2	POWERGRID	WRTS-I	
132	592	400	400kV Parli-Solapur-I & II	18/Feb/18	8:00	19/Feb/18	18:00	Continuous	Construction of 765D/C Warora-Parli TL & 765D/C Parli - Solapur TL & 400D/C Parli-Parli TL	RELIANCE	WRTS-I	
133	597	400/220	Talegaon @ Kalwa	18/Feb/18	9:00	18/Feb/18	20:00	Daily	Isolator overhauling and testing,Maintenance work	MSETCL	MSETCL	
134	611	400	400kV Boisar-Padghe at Boisar	19/Feb/18	09:00	19/Feb/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	POWERGRID	WRTS-II	
135	634	400	400kV Bus # 2 at Wardha	20/Feb/18	9:00	21/Feb/18	18:00	Continuous	Bus Extension for 400 Aurangabad 1 & 2	POWERGRID	WRTS-I	
136	638	220	220kV PGCIL(DEOLI) TO BHUGAON LINE	20/Feb/18	8:00	20/Feb/18	17:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
137	642	400	Chandrapur (Old GCR)-Parli ckt-III@Girwali	20/Feb/18	9:00	20/Feb/18	17:00	Daily	Outage For n/b tightening of hardware at Loc. No. 881, 950	MSETCL	MSETCL	
138	643	400	429- Bay (Main Bay of Warora- Wardha ckt at PGCIL Deoli S/Stn)	20/Feb/18	9:00	20/Feb/18	17:00	Continuous	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Bus-2 is already under shutdown / clubbed with Bus s/d
139	653	400	400kV KOLHAPUR (MSETCL)-I & FUTURE TIE BAY 408 at Kolhapur-GIS.	20/Feb/18	10:00	20/Feb/18	18:00	Daily	For AMP works	POWERGRID	WRTS-I	
140	661	400	400kV Khadka-Auramgabad	21/Feb/18	8:00	23/Feb/18	18:00	Daily	Faulting string replcement works.	MSETCL	MSETCL	
141	662	220	220kV Bhilad-Tarapur	21/Feb/18	8:00	21/Feb/18	18:00	Daily	Bay Maintenance work	GETCO	GETCO	
142	663	400	GCR Chandrapur - Parli Ckt -III	21/Feb/18	8:00	21/Feb/18	17:00	Daily	For Line Signature testing	MSETCL	MSETCL	
143	664	400	400kV FUTURE BAY-II BAY NO 421 & 422 (421 is tie bay of 400kV pgcil and 400kV future-2) @400kV s/s warora end	21/Feb/18	8:00	21/Feb/18	17:00	Daily	Rotuine bay maintenance and relay testing	MSETCL	MSETCL	400Bay No 422 charged on No Load
144	671	220	220kV SOLAPUR- KUMBHARI#1	21/Feb/18	9:00	21/Feb/18	18:00	DAILY	Line side equipment and bay AMP works.	POWERGRID	WRTS-I	
145	673	400	400kV BHILAI-KORADI	21/Feb/18	9:00	21/Feb/18	18:00	Daily	For installation of wave trap at Koradi end.	POWERGRID	WRTS-I	
146	674	400	400kV Aurangabad-2 Main bay-409 at Aurangabad	21/Feb/18	9:00	21/Feb/18	18:00	Daily	for AMP works	POWERGRID	WRTS-I	
147	686	400	400kV WARDHA-PARLI I & II	22/Feb/18	9:00	23/Feb/18	18:00	Daily	for restoration of OPGW in location 325 to 329 in ckt# 1 and insulator replacement at highway crossing.	POWERGRID	WRTS-I	
148	692	400	400kV D/C Koradi II to Koradi III line ckt-1&2	22/Feb/18	7:00	22/Feb/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L .part 2 at power line crossing section	MSETCL	WRTS-II	Proposal from MSETCL O&M Required . No gen. Backdown for Koradi II.