

Maharashtra State Load Despatch Centre

WRPC OCCM approved Monthly Outage list for the Month of February 2020

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason
1	14	400KV-KALWA-PADGHE-2	1-Feb-20	09:00	8-Feb-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
2	21	400KV-BABLESHWAR-PADGHE-PG-1	1-Feb-20	08:00	15-Feb-20	18:00	Daily	MSETCL	For Carrying PID Work
3	22	400KV-RGPPL-NEW KOYNA-2	1-Feb-20	10:00	15-Feb-20	15:00	Daily	MSETCL	PID Test of insulators
4	25	220KV-WARDHA-PUSAD-1	1-Feb-20	08:00	28-Feb-20	17:00	Daily	MSETCL	PID Work.
5	44	400KV-KARAD-NEW KOYNA-2	1-Feb-20	09:00	29-Feb-20	17:00	Daily	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
6	45	400KV-KALWA-KHARGHAR-1	1-Feb-20	09:00	29-Feb-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
7	46	400KV-KARAD-KOLHAPUR-MS-1	1-Feb-20	09:00	29-Feb-20	17:00	Daily	MSETCL	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
8	47	400KV-KARAD-KOLHAPUR-MS-2	1-Feb-20	09:00	29-Feb-20	17:00	Daily	MSETCL	Permission for AR required in Non Auto mode
9	50	400KV-KALWA-PUNE-PG-1	1-Feb-20	07:00	1-Feb-20	18:00	Daily	MSETCL	Routine Maintenance & Diagnostic Testing
10	51	400KV-SSP-DHULE-MS-1	1-Feb-20	08:00	1-Feb-20	16:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
11	52	400KV-SSP-DHULE-MS-2	1-Feb-20	08:00	43862	16:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
12	56	MAIN BAY - 400KV KORADI-III-KORADI-II-LINE - 1 AND 400KV BUS-2 at KORADI - III -400 KV	1-Feb-20	9:00	1-Feb-20	18:00	D	MEGPTCL	Bay Maintenance Activities
13	59	400KV-RGPPL-NEW KOYNA-2	1-Feb-20	08:00	3-Feb-20	18:00	Daily	MSETCL	Cold washing, Routine maint. Work & Faulty string replacement Work
14	61	MAIN BAY - 400KV-WARDHA-AKOLA-2 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	1-Feb-20	9:00	6-Feb-20	18:00	C	POWERGRID_WR1	For Replacement of BHEL CB with GE CB at Akola-MS end.
15	66	BOISAR - 220KV - BUS 1	2-Feb-20	9:00	2-Feb-20	17:00	D	POWERGRID_WR2	FOR AMP
16	81	400KV-KHARGHAR-PUNE-PG-1	3-Feb-20	9:00	3-Feb-20	18:00	D	POWERGRID_WR1	FOR LINE SIDE EQUIPMENT AMP Works at TALEGAON END.
17	83	400KV-SSP-DHULE-MS-1 ALONG WITH 400KLV DHL-SSNNL Ckt-2 A/R Switch in Non Auto Mode.	3-Feb-20	07:00	3-Feb-20	19:00	Daily	MSETCL	Rusted/damaged Earth wire replacement work. disc insulator replacement by long rod.
18	84	400KV-SSP-DHULE-MS-2	3-Feb-20	08:00	3-Feb-20	16:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
19	90	TIE BAY - 765KV-KORADI-III-AKOLA-1 AND 765KV-TIRODA-KORADI-III-2 at KORADI-III - 765KV	3-Feb-20	9:00	3-Feb-20	13:00	D	MEGPTCL	Attending SF6 Gas leakages
20	105	400KV-AKOLA-AURANGABAD-1	3-Feb-20	9:00	3-Feb-20	18:00	D	POWERGRID_WR1	For Amp Work of Line Reactor & For Line AMP works 400KV-AKOLA-AURANGABAD-2 AR to be keep in non auto mode for safety measures.
21	112	MAIN BAY (401) OF TAPTITANDA CKT - 2 @ EKTUNI	3-Feb-20	10:00	3-Feb-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintenance
22	121	220KV-NASIK-NAVSARI-1	3-Feb-20	09:00	6-Feb-20	18:00	Daily	MSETCL	Replacement of old disc insulator by porcelain long rod, Dignostic testing, broken/flash over string replacement found during monkey patrolling, signature analysis, TLS fixing if issued.
23	124	400KV-SSP-DHULE-MS-1	3-Feb-20	7:00	3-Feb-20	18:00	Daily	GETCO	PMM work.
24	127	220KV-SOLAPUR-KUMBARI-2	4-Feb-20	9:00	4-Feb-20	18:00	D	POWERGRID_WR1	CT and Line terminal equipments AMP
25	128	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	4-Feb-20	10:00	4-Feb-20	18:00	D	POWERGRID_WR1	For AMP works & Dia should be kept open & AR of 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 may be kept in Non-auto mode for safety measures.
26	134	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 400KV - BUS 1 at KORADI-III - 400KV	4-Feb-20	09:00	4-Feb-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities
27	139	400KV-RGPPL-NEW KOYNA-1	4-Feb-20	9:00	9-Feb-20	18:00	C	RGPPL	Equipment & Relay testing work /402-52 B bkr O/H work
28	143	400KV-SSP-DHULE-MS-2 ALONGWITH 400KLV DHL-SSNNL Ckt-1 A/R Switch in Non Auto Mode.	4-Feb-20	07:00	4-Feb-20	19:00	Daily	MSETCL	Earth wire replacement work. Disc insulator replacement by long rod.
29	165	MAIN BAY (408) OF BABHALESHWAR CKT - 2 @ EKTUNI	4-Feb-20	10:00	4-Feb-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintenance

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason
30	169	400KV-SSP-DHULE-MS-1	4-Feb-20	08:00	5-Feb-20	18:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
31	173	400KV-RGPPL-NEW KOYNA-1	4-Feb-20	08:00	6-Feb-20	18:00	Daily	MSETCL	Cold washing, Routine maint. Work & Faulty string replacement Work
32	185	400KV-PARLI-PARLI NEW-1	5-Feb-20	9:00	5-Feb-20	18:00	D	POWERGRID_WR1	For line equipment AMP works at Parli(old) end & 400KV-PARLI-PARLI NEW-2 AR to be keep in non auto mode for safety measures.
33	194	KORADI - 400KV - BUS 2	5-Feb-20	08:00	5-Feb-20	18:00	Daily	MSETCL	For replacement of B phase rotory of 29 B isolator of 400kv koradi-Khaperkheda ckt 2
34	199	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	5-Feb-20	09:00	5-Feb-20	17:00	Daily	MSETCL	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .
35	206	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND FUTURE at KORADI-III - 400KV	5-Feb-20	09:00	5-Feb-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities
36	213	400KV-AKOLA-AURANGABAD-2	5-Feb-20	9:00	5-Feb-20	18:00	D	POWERGRID_WR1	For Amp Work of Line Reactor & For Line AMP works 400KV-WARDHA-AKOLA-1 AR to be keep in non auto mode for safety measures.
37	220	400KV-KARAD-SOLAPUR-1	5-Feb-20	10:00	5-Feb-20	17:00	Daily	MSETCL	Quarterly maintenance work
38	221	Main Bay - 400KV-TARAPUR 3&4-PADGHE-1 AND PADGHE - 400KV - Bus 1 at Padghe_MS	5-Feb-20	10:00	5-Feb-20	17:00	D	POWERGRID_WR1	AMP of Tarapur Padghe 1 Line CVT at MSETCL Padghe SS.
39	222	400KV-SOLAPUR-M-SOLAPUR-1	5-Feb-20	10:00	5-Feb-20	18:00	Daily	MSETCL	Relay Retrofitting work of Main II Distance Protection relay.
40	223	MAIN BAY (411) OF BABHALESHWAR CKT - 1 @ EKTUNI	5-Feb-20	10:00	5-Feb-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintainence
41	227	220KV-SOLAPUR-KUMBARI-1	5-Feb-20	11:00	5-Feb-20	16:00	Daily	MSETCL	Quarterly Maintenance
42	230	400KV-SSP-DHULE-MS-2	5-Feb-20	08:00	6-Feb-20	16:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
43	242	TALEGAON - 220KV - BUS 2	6-Feb-20	9:00	6-Feb-20	18:00	D	POWERGRID_WR1	AMP Work
44	250	400KV-SSP-DHULE-MS-1 ALONGWITH 400KLV DHL-SSNNL Ckt- 2 A/R Switch in Non Auto Mode.	6-Feb-20	07:00	6-Feb-20	19:00	Daily	MSETCL	Earth wire replacement work. Disc insulator replacement by long rod.
45	260	TIE BAY (421) OF WARDHA(PG) CKT & FUTURE CKT - 2 @ WARORA	6-Feb-20	09:00	6-Feb-20	17:00	Daily	MSETCL	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolator maintenance work .
46	268	MAIN BAY - 220KV-WARDHA-PUSAD-1 AND WARDHA - 220KV - BUS 1 at Wardha - 220KV	6-Feb-20	9:00	6-Feb-20	18:00	D	POWERGRID_WR1	For Amp Work
47	279	TIE BAY (402) OF TAPTITANDA CKT - 2 @ EKTUNI	6-Feb-20	10:00	6-Feb-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintainence
48	280	220KV-WARDHA-BHUGAON-1	6-Feb-20	10:00	6-Feb-20	18:00	Daily	MSETCL	Routine maintenance work
49	305	400KV-SSP-DHULE-MS-2 ALONGWITH 400KLV DHL-SSNNL Ckt- 1 A/R Switch in Non Auto Mode.	7-Feb-20	07:00	7-Feb-20	19:00	Daily	MSETCL	Earth wire replacement work. Disc insulator replacement by long rod.
50	310	400KV-KALWA-KHARGHAR-1	7-Feb-20	08:30	7-Feb-20	18:00	Daily	MSETCL	Routine Maintenance & Diagnostic Testing
51	315	MAIN BAY (422) OF FUTURE CKT - 2 @ WARORA	7-Feb-20	09:00	7-Feb-20	17:00	Daily	MSETCL	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .
52	316	220KV-TARAPUR 1&2-BOISAR-M-1	7-Feb-20	09:00	7-Feb-20	17:00	Daily	MSETCL	POST MONSOON MAINTENANCE WORK
53	321	MAIN BAY - 400KV-KORADI-II-KORADI-III-2 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	7-Feb-20	09:00	7-Feb-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities
54	348	400KV-SSP-DHULE-MS-1	7-Feb-20	08:00	8-Feb-20	16:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
55	350	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	7-Feb-20	9:00	12-Feb-20	18:00	C	POWERGRID_WR1	For Replacement of BHEL CB with GE CB at Akola-MS end.
56	352	Pole-1 Non base AC filter Z4 (80 MVAR) @Chandrapur HVDC	8-Feb-20	09:00	8-Feb-20	17:00	Daily	MSETCL	For demonstration of DCRM kit along with ABB Transducer
57	353	HVDC 500KV CHANDRAPUR HVDC POLE 2 AND HVDC 500KV CHANDRAPUR HVDC POLE 1	8-Feb-20	06:00	9-Feb-20	18:00	Continuous	MSETCL	To rectify bent bracing of Loc. no. 285 of 500KV Chandrapur-Padghe HVDC Line
58	361	400KV-SSP-DHULE-MS-2	8-Feb-20	08:00	8-Feb-20	16:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
59	370	TIE BAY - 765KV-KORADI-III-AKOLA-1 AND 765KV-AKOLA-EKTUNI-1 at AKOLA - 765KV	8-Feb-20	09:00	8-Feb-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities
60	381	220KV-WARDHA-BHUGAON-1	8-Feb-20	10:00	8-Feb-20	18:00	Daily	MSETCL	Routine maintenance work
61	385	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	8-Feb-20	09:00	8-Feb-20	17:00	Daily	MSETCL	For measurement of CB Timing, DCRM and CRM work.
62	397	400KV-KALWA-PADGHE-1	10-Feb-20	09:00	15-Feb-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason
63	407	AURANGABAD-M (WALUJ) - 400KV - BUS 2	10-Feb-20	09:00	10-Feb-20	17:00	Daily	MSETCL	Routine maintenance of thaptitanda Bay @ Waluj End
64	408	400KV-RGPPL-NAGOTHANE-1	10-Feb-20	08:00	12-Feb-20	18:00	Daily	MSETCL	Cold washing, Routine maint. Work & Faulty string replacement Work
65	412	400KV-SSP-DHULE-MS-1 ALONGWITH 400KLV DHL-SSNNL Ckt-2 A/R Switch in Non Auto Mode.	10-Feb-20	07:00	10-Feb-20	19:00	Daily	MSETCL	Earth wire replacement work. Disc insulator replacement by long rod.
66	413	400KV-SSP-DHULE-MS-2	10-Feb-20	08:00	10-Feb-20	16:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
67	414	400KV-RGPPL-NAGOTHANE-1	10-Feb-20	08:00	10-Feb-20	17:00	Daily	MSETCL	Emergency tree cutting work
68	425	TIE BAY - 400KV-KORADI-II-KORADI-III-1 AND FUTURE at KORADI-III - 400KV	10-Feb-20	09:00	10-Feb-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities
69	438	ALKUD - 400KV - BUS 2	10-Feb-20	10:00	10-Feb-20	17:00	Daily	MSETCL	Quarterly Maint. Work
70	439	TIE BAY (405) OF TAPTITANDA CKT - 1 @ EKTUNI	10-Feb-20	10:00	10-Feb-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintenance
71	440	TIE BAY - 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2 AND KOLHAPUR GIS - 400KV B/R 1 at Kolhapur GIS - 400KV	10-Feb-20	10:00	10-Feb-20	18:00	D	POWERGRID_WR1	For AMP works.
72	450	220KV-NASIK-NAVSARI-2	10-Feb-20	09:00	13-Feb-20	18:00	Daily	MSETCL	For replacement of old disk insulator by porcelain long rod, Dignostic testing,broken/flash over string replacement found during monkey patrolling, signature analysis, TLS fixing if issued.
73	462	CHANDRAPUR - 400KV - BUS 1	11-Feb-20	05:00	13-Feb-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in HVDC- II and 400KV STN T/F-5 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.
74	463	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	11-Feb-20	05:00	13-Feb-20	18:00	Continuous	MSETCL	1) For replacement of old damaged quadraple bus conductor of Main Bus-I in HVDC- II and 400KV STN T/F-5 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.
75	464	400KV/11.5KV CHANDRAPUR-GCR-ST-5 ON TBC-II bay	11-Feb-20	05:00	13-Feb-20	18:00	Continuous	MSETCL	Permission for shifting of 400KV STN T/F-5 bay on TBC-II bay
76	476	400KV-SSP-DHULE-MS-2	11-Feb-20	7:00	11-Feb-20	18:00	Daily	GETCO	PMM work.
77	477	400KV-SSP-DHULE-MS-2 ALONGWITH 400KLV DHL-SSNNL Ckt-1 A/R Switch in Non Auto Mode.	11-Feb-20	07:00	11-Feb-20	19:00	Daily	MSETCL	Earth wire replacement work. Disc insulator replacement by long rod.
78	490	220KV-BOISAR-NALASOPARA-1	11-Feb-20	9:00	11-Feb-20	17:00	D	POWERGRID_WR2	Line outage is required for Main-1 Relay replacement work
79	496	400KV-SOLAPUR-KOLHAPUR L/R @Solapur-400KV	11-Feb-20	9:00	11-Feb-20	18:00	D	POWERGRID_WR1	Reactor AMP and PRD gasket replacement works.
80	507	400KV-KOLHAPUR-MS-ALKUD-1	11-Feb-20	10:00	11-Feb-20	17:00	Daily	MSETCL	Quarterly Maint. Work
81	509	TIE BAY (409) OF BABHALESHWAR CKT - 2 @ EKTUNI	11-Feb-20	10:00	11-Feb-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintenance
82	513	220KV-WARDHA-WARDHA-M-1	11-Feb-20	08:00	12-Feb-20	18:00	Daily	MSETCL	Shifting and Charging of line through ERS from Loc No 15-18 due to raising the height of tower due to NHAI from Loc 16 to 17 and railway crossing from Loc No 17 to 18.
83	514	400KV-SSP-DHULE-MS-1	11-Feb-20	08:00	13-Feb-20	16:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
84	534	400kv SATPURA-KORADI	12-Feb-20	9:00	12-Feb-20	18:00	D	POWERGRID_WR2	For AMP works of CB and terminal equipments at MPPGCL Satpura end by Itarsi and line AMP on opportunity. Dia to be kept open at both ends.
85	538	220KV-PARLI-OSMANABAD-M-1	12-Feb-20	08:00	12-Feb-20	16:00	Daily	MSETCL	LINE maintenance
86	553	220KV-Pandhurna-MP-Kamleshwar	12-Feb-20	9:00	12-Feb-20	18:00	D	MP_SLDC	For bay equipment maintenance and testing work
87	566	TIE BAY (412) OF BABHALESHWAR CKT - 1 @ EKTUNI	12-Feb-20	10:00	12-Feb-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintenance
88	570	400KV-SSP-DHULE-MS-2	12-Feb-20	08:00	13-Feb-20	16:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
89	576	400 KV- Tie Bay - ST-3 & ST-5 at Tiroda SS - 400 KV	13-Feb-20	9:00	13-Feb-20	18:00	D	APML	Bay Maintenance Activities
90	584	220KV-TALEGAON-PUNE-PG-1	13-Feb-20	10:00	13-Feb-20	17:00	Daily	MSETCL	Half yearly maintenance, Diagnostic Testing
91	588	400KV-RGPPL-NAGOTHANE-2	13-Feb-20	08:00	15-Feb-20	18:00	Daily	MSETCL	Cold washing, Routine maint. Work & Faulty string replacement Work
92	590	400KV-RGPPL-NAGOTHANE-2	13-Feb-20	08:00	13-Feb-20	17:00	Daily	MSETCL	Emergency tree cutting work
93	608	400KV-SSP-DHULE-MS-1 ALONGWITH 400KLV DHL-SSNNL Ckt-2 A/R Switch in Non Auto Mode.	13-Feb-20	07:00	13-Feb-20	18:00	Daily	MSETCL	Earth wire replacement work. Disc insulator replacement by long rod.

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason
94	609	220KV-WARDHA-PUSAD-1	13-Feb-20	08:00	13-Feb-20	17:00	Daily	MSETCL	Routine Maintenance Work
95	618	400KV-PARLI-M-SOLAPUR-M-1	13-Feb-20	09:00	13-Feb-20	15:00	Daily	MSETCL	C & Tan Delta measurmnt of Bushing & winding of Reactor. Filtration of 400kv, 50 MVAR Line reactor will be carried out from 13.02.2019 to 14.02.2019. Line will be charged without reactor
96	626	220KV-BOISAR-BOISAR-M-1	13-Feb-20	9:00	13-Feb-20	17:00	D	POWERGRID_WR2	Line outage is required for Main-1 Relay replacement work
97	649	400KV-KALWA-PUNE-PG-1 ON TBC @ KALWA	13-Feb-20	09:00	16-Feb-20	18:00	Continuous	MSETCL	CB pole overhauling work
98	655	400KV-WARDHA-WARORA-1	14-Feb-20	09:00	14-Feb-20	17:00	Daily	MSETCL	Routine maintenance and LINE CVT Tan delta Testing works and isolater maintenance work . Routine Maintenance & Dignostic testing work Nut Bolt Tightning work
99	673	400KV-SSP-DHULE-MS-2 ALONGWITH 400KLV DHL-SSNNL Ckt-1 A/R Switch in Non Auto Mode.	14-Feb-20	07:00	14-Feb-20	19:00	Daily	MSETCL	Earth wire replacement work. Disc insulator replacement by long rod.
100	678	220KV-BOISAR-NALASOPARA-1	14-Feb-20	09:00	14-Feb-20	17:00	Daily	MSETCL	POST MONSOON MAINTENANCE WORK
101	685	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	14-Feb-20	09:00	14-Feb-20	18:00	Daily	MEGPTCL	Bay Maintenance Activities
102	707	AKOLA - 400KV - BUS 2	15-Feb-20	10:00	15-Feb-20	18:00	Daily	MSETCL	Routine Maintenance & testing work
103	713	400KV-WARDHA-KORADI-II-1	15-Feb-20	09:00	15-Feb-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work
104	726	400KV-SSP-DHULE-MS-1	15-Feb-20	08:00	15-Feb-20	16:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
105	727	400KV-SSP-DHULE-MS-2	15-Feb-20	08:00	15-Feb-20	16:00	Daily	MSETCL	PID testing of 400KV DHL-SSNNL line
106	731	400KV-PARLI-M-SOLAPUR-M-1	15-Feb-20	09:00	15-Feb-20	13:00	Daily	MSETCL	400kv, 50 MVAR Line Reactor will be taken into service after filtration
107	744	400KV-RGPPL-NEW KOYNA-2	16-Feb-20	9:00	21-Feb-20	18:00	C	RGPPL	Equipment & Relay testing work .
108	749	400KV-RGPPL-NAGOTHANE-1	16-Feb-20	10:00	29-Feb-20	15:00	Daily	MSETCL	PID testing of insulators
109	750	KALWA - 400KV - BUS 2	16-Feb-20	09:00	16-Feb-20	18:00	Daily	MSETCL	Bus maint. and CVT Maint work
110	751	400KV-PARLI-M-LONIKHAND-II-1	16-Feb-20	09:00	16-Feb-20	18:00	Daily	MSETCL	Filtration of 400kv, 50 MVAR Line reactor will be carried out from 16.02.2019 to 17.02.2019. Line will be charged without reactor at Girwali end on date 10.02.2019.
111	755	400KV-PARLI-M-LONIKHAND-II-1	16-Feb-20	09:00	18-Feb-20	13:00	Daily	MSETCL	400kv, 50 MVAR Line Reactor will be taken into service after filtration
112	768	400KV-BABLESHWAR-PADGHE-2	17-Feb-20	08:00	22-Feb-20	18:00	Daily	MSETCL	For Carrying PID Work
113	769	400KV-KHARGHAR-PUNE-PG-1	17-Feb-20	09:00	22-Feb-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
114	770	400KV-KALWA-PUNE-PG-1	17-Feb-20	09:00	29-Feb-20	17:00	Daily	MSETCL	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
115	771	LONIKHAND-II - 400KV - BUS 1	17-Feb-20	10:00	17-Feb-20	18:00	Daily	MSETCL	Half Yearly maintenance and Diagnostic testing
116	772	220KV-BOISAR-BOISAR-M-1	17-Feb-20	09:00	17-Feb-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing works.
117	777	BHUSAWAL - 400KV - BUS 1	17-Feb-20	06:00	17-Feb-20	18:00	Daily	MSETCL	CVT tan delta and Isolator maintenance work
118	807	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	17-Feb-20	10:00	17-Feb-20	17:00	Daily	MSETCL	Routine Maintenance & testing work
119	825	LONIKHAND-II - 400KV - BUS 2	18-Feb-20	10:00	18-Feb-20	18:00	Daily	MSETCL	Half yearly maintenance and Diagnostic testing
120	831	400KV-SSP-DHULE-MS-2 ALONGWITH 400KLV DHL-SSNNL Ckt-1A/R Switch in Non Auto Mode.	18-Feb-20	07:00	18-Feb-20	19:00	Daily	MSETCL	Earth wire replacement work. Disc insulator replacement by long rod.
121	843	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	18-Feb-20	09:00	18-Feb-20	18:00	Daily	MSETCL	Annual relay testing and maintenance
122	852	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-2 AND CHANDRAPUR - 400KV - BUS 1 at CHANDRAPUR - 400KV	18-Feb-20	9:00	18-Feb-20	18:00	D	POWERGRID_WR1	For AMP works.
123	861	220KV-WARDHA-PUSAD-1	18-Feb-20	10:00	18-Feb-20	18:00	Daily	MSETCL	Routine maintainace work

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason
124	875	AURANGABAD-M (WALUJ) - 400KV - BUS 1	19-Feb-20	09:00	19-Feb-20	17:00	Daily	MSETCL	Babhaleshwar Bay @ Waluj End (Main Bus 1)
125	880	400KV-WARDHA-WARORA-2	19-Feb-20	9:00	19-Feb-20	18:00	D	POWERGRID_WR1	For line AMP works & 400KV-WARDHA-WARORA-1 AR to be keep in non auto mode for safety measures.
126	886	220KV-PANDURNA-KALMESHWAR-1	19-Feb-20	08:00	19-Feb-20	18:00	Daily	MSETCL	Routine Maintenance & Diagnostic testing work
127	895	MAIN BAY - 765KV/400KV TIRODA-ICT-1 AND TIRODA - 400KV - BUS 2 at TIRODA - 400KV	19-Feb-20	09:00	19-Feb-20	18:00	Daily	APML	Bay Maintenance Activities
128	911	220KV-SOLAPUR-JEUR-1	19-Feb-20	10:00	19-Feb-20	18:00	Daily	MSETCL	Quarterly Maintenance of Bus at Jeur
129	914	220KV-SOLAPUR-KUMBARI-2	19-Feb-20	11:00	19-Feb-20	16:00	Daily	MSETCL	Bus outage alongwith line for Quarterly Maintenance
130	921	MAIN BAY - 400KV-WARDHA-AKOLA-1 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	19-Feb-20	9:00	24-Feb-20	18:00	C	POWERGRID_WR1	For Replacement of BHEL CB with GE CB at Akola-MS end.
131	925	220KV-TALEGAON-PUNE-PG-2	20-Feb-20	10:00	20-Feb-20	17:00	Daily	MSETCL	Half yearly maintenance, Diagnostic Testing
132	932	400KV-SSP-DHULE-MS-1 ALONGWITH 400KLV DHL-SSNNL Ckt-2 A/R Switch in Non Auto Mode.	20-Feb-20	07:00	20-Feb-20	19:00	Daily	MSETCL	Earth wire replacement work. Disc insulator replacement by long rod.
133	954	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	20-Feb-20	10:00	20-Feb-20	17:00	Daily	MSETCL	Routine Maintenance & testing work
134	956	220KV-WARDHA-PUSAD-1	20-Feb-20	10:00	20-Feb-20	18:00	Daily	MSETCL	Routine maintainace work
135	967	400KV-KALWA-PADGHE-2 ON TBC @ KALWA	20-Feb-20	09:00	23-Feb-20	18:00	Continuous	MSETCL	CB pole overhauling work
136	989	220KV-TARAPUR 1&2-BORIVALI-1	21-Feb-20	08:00	21-Feb-20	17:00	Daily	MSETCL	Routine Maintenance & work
137	1003	220KV-WARDHA-WARDHA-M-1	21-Feb-20	08:00	22-Feb-20	18:00	Daily	MSETCL	Restoration of line from ERS to new erected tower from Loc No 15-18 due to raising the height of tower due to NHAI from Loc 16 to 17 and railway crossing from Loc No 17 to 18.
138	1006	PADGHE - 400KV - BUS 1	21-Feb-20	00:00	23-Feb-20	17:00	Continuous	MSETCL	Bus Conductor Replacement Work
139	1013	400KV-RGPPL-NAGOTHANE-1	22-Feb-20	9:00	27-Feb-20	18:00	C	RGPPL	Equipment & Relay testing work .
140	1017	400KV-SSP-DHULE-MS-2 ALONGWITH 400KLV DHL-SSNNL Ckt-1 A/R Switch in Non Auto Mode.	22-Feb-20	07:00	22-Feb-20	19:00	Daily	MSETCL	Earth wire replacement work. Disc insulator replacement by long rod.
141	1054	220KV-BOISAR-BOISAR-M-3	24-Feb-20	9:00	24-Feb-20	17:00	D	POWERGRID_WR2	Line outage is required for Main-1 Relay replacement work
142	1055	220KV-BOISAR-BOISAR-M-3	24-Feb-20	09:00	24-Feb-20	17:00	Daily	MSETCL	Routine Maintenance & Dignostic testing works.
143	1058	LONIKAND 1 - CHAKAN	24-Feb-20	09:00	24-Feb-20	17:00	Daily	MSETCL	Half yearly testing and maintenance activities
144	1061	400KV-AURANGABAD-BOISAR-1	24-Feb-20	8:00	24-Feb-20	18:00	D	POWERGRID_WR2	For Insulator Cleaning works. A/R OFF of ckt-2, dia to be kept open at both ends.
145	1095	400KV-KARAD-JAIGAD-1	24-Feb-20	09:00	27-Feb-20	18:00	Daily	JPTL	Hotline insulator washing
146	1096	400KV-KARAD-JAIGAD-2	24-Feb-20	09:00	27-Feb-20	18:00	Daily	JPTL	Hotline insulator washing
147	1099	400KV-DHULE-DHULE-MS-2	24-Feb-20	08:00	29-Feb-20	16:00	Daily	MSETCL	PID Testing work of Dhule-Babheshwar line
148	1100	DHULE-MS - 400KV B/R 1	24-Feb-20	9:00	29-Feb-20	18:00	C	POWERGRID_WR1	for internal inspection & repair due to Acetylene violation
149	1106	PUNE-PG - 400KV - BUS 2	25-Feb-20	9:00	25-Feb-20	18:00	D	POWERGRID_WR1	Replacement of Clamp & connectors
150	1125	400KV-DHULE-KHANDWA-1 L/R@ DHULE - 400KV	25-Feb-20	9:00	25-Feb-20	18:00	D	POWERGRID_WR1	for AMP works Line outage required for isolation of non swithable line reactor take out/in for 20 min for
151	1149	400KV-BABLESHWAR-PADGHE-PG-1	26-Feb-20	09:00	26-Feb-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing
152	1150	400KV-PARLI-M-LONIKHAND-II-2	26-Feb-20	09:00	26-Feb-20	18:00	Daily	MSETCL	C & Tan Delta measurmnt of Bushing & winding of Reactor
153	1151	TIE BAY - 400KV-PARLI-M-LONIKHAND-II-2 AND FUTURE at LONIKHAND-II - 400KV	26-Feb-20	10:00	26-Feb-20	18:00	Daily	MSETCL	Half yearly maintenance and Diagnostic testing
154	1152	400KV-PARLI-M-LONIKHAND-II-2	26-Feb-20	10:00	26-Feb-20	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing
155	1159	220KV-PARLI-PARLI-M-1	26-Feb-20	08:00	26-Feb-20	16:00	Daily	MSETCL	Line Maintenance

Sr.No.	OCCM Sr. No	Line / Element	From	time	to	Time	D	Name of Requesting Agency	reason
156	1160	TIE BAY (426) OF WARORA CKT - 2 @ CHANDRAPUR 2	26-Feb-20	08:00	26-Feb-20	17:00	Daily	MSETCL	Diagnostic testing and allied bay maintenance work
157	1166	220KV Navsari-Nashik line no.1	26-Feb-20	9:00	26-Feb-20	18:00	Daily	GETCO	Bay Maintenance
158	1168	400KV-DHULE-KHANDWA-2 L/R@ DHULE - 400KV	26-Feb-20	9:00	26-Feb-20	18:00	D	POWERGRID_WR1	for AMP works
159	1170	400KV-BHILAI-KORADI-1	26-Feb-20	9:00	26-Feb-20	18:00	D	POWERGRID_WR1	Line outage required for isolation of non swithable line reactor take out/in for 20 min for For Amp Work of Line Reactor at Koradi end & line AMP works.
160	1178	400KV/220KV SOLAPUR-M-ICT-1	26-Feb-20	10:00	26-Feb-20	18:00	Daily	MSETCL	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUSI, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.
161	1179	400/220/33KV ICT - 167 MVA SPARE ICT @LAMBOTI	26-Feb-20	10:00	26-Feb-20	18:00	Daily	MSETCL	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUSI, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.
162	1180	SOLAPUR-M - 400KV - BUS 1	26-Feb-20	10:00	26-Feb-20	18:00	Daily	MSETCL	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bus I, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.
163	1181	400KV-PARLI-M-SOLAPUR-M-1	26-Feb-20	10:00	26-Feb-20	18:00	Daily	MSETCL	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUSI, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.
164	1185	400KV-CHAKAN-PUNE-PG-1	27-Feb-20	08:00	27-Feb-20	18:00	Daily	MSETCL	Line maintenance & routine Diagnostic testing work.
165	1186	NEW KOYNA - 400KV - BUS 1	27-Feb-20	08:00	29-Feb-20	18:00	Continuous	MSETCL	Conductor replacement work
166	1192	220KV-WARDHA-PUSAD-1	27-Feb-20	07:00	27-Feb-20	17:00	Daily	MSETCL	Routine maintenance Work
167	1203	400KV-KOLHAPUR-MS-ALKUD-1	27-Feb-20	9:00	27-Feb-20	17:00	Daily	WTPL	Annual shutdown
168	1204	400KV-KOLHAPUR-MS-SOLAPUR-2	27-Feb-20	9:00	27-Feb-20	17:00	Daily	WTPL	AR Mode to be kept off for attending annual shutdown work in circuit-1 of 400 kV Alkud-Kolhapur-1
169	1208	220KV Navsari-Nashik line no.2	27-Feb-20	9:00	27-Feb-20	18:00	Daily	GETCO	Bay Maintenance
170	1224	400KV-KHARGHAR-PUNE-PG-1	28-Feb-20	07:00	28-Feb-20	18:00	Daily	MSETCL	Routine Maintenance & Diagnostic Testing
171	1225	220KV-TALEGAON-PUNE-PG-1 at PUNE-PG - 400KV	28-Feb-20	9:00	28-Feb-20	18:00	D	POWERGRID_WR1	For line equipments AMP work & Relay Testing,
172	1227	400KV-RGPPL-NAGOTHANE-2	28-Feb-20	9:00	29-Feb-20	18:00	C	RGPPL	Equipment & Relay testing work/ 407-52 A bkr CT (R phase) replacement
173	1228	WARDHA - 765KV - BUS 2	28-Feb-20	9:00	28-Feb-20	18:00	D	POWERGRID_WR1	For AMP work, Phase CVT Errection.
174	1229	400KV-PARLI-M-PARLI-2	28-Feb-20	09:00	28-Feb-20	18:00	Daily	MSETCL	Distance relay testing work
175	1257	Main bay (410) of 765/400KV 1500 MVA ICT-1 @ Ektuni	28-Feb-20	10:00	28-Feb-20	18:00	Daily	MSETCL	Diagnostic Testing & Routine Maintainece
176	1259	400KV-JAIGAD-NEW KOYNA-2	28-Feb-20	09:00	29-Feb-20	18:00	Daily	JPTL	Hotline insulator washing
177	1260	400KV-JAIGAD-NEW KOYNA-1	28-Feb-20	09:00	29-Feb-20	18:00	Daily	JPTL	Hotline insulator washing
178	1262	400KV-EKTUNI-BABLESHWAR-2	29-Feb-20	09:00	29-Feb-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing
179	1263	400KV-BABLESHWAR-PADGHE-2	29-Feb-20	09:00	29-Feb-20	17:00	Daily	MSETCL	Quarterly Maintenance work & Relay Testing
180	1264	TALEGAON - 220KV - BUS 1	29-Feb-20	9:00	29-Feb-20	18:00	D	POWERGRID_WR1	Replacement of Clamp & connectors
181	1267	220KV-TALEGAON-PUNE-PG-2 at PUNE-PG - 400KV	29-Feb-20	9:00	29-Feb-20	18:00	D	POWERGRID_WR1	For line equipments AMP work & Relay Testing,
182	1268	400KV-PARLI-M-LONIKHAND-II-1	29-Feb-20	10:00	29-Feb-20	18:00	Daily	MSETCL	SSN TO DSN conversion / Line Maintenance & Routine Dignostic testing work
183	1281	BOISAR-M - 220KV - BUS 1	29-Feb-20	06:00	1-Mar-20	18:00	Continuous	MSETCL	1) A-Bus Isolator maintenance work. 2) Diagnostic testing of Buscoupler CT & Breaker and A-Bus connected PT.

State Element Outage list for the month of February 2020

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	01-Feb-20	08:00	01-Feb-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220kv 315MVA ICT- II & 501 MVA ICT -III& 501 MVA ICT-IV will be in service
2	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	01-Feb-20	08:00	15-Feb-20	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Nil
3	400 KV	CHANDRAPUR - KHAPERKHEDA	01-Feb-20	08:00	29-Feb-20	17:00	Daily	For PID work	MSETCL	MSETCL	For PID work, shifting of Auto reclose switch to non auto mode.
4	400 KV	PADGHE - NAGOTHANE 1	03-Feb-20	08:00	03-Feb-20	17:00	Daily	(1) Faulty string and Jumper ,cold wasing replacement work (2) Diagnostic Testing Work	MSETCL	MSETCL	NIL
5	400 KV	125MVar BUS REACTOR @ WARORA	03-Feb-20	09:00	03-Feb-20	17:00	Daily	Diagnostic testing activity and maintenance work	MSETCL	MSETCL	Reactor is in OFF condition during outage.
6	400 KV	400KV AKOLA-BHUSAWAL (Bhusawal end)	03-Feb-20	11:00	09-Feb-20	16:00	Daily	PID testing of insulator strings by PID Uint Akola of O&M Circle Akola.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola- Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are
7	400 KV	125 MVar BUS REACTOR @ ALKUD	04-Feb-20	10:00	04-Feb-20	17:00	Daily	Quarterly Maint. Work	MSETCL	MSETCL	NA
8	400 KV	PADGHE - NAGOTHANE 2	04-Feb-20	08:00	04-Feb-20	17:00	Daily	Faulty string and Jumper ,cold wasing replacement work	MSETCL	MSETCL	NIL
9	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	04-Feb-20	08:00	04-Feb-20	16:00	Daily	PID Work	MSETCL	MSETCL	PID Work
10	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	05-Feb-20	08:00	05-Feb-20	17:00	Daily	Diagnostic Testing and allign bay maintenance work	MSETCL	MSETCL	Diagnostic Testing and allign bay maintenance work
11	400 KV	400/220KV 105 MVA SPARE ICT @ KHADKA	05-Feb-20	08:00	05-Feb-20	18:00	Daily	CT tan delta and CB CRM &Timing and routine bay maintenance	MSETCL	MSETCL	NIL
12	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	06-Feb-20	09:00	06-Feb-20	18:00	Daily	Reactor backup relay testing work, Filtration of 400kv, 50 MVar Line reactor	MSETCL	MSETCL	Reactor backup relay testing work, Filtration of 400kv, 50 MVar Line reactor
13	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	06-Feb-20	09:00	06-Feb-20	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	A/R is not applicable for ICT bay. Hence, Out of service option is selected.
14	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	06-Feb-20	08:30	06-Feb-20	17:00	Daily	1.Main Bus CT Tan delta testing. 2.LV CB Timing measurement CRM & LV CT Tan delta	MSETCL	MSETCL	Load will be managed on 501MVA ICT-II during outage period
15	400 KV	MAIN BAY- 414 OF YELWAN CKT-1 @ AKOLA	06-Feb-20	10:00	06-Feb-20	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
16	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	06-Feb-20	08:00	06-Feb-20	16:00	Daily	PID Works	MSETCL	MSETCL	PID Works
17	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	07-Feb-20	08:30	07-Feb-20	17:00	Daily	1.Main Bus CT Tan delta testing. 2.LV CB Timing measurnment CRM & LV CT Tan delta	MSETCL	MSETCL	Load will be managed on 501 MVA ICT-I during outage
18	400 KV	KORADI-NANDGAONPETH (RPL)	07-Feb-20	09:00	07-Feb-20	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
19	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	08-Feb-20	09:00	08-Feb-20	13:00	Daily	400kv, 50 MVar Line Reactor will be taken into service after filtration	MSETCL	MSETCL	400kv, 50 MVar Line Reactor will be taken into service after filtration
20	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	08-Feb-20	08:00	08-Feb-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220kv 315MVA ICT- I & 501 MVA ICT -III& 501 MVA ICT-IV will be in service
21	400 KV	KARAD - TALANDGE CKT 1	10-Feb-20	08:00	12-Feb-20	18:00	Daily	Replacement of Disc Insulator String by Procelain Insulator (LE Scheme)	MSETCL	MSETCL	Karad - Talandge 2 ckt will be in service
22	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	10-Feb-20	11:00	16-Feb-20	16:00	Daily	PID testing of insulator strings by PID Uint Akola of O&M Circle Akola.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Bhusawal & 400 kv Koradi-Nandgaonpeth are in service.
23	400 KV	80 MVar BUS REACTOR - 1 @ BABHALESHWAR	11-Feb-20	09:00	11-Feb-20	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	All 4 nos of ICT and 400kv Lines will be in service
24	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	11-Feb-20	08:00	11-Feb-20	16:00	Daily	PID Work	MSETCL	MSETCL	PID Work
25	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	11-Feb-20	09:00	11-Feb-20	17:00	Daily	For measurement of CT Tan delta and Capacitance	MSETCL	MSETCL	During, this outage 400KV CHD-2 CKT.1 will be in service. The outage on 400KV CHD-2 CKT.2 bay is
26	400 KV	JAIGAD-KARAD-I	11-Feb-20	10:00	11-Feb-20	17:00	Daily	Quarterly Maint Work	MSETCL	MSETCL	Load Managed on Jaigad ckt-II
27	400 KV	KARAD - TALANDGE CKT 2	12-Feb-20	09:00	12-Feb-20	18:00	Daily	Annual Maintenance , relay testing work	MSETCL	MSETCL	Load will be managed on 400kv Karad-Talandge ckt 1
28	400 KV	WARORA - IEPL	12-Feb-20	09:00	12-Feb-20	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
29	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	12-Feb-20	08:00	12-Feb-20	17:00	Daily	For Replacement of Disc insulators if found during PID Testing & line signature Test./ Routine Maintenance work	MSETCL	MSETCL	For Replacement of Disc insulators if found during PID Testing & line signature Test.
30	400 KV	PADGHE - NAGOTHANE 2	12-Feb-20	08:00	12-Feb-20	18:00	Daily	Diagnostic Testing Work	MSETCL	MSETCL	Bay Maintenance
31	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	12-Feb-20	10:00	12-Feb-20	18:00	Daily	Replacement of 220KV Isolators C & D of 400KV ICT II.	MSETCL	MSETCL	Load will Be managed on 400KV ICT I
32	400 KV	MAIN BAY - 404 CHD SWITCHING CKT2 @ CHANDRAPUR 2	12-Feb-20	08:00	12-Feb-20	17:00	Daily	Diagnostic testing and aligned bay maintenance work	MSETCL	MSETCL	Diagnostic testing and aligned bay maintenance work
33	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	12-Feb-20	09:00	12-Feb-20	18:00	Daily	DFRA testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
34	400 KV	DHULE- - BABLESHWAR - I	12-Feb-20	09:00	12-Feb-20	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400kv Dhule ckt II,400kv Bhusawal and 400kv Aurangabad lines will be in service
35	400 KV	KUMBHARGAON (NANDED) - CAHNDRAPUR 2 CKT - 2 @ NANDED	13-Feb-20	10:00	13-Feb-20	18:00	Daily	CT Tan-d, Relay Routine Testing & Equipments Maintenance works.	MSETCL	MSETCL	CT Tan-d, Relay Routine Testing & Equipments Maintenance works.

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.
36	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	13-Feb-20	08:00	13-Feb-20	17:00	Daily	For routine maintenance work	MSETCL	MSETCL	nIL
37	400 KV	TIE BAY - 411 OF PARLI (GIRWALI) CKT-1 @ NANDED	13-Feb-20	10:00	13-Feb-20	18:00	Daily	For conductor & Earthwire Hardware tightening work.	MSETCL	MSETCL	For conductor & Earthwire Hardware tightening work.
38	400 KV	TIE BAY (417) OF ST - 3 AND ST-5 @ TIRORA	13-Feb-20	09:00	13-Feb-20	18:00	Daily	Annual Maintenance Bay Equipments	APML	APML	Annual Maintenance Bay Equipments
39	400 KV	MAIN BAY (404) OF ICT - 2 @ JEJURI	13-Feb-20	09:00	13-Feb-20	17:00	Daily	Annual testing and maintenance of CB of main bay 404 of ICT 2	MSETCL	MSETCL	--
40	400 KV	KARAD - TALANDGE CKT 2	13-Feb-20	08:00	15-Feb-20	18:00	Daily	Replacement of Disc Insulator String by Porcelain Insulator (LE Scheme)	MSETCL	MSETCL	Karad - Talandge 1 ckt will be in service
41	400 KV	NEW KOYNA - STAGE IV CKT 1	13-Feb-20	08:00	13-Feb-20	18:00	Daily	Cold washing, Routine maint. Work & Faulty string replacement Work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 Ckt-II line
42	400 KV	MAIN BAY 417 OF YELWAN CKT - 2 @ AKOLA	13-Feb-20	10:00	13-Feb-20	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	NIL
43	400 KV	MAIN BAY - 410 OF PARLI (GIRWALI) CKT-1 @ NANDED	13-Feb-20	10:00	13-Feb-20	18:00	Daily	For conductor & Earthwire Hardware tightening work.	MSETCL	MSETCL	For conductor & Earthwire Hardware tightening work.
44	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	13-Feb-20	08:00	13-Feb-20	18:00	Daily	Maintenance and Diagnostic testing work	MSETCL	MSETCL	--
45	400 KV	THAPTI TANDA - WALUJ	13-Feb-20	08:00	13-Feb-20	18:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
46	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	14-Feb-20	08:00	14-Feb-20	17:00	Daily	For conductor & Earthwire Hardware tightening work	MSETCL	MSETCL	For conductor & Earthwire Hardware tightening work
47	400 KV	CHANDRAPUR-PARLI CKT-3	14-Feb-20	08:00	14-Feb-20	18:00	Daily	For routine maintenance work	MSETCL	MSETCL	For routine maintenance work
48	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	14-Feb-20	09:00	14-Feb-20	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
49	400 KV	NEW KOYNA - STAGE IV CKT 2	14-Feb-20	08:00	14-Feb-20	18:00	Daily	Cold washing, Routine maint. Work & Faulty string replacement Work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 Ckt-I line
50	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	14-Feb-20	08:30	14-Feb-20	18:00	Daily	R&M and Diagnostic Testing Work	MSETCL	MSETCL	315MVA ICT-1 and ICT-3 will be in service
51	400 KV	400220kv 167MVA SPARE ICT @ DEEPNAGAR	15-Feb-20	08:30	15-Feb-20	17:00	Daily	Bushing & Winding Tan Delta of spare ICT Bus CT Tan delta Testing.	MSETCL	MSETCL	nil
52	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	15-Feb-20	08:00	15-Feb-20	16:00	Daily	PID Works	MSETCL	MSETCL	PID Works
53	400 KV	CHANDRAPUR-PARLI CKT-3	17-Feb-20	09:00	17-Feb-20	17:00	Daily	Bay Maintenance work & Filtration of 400kv, 50 MVAR Line reactor	MSETCL	MSETCL	Bay Maintenance work & Filtration of 400kv, 50 MVAR Line reactor
54	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	17-Feb-20	09:00	17-Feb-20	18:00	Daily	C & Tan Delta measurement of Bushings & windings of all three Units & IV CTs testing work	MSETCL	MSETCL	C & Tan Delta measurement of Bushings & windings of all three Units & IV CTs testing work
55	400 KV	400KV AKOLA-BHUSAWAL (Bhusawal end)	17-Feb-20	08:00	20-Feb-20	18:00	Daily	Work of replacement of faulty strings having 03 & above no. of punctured discs detected in PID by agency by availing Quarterly maintenance work	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are
56	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	17-Feb-20	08:00	17-Feb-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	NIL
57	400 KV	DHULE - BABLESHWAR - I	17-Feb-20	08:00	29-Feb-20	16:00	Daily	PID Testing work of Dhule-Bableshtar line	MSETCL	MSETCL	Dhule-Bableshtar line - 2 A/R Should be kept in Non-Auto mode.
58	400 KV	CHANDRAPUR-PARLI CKT-3	17-Feb-20	08:00	28-Feb-20	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	Chandrapur II- Nanded Ckt-II and Chandrapur GCR-Parli Ckt- III are on DC tower so both lines require on
59	400 KV	CHANDRAPUR-PARLI CKT-3	18-Feb-20	09:00	18-Feb-20	13:00	Daily	400kv, 50 MVAR Line Reactor will be taken into service after filtration	MSETCL	MSETCL	400kv, 50 MVAR Line Reactor will be taken into service after filtration
60	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	18-Feb-20	08:00	18-Feb-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	NIL
61	400 KV	400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	18-Feb-20	09:00	18-Feb-20	17:00	Daily	For measurement of CB Timing and DCRM .	MSETCL	MSETCL	During this outage 400KV ICT-2 bay will be shift on 400kv TBC-1 bay, as the work of measurement of CB
62	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	18-Feb-20	08:00	18-Feb-20	16:00	Daily	PID Works	MSETCL	MSETCL	PID Works
63	400 KV	MAIN BAY (410) OF STATION TF 8A @ CHANDRAPUR SWG S/S	19-Feb-20	08:00	19-Feb-20	17:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
64	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	19-Feb-20	08:00	19-Feb-20	17:00	Daily	Quarterly maintenance work	MSETCL	MSETCL	NIL
65	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	19-Feb-20	10:00	19-Feb-20	18:00	Daily	Replacement of 220KV Isolators C & D of 400KV ICT I.	MSETCL	MSETCL	Load will be managed on 400KV ICT II.
66	400 KV	KORADI-NANDGAONPETH (RPL)	19-Feb-20	09:00	19-Feb-20	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Outage proposed by LMU S/Dn Koradi .
67	400 KV	CHANDRAPUR 2 - DHARIWAL CKT - 2	19-Feb-20	08:00	19-Feb-20	17:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work
68	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	20-Feb-20	10:00	20-Feb-20	18:00	Daily	For conductor & Earthwire Hardware tightening work.	MSETCL	MSETCL	For conductor & Earthwire Hardware tightening work.
69	400 KV	LONIKAND 1 -JEJURI	20-Feb-20	08:00	20-Feb-20	18:00	Daily	Line Maintenance & Routine Dignostic testing work / Annual testing and Maintenance work	MSETCL	MSETCL	----
70	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	20-Feb-20	08:00	20-Feb-20	16:00	Daily	PID Works	MSETCL	MSETCL	PID Works
71	400 KV	LONIKAND 1 - KOYNA STAGE-IV	21-Feb-20	08:00	21-Feb-20	18:00	Daily	Cold line washing of insulators & faulty string replcement work	MSETCL	MSETCL	Koyna Satge4-Jejuri ckt will be in service

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.
72	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	21-Feb-20	08:00	21-Feb-20	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	Load can be managed on 315MVA ICT I
73	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	21-Feb-20	09:00	21-Feb-20	17:00	Daily	ICT 3 bay Routine maintenance works	MSETCL	MSETCL	ICT 3 bay routine maintenance works to be carried out
74	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	22-Feb-20	08:00	22-Feb-20	18:00	Daily	Routine Maint. Work	MSETCL	MSETCL	Load can be managed on 315MVA ICT II
75	400 KV	400/220KV 105 MVA SPARE ICT @ KARAD	24-Feb-20	10:00	24-Feb-20	17:00	Daily	Quarterly Maint Work	MSETCL	MSETCL	Capacitance & Tan Delta measurement Work
76	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	24-Feb-20	08:00	29-Feb-20	18:00	Daily	Work of replacement of faulty strings having 03 & above no. of punctured discs detected in PID by agency by availing 33kV Side IPS tube and insulator coating, Attending oil leakage by agency	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Bhusawal & 400 kv Koradi-Nandgaonpeth are in service.
77	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	24-Feb-20	09:00	24-Feb-20	23:59	Daily	Attending oil leakage by agency	MSETCL	MSETCL	Monday is load staggering day Load will be managed by Tripping 220kv Tilawani-
78	400 KV	NEW KOYNA-KARAD -CKT 1	24-Feb-20	08:00	24-Feb-20	18:00	Daily	Cold washing of breaker	MSETCL	MSETCL	TBC shifting
79	400 KV	DEEPNAGAR - THAPTI TANDA	25-Feb-20	09:00	26-Feb-20	18:00	Daily	Line routine & quarterly maint. work	MSETCL	MSETCL	Nil
80	400 KV	NEW KOYNA -KARAD -CKT 2	25-Feb-20	08:00	25-Feb-20	18:00	Daily	Cold washing of breaker	MSETCL	MSETCL	TBC shifting
81	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	25-Feb-20	08:00	25-Feb-20	16:00	Daily	PID Works	MSETCL	MSETCL	PID Works
82	400 KV	CHANDRAPUR - KHAPERKHEDA	26-Feb-20	09:00	26-Feb-20	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	Outage proposed by LMU S/Dn Koradi
83	400 KV	JAIGAD-NEW KOYNA-I	26-Feb-20	08:00	26-Feb-20	18:00	Daily	Cold washing of breaker	MSETCL	MSETCL	TBC shifting
84	400 KV	JEJURI- KOYNA STAGE-IV	27-Feb-20	08:00	27-Feb-20	18:00	Daily	cold line washing of disc insulators	MSETCL	MSETCL	daily basis
85	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	27-Feb-20	08:00	27-Feb-20	18:00	Daily	Maintenance and Diagnostic testing work	MSETCL	MSETCL	A/R is not applicable for ICT bay, hence Out of service option is selected.
86	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	27-Feb-20	10:00	27-Feb-20	18:00	Daily	Annual testing & equipment maintenance works.	MSETCL	MSETCL	Annual testing & equipment maintenance works.
87	400 KV	400/220KV SPARE ICT @ JEJURI	27-Feb-20	09:00	27-Feb-20	17:00	Daily	Annual testing & maint.	MSETCL	MSETCL	---
88	400 KV	JAIGAD-NEW KOYNA-II	27-Feb-20	08:00	27-Feb-20	18:00	Daily	Cold washing of breaker	MSETCL	MSETCL	TBC shifting
89	400 KV	THAPTI TANDA - WALUJ	27-Feb-20	09:00	28-Feb-20	18:00	Daily	Line routine & quarterly maint. work	MSETCL	MSETCL	NIL
90	400 KV	DHULE- - BABLESHWAR - I	27-Feb-20	08:00	27-Feb-20	17:00	Daily	PID will be carried out from 17/02/2020 to 29/02/2020. if any strings found suspicious/ faulty, it will be replaced in	MSETCL	MSETCL	Dhule-Bableshtar line - 2 A/R should be kept in Non-Auto mode.
91	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	27-Feb-20	08:00	27-Feb-20	18:00	Daily	PID Works	MSETCL	MSETCL	PID Works
92	400 KV	NEW KOYNA -KARAD -CKT 2	28-Feb-20	08:00	28-Feb-20	18:00	Daily	Cold line washing of insulators	MSETCL	MSETCL	N.Koyna-Karad ckt 1 will be in service
93	400 KV	DHULE- - BABLESHWAR - II	28-Feb-20	08:00	28-Feb-20	17:00	Daily	PID will be carried out from 17/02/2020 to 29/02/2020. if CT tan delta and CB CRM &Timing and routine bay maintenance	MSETCL	MSETCL	Dhule-Bableshtar line - 2 A/R should be kept in Non-Auto mode.
94	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	29-Feb-20	08:00	29-Feb-20	18:00	Daily		MSETCL	MSETCL	nil