

Maharashtra State Load Despatch Centre

WRPC OCCM approved Monthly Outage list for the Month of February 2021

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D / C	Name of Requesting Agency	Reason	Remarks
1	2	220KV-BOISAR-BOISAR-M-1	1-Feb-21	09:00	5-Feb-21	16:00	D	MSETCL	PID of Line in A/R Off mode	PID of Line in A/R Off mode
2	4	400KV-KALWA-KHARGHAR-1	1-Feb-21	08:00	14-Feb-21	19:00	D	MSETCL	Live line installation of OPGW by MTCIL and PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	Work will be carried out on 400 KV Kalwa-Talegaon & 400 KV Kalwa-Kharghar (D/C) line (On both line)
3	5	LONIKHAND-II - 400KV - BUS 1	1-Feb-21	09:00	14-Feb-21	18:00	C	MSETCL	To carry out PID.	--
4	6	400KV-SOLAPUR-M-SOLAPUR-1	1-Feb-21	10:00	14-Feb-21	18:00	D	MSETCL	PID Testing Work	Bypass AR Switch. Without Load Interruption.
5	8	400KV-BABLESHWAR-PADGHE-1	1-Feb-21	08:00	15-Feb-21	18:00	D	MSETCL	For Carrying PID Work	-
6	9	400KV-CHAKAN-PUNE-PG-1	1-Feb-21	09:00	15-Feb-21	18:00	D	MSETCL	To carryout PID test	PID of Line in A/R Off mode
7	13	400KV-SSP-DHULE-MS-1	1-Feb-21	09:00	27-Feb-21	17:00	D	MSETCL	Online PID testing work	400kv SSNNL Ckt-1, A/R switch will be kept on non auto mode
8	24	220KV-WARDHA-PUSAD-1	1-Feb-21	07:00	28-Feb-21	17:00	D	MSETCL	PID Work	Outage is proposed on dt.18/02/2021 from 8:00 To 18:00 & 25/02/2021 from 7:00 to 18:00 by EHV LM
9	29	400KV-DHULE-MS-BABLESHWAR-1	1-Feb-21	08:00	28-Feb-21	17:00	D	MSETCL	Online PID testing Work	400kv Dhule-BBLR-1 A/R swirch kept on non auto mode
10	30	400KV-DHULE-MS-BABLESHWAR-2	1-Feb-21	08:00	28-Feb-21	17:00	D	MSETCL	Online PID testing work	400KV DHL-BBLR-2 A/R switch kept on non auto mode
11	31	400KV-CHANDRAPUR-II-NANDED-2	1-Feb-21	08:00	28-Feb-21	17:00	D	MSETCL	For PID Work,Shifting of auto reclose switch to non auto mode.	Chandrapur 2- Nanded Ckt-II & Chandrapur GCR-Parli Ckt- III These lines are on DC tower so both lines
12	32	400KV-CHANDRAPUR-GCR-PARLI-M-3	1-Feb-21	08:00	28-Feb-21	17:00	D	MSETCL	For PID Work,Shifting of auto reclose switch to non auto mode.	Chandrapur 2- Nanded Ckt-II & Chandrapur GCR-Parli Ckt- III These lines are on DC tower so both lines
13	43	400KV-KALWA-PUNE-PG-1	1-Feb-21	08:00	28-Feb-21	19:00	D	MSETCL	Live line installation of OPGW by MTCIL and PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	Live line installation of OPGW by MTCIL and PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.
14	44	400KV-KARAD-KOLHAPUR-MS-1	1-Feb-21	09:00	28-Feb-21	17:00	D	MSETCL	Permission for AR required in Non Auto mode	Permission for AR required in Non Auto mode
15	45	400KV-KARAD-KOLHAPUR-MS-2	1-Feb-21	09:00	28-Feb-21	17:00	D	MSETCL	Permission for AR required in Non Auto mode	Permission for AR required in Non Auto mode
16	46	400KV-JEJURI-KOYNA STAGE IV-1	1-Feb-21	09:00	28-Feb-21	17:00	D	MSETCL	Permission for AR required in Non Auto mode	Permission for AR required in Non Auto mode
17	47	400KV-KOYNA STAGE IV-LONIKHAND-1	1-Feb-21	09:00	28-Feb-21	17:00	D	MSETCL	Permission for AR required in Non Auto mode	Permission for AR required in Non Auto mode
18	48	400KV-SOLAPUR-M-SOLAPUR-1	1-Feb-21	9:00	28-Feb-21	18:30	D	WTPL	Auto recloser to be kept in disable mode while carrying out PID testing in Ckt-1	
19	49	220KV-SOLAPUR-JEUR-1	1-Feb-21	9:00	28-Feb-21	18:30	D	WTPL	Auto recloser to be kept in disable mode while carrying out PID testing in Ckt-1	
20	50	400KV-KOLHAPUR-MS-SOLAPUR-2	1-Feb-21	9:00	28-Feb-21	18:30	D	WTPL	Auto recloser to be kept in disable mode while carrying out PID testing in Ckt-2	
21	51	400KV-KOLHAPUR-MS-ALKUD-1	1-Feb-21	9:00	28-Feb-21	18:30	D	WTPL	Auto recloser to be kept in disable mode while carrying out PID testing in Ckt-1	
22	57	400KV-SSP-DHULE-MS-2	1-Feb-21	08:00	1-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
23	64	400KV-CHANDRAPUR-BHADRAWATI-1	1-Feb-21	09:00	1-Feb-21	13:00	D	MSETCL	1) To provide the CT & PT to IEM under AMR Project. 2) Maintenance and Alignment work of Isolator.	As per guidelines from competent authority and CO, it is very necessary to commissioned and complete AMR project at earliest.
24	67	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	1-Feb-21	09:00	1-Feb-21	18:00	D	MSETCL	1. Annual Maintenance Work 2. Diagnostic Testing of CB & CT 3. Annual relay testing work	Monday is Load Staggering day in Kolhapur
25	81	400KV-PADGHE-BOISAR-1	1-Feb-21	11:30	1-Feb-21	14:00	D	MSETCL	AMR commissioning work for Disconnection / connection of metering CT	M/s L& T team will available on site
26	94	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARORA - 400KV - BUS 1 at WARORA - 400KV	1-Feb-21	09:00	6-Feb-21	17:00	C	MSETCL	Overhauling of CB By agency and Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	400KV PGCIL Line will be charged through Tie CB 421.
27	97	KORADI - 400KV - TRANSFER BUS 1	1-Feb-21	09:00	13-Feb-21	17:00	C	MSETCL	For CB pole overhauling work by an agency	Outages will be availed subject to weather conditions.
28	102	400KV-RGPPL-NEW KOYNA-2	1-Feb-21	08:00	10-Feb-21	18:00	C	MSETCL	dismantling of existing tilted old tower at location no 94 and erection of new tower (B+9ST) with foundation and stringing of conductor	planned outage
29	107	HVDC 500KV CHANDRAPUR HVDC POLE 2	1-Feb-21	08:00	7-Feb-21	18:00	C	MSETCL	FOR ANNUAL MAINTENANCE WORK IN AC , DC YARD, VALVE HALL ,FEEDERS ETC	TO COMPLETE BALANCE DIAGNOSTIC TESTING WORK AND ANNUAL MAINTENANCE WORK

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D / C	Name of Requesting Agency	Reason	Remarks
30	108	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	1-Feb-21	04:00	4-Feb-21	18:00	C	MSETCL	1) For dismantling of IPS tube of B-ph PG-1 Isolator required for replacement of old damaged quadraple bus conductor of Main Bus-I in 400KV HVDC ckt.-2 bay and 400KV ST-5 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
31	110	400KV-SSP-DHULE-MS-2	2-Feb-21	09:00	27-Feb-21	17:00	D	MSETCL	online PID testing work	400kv SSNNL-2 A/R switch kept on non auto mode
32	117	400KV-SSP-DHULE-MS-1	2-Feb-21	08:00	2-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
33	124	400KV-CHANDRAPUR-BHADRAWATI-3	2-Feb-21	09:00	2-Feb-21	13:00	D	MSETCL	1) To provide the CT & PT to IEM under AMR Project. 2) Maintenance and Alignment work of Isolator.	As per guidelines from competent authority and CO, it is very necessary to commissioned and complete AMR project at earliest.
34	128	400KV-KOLHAPUR-MS-SOLAPUR-2	2-Feb-21	09:00	2-Feb-21	18:00	D	MSETCL	1. QM work 2. A Bus iso alignment work by Hot line unit 3. C Bus iso alignment work.	Load will be managed on 400kv Kolhapur-Alkud Line
35	145	MAIN BAY - 765KV-AKOLA-EKTUNI-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	2-Feb-21	11:00	2-Feb-21	17:00	D	MSETCL	Diagnostic Testing & Routine Maintenance	765kv Akola Ckt-I Will be in service through its TIE (705) Bay and Main Bus-I
36	149	220KV-NASIK-NAVSARI-1	2-Feb-21	08:00	3-Feb-21	18:00	D	MSETCL	maintenance work	-
37	156	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	2-Feb-21	08:31	4-Feb-21	17:30	D	MSETCL	Insulator cleaning work	220KV Halkarni-Tilari & 220KV Halkarni- Mahalaxmi & 220KV Tilari-Amona line is service
38	187	400KV-CHANDRAPUR-BHADRAWATI-4	3-Feb-21	09:00	3-Feb-21	18:00	D	MSETCL	1) To provide the CT & PT to IEM under AMR Project. 2) Maintenance and Alignment work of Isolator.	As per guidelines from competent authority and CO, it is very necessary to commissioned and complete AMR project at earliest.
39	198	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1 at EKTUNI - 765KV	3-Feb-21	10:30	3-Feb-21	18:00	D	MSETCL	*Diagnostic Testing & Routine Maintenance *	*i) 765KV ICT-II Will be in service through its Main (713) Bay and Main Bus-II ii) 765KV Bus-Reactor will be in service through its Main (711) Bay & Main Bus-I*
40	200	132KV-DHARNI-NEPANAGAR-1	3-Feb-21	11:00	3-Feb-21	17:00	D	MSETCL	*1)Jumper connection from 132kv BUS to 132kv Bus section bay to charge additional 25MVA TF-II 2) Diagnostics Testing & Routine Maintenance .	Nil
41	219	220KV-TELEGAON-PUNE-PG-2	4-Feb-21	7:00	4-Feb-21	18:00	D	POWERGRID_WR1	For AMP Work	AC TRANSMISSION LINE CIRCUIT
42	225	400KV-SSP-DHULE-MS-2	4-Feb-21	08:00	4-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
43	241	400KV-KORADI-II-KORADI-III-2	4-Feb-21	10:00	4-Feb-21	18:00	D	MSETCL	Replacement of base support insulator of Lightning Arrester at bay 406	400KV Koradi-II to Koradi-III(Tidangi) Ckt.-I will remain in service as alternate source.
44	264	400KV-SSP-DHULE-MS-1	5-Feb-21	08:00	5-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
45	265	220KV-WARDHA-BHUGAON-1	5-Feb-21	08:00	5-Feb-21	18:00	D	MSETCL	Routine line maintainace work	NA
46	268	220KV-BOISAR-BORIVALI-1	5-Feb-21	09:00	5-Feb-21	17:00	D	MSETCL	FIXING OF MISSING SPACERS AND MAINTEANACE WORK & AMR Meter commissioning work at 220KV Borivali S/stn	FIXING OF MISSING SPACERS AND MAINTEANACE WORK & AMR Meter commissioning work at 220KV Borivali S/stn
47	289	220KV-NASIK-NAVSARI-2	5-Feb-21	08:00	6-Feb-21	18:00	D	MSETCL	Line maintenance work	-
48	292	220KV-AURANGABAD-SHENDRA-1	5-Feb-21	09:00	6-Feb-21	18:00	C	MSETCL	220kv Shendra 2PGCIL Ckt No. 1, 245kv Circuit Breaker Servicing & Overhauling work by Agency & Quarterly Maint. & 89C Isolator Maintenance work.	After Completion Maintenance work of 89C Iso. Of 220kv Shendra 2PGCIL Ckt No. 1, after that 220kv Shendra-PGCIL Ckt No. 1 is charged through TBC-1.
49	294	220KV-PANDURNA-KALMESHWAR-1	5-Feb-21	08:00	14-Feb-21	18:00	C	MSETCL	Height Raising work for NHA1 at chainage No. 22+330 & Routine Maintenance & Dignostic testing work	Agency- NHA1
50	312	400KV-SSP-DHULE-MS-2	6-Feb-21	08:00	6-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
51	318	PUNE-PG - 220KV - BUS 2	6-Feb-21	9:00	6-Feb-21	18:00	D	POWERGRID_WR1	For AMP Work	Bus
52	322	HVDC TIE - 1 @ PADGHA	6-Feb-21	09:30	6-Feb-21	17:30	D	MSETCL	1) Bay maintenance Work 2) Diagnostic Testing work	400kv HVDC 2 will be in service
53	327	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	6-Feb-21	09:00	6-Feb-21	18:00	D	MSETCL	1)Measurement of CT Tan delta. 2) Breaker Timing, CRM & DCRM Relay testing work 3)	Outage will be availed subjected to weather conditions.
54	351	220KV-BOISAR-BOISAR-M-1	7-Feb-21	08:00	7-Feb-21	18:00	D	MSETCL	MAINTENANCE WORK	MAINTENANCE WORK
55	354	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	7-Feb-21	09:00	7-Feb-21	18:00	D	MSETCL	1)Measurement of CT Tan delta. 2) Relay testing work	Outage will be availed subjected to weather conditions.
56	355	400KV-KALA-KUDUS-2	7-Feb-21	7:00	7-Feb-21	18:00	D	POWERGRID_WR1	For line side equipment/Relay testing at Kudus end.	AC TRANSMISSION LINE CIRCUIT

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D / C	Name of Requesting Agency	Reason	Remarks
57	358	400KV-KALA-KUDUS-2	7-Feb-21	09:00	7-Feb-21	17:00	D	MSETCL	AMR project metering connection to main metering of above line and Line CTs tand delta and Relay testing work.	AMR project metering connection to main metering of above line and Line CTs tand delta and Relay testing work.
58	370	NEW KOYNA - 400KV - BUS 1	8-Feb-21	08:00	9-Feb-21	18:00	C	MSETCL	Bus conductor replacement Work	PLANNED OUTAGE
59	371	400KV-KOYNA STAGE IV-NEW KOYNA-1	8-Feb-21	08:00	9-Feb-21	18:00	C	MSETCL	Bus condutor replacement Work	PLANNED OUTAGE
60	372	BUS COUPLER @ NEW KOYNA	8-Feb-21	08:00	9-Feb-21	18:00	C	MSETCL	Bus conductor replacement Work	PLANNED OUTAGE
61	390	400KV-PADGHE-BOISAR-1	8-Feb-21	7:00	8-Feb-21	18:00	D	POWERGRID_WR1	For line side equipment at Padghe MSETCL SS.	AC TRANSMISSION LINE CIRCUIT
62	392	400KV-SSP-DHULE-MS-1	8-Feb-21	08:00	8-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode
63	393	220KV-WARDHA-PUSAD-1	8-Feb-21	08:00	8-Feb-21	18:00	D	MSETCL	Routine line maintainace work	NA
64	397	220KV-BOISAR-BOISAR-M-3	8-Feb-21	09:00	8-Feb-21	16:00	D	MSETCL	PID of Line in A/R Off mode	PID of Line in A/R Off mode
65	399	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	8-Feb-21	09:00	8-Feb-21	18:00	D	APML	Bay Maintenance Activities	Bay Maintenance Activities
66	413	220KV-AURANGABAD-CHITEGAON-1	8-Feb-21	10:00	8-Feb-21	18:00	D	MSETCL	Routine Maintenance & Diagnostic testing work	Routine Maintenance & Diagnostic testing work
67	430	BUS COUPLER BAY OF DHULE - 400KV - BUS 1 AND DHULE - 400KV - BUS 2 @DHULE - 400KV at DHULE - 400KV	8-Feb-21	09:00	11-Feb-21	17:00	C	MSETCL	Breaker Overhauling work	
68	460	400KV-DHULE-DHULE-MS-1	9-Feb-21	09:00	9-Feb-21	17:00	D	MSETCL	Routine Testing & Maint Work	CB DCRM CVT
69	482	220KV-WARDHA-WARDHA-M-1	9-Feb-21	10:00	9-Feb-21	18:00	D	MSETCL	Routine line maintainace work	NA
70	483	Tie bay (408) of Ektuni line 1 @ Taptitanda	9-Feb-21	11:00	9-Feb-21	17:00	D	MSETCL	CB diagnostic testing work	Nil
71	488	KOLHAPUR-MS - 400KV B/R 2	9-Feb-21	7:00	11-Feb-21	18:00	C	POWERGRID_WR1	For CB overhauling works, Outage required on CB only for mechanism overhauling works. Reactor can be kept in service through TBC CB.	BUS REACTOR
72	507	DHULE-MS - 400KV B/R 1	10-Feb-21	7:00	10-Feb-21	18:00	D	POWERGRID_WR1	For AMP Works	BUS REACTOR
73	515	400KV-RGPPL-NAGOTHANE-1	10-Feb-21	08:00	10-Feb-21	17:00	D	MSETCL	Emergency tree cutting work	nil
74	516	220KV-PARLI-OSMANABAD-M-1	10-Feb-21	08:00	10-Feb-21	17:00	D	MSETCL	LINE maintenance	-
75	529	400KV-DHULE-DHULE-MS-2	10-Feb-21	09:00	10-Feb-21	17:00	D	MSETCL	Routine Testing & Maint Work	DCRM Cb CVT
76	532	MAIN BAY - 400KV-KORADI-II-KORADI-III-3 AND KORADI-III - 400KV - BUS 2 at KORADI-III - 400KV	10-Feb-21	09:00	10-Feb-21	18:00	D	MEGPTCL	R-Phase CT Replacement Activity due to Leakage in CT.	R-Phase CT Replacement Activity due to Leakage in CT.
77	544	KUMBARI - 220KV - BUS 1	10-Feb-21	10:00	10-Feb-21	16:00	D	MSETCL	Quarterly Maintenance	Outage is required for Quarterly Maintenance
78	545	220KV-SOLAPUR-KUMBARI-1	10-Feb-21	10:00	10-Feb-21	16:00	D	MSETCL	Quarterly Maintenance	Outage is required for Quarterly Maintenance
79	547	MAIN BAY (409) of EKTUNI CKT-1 @ TAPITTANDA	10-Feb-21	11:00	10-Feb-21	17:00	D	MSETCL	CB diagnostic testing work.	Nil
80	556	400KV-RGPPL-NAGOTHANE-1	11-Feb-21	08:00	25-Feb-21	18:00	D	MSETCL	PID Test of Insulators with permission to keep A/R off at Nagothane end	PLANNED OUTAGE
81	559	400KV-PADGHE-PG-KUDUS-1	11-Feb-21	09:00	11-Feb-21	17:00	D	MSETCL	AMR project metering connection to main metering of above line.	AMR project metering connection to main metering of above line.
82	561	BUS COUPLER BAY - KARAD - 400KV - BUS 1 AND KARAD - 400KV - BUS 2 at KARAD - 400KV	11-Feb-21	09:00	11-Feb-21	18:00	D	MSETCL	CT Tan delta & capacitance,Quarterly. Maint. Work	Load will be managed on each Bus i.e. Bus-I&II
83	571	400KV-BHILAI-KORADI	11-Feb-21	7:00	11-Feb-21	18:00	D	POWERGRID_WR1	For AMP of Line equipment at Koradi end.	AC TRANSMISSION LINE CIRCUIT
84	579	400KV-KORADI-II-KORADI-III-1	11-Feb-21	08:00	11-Feb-21	18:00	D	MSETCL	Line Signature Test and line maintenance work	-
85	580	220KV-WARDHA-PUSAD-1	11-Feb-21	08:00	11-Feb-21	18:00	D	MSETCL	Routine line maintainace work	NA
86	606	220KV-WARDHA-BADNERA-1	11-Feb-21	10:00	11-Feb-21	18:00	D	MSETCL	Routine line maintainace work	NA
87	611	400KV-BHUSAWAL-DEEPNAGAR-1 ON TBC @ KHADKA	11-Feb-21	08:00	13-Feb-21	18:00	C	MSETCL	For overhauling of 400 KV Main Bus-1 &2 PG Isolator	During above period 400 KV Deepnagar-1 circuit will be shifted on TBC (Non Auto Mode)
88	615	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	12-Feb-21	08:00	14-Feb-21	18:00	C	MSETCL	For replacement of quadraple conductor span between 400kV Talegaon & Kalwa line of 400kV B Bus.	Already approved in OCCM,WRLDC on 16.10.2020 to 18.10.2020, but outage deferred due to system condition and once again outage is deferred on 18.10.2020 to 24.10.2020
89	616	KHARGHAR - 400KV - BUS 2	12-Feb-21	08:00	14-Feb-21	18:00	C	MSETCL	For replacement of quadraple conductor span between 400kV Talegaon & Kalwa line of 400kV B Bus.	Already approved in OCCM,WRLDC on 16.10.2020 to 18.10.2020, but outage deferred due to system condition and once again outage is deferred on 18.10.2020 to 24.10.2020
90	617	400KV-KALWA-KHARGHAR-1	12-Feb-21	08:00	14-Feb-21	18:00	C	MSETCL	For replacement of quadraple conductor span between 400kV Talegaon & Kalwa line of 400kV B Bus.	Already approved in OCCM,WRLDC on 16.10.2020 to 18.10.2020, but outage differed due to system condition and once again outage is differed on 18.10.2020 to 24.10.2020
91	618	400KV-PARLI-M-LONIKHAND-II-1	12-Feb-21	09:30	12-Feb-21	18:30	D	MSETCL	Work of Replacement of spacers cum vibration damper	Work will be done by agency

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D / C	Name of Requesting Agency	Reason	Remarks
92	629	400KV-KORADI-SATPURA	12-Feb-21	7:00	12-Feb-21	18:00	D	POWERGRID_WRI	For AMP of Line equipment at Koradi end.	AC TRANSMISSION LINE CIRCUIT
93	634	400KV-KORADI-II-KORADI-III-2	12-Feb-21	08:00	12-Feb-21	18:00	D	MSETCL	Line Signature Test and line maintenance work	-
94	657	220KV-AURANGABAD-SHENDRA-2	12-Feb-21	09:00	13-Feb-21	18:00	C	MSETCL	220kV Shendra 2PGCIL Ckt No. II, 245kV Circuit Breaker Servicing & Overhauling work by Agency & Quarterly Maint. & 89C Isolator Maintenance work.	After Completion Maintenance work of 89C Iso. Of 220kV Shendra 2PGCIL Ckt No.II, after that 220kV Shendra-PGCIL Ckt No. II is charged through TBC-II.
95	661	TIE BAY (402) OF ICT -1 AND LONIKAND1 @ JEJURI	12-Feb-21	09:30	19-Feb-21	17:30	C	MSETCL	CB Overhauling work & Annual maintenance work & testing work.	---
96	667	400KV-PADGHE-PG-KUDUS-2	13-Feb-21	09:00	13-Feb-21	17:00	D	MSETCL	AMR project metering connection to main metering of above line.	AMR project metering connection to main metering of above line.
97	671	400KV-PARLI-M-LONIKHAND-II-2	13-Feb-21	09:30	14-Feb-21	18:30	D	MSETCL	Work of Fixing of spacers cum vibration damper	Work will be done by agency
98	673	400KV-WARORA-CHANDRAPU-II-2	13-Feb-21	09:00	13-Feb-21	18:00	D	MSETCL	Voltage ratio test by Agency and Routine maintenance and diagnostic testing such as CVT/ CT tandelta,and ,isolater maintainance work	Load will be managed on 400KV chandrapur -2Ckt-1 bay no 413
99	684	400 KV RADSS Busbar @ BABHALESHWAR	13-Feb-21	08:00	13-Feb-21	21:00	D	MSETCL	Busbar Relay testing	400 KV RADSS Busbar@BBLR
100	686	400KV-WARORA-CHANDRAPU-II-1	13-Feb-21	09:00	13-Feb-21	18:00	D	MSETCL	Voltage ratio test by Agency and Routine maintenance and diagnostic testing such as CVT/ CT tan delta,and ,isolater maintenance work	Load will be managed on 400KV chandrapur -2 Ckt-2 bay no 415
101	692	HVDC TIE - 2 ON TBC @ PADGHE	13-Feb-21	09:30	22-Feb-21	17:30	C	MSETCL	400kV HVDC 2 on TBC for CB Overhauling work	Agency will be present on site for the work
102	701	400KV-SSP-DHULE-MS-1	14-Feb-21	7:00	14-Feb-21	18:00	D	GETCO	PMM work. A/R of 400 KV SSP-Dhule-2 will remain out	
103	702	400KV-SSP-DHULE-MS-1	14-Feb-21	08:00	14-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode
104	703	400KV-PARLI-M-LONIKHAND-II-2	14-Feb-21	09:00	14-Feb-21	17:00	D	MSETCL	DT / Line Maintenance and chemical cleaning (Cold washing).	---
105	705	BABLESHWAR - 400KV B/R 1 ON TBC	14-Feb-21	09:00	20-Feb-21	18:00	C	MSETCL	400kV CGL make CB pole overhauling work	400kV Reactor 1 on TBC
106	706	400KV-KHARGHAR-PUNE-PG-1	15-Feb-21	08:00	28-Feb-21	19:00	D	MSETCL	Live line installation of OPGW by MTCIL and PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	Work will be carried out on 400 KV Kalwa-Talegaon & 400 KV Kharghar-Talegaon (D/C) line (On both line)
107	707	LONIKHAND-II - 400KV - BUS 2	15-Feb-21	09:00	28-Feb-21	18:00	C	MSETCL	To carry out PID.	--
108	708	400KV-PARLI-M-SOLAPUR-M-1	15-Feb-21	10:00	28-Feb-21	18:00	D	MSETCL	PID Testing Work	Bypass AR Switch. Without Load Interruption.
109	714	220KV-TARAPUR 1&2-BORIVALI-1	15-Feb-21	09:00	15-Feb-21	17:00	D	MSETCL	FIXING OF MISSING SPACERS AND MAINTENANCE WORK	FIXING OF MISSING SPACERS AND MAINTENANCE WORK
110	722	400KV-DHULE-MS-BABLESHWAR-1	15-Feb-21	08:00	15-Feb-21	18:00	D	MSETCL	Replacement of faulty string insulators if Found faulty in PID testing.	A/R switch of 400kV Dhule-BBLR II to be kept on Nonauto mode.
111	723	220KV-WARDHA-BHUGAON-1	15-Feb-21	08:00	15-Feb-21	18:00	D	MSETCL	Routine line maintainance work	NA
112	732	400KV-IEPL-WARORA-1	15-Feb-21	09:00	15-Feb-21	18:00	D	MSETCL	Voltage ratio test by Agency and Routine maintenance and diagnostics testing such as CVT/ CT tan delta, and ,isolater maintenance work	Load will be managed on 400KV PGCIL Ckt
113	745	400KV-RGPPL-NAGOTHANE-1	15-Feb-21	08:00	16-Feb-21	18:00	D	MSETCL	E/W replacement Work	PLANNED OUTAGE
114	747	400KV-JAIGAD-NEW KOYNA-1	15-Feb-21	09:00	16-Feb-21	18:00	D	JPTL	Hotline insulator washing works	AR to be disabled
115	748	400KV-JAIGAD-NEW KOYNA-2	15-Feb-21	09:00	16-Feb-21	18:00	D	JPTL	Hotline insulator washing works	AR to be disabled
116	758	BUSBAR PROTECTION @ TALANDGE	15-Feb-21	09:00	20-Feb-21	18:00	C	MSETCL	220kV Bus Bar protection relay testing work	Permission for Bus Bar protection out only.
117	764	400KV-TIRODA-WARORA-2	16-Feb-21	08:00	28-Feb-21	18:00	D	ATIL	Auto recloser to be kept in disable mode while carrying out PID testing in CKT - 1	Auto recloser to be kept in disable mode while carrying out PID testing in CKT - 1
118	765	400KV-BABLESHWAR-PADGHE-2	16-Feb-21	08:00	28-Feb-21	18:00	D	MSETCL	For Carrying PID Work	-
119	784	400KV-SSP-DHULE-1	16-Feb-21	8:00	16-Feb-21	18:00	D	NCA	Termination of cables and testing of the feeder tripping, other interlocks and measurements in New Bus Bar protection.	Preventive Maintenance

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D / C	Name of Requesting Agency	Reason	Remarks
120	788	400KV-SSP-DHULE-MS-1	16-Feb-21	08:00	16-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kv SSNNL Ckt-2 A/R switch will be kept on non auto mode
121	789	400KV-DHULE-MS-BABLESHWAR-2	16-Feb-21	08:00	16-Feb-21	18:00	D	MSETCL	Replacement of Faulty string insulator if found Faulty in PID testing.	A/R switch of 400kv Dhule-BBLR 1 , to be kept on nonauto mode.
122	791	400KV-WARDHA-WARORA-1	16-Feb-21	09:00	16-Feb-21	17:00	D	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400KV WARORA-IEPL Line is in ckt
123	795	400KV-WARDHA-WARORA-1	16-Feb-21	09:00	16-Feb-21	18:00	D	MSETCL	Voltage ratio test by Agency and Routine maintenance and diagnostic testing such as CVT/ CT tan delta,and ,isolator maintenance work	Load will be managed on 400KV IEPL Ckt
124	808	400KV-EKTUNI-BABLESHWAR-1	16-Feb-21	09:30	17-Feb-21	18:00	D	MSETCL	Missing Disc Insulator Replacement Work, Tightening of Nut Bolts at various locations alongwith Jumper Nut bolt Tightening with fixing of Quarter pins at various locations	400kv Ektuni- Bableshwar II will be in service
125	811	400KV-DHULE-DHULE-MS- 1	16-Feb-21	8:00	18-Feb-21	18:00	D	BDTCL	A/R in Non Auto Mode for defect rectification.	AR OFF
126	812	400KV-DHULE-DHULE-MS- 2	16-Feb-21	8:00	18-Feb-21	18:00	D	BDTCL	A/R in Non Auto Mode for defect rectification.	AR OFF
127	813	400KV-BHUSAWAL-DEEPNAGAR-2 ON TBC @ BHUSAWAL	16-Feb-21	08:00	18-Feb-21	18:00	C	MSETCL	For overhauling of 400 KV Main Bus-1 & 2 PG Isolator	During above period 400 KV deepnagar-2 circuit will be shifted on TBC (Non Auto Mode)
128	822	400KV-SSP-DHULE-MS-2	17-Feb-21	08:00	17-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
129	825	KORADI-III - 400KV - BUS 1	17-Feb-21	09:00	17-Feb-21	18:00	D	MEGPTCL	Maintenance of Bus Related Equipments	Maintenance of Bus Related Equipments
130	826	400KV-SSP-DHULE-MS-2	17-Feb-21	7:00	17-Feb-21	18:00	D	GETCO	PMM work. A/R of SSP-Dhule-1 will remain out	
131	831	220KV-PARLI-OSMANABAD-M-1	17-Feb-21	08:00	17-Feb-21	17:00	D	MSETCL	Line maintenance	-
132	832	400KV-SSP-DHULE-2	17-Feb-21	8:00	17-Feb-21	18:00	D	NCA	Termination of cables and testing of the feeder tripping, other interlocks and measurements in New Bus Bar protection.	Preventive Maintenance
133	853	400KV-PARLI-M-SOLAPUR-M-1	17-Feb-21	09:30	17-Feb-21	18:30	D	MSETCL	Hardware Tightening and Fitting Work.	-
134	854	ZIV BUBAR & LBB Protection from old RADSS @ KHADKA	17-Feb-21	10:00	17-Feb-21	14:00	D	MSETCL	Following works to be carried out: 1. 400KV Old ABB RADSS will be made out of service permanently. 2. 400KV New ZIV Bus bar will be made out of service for	
135	855	KUMBARI - 220KV - BUS 2	17-Feb-21	10:00	17-Feb-21	16:00	D	MSETCL	Quarterly Maintenance	Outage is required for Quarterly Maintenance work
136	856	220KV-SOLAPUR-KUMBARI-2	17-Feb-21	10:00	17-Feb-21	16:00	D	MSETCL	Quarterly Maintenance	Outage is required for Quarterly Maintenance
137	858	400KV-RGPPL-NAGOTHANE-2	17-Feb-21	08:00	18-Feb-21	18:00	D	MSETCL	E/W replacement Work	PLANNED OUTAGE
138	861	400KV-KARAD-JAIGAD-1	17-Feb-21	09:00	18-Feb-21	18:00	D	JPTL	Hotline insulator washing	AR to be disabled
139	862	400KV-KARAD-JAIGAD-2	17-Feb-21	09:00	18-Feb-21	18:00	D	JPTL	Hotline insulator washing	AR to be disabled
140	867	220KV-TALEGAON-PUNE-PG-1	18-Feb-21	10:00	18-Feb-21	17:00	D	MSETCL	Half yearly maintenance, Diagnostic Testing.	---
141	870	400KV-WARDHA-KORADI-II-1	18-Feb-21	09:00	18-Feb-21	17:00	D	MSETCL	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	400 KV WARORA - DEOLI 2 Line is in ckt
142	872	SOLAPUR-M - 400KV - BUS 1	18-Feb-21	10:00	18-Feb-21	18:00	D	MSETCL	Diagnostic Testing Work	Load will be managed on 400kv Main Bus II
143	886	BAY NO. 403 @ KUDUS	18-Feb-21	09:00	18-Feb-21	17:00	D	MSETCL	To Carry out diagnostic tests i.e. CB CRM , DCRM, Timing, CT Tan delta and other maintenance work.	Actual outage required on spare Bay no.403.
144	903	400KV-EKTUNI-BABLESHWAR-2	18-Feb-21	09:30	19-Feb-21	18:00	D	MSETCL	Missing Disc Insulator Replacement Work, Tightening of Nut Bolts at various locations alongwith Jumper Nut bolt Tightening with fixing of Quarter pins	400kv Ektuni- Bableshwar I will be in Service
145	909	TIRODA - 400KV - BUS 2	18-Feb-21	09:00	18-Feb-21	18:00	D	APML	Maintenance of Bus Related Equipments	Maintenance of Bus Related Equipments
146	914	400KV/21KV TIRODA-GT-2	19-Feb-21	9:00	19-Feb-21	18:00	D	APML	Bay Maintenance & Testing Activities. Outage will be availed based on real time condition of Unit.	
147	919	400KV-WARORA-PG-WARDHA-2	19-Feb-21	7:00	19-Feb-21	18:00	D	POWERGRID_WR1	For AMP works, Dia to be keep open & 400KV-WARORA-PG-WARDHA-1 A/R to be keep in non auto mode for safety precautions.	AC TRANSMISSION LINE CIRCUIT
148	928	400KV-KALWA-PUNE-PG-1	19-Feb-21	08:00	19-Feb-21	18:00	D	MSETCL	Routine Line Maintenance and Chemical cleaning (Cold washing).	---

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D / C	Name of Requesting Agency	Reason	Remarks
149	929	400KV-RGPPL-NEW KOYNA-1	19-Feb-21	08:00	19-Feb-21	18:00	D	MSETCL	Routine maint. Work	PLANNED OUTAGE
150	948	TIRODA - 400KV - BUS 1	19-Feb-21	09:00	19-Feb-21	18:00	D	APML	Maintenance of Bus Related Equipments	Maintenance of Bus Related Equipments
151	958	400KV/21KV TIRODA-GT-3	20-Feb-21	9:00	20-Feb-21	18:00	D	APML	Bay Maintenance & Testing Activities. Outage will be availed based on real time	
152	961	KORADI-III - 765KV - BUS 1	20-Feb-21	08:00	20-Feb-21	18:00	D	MEGPTCL	Maintenance of Bus Related Equipments	Maintenance of Bus Related Equipments
153	971	400KV-SSP-DHULE-MS-2	20-Feb-21	08:00	20-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode
154	983	HVDC TIE - 2 @ PADGHE	20-Feb-21	09:30	20-Feb-21	17:30	D	MSETCL	Bay Maintenance Work Dignostic Testing work	400kV HVDC 1 in service
155	984	220KV-TALEGAON-PUNE-PG-2	20-Feb-21	10:00	20-Feb-21	17:00	D	MSETCL	Half yearly maintenance, Diagnostic Testing.	---
156	987	MAIN BAY (403) OF LONIKAND CKT @ JEJURI	20-Feb-21	09:30	27-Feb-21	17:30	C	MSETCL	CB Overhauling work & Annual maintenance work & testing work.	---
157	997	400KV-SSP-DHULE-MS-1	21-Feb-21	08:00	21-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode
158	998	WARORA - 400KV - BUS 1	21-Feb-21	09:00	21-Feb-21	18:00	D	MSETCL	Routine maintainance and diagonastic testing such as CVT/ CT tandelta,and ,isolater maintainance work	400KV MAIN BUS-2 WILL BE IN SERVICE
159	1004	765KV/21KV TIRODA-GT-5	22-Feb-21	9:00	22-Feb-21	18:00	D	APML	Bay Maintenance & Testing Activities. Outage will be availed based on real time condition of Unit.	
160	1022	400KV-SSP-DHULE-MS-1	22-Feb-21	08:00	22-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode
161	1053	400KV-KORADI-BHUSAWAL-1 ON TBC @ BHUSAWAL	22-Feb-21	08:00	24-Feb-21	18:00	C	MSETCL	For overhauling of 400 KV Main Bus-1 &2 PG Isolator	During above period 400 KV Khadka-Koradi circuit will be shifted on TBC (Non-Auto Mode)
162	1063	765KV/21KV TIRODA-GT-4	23-Feb-21	9:00	23-Feb-21	18:00	D	APML	Bay Maintenance & Testing Activities. Outage will be availed based on real time condition of Unit.	
163	1064	BOISAR-M - 220KV - BUS 2	23-Feb-21	08:00	23-Feb-21	18:00	C	MSETCL	MAINTENANCE WORK	MAINTENANCE WORK
164	1079	BABLESHWAR - 400KV - BUS 2	23-Feb-21	08:00	23-Feb-21	18:00	D	MSETCL	Bus CVT testing work	400KV Bus 1 will be in service
165	1080	400KV-SSP-DHULE-MS-2	23-Feb-21	08:00	23-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode
166	1088	MAIN BAY - 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 at KUDUS - 400KV	23-Feb-21	09:00	23-Feb-21	17:00	D	MSETCL	To Carry out diagnostic tests i.e. CB CRM , DCRM, Timing, CT Tan delta and other maintenance work.	To Carry out diagnostic tests i.e. CB CRM , DCRM, Timing, CT Tan delta and other maintenance work.
167	1089	400KV-IEPL-WARORA-1	23-Feb-21	09:00	23-Feb-21	17:00	D	MSETCL	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work.	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
168	1109	KOLHAPUR-MS - 400KV - BUS 2	23-Feb-21	09:00	27-Feb-21	18:00	C	MSETCL	1. Annual Maintenance Work. 2. 400kV TBC B bus isolator replacement work.	All 400kV bays will be shift online on Main Bus 1.
169	1110	400KV/21KV TIRODA-GT-1	24-Feb-21	9:00	24-Feb-21	18:00	D	APML	Bay Maintenance & Testing Activities. Outage will be availed based on real time	
170	1112	400KV-CHAKAN-PUNE-PG-1	24-Feb-21	7:00	24-Feb-21	18:00	D	POWERGRID_WR1	For AMP Work	AC TRANSMISSION LINE CIRCUIT
171	1113	AKOLA - 400KV - BUS 1	24-Feb-21	09:00	24-Feb-21	17:00	D	MSETCL	Routine maintenance & testing work	Bus -2 will be in service
172	1125	400KV-DHULE-MS-BABLESHWAR-1	24-Feb-21	08:00	24-Feb-21	18:00	D	MSETCL	Replacement of Faulty string insulators if found Faulty in PID testing.	A/R switch of 400kv Dhule-BBLR II is to be kept on Non-auto mode.
173	1132	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	24-Feb-21	09:00	24-Feb-21	17:00	D	MSETCL	Routine Maintenance & Dignostic testing work .	Line will be charged through Tie CB 428.
174	1146	220KV-SOLAPUR-JEUR-1	24-Feb-21	10:00	24-Feb-21	17:00	D	MSETCL	Quarterly Maintenance Work	Outage is required for Quarterly Maintenance Work
175	1149	220KV-PARLI-PARLI-M-2	24-Feb-21	08:00	25-Feb-21	17:00	D	MSETCL	Line Maintenance	-
176	1158	400KV/11.5KV TIRODA-ST-1	25-Feb-21	8:00	25-Feb-21	14:00	D	APML	Transformer & Bay Maintenance Activities. Dia need to be kept opened during the outage to carry out maintenance of Main & Tie Bay of ST - 1	Transformer & Bay Maintenance Activities. Dia need to be kept opened during the outage to carry out maintenance of Main & Tie Bay of ST - 1
177	1159	AKOLA - 400KV - BUS 2	25-Feb-21	09:00	25-Feb-21	17:00	D	MSETCL	Routine maintenance & testing	Bus-1 will be in service

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D / C	Name of Requesting Agency	Reason	Remarks
178	1160	400KV/11.5KV TIRODA-ST-4	25-Feb-21	14:00	25-Feb-21	18:00	D	APML	Bay Maintenance & Testing Activities	Bay Maintenance & Testing Activities
179	1170	KORADI-III - 765KV - BUS 2	25-Feb-21	08:00	25-Feb-21	18:00	D	MEGPTCL	Maintenance of Bus Related Equipments	Maintenance of Bus Related Equipments
180	1171	400KV-DHULE-MS-BABLESHWAR-2	25-Feb-21	08:00	25-Feb-21	18:00	D	MSETCL	Replacement of faulty insulator strings if found Faulty in PID testing.	A/R switch of 400KV Dhule-BBLR 1, is to be kept on Non-auto mode.
181	1180	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	25-Feb-21	09:00	25-Feb-21	17:00	D	MSETCL	Routine Maintenance & Dignostic testing work .	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
182	1184	BUS COUPLER BAY - LONIKHAND - 400KV - BUS 1 AND LONIKHAND - 400KV - BUS 2 at LONIKHAND - 400KV	25-Feb-21	09:00	25-Feb-21	18:00	D	MSETCL	DT / Routine Maintenance .	---
183	1204	400KV-RGPPL-NAGOTHANE-2	26-Feb-21	08:00	28-Feb-21	18:00	D	MSETCL	PID Test of Insulators with permission to keep A/R off at Nagothane end	PLANNED OUTAGE
184	1207	400KV/11.5KV TIRODA-ST-5	26-Feb-21	14:00	26-Feb-21	18:00	D	APML	Bay Maintenance and Testing Activities	Bay Maintenance and Testing Activities
185	1209	400KV/11.5KV TIRODA-ST-3	26-Feb-21	8:00	26-Feb-21	14:00	D	APML	Transformer & Bay Maintenance Activities. Dia need to be kept opened during the outage to carry out Maintenance of Main & Tie Bay of ST - 3	Transformer & Bay Maintenance Activities. Dia need to be kept opened during the outage to carry out Maintenance of Main & Tie Bay of ST - 3
186	1210	400KV WARDHA-AKOLA-1	26-Feb-21	7:00	26-Feb-21	18:00	D	POWERGRID_WR1	For Tie CB 42052 LBB circuit checking & testing. Complete diameter required to be open.	AC TRANSMISSION LINE CIRCUIT
187	1211	400KV-WARDHA-AKOLA-2	26-Feb-21	7:00	26-Feb-21	18:00	D	POWERGRID_WR1	For AMP of Line equipment & Bay- ProtectionTesting at Akola end & For line AMP works 400KV-WARDHA-AKOLA-1 A/R to be keep in non auto mode for safety measures.	AC TRANSMISSION LINE CIRCUIT
188	1216	400KV/11.5KV CHANDRAPUR-GCR-ST-5	26-Feb-21	04:00	28-Feb-21	18:00	C	MSETCL	1) For dismantling of IPS tube of B-ph PG-1 Isolator required for replacement of old damaged quadruple bus conductor of Main Bus-I in 400KV HVDC ckt.-2 bay and 400KV ST-5 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
189	1219	400KV-PARLI-M-LONIKHAND-II-1	26-Feb-21	09:00	26-Feb-21	17:00	D	MSETCL	Line Maintenance and chemical cleaning (Cold washing).	---
190	1231	400KV-SSP-DHULE-MS-2	26-Feb-21	08:00	26-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kv SSNNL Ckt-1 A/R switch will be kept on non auto mode
191	1240	220kV Navsari-Nashik line no.1	26-Feb-21	9:00	26-Feb-21	18:00	D	GETCO	Maintenance work	
192	1241	400kV SATPURA-KORADI	26-Feb-21	9:00	26-Feb-21	18:00	D	POWERGRID_WR2	Proposed by Itarsi- For AMP of Terminal Equipments	PG-WR2-Itarsi
193	1250	400KV-IEPL-KORADI-II-1	26-Feb-21	08:00	27-Feb-21	18:00	C	MSETCL	Restrtring work for increasing ground clearance between tower No. 10 & 11	-
194	1256	765KV-AKOLA (2)-EKTUNI-2	26-Feb-21	08:00	8-Mar-21	18:00	C	MEGPTCL	Work is to be carried out to accommodate other utility i.e., Maharashtra State Road Development Corporation (MSRDC - Highway Authority), modification construction of line to accommodate/ maintain require clearance from Nagpur - Mumbai Express Highway. Hence, Outage to be considered as deemed available.	Work is to be carried out to accommodate other utility i.e., Maharashtra State Road Development Corporation (MSRDC - Highway Authority), modification construction of line to accommodate/ maintain require clearance from Nagpur - Mumbai Express Highway. Hence, Outage to be considered as deemed available.
195	1257	CHANDRAPUR-GCR - 400KV - BUS 1	26-Feb-21	04:00	28-Feb-21	18:00	C	MSETCL	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in 400KV HVDC ckt.-2 bay and 400KV ST-5 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
196	1258	400KV-CHANDRAPUR-BHADRAWATI-3	26-Feb-21	04:00	28-Feb-21	18:00	C	MSETCL	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in 400KV HVDC ckt.-2 bay and 400KV ST-5 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	Outage is required on 400KV GCR C'pur - PGCIL Bhadrawati Ckt. No.- 3 line, as the this circuit can not be shifted on 400KV Main Bus-2 due to problems of PG isolators of Bus-2 .
197	1259	400KV-CHANDRAPUR-BHADRAWATI-4	26-Feb-21	04:00	28-Feb-21	18:00	C	MSETCL	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in 400KV HVDC ckt.-2 bay and 400KV ST-5 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	Outage is required on 400KV GCR C'pur - PGCIL Bhadrawati Ckt. No.- 4 line, as the this circuit can not be shifted on 400KV Main Bus-2 due to problems of PG isolators of Bus-2 .

Sr.No.	OCCM Sr. No	Line / Element	From	Time	To	Time	D / C	Name of Requesting Agency	Reason	Remarks
198	1260	400KV/21KV CHANDRAPUR-GT-6	26-Feb-21	04:00	28-Feb-21	18:00	C	MSETCL	1) For dismantling of IPS tube of B-ph PG-1 Isolator required for replacement of old damaged quadruple bus conductor of Main Bus-I in 400KV HVDC ckt.-2 bay and 400KV ST-5 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
199	1261	400KV/220KV AKOLA-ICT-2	26-Feb-21	09:00	17-Mar-21	19:00	C	MSETCL	1. Draining,filtration &refilling of oil for internal inspection of 3-phase ICT-02 due to the higher values of DGA. 2. Internal inspection work & repairing work if any abnormality observed during inspection. 3. All testing activities required before charging & maintenance work.	1. Work will be carried out by manufacturer IMP powers limited 2. Load will be shifted on ICT-01 during outage period 3.Previous outage was proposed from 23/11/2020 to 12/12/2020 but outage was not availed due to system constraint
200	1264	400KV/11.5KV TIRODA-ST-2	27-Feb-21	09:00	27-Feb-21	18:00	D	APML	Bay Maintenance and Testing Activities	Bay Maintenance and Testing Activities
201	1265	KALWA - 400KV - BUS 2	27-Feb-21	09:00	27-Feb-21	18:00	D	MSETCL	Y ph Bus PT replacement work	Y ph Bus PT replacement work
202	1268	400KV-WARDHA-AKOLA-2	27-Feb-21	7:00	27-Feb-21	18:00	D	POWERGRID_WR1	For Tie CB 41752 LBB circuit checking & testing. Complete diameter required to be open.	AC TRANSMISSION LINE CIRCUIT
203	1270	400KV-LONIKHAND-CHAKAN-1	27-Feb-21	09:00	27-Feb-21	17:00	D	MSETCL	Diagnostic testing and maintenance activities.	---
204	1282	400KV-SSP-DHULE-MS-1	27-Feb-21	08:00	27-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode
205	1283	220KV-TARAPUR 1&2-BOISAR-M-1	27-Feb-21	08:00	27-Feb-21	18:00	D	MSETCL	MAINTENANCE WORK	MAINTENANCE WORK
206	1286	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	27-Feb-21	09:00	27-Feb-21	17:00	D	MSETCL	Routine Maintenance & Dignostic testing work .	Line will be charged through mainCB 429.
207	1288	220kv Navsari-Nashik line no.2	27-Feb-21	9:00	27-Feb-21	18:00	D	GETCO	Maintenance work	
208	1300	KALWA - 400KV - BUS 1	28-Feb-21	09:00	28-Feb-21	18:00	D	MSETCL	Maintenance & Testing work	Maintenance & Testing work
209	1304	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV - BUS 2 at BABLESHWAR - 400KV	28-Feb-21	08:00	28-Feb-21	18:00	D	MSETCL	Diagnostic Testing CT CB	400KV Buus 1 & 2 seperated
210	1309	220KV-BOISAR-BOISAR-M-3	28-Feb-21	08:00	28-Feb-21	18:00	D	MSETCL	MAINTENANCE WORK	MAINTENANCE WORK
211	1313	400KV-SSP-DHULE-MS-1	28-Feb-21	08:00	28-Feb-21	18:00	D	MSETCL	Replacement of damaged earthwire and PID suspicious disc insulator replacement,other maintenance work	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode

Maharashtra State Load Despatch Centre

Monthly Outages from 01/Feb/2021 To 28/Feb/2021

Sr.No.	Category	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	1	400 KV	DEEPNAGAR - THAPTI TANDA	01-Feb-21	06:00	03-Feb-21	18:00	Daily	For replacement of Faulty insulator strings detected in PID	MSETCL	MSETCL	NIL
2	1	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	01-Feb-21	08:00	14-Feb-21	17:00	Daily	For Conductor & Earthwire H/W tightening work	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work
3	1	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	01-Feb-21	10:00	27-Feb-21	16:00	Daily	PID testing of insulator strings. AVR shall be kept in non auto mode. PID of 400 kV Akola- Nandgaonpeth line shall be carried out by PID unit Akola	MSETCL	MSETCL	PID of 400 kV Akola- Nandgaonpeth line shall be carried out by PID unit Akola
4	1	400 KV	CHANDRAPUR - KHAPERKHEDA	01-Feb-21	08:00	13-Feb-21	17:00	Daily	for PID Testing Work,shifting autoreclose switch to Non auto Mode	MSETCL	MSETCL	for PID Testing Work,shifting autoreclose switch to Non auto Mode
5	1	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	02-Feb-21	08:00	02-Feb-21	18:00	Daily	For diagnostic testing and routine bay maintenance work	MSETCL	MSETCL	nil
6	1	400 KV	400/132 KV 200 MVA ICT - 1 ON TBC @ KHADKA	03-Feb-21	08:00	04-Feb-21	18:00	Continuous	For overhauling of 400 KV Main Bus-1 & 2 PG Isolator	MSETCL	MSETCL	During above period 400/132 KV,200 MVA ICT-1 will be shifted on TBC (No Interruption)
7	1	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	03-Feb-21	10:00	03-Feb-21	18:00	Daily	Centre Break Isolator Maintenance Work & CT Tan Delta	MSETCL	MSETCL	-
8	1	400 KV	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	03-Feb-21	10:00	03-Feb-21	18:00	Daily	SFRA Testing	MSETCL	MSETCL	Load will be managed on 400/220/33KV 501MVA ICT II
9	1	400 KV	KARAD - LONIKAND 1	03-Feb-21	08:00	03-Feb-21	18:00	Daily	DT / Routine Maintenance & Routine Line maintenance work.	MSETCL	MSETCL	---
10	1	400 KV	400kv Stn. TF No 4 @ C'pur GCR	04-Feb-21	09:00	04-Feb-21	13:00	Daily	1) To provide the CT & PT to IEM under AMR Project.	MSETCL	MSETCL	During the work, 400KV STN T/F No.-V bay will be in service.
11	1	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	04-Feb-21	09:00	04-Feb-21	17:00	Daily	Diagnostic testing and maintenance activities	MSETCL	MSETCL	---
12	1	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	04-Feb-21	06:00	06-Feb-21	18:00	Daily	For replacement of Faulty insulator strings detected in PID	MSETCL	MSETCL	NIL
13	1	400 KV	LONIKAND 1-JEJURI	04-Feb-21	09:30	04-Feb-21	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400kV Jejuri-Koyna Stage-IV line will be in service.
14	1	400 KV	JEJURI- KOYNA STAGE-IV	05-Feb-21	08:00	05-Feb-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
15	1	400 KV	KARAD - TALANDGE CKT 2	05-Feb-21	08:00	05-Feb-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
16	1	400 KV	THAPTI TANDA - WALUJ	05-Feb-21	09:00	05-Feb-21	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance
17	1	400 KV	400kv Stn. TF No 5 @ C'pur GCR	05-Feb-21	09:00	05-Feb-21	13:00	Daily	1) To provide the CT & PT to IEM under AMR Project.	MSETCL	MSETCL	During the work, 400KV STN T/F No.-IV bay will be in service.
18	1	400 KV	KARAD - TALANDGE CKT 2	05-Feb-21	09:00	05-Feb-21	18:00	Daily	1. B pin C.V.I replacement work 2. Annual Maintenance work.	MSETCL	MSETCL	Monday is load staggering day in Kolhapur
19	1	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	06-Feb-21	09:00	06-Feb-21	17:00	Daily	2. A & B Bus Isolator alignment work change	MSETCL	MSETCL	-
20	1	400 KV	KARAD - TALANDGE CKT 1	06-Feb-21	08:00	06-Feb-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
21	1	400 KV	400/132 KV 200 MVA ICT - 2 @ KHADKA	06-Feb-21	08:00	06-Feb-21	18:00	Daily	For Diagnostic testing and routine bay maintenance work	MSETCL	MSETCL	Nil
22	1	400 KV	KARAD - TALANDGE CKT 1	06-Feb-21	09:00	06-Feb-21	18:00	Daily	1. Annual maintenance work. 2. A & B Bus Isolator alignment work by Hot line unit	MSETCL	MSETCL	Load will be managed on Karad-Talandge Ckt-2
23	1	400 KV	NEW KOYNA-KARAD -CKT 1	07-Feb-21	08:00	07-Feb-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	planned outage
24	1	400 KV	400/132 KV 200 MVA ICT - 2 ON TBC @ KHADKA	08-Feb-21	08:00	09-Feb-21	18:00	Continuous	For overhauling of 400 KV Main Bus-1 & 2 PG Isolator	MSETCL	MSETCL	During above period 400/132 KV,200 MVA ICT-2 will be shifted on TBC (No Interruption)
25	1	400 KV	CHANDRAPUR-PARLI CKT-3	08-Feb-21	09:00	08-Feb-21	18:00	Daily	Line Maintenance Work at 400 kV LMS-2 Girwali	MSETCL	MSETCL	-
26	1	400 KV	PADGHE - NAGOTHANE 1	08-Feb-21	08:00	08-Feb-21	17:00	Daily	Sample lighting and cold washing work	MSETCL	MSETCL	nil

Sr.No.	Category	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
27	1	400 KV	DHULE- - BABLESHWAR - I	08-Feb-21	09:00	08-Feb-21	17:00	Daily	CT & CVT C & tan D testing	MSETCL	MSETCL	-
28	1	400 KV	KHADKA-AURANGABAD	08-Feb-21	06:00	09-Feb-21	18:00	Daily	For CT ratio conversion and replacement of faulty insulator strings	MSETCL	MSETCL	NIL
29	1	400 KV	JAIGAD-NEW KOYNA-I	08-Feb-21	08:00	08-Feb-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	PLANNED OUTAGE
30	1	400 KV	CHANDRAPUR-PARLI CKT-3	08-Feb-21	09:00	08-Feb-21	18:00	Daily	Line Maintenance Work	MSETCL	MSETCL	-
31	1	400 KV	NEW KOYNA -KARAD -CKT 2	09-Feb-21	08:00	09-Feb-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	PLANNED OUTAGE
32	1	400 KV	TIE BAY (403) OF BUS RECTOR & ICT -I @ WARORA	09-Feb-21	09:00	09-Feb-21	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing work and isolator maintenance work	MSETCL	MSETCL	only Tie CB 403 is in OFF condition ,respective bay charged through its own main CB.
33	1	400 KV	NEW KOYNA -KARAD -CKT 2	09-Feb-21	08:00	09-Feb-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
34	1	400 KV	PADGHE - NAGOTHANE 2	09-Feb-21	08:00	09-Feb-21	17:00	Daily	Summer lightning and cold washing work	MSETCL	MSETCL	nil
35	1	400 KV	DHULE- - BABLESHWAR - II	09-Feb-21	09:00	09-Feb-21	17:00	Daily	CT ratio change	MSETCL	MSETCL	CT ratio change
36	1	400 KV	JAIGAD-NEW KOYNA-II	09-Feb-21	08:00	09-Feb-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	PLANNED OUTAGE
37	1	400 KV	400/220/33 315 MVA ICT-II @Karad	09-Feb-21	09:00	09-Feb-21	18:00	Daily	RRS related work.Quarterly. Maint. Work	MSETCL	MSETCL	Load will be managed on other two ICTs
38	1	400 KV	KHADKA- DEEPNAGAR CKT 1	10-Feb-21	08:00	10-Feb-21	18:00	Daily	For diagnostic testing and routine bay maintenance work	MSETCL	MSETCL	Nil
39	1	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	10-Feb-21	10:00	10-Feb-21	18:00	Daily	Routine maintenance & Diagnostic Testing work	MSETCL	MSETCL	Load will be managed on 400/220/33KV 501 MVA ICT I
40	1	400 KV	TIE BAY (406) OF ICT -2 @ WARORA	10-Feb-21	09:00	10-Feb-21	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Presently this bay is off condition.
41	1	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	10-Feb-21	08:00	10-Feb-21	18:00	Daily	CT CB relay testing work	MSETCL	MSETCL	-
42	1	400 KV	LONIKAND 1 - KOYNA STAGE-IV	10-Feb-21	09:00	10-Feb-21	18:00	Daily	DT / Routine Maintenance.	MSETCL	MSETCL	---
43	1	400 KV	400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	11-Feb-21	09:00	11-Feb-21	18:00	Daily	DT / Routine Maintenance.	MSETCL	MSETCL	---
44	1	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	11-Feb-21	09:30	11-Feb-21	17:30	Daily	Annual Testing & Maintenance work.	MSETCL	MSETCL	400/220/33kv 501MVA, ICT-I & II will be in service.
45	1	400 KV	JEJURI- KOYNA STAGE-IV	11-Feb-21	08:00	11-Feb-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
46	1	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	11-Feb-21	10:00	11-Feb-21	18:00	Daily	line maintenance work	MSETCL	MSETCL	-
47	1	400 KV	LONIKAND 1 - KOYNA STAGE-IV	12-Feb-21	08:00	12-Feb-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
48	1	400 KV	400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	12-Feb-21	08:30	12-Feb-21	17:30	Daily	For Line CT Tandelta & Main and Tie CB DCRM testing work also bay	MSETCL	MSETCL	work to be done as per diagnostic plan
49	1	400 KV	THAPTI TANDA - WALUJ	12-Feb-21	09:00	12-Feb-21	17:00	Daily	Routine Maintenance Works	MSETCL	MSETCL	Routine Maintenance Works
50	1	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	12-Feb-21	08:00	12-Feb-21	18:00	Daily	For Routine Maintenance & Diagnostic Test	MSETCL	MSETCL	400KV ICT-II & ICT-III will be in service.
51	1	400 KV	400/220/33 KV 500MVA ICT - 2 @ DEEPNAGAR	13-Feb-21	08:30	13-Feb-21	17:30	Daily	for Line Ct Tandelta testing TIE & Main CB DCRM testing work and Bay maint work	MSETCL	MSETCL	need to be done as per diagnostic plan
52	1	400 KV	400/220kv 105 MVA SPARE ICT @ NEW KOYNA	13-Feb-21	08:00	13-Feb-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	PLANNED OUTAGE
53	1	400 KV	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	15-Feb-21	08:00	15-Feb-21	17:00	Daily	Regular maintenance work	MSETCL	MSETCL	nil
54	1	400 KV	KHADKA- DEEPNAGAR CKT 2	15-Feb-21	08:00	15-Feb-21	18:00	Daily	For diagnostic testing and routine bay maintenance work	MSETCL	MSETCL	Nil
55	1	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	15-Feb-21	09:00	15-Feb-21	18:00	Daily	(1) Earthwire stringing & Hardware Tightening & fitting work at 400 kV LMS-2 Girwali. (2) Breaker DCRM & Timing measurement. (3) Bay maintenance work.	MSETCL	MSETCL	-

Sr.No.	Category	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
56	1	400 KV	KHADKA- DEEPNAGAR CKT 2	15-Feb-21	08:30	15-Feb-21	14:30	Daily	For Line Bus & Tie CT tan delta testing work	MSETCL	MSETCL	to be done as per plan
57	1	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	15-Feb-21	08:00	27-Feb-21	17:00	Daily	for PID Testing Work,shifting autoreclose switch to Non auto Mode	MSETCL	MSETCL	for PID Testing Work,shifting autoreclose switch to Non auto Mode
58	1	400 KV	400/220/33 315 MVA ICT-I @Karad	15-Feb-21	09:00	16-Feb-21	18:00	Continuos	220 KV CT Tan delta & capacitance,400 KV & 220 KV CB timing & CRM,DCRM ,RRS related work,Quarterly. Maint. Work	MSETCL	MSETCL	Load will be managed on other two ICTs
59	1	400 KV	KARAD - LONIKAND 1	16-Feb-21	08:00	17-Feb-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
60	1	400 KV	400/220/20 KV 300 MVA ICT - 1 @ KORADI	16-Feb-21	09:00	16-Feb-21	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
61	1	400 KV	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	16-Feb-21	08:00	16-Feb-21	17:00	Daily	Regular maintenance work	MSETCL	MSETCL	nil
62	1	400 KV	DEEPNAGAR - THAPTI TANDA	17-Feb-21	09:00	17-Feb-21	17:00	Daily	Routine Maintenance Works at Waluj end	MSETCL	MSETCL	Routine Maintenance Works at Waluj end
63	1	400 KV	400/220/33 KV 315MVA ICT - 1 @ AKOLA	17-Feb-21	09:00	17-Feb-21	18:00	Daily	Routine maintenance & testing work	MSETCL	MSETCL	Load will be shifted on ICT-2
64	1	400 KV	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	17-Feb-21	08:00	17-Feb-21	17:00	Daily	Regular maintenance work	MSETCL	MSETCL	nil
65	1	400 KV	400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	18-Feb-21	08:00	18-Feb-21	19:00	Daily	Half yearly maintenance and diagnostic testing work.	MSETCL	MSETCL	---
66	1	400 KV	JEJURI- KOYNA STAGE-IV	18-Feb-21	08:00	18-Feb-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
67	1	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	19-Feb-21	09:00	19-Feb-21	18:00	Daily	(1) Line Maintenance Work at 400 kV LMS-2 Girwali. (2) Reactor B/U protn. relay testing. (3) Bay maintenance work.	MSETCL	MSETCL	-
68	1	400 KV	KORADI-KHAPERKHEDA I	19-Feb-21	09:00	19-Feb-21	17:00	Daily	For relay testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
69	1	400 KV	KHADKA - BABLESHWAR	19-Feb-21	06:00	20-Feb-21	18:00	Daily	For CT Ratio conversion and replacement of Faulty insulator strings detected in PID & Monkey Patrolling	MSETCL	MSETCL	NIL
70	1	400 KV	KORADI-KHADKA	20-Feb-21	08:00	20-Feb-21	18:00	Daily	For diagnostic testing and routine bay maintenance work	MSETCL	MSETCL	Nil
71	1	400 KV	NEW KOYNA - STAGE IV CKT 2	20-Feb-21	08:00	20-Feb-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	PLANNED OUTAGE
72	1	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	22-Feb-21	06:00	27-Feb-21	18:00	Daily	For replacement of Dead end & Mid Span Joint	MSETCL	MSETCL	NIL
73	1	400 KV	GT - 7 @ KORADI-I	22-Feb-21	09:00	22-Feb-21	17:00	Daily	For diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
74	1	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	22-Feb-21	10:00	22-Feb-21	17:00	Daily	ICT Diagnostic testing & Isolator Maintenance	MSETCL	MSETCL	Nil
75	1	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	22-Feb-21	08:00	22-Feb-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	PLANNED OUTAGE
76	1	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	22-Feb-21	09:00	22-Feb-21	18:00	Daily	1. Annual Maintenance work 2. 220kV side C Bus isolator alignment work. 3. Annual relay testing work	MSETCL	MSETCL	Monday is load Staggering day in Kolhapur. Required 220kV Tilawani - Miraj line H/T if ICT loading at 400kV Talandge raises.
77	1	400 KV	400/220/33 315 MVA ICT-III @Karad	22-Feb-21	09:00	22-Feb-21	18:00	Daily	400 KV CT Tan delta & capacitance,Quarterly. Maint. Work	MSETCL	MSETCL	Load will be managed on other two ICTs
78	1	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	23-Feb-21	08:00	23-Feb-21	17:00	Daily	For Conductor & Earthwire H/W tightening work	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work
79	1	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	23-Feb-21	08:00	23-Feb-21	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	PLANNED OUTAGE
80	1	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	24-Feb-21	09:00	24-Feb-21	17:00	Daily	Routine Maintenance Works	MSETCL	MSETCL	Routine Maintenance Works

Sr.No.	Category	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
81	1	400 KV	GT - 6 @ KORADI-1	24-Feb-21	09:00	24-Feb-21	17:00	Daily	For diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
82	1	400 KV	DEEPNAGAR - THAPTI TANDA	24-Feb-21	09:00	25-Feb-21	18:00	Daily	Line routine maint. work	MSETCL	MSETCL	Nil
83	1	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	24-Feb-21	08:00	24-Feb-21	17:00	Daily	For Conductor & Earthwire H/W tightening work	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work
84	1	400 KV	KHADKA- DEEPNAGAR CKT 2	24-Feb-21	08:30	24-Feb-21	10:30	Daily	Line Bus & Tie CT Tan delta testing work	MSETCL	MSETCL	as per yearly plan
85	1	400 KV	KHADKA-AURANGABAD	25-Feb-21	09:00	25-Feb-21	17:00	Daily	Routine Maintenance Works	MSETCL	MSETCL	Routine Maintenance Works
86	1	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	25-Feb-21	09:00	25-Feb-21	18:00	Daily	1. REF & NDR relay testing work. 2.Bay maintenance work.	MSETCL	MSETCL	-
87	1	400 KV	JEJURI- KOYNA STAGE-IV	25-Feb-21	08:00	25-Feb-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
88	1	400 KV	THAPTI TANDA - WALUJ	26-Feb-21	09:00	27-Feb-21	18:00	Daily	Line routine maintenance work	MSETCL	MSETCL	Nil
89	1	400 KV	CHANDRAPUR-PARLI CKT-3	26-Feb-21	08:00	26-Feb-21	17:00	Daily	For Conductor & Earthwire H/W tightening work.	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work.
90	1	400 KV	125MVAr BUS REACTOR @ WARORA	26-Feb-21	09:00	26-Feb-21	18:00	Daily	Routine maintainance and Testing works and isolater maintainance work .	MSETCL	MSETCL	During outage reactor is in off condition
91	1	400 KV	KHADKA-AURANGABAD	26-Feb-21	08:00	26-Feb-21	18:00	Daily	For Changing CT Ratio from 1000 A TO 2000 A	MSETCL	MSETCL	Work will be carried out by Testing Unit Khadka
92	1	400 KV	NEW KOYNA-KARAD -CKT 1	26-Feb-21	08:00	26-Feb-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
93	1	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	26-Feb-21	09:00	26-Feb-21	17:00	Daily	Routine Maintenance of BAY	MSETCL	MSETCL	Routine Maintenance of BAY
94	1	400 KV	400/220/33 KV 315 MVA ICT - 1 @ DHULE	27-Feb-21	09:00	27-Feb-21	17:00	Daily	Routine Maint /Testing work	MSETCL	MSETCL	Testing of ICT, CT CB HV & LV side
95	1	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	27-Feb-21	08:00	27-Feb-21	18:00	Daily	LTS relay retrofitting work	MSETCL	MSETCL	ICT 1, 3, 4 will be in service
96	1	400 KV	KARAD - LONIKAND 1	27-Feb-21	08:00	27-Feb-21	18:00	Daily	PID Faulty disc insulator replacement work & Cold line washing work	MSETCL	MSETCL	PID Faulty disc insulator replacement work & Cold line washing work
97	1	400 KV	KHADKA - BABLESHWAR	27-Feb-21	08:00	27-Feb-21	18:00	Daily	For changing of CT Ratio from 1000 A to 2000 A	MSETCL	MSETCL	Work will be carried out by Testing Unit jalgaon
98	1	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	28-Feb-21	08:00	28-Feb-21	17:00	Daily	For Conductor & Earthwire H/W tightening work	MSETCL	MSETCL	For Conductor & Earthwire H/W tightening work