

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of February' 2022

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/continuous	Reason	From	time	to	Time	Remarks
1	1	MSETCL	400KV-PADGHE HVDC-PADGHE-2	Continuous	1) 400kV HVDC -2 Pole 2) PG Isolator replacement	28-Jan-22	08:00	10-Feb-22	18:00	1)400kV HVDC -2 in service through TBC 2) Hot line work for Hanger replacement 3) Agency will present on site
2	5	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damage earth wire and PID suspicious disc insulator strings and other maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	1-Feb-22	08:00	1-Feb-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
3	7	NCA	400KV SSP - DHULE-I	Daily	TC-1 circuit checking work & switchyard Preventive maintenance work	1-Feb-22	8:00	1-Feb-22	18:00	A/R switch of Dhule-II is to be put on Non Auto
4	14	MSETCL	400KV-Wardha-WARORA-1	Daily	Routine Maintenance & Dignostic testing work	1-Feb-22	09:00	1-Feb-22	17:00	400KV WARORA-IEPL Line is in ckt
5	48	MSETCL	400KV-RGPPL-NEW KOYNA-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	1-Feb-22	08:00	5-Feb-22	18:00	---
6	58	MSETCL	400KV-KALWA-PADGHE-1	Daily	PID Testing Auto-Reclose function to be out of service.	1-Feb-22	09:00	10-Feb-22	18:00	PID Testing Auto-Reclose function to be out of service.
7	59	MSETCL	400KV-LONIKHAND-CHAKAN-1	Daily	PID Testing.	1-Feb-22	08:00	12-Feb-22	18:00	---
8	60	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	PID testing	1-Feb-22	09:00	12-Feb-22	17:00	PID testing
9	63	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2 (on TBC)	Continuous	monitoring assembly, Hydraulic pressure monitoring assembly and Poles and Interrupters. 2) Measurement of Timing, CRM and DCRM of CB. 3) Maintenance and alignments of PG-1 and PG-2 Isolators.	1-Feb-22	05:00	15-Feb-22	18:00	TBC-2 and there will not be any power restriction on HVDC Pole-1 & 2.
10	64	MSETCL	400KV-CHAKAN-PUNE-PG-1	Continuous	1) Direction of 27A(N+27) & 28A(N+27). 2) Loc.no. 27A to 28A Stringing 3) Loc. No.22 to 27 stringing . 4) Loc.no.28 to 29 stringing .	1-Feb-22	8:00	15-Feb-22	18:00	subject to load relief of around 100-150MW at 220KV Chinchwad -1 s/s
11	65	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	PID testing work	1-Feb-22	08:00	15-Feb-22	18:00	-
12	68	MSETCL	400KV-TAPTHITHANDA-DEEPNAGAR-1	Continuous	for tower height raising work at Loc No. 155 & 156 crossing to Nagpur-Mumbai Samruddhi Highway work. The work includes the dismantling of existing Loc No. 155 (DA+0) & Loc No. 156 (DA+0)	1-Feb-22	9:00	18-Feb-22	18:00	Nagpur-Mumbai Samruddhi Highway work
13	69	MSETCL	400KV-AURANGABAD-M (WALUJ)-TAPTHITHANDA-1	Continuous	for tower height raising work at Loc No. 155 & 156 crossing to Nagpur-Mumbai Samruddhi Highway work. The work includes the dismantling of existing Loc No. 155 (DA+0) & Loc No. 156 (DA+0)	1-Feb-22	9:00	18-Feb-22	18:00	Nagpur-Mumbai Samruddhi Highway work
14	73	MSETCL	220KV-SOLAPUR-JEUR-1	Daily	An outage is required for Insulator String PID Testing.	1-Feb-22	09:00	20-Feb-22	18:00	Work will be carried out by hot line method. Only A/R at Jeur & PGCIL end required to be out of service during outage
15	86	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Shifting of auto reclose switch to non auto mode, for fixing of fiber insulation cap type bird waste deposition guard	1-Feb-22	08:00	28-Feb-22	17:00	-
16	89	MSETCL	400KV-JEJURI-KOYNA STAGE IV-1	Daily	For 48 F OPGW installation.	1-Feb-22	08:00	28-Feb-22	18:00	Work is to be carried by MTCIL.
17	90	MSETCL	400KV-LONIKHAND-JEJURI-1	Daily	For 48 F OPGW installation.	1-Feb-22	08:00	28-Feb-22	18:00	Work is to be carried by MTCIL.
18	96	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Online PID testing work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	1-Feb-22	09:00	28-Feb-22	17:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
19	111	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	LINE maintenance	2-Feb-22	08:00	2-Feb-22	17:00	-
20	131	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	Daily	routine maintenance	2-Feb-22	09:00	2-Feb-22	18:00	-

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/continuous	Reason	From	time	to	Time	Remarks
21	132	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	Daily	routine maintenance	2-Feb-22	09:00	2-Feb-22	18:00	-
22	154	MSETCL	400KV-RGPPL-NEW KOYNA-2(TBC)	Continuous	C.B. Overhauling work Shitting on TBC	2-Feb-22	08:00	9-Feb-22	18:00	-----
23	156	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Online PID testing work. 400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	2-Feb-22	09:00	28-Feb-22	17:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
24	163	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintainance Work	3-Feb-22	07:00	3-Feb-22	18:00	Shifting of auto reclose switch to non auto mode, for fixing of fiber insulation cap type bird waste deposition guard by AEE LMSDN Pusad from 8:00
25	170	MSETCL	LONIKHAND-II - 400KV - BUS 2	Daily	Diagnostic testing and Maintenance.	3-Feb-22	08:00	3-Feb-22	18:00	---
26	171	ATIL	400KV-TIRODA-WARORA-1	Daily	Annual maintenance of line	3-Feb-22	08:00	3-Feb-22	18:00	Annual maintenance of line
27	172	ATIL	400KV-TIRODA-WARORA-2	Daily	Auto reclosure off	3-Feb-22	08:00	3-Feb-22	18:00	Auto reclosure off
28	184	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	Continuous	Tan Delta of 245 kV CT which is under Monitoring due to rising trend of Tan delta	3-Feb-22	08:00	3-Feb-22	20:00	Outage is required in daytime due to testing result constraints & there is no power restriction due to this proposed Filter Outage
29	187	MSETCL	400KV-EKTUNI-BABLESHWAR-1	Daily	CT, CB relay testing work & 29D & 29C Isolator repairing work and Line maintenance work	3-Feb-22	09:00	3-Feb-22	17:00	400kV Ektuni ckt II,400kV Bhusawal, Dhule I&II and 400kV Aurangabad will be in in service
30	188	MSETCL	400KV-WARDHA-KORADI-II-1	Daily	Routine Maintenance & Dignostic testing work.	3-Feb-22	09:00	3-Feb-22	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
31	190	POWERGRID_WR2	400KV-KALA-KUDUS-2	Daily	AMP works at Kala. Also, line AMP works. A/R OFF on ckt-1	3-Feb-22	9:00	3-Feb-22	17:30	PG-WR2-Kala
32	204	MSETCL	NANDED - 400KV - BUS 1	Continuous	Bus CVT Testing, Bus Isolator Maintenance & Relay Routine Testing.	3-Feb-22	10:30	3-Feb-22	18:00	-
33	231	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	4-Feb-22	08:00	4-Feb-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
34	243	MSETCL	400KV-EKTUNI-BABLESHWAR-2	Daily	CT, CB relay testing work & 29D & 29C Isolator repairing work.	4-Feb-22	09:00	4-Feb-22	17:00	400kV Ektuni ckt I,400kV Bhusawal, Dhule I&II and 400kV Aurangabad will be in in service
35	247	POWERGRID_WR2	400KV-KALA-KUDUS-1	Daily	AMP works at Kala. Also, line AMP works. A/R OFF on ckt-2	4-Feb-22	9:00	4-Feb-22	17:30	PG-WR2-Kala
36	250	MEGPTCL	Tie Bay - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - Bus 1	Daily	Annual Maintenance of Bay Equipments	4-Feb-22	09:00	4-Feb-22	18:00	Annual Maintenance of Bay Equipments
37	285	MSETCL	400KV-KALWA-KHARGHAR-1	Daily	All diagnostic testing work, Bay maintenance work. CB, DCRM /Timing testing work.	5-Feb-22	08:00	5-Feb-22	17:00	All diagnostic testing work, Bay maintenance work. CB, DCRM /Timing testing work.
38	288	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	5-Feb-22	08:00	5-Feb-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
39	296	GETCO	220kV Navsari-Nashik line no.2	Daily	Bay maintance Work	5-Feb-22	9:00	5-Feb-22	18:00	
40	303	MSETCL	JEJURI - 400KV - BUS 1	Daily	Faulty Insulator string replacement, Annual Testing, Maintenance, CTR repairs work	5-Feb-22	09:30	5-Feb-22	17:30	400/220/33kV 501MVA ICT-II & ICT-III will be in service through 400kV Main bus-II.
41	306	MSETCL	765KV/400KV EKTUNI-ICT-1	Daily	Diagnostic Testing & Routine Maintainence work	5-Feb-22	10:00	5-Feb-22	18:30	1500MVA ICT-II Will be in service
42	308	MSETCL	BOISAR-M - 220KV - BUS 1	Continuous	Bus Maintenance works. 220 KV Boisar-Boisar(PG) ckt-1 & 2 shifted on BUS-2 through TBC	5-Feb-22	06:00	6-Feb-22	19:00	Bus Maintenance works.

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/contin uous	Reason	From	time	to	Time	Remarks
43	310	POWERGRID_WR1	220kV Wardha-Pusad MSETCL line	Daily	Loc. 03 Wardha-Warora new tower erection for TL diversion works associated with Bus-splitting Scheme	5-Feb-22	7:00	10-Feb-22	19:00	
44	316	POWERGRID_WR1	220KV-TALEGAON-PUNE-PG-2	Daily	For AMP works.	6-Feb-22	8:30	6-Feb-22	18:00	
45	318	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-BOISAR-M-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	Daily	For Isolator Servicing. Outage of 220kV Bus-2 is required	6-Feb-22	6:00	6-Feb-22	10:00	PG-WR2-Boisar
46	319	POWERGRID_WR2	BOISAR - 220KV - BUS 2	Daily	For Isolator Servicing	6-Feb-22	6:00	6-Feb-22	18:00	PG-WR2-Boisar
47	321	MSETCL	400KV-KALWA-PADGHE-2	Daily	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity.	6-Feb-22	09:00	6-Feb-22	18:00	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity.
48	322	MSETCL	220KV-BOISAR-NALASOPARA-1	Daily	For Bay Mintanance at Nalasopara & Line maintenance by Line Maint S/D. Boisar Unit	6-Feb-22	09:00	6-Feb-22	18:00	For Bay Mintanance at Nalasopara & Line maintenance by Line Maint S/D. Boisar Unit
49	323	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-NALASOPARA-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	Daily	For Isolator Servicing. Outage of 220kV Bus-2 is required	6-Feb-22	10:00	6-Feb-22	14:00	PG-WR2-Boisar
50	324	MSETCL	220KV-TALEGAON-PUNE-PG-2	Daily	Half yearly maintenance, Diagnostic Testing.	6-Feb-22	10:00	6-Feb-22	18:00	---
51	325	MSETCL	765KV/400KV EKTUNI-ICT-2	Daily	Diagnostic Testing & Routine Maintainence work	6-Feb-22	10:00	6-Feb-22	18:30	1500MVA ICT-I Will be in service
52	347	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	7-Feb-22	08:00	7-Feb-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
53	354	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-2	Daily	For AMP of line terminal equipment work at Akola SS. AR to be kept in non Auto mode for 400kV Akola-Aurangabad-I	7-Feb-22	8:00	7-Feb-22	18:00	
54	355	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-2 L/R@ AKOLA - 400KV	Daily	For AMP of Reactor work at Akola SS.	7-Feb-22	8:00	7-Feb-22	18:00	
55	361	MSETCL	MAIN BAY OF 400KV-KUDUS-PADGHE-1 AND KUDUS - 400KV - BUS 2 @KUDUS - 400KV at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work.	7-Feb-22	09:00	7-Feb-22	17:00	Simultaneously outage is required on TIE BAY (402) OF KALA CKT - 2 @ KUDUS for line CT testing work.
56	362	MSETCL	Tie Bay - 400KV-KALA-KUDUS-2 AND FUTURE	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	7-Feb-22	09:00	7-Feb-22	17:00	Simultaneously outage is required on MAIN BAY (403) OF FUTURE LINE @ KUDUS for line CT testing work.
57	363	MSETCL	400KV-KOLHAPUR-MS-ALKUD-1	Daily	QM Work	7-Feb-22	09:00	7-Feb-22	17:00	Load will be managed on Alkud-Solapur Line
58	384	MEGPTCL	AKOLA (2) - 400KV - BUS 1	Daily	Annual Maintenance of Bus Equipments	7-Feb-22	10:00	7-Feb-22	15:00	Annual Maintenance of Bus Equipments
59	385	MSETCL	220KV-Wardha-WARDHA-M-1	Daily	Routine line maintenance work	7-Feb-22	10:00	7-Feb-22	18:00	NA
60	388	APML-ADANI	400KV/11.5KV TIRODA-ST-1	Continuous	Bay equipment and Transformer Maintenance	7-Feb-22	8:00	8-Feb-22	18:00	Bay & Transformer Outage
61	393	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1(ON TBC)	Continuous	CB Maintenance works by shifting the line on TBC.	7-Feb-22	08:00	8-Feb-22	19:00	CB Maintenance works by shifting the line on TBC.
62	403	MSETCL	400KV-RGPPL-NEW KOYNA-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	7-Feb-22	08:00	12-Feb-22	18:00	---
63	404	GETCO	220kV Navsari-Nashik line no.1	Continuous	220kV Areva make Breaker overhauling work	7-Feb-22	9:00	12-Feb-22	18:00	

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/contin uous	Reason	From	time	to	Time	Remarks
64	412	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-1	Daily	AMP OF PADGHE KUDUS LINE 1 EQUIPMENTS/RELAY TESTING AT PADGHE/KUDUS END. AR to be kept in non Auto mode for 400kV Padghe Kudus-II	8-Feb-22	7:00	8-Feb-22	17:00	
65	427	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	8-Feb-22	08:00	8-Feb-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
66	428	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	8-Feb-22	08:00	8-Feb-22	18:00	NA
67	430	NCA	400KV SSP - DHULE-II	Daily	CVT oil level checking & Preventive maintenance & switchyard Maintenance	8-Feb-22	8:00	8-Feb-22	18:00	A/R swich of Dhule-I is to be put on Non Auto
68	437	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1	Daily	For AMP of line terminal equipment work at Akola SS. AR to be kept in non Auto mode for 400kV Akola-Aurangabad-II	8-Feb-22	8:00	8-Feb-22	18:00	
69	438	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1 L/R@ AKOLA - 400KV	Daily	For AMP of Reactor work at Akola SS.	8-Feb-22	8:00	8-Feb-22	18:00	
70	439	POWERGRID_WR1	400KV-KORADI-SATPURA-1	Daily	For AMP of Line Terminal equipments	8-Feb-22	8:00	8-Feb-22	18:00	
71	448	MSETCL	Tie Bay of 400KV-KALA-KUDUS-1 AND FUTURE @KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work.	8-Feb-22	09:00	8-Feb-22	17:00	Simultaneously Outage on MAIN BAY (406) OF FUTURE CKT @ KUDUS is required for line CT testing work.
72	449	MSETCL	MAIN BAY - 400KV-KUDUS-FUTURE-1 AND KUDUS - 400KV - BUS 2 at KUDUS - 400KV	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	8-Feb-22	09:00	8-Feb-22	17:00	Simultaneously Outage on TIE BAY (405) OF KALA CKT - 1 @ KUDUS is required for line CT testing work.
73	450	MSETCL	ALKUD - 400KV - BUS 1	Daily	QM Work	8-Feb-22	09:00	8-Feb-22	17:00	Load will be managed on 400KV Main Bus-2
74	457	MEGPTCL	Tie Bay -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-TIRODA-KORADI-III-1	Daily	Annual Maintenance of Bay Equipments	8-Feb-22	09:00	8-Feb-22	18:00	Annual Maintenance of Bay Equipments
75	471	MSETCL	220KV-Wardha-BADNERA-1	Daily	Routine line maintenance work	8-Feb-22	10:00	8-Feb-22	18:00	NA
76	473	MSETCL	MAIN BAY - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 400KV - BUS 2 at EKTUNI - 400KV	Daily	"Daignostic Testing & Routine Maintainence"	8-Feb-22	11:00	8-Feb-22	18:00	ICT-I IV will be in service through its TIE (409) Bay & 400kV Main Bus-I
77	476	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Cold washing work	8-Feb-22	08:00	9-Feb-22	18:00	Planned outage
78	479	JPTL	400KV-KARAD-JAIGAD-1	Daily	Online work for hotline washing of insulator strings	8-Feb-22	09:00	9-Feb-22	18:00	A/R for ckt-1 to be kept into non auto mode during Hotline Washing.
79	480	JPTL	400KV-KARAD-JAIGAD-2	Daily	Online work for hotline washing of insulator strings	8-Feb-22	09:00	9-Feb-22	18:00	A/R for Ckt-2 to be kept into non auto mode during Hotline Washing.
80	490	MSETCL	400KV/220KV PARLI-M-ICT-2 (ON TBC)	Continuous	Overhauling of 400kV Circuit Breaker (CGL Make) of 400/220kV, 315 MVA ICT-2 @ Girwali	8-Feb-22	08:00	16-Feb-22	18:00	400/220kV, 315 MVA ICT-2 will remain charged through TBC
81	495	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-2	Daily	AMP OF PADGHE KUDUS LINE 1 EQUIPMENTS/RELAY TESTING AT PADGHE/KUDUS END. AR to be kept in non Auto mode for 400kV Padghe Kudus-I	9-Feb-22	7:00	9-Feb-22	17:00	
82	502	MSETCL	BUS COUPLER @ NAGOTHANE(Element not aaded in WRLDC outage portal)	Daily	DCRM and tan delta testing	9-Feb-22	08:00	9-Feb-22	17:00	NA
83	503	MSETCL	220KV-PARLI-PARLI-M-2	Daily	LINE maintenance	9-Feb-22	08:00	9-Feb-22	17:00	-
84	509	MSETCL	220KV-WARDHA-BHUGAON-1	Daily	Routine line maintenance work	9-Feb-22	08:00	9-Feb-22	18:00	NA

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/continuous	Reason	From	time	to	Time	Remarks
85	522	MSETCL	MAIN BAY (409) OF FUTURE CKT @ KUDUS(Element not added WRLDC outage portal)	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work	9-Feb-22	09:00	9-Feb-22	16:00	Simultaneously outage is required on TIE BAY OF (408) OF ICT-1 AND FUTURE CKT @ KUDUS for line CT testing work.
86	523	MSETCL	TIE BAY OF (408) OF ICT-1 AND FUTURE CKT @ KUDUS(Element not added on WRLDC outage portal)	Daily	Annual Maintenance of bays equipment & Diagnostics Testing Work.	9-Feb-22	09:00	9-Feb-22	17:00	Simultaneously outage is required on MAIN BAY (409) OF FUTURE CKT @ KUDUS for line CT testing work.
87	524	MSETCL	400KV-WARORA-CHANDRAPU-II-2	Daily	R Phase Line CVT replacement by agency and Diagnostic testing work of CVT.	9-Feb-22	09:00	9-Feb-22	17:00	Load will managed by 400KV WARORA-CHANDRAPUR 2 CKT. 1 Bay no 413.
88	525	MSETCL	220KV-PANDURNA-KALMESHVAR-1	Daily	Routine Maintenance & Dignostic testing work	9-Feb-22	09:00	9-Feb-22	17:00	NA
89	526	MSETCL	132KV-PENCH-MP-KANHAN-1	Daily	Routine Maintenance work.	9-Feb-22	09:00	9-Feb-22	17:00	NA
90	531	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	routine maintenance	9-Feb-22	09:00	9-Feb-22	18:00	-
91	532	MSETCL	JEUR - 220KV - BUS 1	Daily	An outage is required for Quarterly maintenance . During outage JEUR - SOLAPUR PG and JEUR - TEMBHURNI LINE CB hand tripped from JEUR END	9-Feb-22	09:00	9-Feb-22	18:00	Quarterly maintenance. NOC required from MSDDL
92	533	MSETCL	220KV-SOLAPUR-JEUR-1	Daily	An outage is required for Quarterly maintenance . During outage JEUR - SOLAPUR PG and JEUR - TEMBHURNI LINE CB hand tripped from JEUR END	9-Feb-22	09:00	9-Feb-22	18:00	Quarterly maintenance. NOC required from MSDDL
93	534	MSETCL	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	Daily	routine maintenance	9-Feb-22	09:00	9-Feb-22	18:00	-
94	535	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	Daily	routine maintenance	9-Feb-22	09:00	9-Feb-22	18:00	-
95	548	MEGPTCL	765KV-AKOLA (2)-KORADI-III-1	Daily	Annual Maintenance of Line Equipments	9-Feb-22	09:00	9-Feb-22	19:00	Annual Maintenance of Line Equipments
96	551	MSETCL	SOLAPUR-M - 400KV - BUS 1	Daily	Diagnostic Testing Work	9-Feb-22	10:00	9-Feb-22	13:00	Without Load Interruption. Load will be managed by 400kV Main Bus II.
97	556	MSETCL	SOLAPUR-M - 400KV - BUS 2	Daily	Diagnostic Testing Work	9-Feb-22	14:00	9-Feb-22	17:00	Without Load interruption. Load will be managed by 400kV Main Bus I
98	558	APML-ADANI	400KV/11.5KV TIRODA-ST-2	Continuous	Bay equipment and Transformer Maintenance	9-Feb-22	8:00	10-Feb-22	18:00	Bay & Transformer Outage
99	574	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintainance Work	10-Feb-22	07:00	10-Feb-22	18:00	Shifting of auto reclose switch to non auto mode, for fixing of fiber insulation cap type bird waste deposition guard by AEE LMSDN Pusad from 8:00
100	578	MSETCL	400KV-WARORA-CHANDRAPU-II-2	Daily	For conductor & Earthwire H/W tightening work	10-Feb-22	08:00	10-Feb-22	17:00	400Kv Chandrapur2-Warora ckt-I will be in service
101	582	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	10-Feb-22	08:00	10-Feb-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
102	583	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	10-Feb-22	08:00	10-Feb-22	18:00	NA
103	598	MSETCL	400KV-LONIKHAND-CHAKAN-1	Daily	Diagnostic testing and maintenance activities.	10-Feb-22	09:00	10-Feb-22	18:00	---
104	600	MP_SLDC	220KV-PANDHURNA-MP-KALMESHVAR-MH	Daily	FOR LINE MAINTENANCE WORK	10-Feb-22	9:00	10-Feb-22	18:00	
105	607	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	Hardware Tightening & Fitting work	10-Feb-22	09:30	10-Feb-22	18:30	-

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/continuous	Reason	From	time	to	Time	Remarks
106	609	MSETCL	400KV-WARORA-CHANDRAPU-II-1	Daily	Daignostic testing work	10-Feb-22	10:00	10-Feb-22	17:00	Daignostic testing work
107	613	MSETCL	Tie Bay - 400KV-EKTUNI-BABLESHWAR-1 AND FUTURE	Daily	"Daignostic Testing & Routine Maintainece "	10-Feb-22	11:00	10-Feb-22	18:00	400kV Bhabaleshwar ckt-1 will be in service through its Main (411) Bay & Main Bus-1
108	619	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Cold washing work	10-Feb-22	08:00	11-Feb-22	18:00	Planned outage
109	625	JPTL	400KV-JAIGAD-NEW KOYNA-2	Daily	Online work for hotline washing of insulator strings	10-Feb-22	09:00	11-Feb-22	18:00	A/R for Ckt-2 to be kept into non auto mode during Hotline Washing.
110	626	JPTL	400KV-JAIGAD-NEW KOYNA-1	Daily	Online work for hotline washing of insulator strings	10-Feb-22	09:00	11-Feb-22	18:00	Hotline Washing.
111	640	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	Daily	AMP of Line /Bay Equipment/ Updating Siemens Distance Relay to Comply IEC61850 and Resolving Front Port Communication Issue of M1 Relay of Padghe Boisar Line at Padghe MSETCL SS.	11-Feb-22	7:00	11-Feb-22	17:00	
112	645	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	earth wire Replacement and jumper tightening work	11-Feb-22	08:00	11-Feb-22	17:00	NA
113	647	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	11-Feb-22	08:00	11-Feb-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
114	648	MSETCL	220KV-WARDHA-PUSAD-1	Daily	Routine line maintenance work	11-Feb-22	08:00	11-Feb-22	18:00	NA
115	664	MEGPTCL	KORADI-III - 765KV - BUS 1	Daily	Annual Maintenance of Bus Equipments	11-Feb-22	09:00	11-Feb-22	18:00	Annual Maintenance of Bus Equipments
116	665	MSETCL	220KV-NASIK-NAVSARI-1	Daily	Bay maint. & any abnormalities observed attending,other works if any required to be carried out will be covered during this outage. Line maintenance work	11-Feb-22	09:00	11-Feb-22	18:00	-
117	680	APML-ADANI	400KV/11.5KV TIRODA-ST-3	Continuous	Bay equipment and Transformer Maintenance	11-Feb-22	8:00	12-Feb-22	18:00	Bay & Transformer Outage
118	688	MSETCL	PADGHE - 400KV - BUS 2	Continuous	1) B- Bus conductor replacement work (partial Bus outage) 2) Replacement of PG isolator under LES scheme	11-Feb-22	00:02	13-Feb-22	23:59	1) Agency will be present on site 2) Details of partial bus configuration under outage will be submitted on D-3 basis..
119	690	MSETCL	400KV/220KV NEW KOYNA-ICT-2(ON TBC)	Continuous	C.B. Overhauling work Shitting on TBC	11-Feb-22	08:00	18-Feb-22	18:00	----
120	691	MSETCL	400KV-KALWA-PADGHE-2	Daily	PID Testing Auto-Reclose function to be out of service.	11-Feb-22	09:00	19-Feb-22	18:00	PID Testing Auto-Reclose function to be out of service.
121	695	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-1	Daily	AMP OF 400 KV Padghe Tarapur-1 Line Equipment/ CT Replacement at Padghe MSETCL SS.	12-Feb-22	7:00	12-Feb-22	17:00	
122	696	MSETCL	220KV-BOISAR-BOISAR-M-2	Daily	Bay Maintenance works.	12-Feb-22	07:00	12-Feb-22	18:00	Bay Maintenance works.
123	697	POWERGRID_WR1	220KV-AURANGABAD-CHITEGAON-1	Daily	207L Bay AMP Works	12-Feb-22	7:00	12-Feb-22	18:00	
124	698	MSETCL	400KV-WARORA-CHANDRAPU-II-1	Daily	For conductor & Earthwire H/W tightening work	12-Feb-22	08:00	12-Feb-22	17:00	400Kv Chandrapur2-Warora ckt-II will be in service
125	704	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	12-Feb-22	08:00	12-Feb-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/continuous	Reason	From	time	to	Time	Remarks
126	717	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-1	Continuous	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	12-Feb-22	08:00	13-Feb-22	18:00	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line. NOC from Ratan India required.
127	718	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-2	Continuous	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line.	12-Feb-22	08:00	13-Feb-22	18:00	To attend the sag corection in tower no. 534 of 765KV-AKOLA (2)-KORADI-III-2 to stop the deformaing of tower member in the first section. The 400KV-RPL-AKOLA (2)-1 is crossing in between T.No. 534 & 535 of 765kV Line. NOC from Ratan India required.
128	728	POWERGRID_WR1	400KV-KHARGHAR-PUNE-PG-1	Daily	For AMP works.	13-Feb-22	8:30	13-Feb-22	18:00	
129	730	MSETCL	220KV-BOISAR-BOISAR-M-3	Daily	Bay Maintenance works.	13-Feb-22	07:00	13-Feb-22	18:00	Bay Maintenance works.
130	731	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	"Diagnostic and R&M Work. MTAMC project related work"	13-Feb-22	08:00	13-Feb-22	18:00	NA
131	732	MSETCL	WARORA - 400KV - BUS 1	Daily	Routine maintenance and dagnostic testing such as CVT/ CT tan delta, and, isolater maintenance work	13-Feb-22	08:00	13-Feb-22	18:00	2-DURING OUTAGE REACTOR WILL IN OFF CONDITION
132	733	MSETCL	400KV-KALWA-PADGHE-1	Daily	1) Corona line cleaning, Chemical cleaning of insulators and routine Maintenance Activity. 2) All diagnostic testing work, Bay maintenance work. CB, DCRM /Timing testing work at 400KV DS Kalwa Station.	13-Feb-22	08:00	13-Feb-22	18:00	Insulators and Routine Maintenance Activity. 2) All diagnostic testing work, Bay maintenance work. CB, DCRM /Timing testing work at 400KV
133	734	MSETCL	220KV-TARAPUR 1&2-BORIVALI-1	Daily	Maintenance Work of Line	13-Feb-22	09:00	13-Feb-22	17:00	Maintenance Work of Line
134	735	MSETCL	220KV-TALEGAON-PUNE-PG-1	Daily	Half yearly maintenance, Diagnostic Testing.	13-Feb-22	10:00	13-Feb-22	18:00	---
135	738	POWERGRID_WR1	400KV-KALA-KUDUS-1	Daily	AMP OF KALA KUDUS LINE 1 EQUIPMENTS/RELAY TESTING AT KUDUS END.	13-Feb-22	7:00	13-Feb-22	17:00	
136	747	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	14-Feb-22	08:00	14-Feb-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
137	762	MSETCL	400KV-ALKUD-SOLAPUR-1	Daily	QM work	14-Feb-22	09:00	14-Feb-22	17:00	Load will be managed on 400KV Alkud-Kolhapur Line
138	775	APML-ADANI	400KV/11.5KV TIRODA-ST-4	Continuous	Bay equipment and Transformer Maintenance	14-Feb-22	8:00	15-Feb-22	18:00	Bay & Transformer Outage
139	784	MSETCL	400KV-RGPPL-NAGOTHANE-1	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	14-Feb-22	08:00	19-Feb-22	18:00	---
140	788	MSETCL	400KV-SOLAPUR-M-SOLAPUR-1	Daily	PID testing	14-Feb-22	09:00	22-Feb-22	17:00	PID testing
141	801	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	15-Feb-22	08:00	15-Feb-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
142	810	POWERGRID_WR1	PUNE-PG - 220KV - BUS 2	Daily	For AMP works.	15-Feb-22	8:30	15-Feb-22	18:00	
143	812	MSETCL	ALKUD - 400KV - BUS 2	Daily	QM Work	15-Feb-22	09:00	15-Feb-22	17:00	Load will be managed on 400KV Main Bus 1
144	817	MEGPTCL	KORADI-III - 765KV - BUS 2	Daily	Annual Maintenance of Bus Equipments	15-Feb-22	09:00	15-Feb-22	18:00	Annual Maintenance of Bus Equipments
145	824	MSETCL	400KV-EKTUNI-BABLESHWAR-1	Daily	Replacement of Cut-Point Disc Insulator, Damaged nut bolts, corona Ring.	15-Feb-22	09:30	15-Feb-22	18:30	400kV Ektuni-Bhableshtar Ckt-II will be in service

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/continuous	Reason	From	time	to	Time	Remarks
146	826	MSETCL	400KV-RGPPL-NEW KOYNA-1	Daily	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work	15-Feb-22	08:00	16-Feb-22	18:00	Planned outage
147	841	MSETCL	220KV-PARLI-OSMANABAD-M-1	Daily	LINE maintenance	16-Feb-22	08:00	16-Feb-22	17:00	-
148	842	POWERGRID_WRI	Main Bay - 400KV PADGHE KUDUS -2 AND KUDUS- BUS -2 at KUDUS-400KV	Daily	AMP OF 418 Main Bay of 400 KV Padghe Line 2 and Bus 2 at Kudus MSETCL SS.	16-Feb-22	8:00	16-Feb-22	17:00	
149	846	GETCO	400KV-SSP-DHULE-MS-1	Daily	PMM. Auto reclose of 400 kV SSP-Dhule 2 will remain out.	16-Feb-22	8:00	16-Feb-22	18:00	Non auto reclose code for 400kv SSP-Dhule no-2 is to be required.
150	856	MSETCL	132KV-MANSAR-MS-PENCH-1	Daily	Routine Maintenance work.	16-Feb-22	09:00	16-Feb-22	17:00	NA
151	860	MSETCL	400KV-PARLI-M-SOLAPUR-M-1	Daily	Faulty string replacement	16-Feb-22	09:00	16-Feb-22	18:00	400kV Lamboti-Solapur(PG) in service
152	861	MSETCL	220KV-TILLARI-AMONA-1	Daily	routine maintenance	16-Feb-22	09:00	16-Feb-22	18:00	-
153	870	MSETCL	400KV-EKTUNI-BABLESHWAR-2	Daily	Replacement of Cut-Point Disc Insulator, Damaged nut bolts, corona Ring.	16-Feb-22	09:30	16-Feb-22	18:30	400kV Ektuni-Bhabaleshwar Ckt-I will be in service
154	871	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-1	Daily	Annual Maintenance of Line Equipments	16-Feb-22	09:30	16-Feb-22	18:30	Annual Maintenance of Line Equipments
155	872	MSETCL	AKOLA - 400KV - BUS 1	Daily	Routine maintenance and testing work	16-Feb-22	10:00	16-Feb-22	17:00	400KV Main Bus-02 will be in service
156	877	APML-ADANI	400KV/11.5KV TIRODA-ST-5	Continuous	Bay equipment and Transformer Maintenance	16-Feb-22	8:00	17-Feb-22	18:00	Bay & Transformer Outage
157	879	MSETCL	400KV-KOLHAPUR-MS-ALKUD-1	Daily	PID testing work	16-Feb-22	09:00	17-Feb-22	17:00	AR to be kept out of service for PID Testing
158	881	MSETCL	JEJURI - 400KV - BUS 1	Daily	PID testing and insulator string replacement work.	16-Feb-22	09:30	22-Feb-22	17:30	All Lines & ICTs will be in service.
159	883	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	PID Testing work	16-Feb-22	08:00	28-Feb-22	18:00	-
160	885	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintenance Work	17-Feb-22	07:00	17-Feb-22	18:00	Shifting of auto reclose switch to non auto mode, for fixing of fiber insulation cap type bird waste deposition guard by AEE LMSDN Yavatmal from
161	888	GETCO	400KV-SSP-DHULE-MS-2	Daily	PMM. Auto reclose of 400 kV SSP-Dhule 1 will remain out.	17-Feb-22	8:00	17-Feb-22	18:00	Non auto reclose code for 400kv SSP-Dhule no-1 is to be required.
162	894	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	earth wire Replacement and jumper tightening work	17-Feb-22	08:00	17-Feb-22	17:00	NA
163	899	MSETCL	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV - BUS 2 at BABLESHWAR - 400KV	Daily	Relay,Bushing, CT,CB Diagnostic testing & bay maintenance work	17-Feb-22	08:00	17-Feb-22	18:00	400kV Main Bus I & II will be seperated.
164	900	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	17-Feb-22	08:00	17-Feb-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
165	909	MSETCL	MAIN BAY (420) OF WARDHA (PG) CKT @ WARORA(Element not added in WRLDC outage portal)	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	17-Feb-22	09:00	17-Feb-22	17:00	Line will charged through tie bay no 421.
166	913	MSETCL	400KV-PARLI-M-LONIKHAND-II-1	Daily	1) C & tan delta measurement of reactor. (2)Bay maintenance work. 2)Hardware Tightening and Fitting Work.	17-Feb-22	09:00	17-Feb-22	18:00	-

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/contin uous	Reason	From	time	to	Time	Remarks
167	920	MSETCL	NANDED - 400KV - BUS 2	Continuous	Bus CVT Testing, Bus Isolator Maintenance & Relay Routine Testing.	17-Feb-22	10:30	17-Feb-22	18:00	-
168	925	MSETCL	400KV-RGPPL-NEW KOYNA-2	Daily	Cold washing work, Diagnostic testing & Relay testing work & Routine maint. Work	17-Feb-22	08:00	18-Feb-22	18:00	Planned outage
169	945	POWERGRID_WR1	220KV-SOLAPUR-KUMBARI-2	Daily	Line side equipments AMP	18-Feb-22	7:00	18-Feb-22	18:00	
170	956	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	18-Feb-22	08:00	18-Feb-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
171	960	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	Daily	For AMP of line terminal equipment work at Akola SS.	18-Feb-22	8:00	18-Feb-22	18:00	
172	965	MSETCL	400KV-BABLESHWAR-PADGHE-2	Daily	Line maintenance work Replacement of PID faulty insulators and CT, CB relay testing work, quarterly maintenance work	18-Feb-22	09:00	18-Feb-22	17:00	400kV Padghe I will be in service
173	976	MSETCL	BUS COUPLER BAY - PADGHE - 400KV - BUS 1 AND PADGHE - 400KV - BUS 2 at PADGHE - 400KV	Daily	1) Bay maintenance work 2) Diagnostic testing work 3) PG Isolator replacement work under LES scheme .Hanger Rod replacement by Hotline Method 4) MTAMC work	18-Feb-22	09:00	18-Feb-22	19:00	1) Agency will be present on site 2) weather condition should be clear 3) Hotline team will be present on site
174	984	MSETCL	400KV/11.5KV CHANDRAPUR-GCR-ST-4	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I. 3) Measurement of Timing, CRM and DCRM of CB.	18-Feb-22	04:00	20-Feb-22	18:00	Outage required to disconnect old bus jumpers and reconnect the new bus jumpers. During outage, STN TF no.- 3 & 5 will be in service and load of STN TF no.-4 will be shifted on STN TF no.- 3 & 5.
175	985	MSETCL	CHANDRAPUR - 400KV - BUS 1	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	18-Feb-22	04:00	20-Feb-22	18:00	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
176	986	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I.	18-Feb-22	04:00	20-Feb-22	18:00	During outage, all connected bays/feeders of Main Bus-I will be shifted to Main Bus-II by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-I on 400KV Main Bus-II, then after the 400KV Bus Coupler bay will be kept off.
177	987	MSETCL	400KV-CHANDRAPUR-BHADRAWATI-3	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I. 3) Measurement of Timing, CRM and DCRM of CB.	18-Feb-22	04:00	20-Feb-22	18:00	Outage is required on 400KV GCR C'pur - PGCIL Bhadrawati Ckt. No.- 3 line, as the this circuit can not be shifted on 400KV Main Bus-2 due to problems of PG isolators of Bus-2 .
178	988	MSETCL	400KV-CHANDRAPUR-BHADRAWATI-4	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-I in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-I. 3) Measurement of Timing, CRM and DCRM of CB.	18-Feb-22	04:00	20-Feb-22	18:00	Outage is required on 400KV GCR C'pur - PGCIL Bhadrawati Ckt. No.- 4 line, as the this circuit can not be shifted on 400KV Main Bus-2 due to problems of PG isolators of Bus-2 .
179	989	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	Providing additional twin conductor jumps at all cut points.	18-Feb-22	08:00	20-Feb-22	18:00	---
180	990	POWERGRID_WR1	CHANDRAPUR-GCR - 400KV - BUS 1	Continuous	Replacement of BUS 1 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	18-Feb-22	8:00	20-Feb-22	18:00	
181	991	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-3	Continuous	Replacement of BUS 1 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	18-Feb-22	8:00	20-Feb-22	18:00	

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/continuous	Reason	From	time	to	Time	Remarks
182	992	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-4	Continuous	Replacement of BUS 1 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	18-Feb-22	8:00	20-Feb-22	18:00	
183	993	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2(ON TBC)	Continuous	1) Dismantled 4" IPS tube of R, Y & B-ph PG-1 Isolator required for replacement of jumpers of quadraple bus conductor of Main Bus-I	18-Feb-22	14:00	20-Feb-22	16:00	service via TBC-2. Please Note: 1. Shifting of 400KV HVDC Ckt. no.-2 bay on TBC-2 bay 2.Shifting of 400KV HVDC Ckt. no.-2 bay from
184	994	MSETCL	400KV/21KV CHANDRAPUR-GT-6(ON TBC)	Continuous	span. 2)Tightening of nut bolts & hardware of Main Bus-I. 3) Measurement of Timing, CRM and DCRM of CB.	18-Feb-22	16:00	20-Feb-22	16:00	During outage, GT-6 bay will be in service via TBC-2.
185	999	POWERGRID_WR1	220KV-AURANGABAD-SHENDRA-1	Daily	208L Bay AMP Works	19-Feb-22	7:00	19-Feb-22	18:00	
186	1012	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	DT/Line Maintenance.	19-Feb-22	08:00	19-Feb-22	18:00	---
187	1013	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	19-Feb-22	08:00	19-Feb-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
188	1019	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	Daily	For AMP of line terminal equipment work at Akola SS.	19-Feb-22	8:00	19-Feb-22	18:00	
189	1020	MSETCL	400KV-BABLESHWAR-PADGHE-1	Daily	Line maintenance work Replacement of PID faulty insulators and CT, CB relay testing work, quarterly maintenance work	19-Feb-22	09:00	19-Feb-22	17:00	400kV Padghe II will be in in service
190	1025	MSETCL	220KV-BOISAR-BOISAR-M-1(ON TBC)	Continuous	CB Maintenance works by shifting the line on TBC	19-Feb-22	07:00	20-Feb-22	18:00	CB Maintenance works by shifting the line on TBC
191	1029	MSETCL	400KV-KOYNA STAGE IV-NEW KOYNA-2(ON TBC)	Continuous	C.B. Overhauling work Shitting on TBC	19-Feb-22	08:00	26-Feb-22	18:00	----
192	1035	POWERGRID_WR1	400KV-KALA-KUDUS-2	Daily	AMP OF KALA KUDUS LINE 2 EQUIPMENTS/RELAY TESTING AT KUDUS END.	20-Feb-22	7:00	20-Feb-22	17:00	
193	1041	MSETCL	220KV-BOISAR-BORIVALI-1	Daily	Maintenance Work of Line	20-Feb-22	09:00	20-Feb-22	17:00	Maintenance Work of Line
194	1042	MSETCL	400KV-KHARGHAR-PUNE-PG-1	Daily	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity	20-Feb-22	09:00	20-Feb-22	18:00	Cold line cleaning, Chemical cleaning of Insulators and Routine Maintenance Activity
195	1043	MSETCL	400KV-KALWA-PADGHE-1	Daily	2) Diagnostic Testing work 3) MTAMC work 4) Replacement of PG isolator under LES scheme	20-Feb-22	09:00	20-Feb-22	19:00	1) Agency will be present on site
196	1044	WTPL-ADANI	400KV-PARLI-SOLAPUR-2	Daily	Line outage required for spacers correction in the span of 210 to 212, 215 to 217, 241 to 244.	20-Feb-22	10:00	20-Feb-22	18:00	Line outage
197	1045	WTPL-ADANI	400KV-PARLI-SOLAPUR-1	Daily	AR to be kept OFF for safety purpose during 400KV-PARLI-SOLAPUR-2 outage.	20-Feb-22	10:00	20-Feb-22	18:00	AR Mode OFF
198	1046	MSETCL	400KV/21KV CHANDRAPUR-GT-6	Continuous	To made available the TBC-2 bay free which is required for replacement of bus conductor of Main Bus-1.	20-Feb-22	16:00	20-Feb-22	17:00	required for replacement of bus conductor of Main Bus-1.
199	1071	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	21-Feb-22	08:00	21-Feb-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
200	1090	MEGPTCL	400KV-AKOLA (2)-NANDGAONPETH-2	Daily	Annual Maintenance of Line Equipments	21-Feb-22	09:30	21-Feb-22	18:30	Annual Maintenance of Line Equipments
201	1106	MSETCL	400KV/220KV AURANGABAD-M (WALUJ)-ICT-1	Continuous	1) ICT Painting Work 2)Diagnostic Testing Work 3) Routine Maintenance Work	21-Feb-22	10:00	24-Feb-22	18:00	M/s. Jaidurga Agency will carry out ICT painting work
202	1110	MSETCL	400KV-RGPPL-NAGOTHANE-2	Daily	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	21-Feb-22	08:00	26-Feb-22	18:00	---

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/continuous	Reason	From	time	to	Time	Remarks
203	1114	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	PID Testing Auto-Reclose function to be out of service.	21-Feb-22	09:00	28-Feb-22	18:00	PID Testing Auto-Reclose function to be out of service.
204	1126	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	22-Feb-22	08:00	22-Feb-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
205	1135	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	Daily	Annual Maintenance of Bay Equipments	22-Feb-22	09:00	22-Feb-22	18:00	Annual Maintenance of Bay Equipments
206	1141	MSETCL	EKTUNI - 765KV - BUS 2	Daily	Diagnostic Testing & Routine Maintenance work	22-Feb-22	10:30	22-Feb-22	18:30	765kV Main Bus-1 will be in service
207	1150	MSETCL	400KV/11.5KV CHANDRAPUR-GCR-ST-4	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-2 in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-2.	22-Feb-22	04:00	24-Feb-22	18:00	Outage required to disconnect old bus jumpers and reconnect the new bus jumpers. During outage, STN TF no.- 3 & 5 will be in service and laod of STN TF no.-4 will be shifted on STN TF no.- 3 & 5.
208	1151	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-2 in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-2.	22-Feb-22	04:00	24-Feb-22	18:00	During outage, HVDC ckt. no-1& 2 will not be in service and hence HVDC Bipole power will be 0 MW.
209	1152	MSETCL	400KV-CHANDRAPUR-BHADRAWATI-2	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-2 in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-2.	22-Feb-22	04:00	24-Feb-22	18:00	Outage is required on 400KV GCR C'pur - PGCIL Bhadrawati Ckt. No- 2 line, as the this circuit can not be shifted on 400KV Main Bus-2 due to problems of PG isolators of Bus-1 .
210	1153	MSETCL	400KV-CHANDRAPUR-BHADRAWATI-1	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-2 in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-2.	22-Feb-22	04:00	24-Feb-22	18:00	Outage is required on 400KV GCR C'pur - PGCIL Bhadrawati Ckt. No- 1 line, as the this circuit can not be shifted on 400KV Main Bus-1 due to problems of PG isolators of Bus-2 .
211	1154	MSETCL	CHANDRAPUR - 400KV - BUS 2	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-1 in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-2.	22-Feb-22	04:00	24-Feb-22	18:00	During outage, all connected bays/feeders of Main Bus-2 will be shifted to Main Bus-1 by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-2 on 400KV Main Bus-1, then after the 400KV Bus Coupler bay will be kept off.
212	1155	MSETCL	400KV/21KV CHANDRAPUR-GT-6(ON TBC)	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-1 in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-1. 3) Measurement of Timing, CRM and DCRM of CB.	22-Feb-22	04:00	24-Feb-22	18:00	During outage, GT-6 bay will be in service via TBC-2.
213	1156	MSETCL	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	Continuous	1) For replacement of old damaged quadruple bus conductor of Main Bus-2 in 400KV HVDC ckt.-1 bay and 400KV GT-6 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-2.	22-Feb-22	04:00	24-Feb-22	18:00	During outage, HVDC ckt. no-1& 2 will not be in service and hence HVDC Bipole power will be 0 MW.
214	1158	POWERGRID_WR1	CHANDRAPUR-GCR - 400KV - BUS 2	Continuous	Replacement of BUS-2 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	22-Feb-22	8:00	24-Feb-22	18:00	
215	1159	POWERGRID_WR1	400kV BHADRAWATI-CHANDRAPUR#1	Continuous	Replacement of BUS-2 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	22-Feb-22	8:00	24-Feb-22	18:00	
216	1160	POWERGRID_WR1	400kV BHADRAWATI-CHANDRAPUR#2	Continuous	Replacement of BUS-2 Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	22-Feb-22	8:00	24-Feb-22	18:00	

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/continuous	Reason	From	time	to	Time	Remarks
217	1176	MSETCL	220KV-PARLI-PARLI-M-2	Daily	LINE maintenance	23-Feb-22	08:00	23-Feb-22	17:00	-
218	1177	MSETCL	BABLESHWAR - 400KV - BUS 1	Daily	Permission to shift LBB protection wire from 400kV RADS & 400kV ZIV Numerical Busbar	23-Feb-22	08:00	23-Feb-22	18:00	outage propose on 400kV RADSS & 400kV Numerical Busbar@BBLR
219	1184	MSETCL	132KV-MANSAR-MS-KANHAN-1	Daily	Routine Maintenance work.	23-Feb-22	09:00	23-Feb-22	17:00	NA
220	1185	POWERGRID_WR2	400KV-PADGHE-BOISAR-1	Daily	For AMP work at Boisar. Also, line AMP works and dia to be kept open.	23-Feb-22	9:00	23-Feb-22	17:30	PG-WR2-Boisar
221	1187	MSETCL	400KV-SOLAPUR-M-SOLAPUR-1	Daily	Faulty string replacement	23-Feb-22	09:00	23-Feb-22	18:00	400kV Lamboti-Parli line in service
222	1212	MSETCL	220KV-WARDHA-PUSAD-1	Daily	For Routine Maintainance Work	24-Feb-22	07:00	24-Feb-22	18:00	Shifting of auto reclose switch to non auto mode, for fixing of fiber insulation cap type bird waste deposition guard by AEE LMSDN Yavatmal from
223	1221	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	24-Feb-22	08:00	24-Feb-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
224	1225	POWERGRID_WR1	KOLHAPUR-MS - 400KV B/R 2	Daily	Bay AMP, Outage required on CB only. Bus reactor can be kept in service through TBC.	24-Feb-22	8:00	24-Feb-22	18:00	
225	1230	MEGPTCL	MAIN BAY OF 765KV-TIRODA-KORADI-III-1 AND KORADI-III - 765KV - BUS 1 @KORADI-III - 765KV at KORADI-III - 765KV	Daily	Annual Maintenance of Bay Equipments	24-Feb-22	09:00	24-Feb-22	18:00	Annual Maintenance of Bay Equipments
226	1231	MSETCL	400KV-PARLI-M-LONIKHAND-II-2	Daily	1) DCRM & Timing measurement of breaker. 2) Bay maintenance work.3)Hardware Tightening and Fitting Work.	24-Feb-22	09:00	24-Feb-22	18:00	-
227	1234	MSETCL	EKTUNI - 400KV - BUS 1	Daily	Diagnostic Testing & Routine Maintainence work	24-Feb-22	10:30	24-Feb-22	18:30	400kV Main Bus-II will be in service
228	1235	MSETCL	400KV/21KV CHANDRAPUR-GT-6	Continuous	To made available the TBC-2 bay free which is required for shifting of feeders from Main Bus-2 to Main Bus-1.	24-Feb-22	18:00	24-Feb-22	19:00	Shifting of 400KV GT-6 bay from TBC-2 CB to Main own CB of GT-6 bay.
229	1237	POWERGRID_WR1	132kV Wardha - Deoli MSETCL line	Continuous	Loc. 03-04 MSEDCL Powerline Crossing stringing for TL diversion works associated with Bus-splitting Scheme	24-Feb-22	7:00	25-Feb-22	18:00	
230	1253	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	25-Feb-22	08:00	25-Feb-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
231	1258	MSETCL	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	Daily	Routine Maintenance & Dignostic testing work .	25-Feb-22	09:00	25-Feb-22	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
232	1263	MSETCL	220KV-NASIK-NAVSARI-2	Daily	Bay maint. & any abnormalities observed attending other works if any required to be carried out will be covered during this outage. Line maintenance work	25-Feb-22	09:00	25-Feb-22	18:00	-
233	1271	MSETCL	400KV/220KV PADGHE-ICT-4	Continuous	1) Oil filtration of B-PH Unit due to low BDV value 40kV and water content 20 mg/kg Total Gas 1269 2) B-PH unit dusts total 544 and increasing trend of flow rates	25-Feb-22	00:02	27-Feb-22	23:59	1) Agency will be present on site 2) Weather condition should be clear
234	1272	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	Providing additional twin conductor jumps at all cut points.	25-Feb-22	08:00	27-Feb-22	18:00	--
235	1281	MSETCL	400KV/220KV AURANGABAD-M (WALUJ)-ICT-2	Continuous	1) ICT Painting Work 2)Diagnostic Testing Work 3) Routine Maintenance Work	25-Feb-22	10:00	28-Feb-22	18:00	M/s. Jaidurga Agency will carry out ICT painting work
236	1286	MSETCL	BHUSAWAL - 400KV - BUS 2	Daily	for CVT testing and routine bay maintaainance work	26-Feb-22	06:00	26-Feb-22	18:00	NIL

Sr. No	OCCM Sr. No	Name of Requesting Agency	Line / Element	Daily/continuous	Reason	From	time	to	Time	Remarks
237	1289	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 2	Daily	Measurment of Tan delta pole-2 B-ph converter CT	26-Feb-22	08:00	26-Feb-22	14:00	Tan delta pole-2 B-ph converter CT is 0.669% on Dt. 26 Nov 2021. Outage required for trend analysis
238	1291	MSETCL	400KV-KALWA-KHARGHAR-1	Daily	"Diagnostic and R&M Work. MTAMC project related work"	26-Feb-22	08:00	26-Feb-22	18:00	NA
239	1292	MSETCL	400KV-SSP-DHULE-MS-2	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.	26-Feb-22	08:00	26-Feb-22	18:00	400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
240	1295	MSETCL	Tie Bay - 400KV-Wardha-WARORA-1 AND FUTURE	Daily	Routine Maintenance & Dignostic testing work .	26-Feb-22	09:00	26-Feb-22	17:00	Line will be charged through Main CB 429.
241	1296	MSETCL	220KV-TARAPUR 1&2-BOISAR-M-1	Daily	Maintenance Work of Line	26-Feb-22	09:00	26-Feb-22	17:00	Maintenance Work of Line
242	1305	MSETCL	220KV-BOISAR-BOISAR-M-2(ON TBC)	Continuous	CB Maintenance works by shifting the line on TBC.	26-Feb-22	07:00	27-Feb-22	18:00	CB Maintenance works by shifting the line on TBC.
243	1312	MSETCL	400KV-CHANDRAPUR-PARLI-M-1	Continuous	MTAMC relay retrofitting works under MTAMC project	26-Feb-22	07:00	28-Feb-22	18:00	2,400KV K'kheda line & 400KV PGCIL Ckt. - 1, 2, 3 and 4will be in service.
244	1313	POWERGRID_WR1	CHANDRAPUR-GCR - 400KV - TRANSFER BUS	Continuous	Replacement of AUXILLARY BUS Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	26-Feb-22	8:00	28-Feb-22	18:00	
245	1314	POWERGRID_WR1	400kV BHADRAWATI-CHANDRAPUR#1	Continuous	Replacement of AUXILLARY BUS Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	26-Feb-22	8:00	28-Feb-22	18:00	
246	1315	POWERGRID_WR1	400kV BHADRAWATI-CHANDRAPUR#2	Continuous	Replacement of AUXILLARY BUS Pantograph isolators of PGCIL ckt-1 and PGCIL ckt-2 at GCR	26-Feb-22	8:00	28-Feb-22	18:00	
247	1323	POWERGRID_WR1	400KV-KALWA-PUNE-PG-1	Daily	For Line AMP and relay testing works.	27-Feb-22	7:30	27-Feb-22	18:00	
248	1325	POWERGRID_WR2	MAIN BAY - 400KV/220KV BOISAR-ICT-2 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	Daily	For Isolator Servicing. Outage of 220kV Bus-2 is required	27-Feb-22	6:00	27-Feb-22	10:00	PG-WR2-Boisar
249	1326	POWERGRID_WR2	BOISAR - 220KV - BUS 2	Daily	For Isolator Servicing	27-Feb-22	6:00	27-Feb-22	18:00	PG-WR2-Boisar
250	1329	MSETCL	HVDC 500KV CHANDRAPUR HVDC POLE 1	Daily	measurment of tan delta of pole-1 converter R-ph CT	27-Feb-22	08:00	27-Feb-22	14:00	tan delta of pole-1 converter R-ph CT is 0.724% shown in previous measurment on Dt.15 nov 2021.Outage required for trend analysis
251	1330	MSETCL	400KV-KALWA-PUNE-PG-1	Daily	Cold line cleaning. Chemical cleaning of Insulators and Routine Maintenance Activity	27-Feb-22	09:00	27-Feb-22	18:00	Cold line cleaning. Chemical cleaning of Insulators and Routine Maintenance Activity
252	1332	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-BOISAR-M-2 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	Daily	For Isolator Servicing. Outage of 220kV Bus-2 is required	27-Feb-22	10:00	27-Feb-22	14:00	PG-WR2-Boisar
253	1347	MSETCL	400KV-SSP-DHULE-MS-1	Daily	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.	28-Feb-22	08:00	28-Feb-22	18:00	400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
254	1363	MSETCL	EKTUNI - 400KV - BUS 2	Daily	Diagnostic Testing & Routine Maintainence work	28-Feb-22	10:30	28-Feb-22	18:30	400kV Main Bus-1 will be in service

State Element List for the month of February'2022

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	01-Feb-22	10:00	28-Feb-22	16:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto mode. PID of 400 kV Koradi-Bhusawal line shall be carried out by PID unit	MSETCL	MSETCL	PID will be carried out as per the weather condition & availability of PID unit Akola.
2	400 KV	CHANDRAPUR - KHAPERKHEDA	01-Feb-22	08:00	05-Feb-22	17:00	Daily	For PID Testing work, shifting autoreclose switch to non auto mode	MSETCL	MSETCL	CHANDRAPUR - KHAPERKHEDA line will be in service.
3	400 KV	TBC @ KHADKA	01-Feb-22	08:00	01-Feb-22	18:00	Daily	For CT tandelta and routine bay maintainance work	MSETCL	MSETCL	Nil
4	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	02-Feb-22	10:00	02-Feb-22	18:00	Daily	Maintenance & Testing Activities	MSETCL	MSETCL	Without Load Interruption. Load will be managed by 400kV ICT-1
5	400 KV	WARORA - IEPL	02-Feb-22	09:00	02-Feb-22	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
6	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	03-Feb-22	09:30	03-Feb-22	17:30	Daily	Faulty Insulator string replacement, Annual Testing, Maintenance, CTR repairs work	MSETCL	MSETCL	400/220/33kV 501MVA ICT-II & ICT-III will be in service through 400kV Main bus-II.
7	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	03-Feb-22	09:00	03-Feb-22	18:00	Daily	For Commissioning of Online DGA and Diagnostic testing and maintenance activities.	MSETCL	MSETCL	---
8	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	04-Feb-22	09:00	04-Feb-22	18:00	Daily	1) C & tan delta measurement of C.VTs. 2) Bay maintenance work. 3)Hardware Tightening & Fitting work	MSETCL	MSETCL	-
9	400 KV	400/220/33KV 315MVA ICT - 2 @ LONIKAND	04-Feb-22	09:00	04-Feb-22	17:30	Daily	Half yearly DT & Maintenance	MSETCL	MSETCL	---
10	400 KV	KORADI-NANDGAONPETH (RPL)	04-Feb-22	09:00	04-Feb-22	17:00	Daily	Routine diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
11	400 KV	400/220 125MVAr BUS REACTOR @ LAMBOTI	04-Feb-22	10:00	04-Feb-22	18:00	Daily	Diagnostic Testing work	MSETCL	MSETCL	Without interruption
12	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	04-Feb-22	08:00	05-Feb-22	18:00	Continuou s	For MTAMC,Relay retrofitting,CBCRM and routine bay maintaianance work	MSETCL	MSETCL	load will be shifted on ICT-2
13	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	05-Feb-22	08:00	05-Feb-22	18:00	Daily	For MTAMC work and R&M work	MSETCL	MSETCL	na
14	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	05-Feb-22	08:00	05-Feb-22	18:00	Daily	Relay testing work and bay maintenance work	MSETCL	MSETCL	ICT 1, 3, 4 will be in service
15	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	07-Feb-22	08:00	07-Feb-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA
16	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	07-Feb-22	07:00	07-Feb-22	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	---
17	400 KV	125MVAr BUS REACTOR @ WARORA	07-Feb-22	09:00	07-Feb-22	17:00	Daily	Routine Maintenance & Dignostic testing work etc.	MSETCL	MSETCL	During outage reactor is in off condition
18	400 KV	TIE BAY (414) OF GT-8 @ CHANDRAPUR SWITCHING SS	07-Feb-22	09:00	07-Feb-22	17:00	Continuou s	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
19	400 KV	TBC @ BABHALESHWAR	08-Feb-22	08:00	08-Feb-22	18:00	Daily	Relay,Bushing, CT,CB Diagnostic testing & bay maintenance work	MSETCL	MSETCL	-
20	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	08-Feb-22	09:00	08-Feb-22	18:00	Continuou s	1) C & tan delta measurement of reactor. 2) Bay maintenance work. 3) Hardware Tightening and Fitting Work.	MSETCL	MSETCL	-
21	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	08-Feb-22	09:00	08-Feb-22	17:00	Continuou s	Daignostic testing work	MSETCL	MSETCL	Daignostic testing work
22	400 KV	GT - 6 @ KORADI-1	09-Feb-22	09:00	09-Feb-22	17:00	Daily	CRM, CB TIMING,DCRM	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
23	400 KV	KORADI - KHADKA(ON TBC)	09-Feb-22	08:00	09-Feb-22	18:00	Daily	For CBCRM and routine bay maintaainance work	MSETCL	MSETCL	During above period line will be charged through TBC
24	400 KV	TIE BAY - 403 OF 400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	09-Feb-22	10:00	09-Feb-22	17:00	Daily	Diagnostic Testing of CB	MSETCL	MSETCL	ICT will be charged from Main Bay
25	400 KV	PADGHE - NAGOTHANE CKT - 1	10-Feb-22	08:00	10-Feb-22	17:00	Daily	earth wire Replacement and jumper tightening work	MSETCL	MSETCL	NA
26	400 KV	80 MVAr BUS REACTOR - 2 @ BABHALESHWAR	10-Feb-22	09:00	10-Feb-22	18:00	Daily	Relay testing work	MSETCL	MSETCL	-
27	400 KV	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	10-Feb-22	09:30	10-Feb-22	17:30	Daily	Annual testing, maintenance & CTR repairs work	MSETCL	MSETCL	400/220/33kv 501MVA ICT-I & ICT-III will be in service.
28	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	10-Feb-22	09:00	10-Feb-22	17:30	Daily	Half yearly DT & Maintenance	MSETCL	MSETCL	---
29	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	11-Feb-22	11:00	11-Feb-22	17:00	Daily	Diagnostic Testing of ICT & Quarterly maintenance work	MSETCL	MSETCL	Nil
30	400 KV	MAIN BAY - 404 CHD SWITCHING CKT2 @ CHANDRAPUR 2	11-Feb-22	09:00	11-Feb-22	17:00	Continuou s	Daignostic testing and allied bay maintenance work	MSETCL	MSETCL	Daignostic testing and allied bay maintenance work
31	400 KV	CHANDRAPUR - KHAPERKHEDA	11-Feb-22	08:00	11-Feb-22	17:00	Daily	Replacement of faulty disc insulator	MSETCL	MSETCL	Replacement of faulty disc insulator
32	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	11-Feb-22	10:00	11-Feb-22	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	NA
33	400 KV	400/132 KV 200 MVA ICT - 2 @ KHADKA	11-Feb-22	08:00	12-Feb-22	18:00	Continuou s	For MTAMC,Relay retrofitting,CBCRM,Diagnostic testing & routine bay maintaainance work	MSETCL	MSETCL	Load will be shifted on ICT-1
34	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	12-Feb-22	10:30	12-Feb-22	18:00	Daily	Replacement of Broken Vibration Damper by LMSD. Line CVT Testing & Bay maintenance. Relay Routine Testing.	MSETCL	MSETCL	-
35	400 KV	PADGHE - NAGOTHANE CKT - 2	12-Feb-22	08:00	12-Feb-22	17:00	Daily	cold washing and jumper tighting work	MSETCL	MSETCL	NA
36	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	12-Feb-22	09:00	12-Feb-22	18:00	Daily	Relay testing work and bay maintenance work	MSETCL	MSETCL	ICT 1, 2, 3 will be in service
37	400 KV	80 MVAr BUS REACTOR - 1 @ BABHALESHWAR	14-Feb-22	09:00	14-Feb-22	18:00	Daily	Relay testing work	MSETCL	MSETCL	-

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
38	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	14-Feb-22	08:00	14-Feb-22	18:00	Daily	Diagnostic testing & Relay testing work & Routine maint. Work	MSETCL	MSETCL	---
39	400 KV	Akola II (Yelwan) - Akola I CKT - 1	14-Feb-22	09:00	14-Feb-22	19:00	Daily	Replacement of old Metering CVT with new design Metering CVT as per OEM recommendation	MEGPTCL	MEGPTCL	Replacement of old Metering CVT with new design Metering CVT as per OEM recommendation
40	400 KV	Akola II (Yelwan) - Akola I CKT - 1	14-Feb-22	10:00	14-Feb-22	17:00	Daily	Routine maintenance and testing work	APTCL	APTCL	Yelwan ckt-02 will be in service
41	400 KV	500 MVA 400/220 KV ICT - I @ CHANDRAPUR 2	15-Feb-22	10:00	16-Feb-22	18:00	Continuou s	Daignostic testing and allied bay maintenance work	MSETCL	MSETCL	Daignostic testing and allied bay maintenance work
42	400 KV	WARORA - IEPL	15-Feb-22	09:00	15-Feb-22	17:00	Daily	Routine maintenance and dignostic testing such as CVT/ CT tan delta, and, isolater maintenance work	MSETCL	MSETCL	Load will be managed on 400KV PGCIL Ckt .
43	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KORADI	16-Feb-22	09:00	16-Feb-22	18:00	Daily	CRM, CB TIMING,DCRM	MSETCL	MSETCL	ICT-II will be shifted on TBC
44	400 KV	KHADKA-AURANGABAD	16-Feb-22	08:00	16-Feb-22	18:00	Daily	For CBCRM and routine bay maintaianance work	MSETCL	MSETCL	during above period line will be charged through TBC
45	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	16-Feb-22	08:00	18-Feb-22	18:00	Daily	For replacement ofpolymer Insulator to antifog Long ROD Porcelain Insulator	MSETCL	MSETCL	.
46	400 KV	CHANDRAPUR-PARLI CKT-3	17-Feb-22	09:00	17-Feb-22	18:00	Continuou s	Hardware Tightening & Fitting work	MSETCL	MSETCL	-
47	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	17-Feb-22	09:30	17-Feb-22	17:30	Daily	Annual testing, maintenance & CTR repairs work	MSETCL	MSETCL	400/220/33kV 501MVA ICT-I & ICT-II will be in service.
48	400 KV	LONIKAND I - KOYNA STAGE-IV	17-Feb-22	09:00	17-Feb-22	17:30	Daily	Half yearly DT & Maintenance.	MSETCL	MSETCL	---
49	400 KV	TIE BAY (415) OF YELWAN CKT - 1 @ AKOLA	18-Feb-22	10:00	18-Feb-22	17:00	Daily	Routine maintenance and testing work	APTCL	APTCL	Load will be shifted on Main Bay 417
50	400 KV	KHADKA - BABLESHWAR	18-Feb-22	09:00	18-Feb-22	17:00	Daily	Line maintenance work Cold line washing and CT, CB relay testing work, quarterly maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Aurangabad, Dhule I&II will be in in service
51	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	18-Feb-22	08:00	19-Feb-22	18:00	Continuou s	For MTAMC,Relay retrofitting,CBCRM,Diagnostic testing and routine bay maintaianance work	MSETCL	MSETCL	load will be shifted on 220 KV deepnagar and ICT-4&5
52	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	19-Feb-22	08:00	19-Feb-22	18:00	Daily	For MTAMC work and RM Work	MSETCL	MSETCL	NA
53	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	19-Feb-22	09:00	19-Feb-22	17:00	Daily	CVT Tand testing, CT ratio change and qarterly maintenance work and Cold line washing for line maintenance work.	MSETCL	MSETCL	400kV Ektuni ckt I&II,400kV Bhusawal, Dhule I&II will be in in service
54	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	21-Feb-22	10:30	21-Feb-22	18:00	Continuou s	Replacement of Broken Vibration Damper by LMSD. Line CVT Testing & Bay maintenance. Relay Routine Testing.	MSETCL	MSETCL	-
55	400 KV	CHANDRAPUR-PARLI CKT-3	21-Feb-22	08:00	23-Feb-22	18:00	Daily	For replacement ofpolymer Insulator to antifog Long ROD Porcelain Insulator	MSETCL	MSETCL	.
56	400 KV	TIE BAY 418 OF YELWAN CKT - 2 @ AKOLA	21-Feb-22	10:00	21-Feb-22	17:00	Daily	Routine maintenance and testing work	APTCL	APTCL	Load will be shifted on Main Bay 417

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
57	400 KV	PADGHE - NAGOTHANE CKT - 1	21-Feb-22	08:00	21-Feb-22	17:00	Daily	cold washing and jumper tightening work	MSETCL	MSETCL	NA
58	400 KV	400/220 KV 500 MVA ICT @ ALKUD	22-Feb-22	09:00	22-Feb-22	17:00	Daily	QM Work	MSETCL	MSETCL	Load will be managed on 400KV Karad & Talandge S/S.
59	400 KV	CHANDRAPUR-PARLI CKT-3	22-Feb-22	08:00	22-Feb-22	18:00	Daily	For replacement of polymer insulator to antifog long ROD porcelain insulator	MSETCL	MSETCL	For replacement of polymer insulator to antifog long ROD porcelain insulator
60	400 KV	PADGHE - NAGOTHANE CKT - 2	22-Feb-22	08:00	22-Feb-22	17:00	Daily	cold washing and jumper tightening work	MSETCL	MSETCL	NA
61	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	22-Feb-22	09:00	22-Feb-22	18:00	Daily	1) IV Backup relay & CTs Testing work. 2) Bay maintenance work.	MSETCL	MSETCL	-
62	400 KV	500 MVA 400/220 KV ICT - II @ CHANDRAPUR 2	22-Feb-22	09:00	23-Feb-22	18:00	Continuou s	Daignostic testing and allied bay maintenance work	MSETCL	MSETCL	Daignostic testing and allied bay maintenance work
63	400 KV	MAIN BAY (401) OF 167 MVA SPARE ICT @ WARORA	23-Feb-22	07:00	23-Feb-22	17:00	Daily	Routine maintenance and diagnostics testing such as CT tan delta, and, isolater maintenance work	MSETCL	MSETCL	400/220/33KV SPARE ICT BAY NO 401 IS PRESENTLY OFF CONDITION (400/220/33KV SPARE
64	400 KV	MAIN BAY 416 OF STN TF 5A @ 400 KV KHAPARKHEDA 2	23-Feb-22	10:00	23-Feb-22	17:00	Daily	Diagnostic Testing of CB	MSETCL	MSETCL	Stn TF will be charged from Tie Bay
65	400 KV	KHADKA- DEEPNAGAR CKT 1	23-Feb-22	08:00	23-Feb-22	18:00	Daily	For CBCRM and routine bay maintaianance work	MSETCL	MSETCL	During above period line will be charged through TBC
66	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	24-Feb-22	09:00	24-Feb-22	17:30	Daily	Half yearly DT & Maintenance.	MSETCL	MSETCL	---
67	400 KV	400/220KV 315MVA ICT - 3 @ CHAKAN	24-Feb-22	09:00	24-Feb-22	18:00	Daily	Diagnostic testing and maintenance activities.	MSETCL	MSETCL	---
68	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	24-Feb-22	10:30	24-Feb-22	18:00	Continuou s	Replacement of Broken Vibration Damper by LMSD. Line CVT Testing & Bay maintenance. Relay Routine Testing.	MSETCL	MSETCL	-
69	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	24-Feb-22	10:00	24-Feb-22	16:00	Daily	PID testing of insulator strings. A/R shall be kept in non auto mode. PID of 400 kV Koradi-Bhusawal line shall be carried out by PID unit	MSETCL	MSETCL	PID will be carried out as per the weather & availability of PID unit Akola. condition
70	400 KV	KORADI II - IEPL	25-Feb-22	08:00	25-Feb-22	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NA
71	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	25-Feb-22	08:00	27-Feb-22	17:00	Daily	For replacement of polymer insulator to antifog long ROD porcelain insulator	MSETCL	MSETCL	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 2 will be in service
72	400 KV	CHANDRAPUR 2 - DHARIWAL CKT - 2	25-Feb-22	10:00	25-Feb-22	17:00	Continuou s	Daignostic testing and allied bay maintenance work	MSETCL	MSETCL	Daignostic testing and allied bay maintenance work
73	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	25-Feb-22	08:00	25-Feb-22	18:00	Daily	"R&M Work and Diagnostic testing Work MTAMC related Work"	MSETCL	MSETCL	NA
74	400 KV	DHULE- - BABLESHWAR - I	25-Feb-22	09:00	25-Feb-22	17:00	Daily	Cold Line washing & Relay testing work and qaurterly maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II, 400 kV Dhule-II, 400kV Aurangabad and Bhusawal lines will be in service
75	400 KV	DHULE- - BABLESHWAR - II	26-Feb-22	09:00	26-Feb-22	17:00	Daily	Cold Line washing & Relay testing work and qaurterly maintenance work	MSETCL	MSETCL	400kV Ektuni ckt I&II, 400 kV Dhule-I, 400kV Aurangabad and Bhusawal lines will be in service

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
76	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	28-Feb-22	09:00	28-Feb-22	18:00	Continuou s	1)HV backup relay testing & SFRA measurement of ICT Units. 2) Bay maintenance work.	MSETCL	MSETCL	-