

Maharashtra State Load Despatch Centre													
Monthly Outage list approved in WRLDC OCCM for the Month of February 2024													
Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/C	Reason	From Date	From Time	To Date	To Time	Remarks	
1	1	PLANNED	OCC_575	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-1	C	Stringing of diversion work of 400kV Tarapur-Boisar	23-Jan-2024	7:00	31-Jan-2024	18:00	PG-WR2-BOISAR TLM	
2	2	PLANNED	OCC_575	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-2	C	Stringing of diversion work of 400kV Tarapur-Boisar	23-Jan-2024	7:00	31-Jan-2024	19:00	PG-WR2-BOISAR TLM	
3	3	PLANNED	OCC_575	POWERGRID_WR2	400KV-TARAPUR 3&4-BOISAR-1	D	AMP WORK	31-Jan-2024	7:00	31-Jan-2024	17:30	PG-WR2-BOISAR	
4	27	PLANNED	OCC_575	MSLDC_OUTAGE	TIE BAY OF 400KV-KARJAT-LONIKHAND-II-2 AND FUTURE @LONIKHAND-II - 400KV at LONIKHAND-II - 400KV	D	Diagnostic testing and Maintenance	01-Feb-2024	08:00	01-Feb-2024	18:00	-	
5	28	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY OF 400KV-KARJAT-LONIKHAND-II-2 AND LONIKHAND-II - 400KV - BUS 2 @LONIKHAND-II - 400KV at LO	D	Diagnostic testing and Maintenance	01-Feb-2024	08:00	01-Feb-2024	18:00	-	
6	29	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work.	01-Feb-2024	08:00	01-Feb-2024	18:00	--	
7	30	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	Relay testing work	01-Feb-2024	10:00	01-Feb-2024	18:00	-	
8	35	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	C	Shifting of 400 KV Babhaleshwar- Padghe Ckt-2 on 400 KV Talegaon-Padghe (Dead Ckt). Outage No. 1 on Ckt#2 this temporarily arrangement for 14 days 1. Bunching and ERS Stringing between Loc 33 & 108. 2. Bunching between Loc 57 & 132. 3. Removing of Jumpers at Loc 33 and 57. 4. Removing of jumper at Loc 106. 5. Transferring of 400KV BBLR-PDG Ckt-2 on 400KV Talegaon-PDG Ckt. 6. Charging of 400KV BBLR-PDG Ckt-2 on 400KV Talegaon-PDG CKT. 7 Above temporarily arrangement will be for 14 days	01-Feb-2024	22:00	02-Feb-2024	6:00	400kV Bhambhleshwar-Padghe d/c for line shifting infringing in Samruddhi highway crossing under ORC for 400kV Bhambhleshwar-Padghe ckt- 1 & 2 between location no. 41 to 44 under HVDC R.S. O&M circle, Padghe	
9	39	PLANNED	OCC_575	MSLDC_OUTAGE	400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA(element not found)	C	CS Type Gantry Extension work for RRS Scheme Work of ICT	01-Feb-2024	10:00	03-Feb-2024	17:00	NA	
10	41	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-2 AND PADGHE - 400KV - BUS 1 @PADGHE - 400KV at PADGHE - 400KV	C	1.Diagnostic Testing Work 2.Replacement of all phase LA. 3. Replacement of Distance & Over Voltage Relay. 4.CB Mechanism Pole Overhauling Work. 5. A & B Bus PG Isolator Maintenance Work. 6.B Bus PG Isolator Replacement work under LES Scheme. 7.Replacement of 29 D Isolator Under LES Scheme. After removing IPS Tube Between 29 C & 29 D Isolator BBLR-2 line will be taken on TBC. 8. After Completion of work.	01-Feb-2024	09:30	05-Feb-2024	23:00	Weather Condition should be clear	
11	46	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01-Feb-2024	09:00	15-Feb-2024	17:00	No outage required	
12	50	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01-Feb-2024	08:00	24-Feb-2024	17:00	---	

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
13	64	PLANNED	OCC_575	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for replacement of insulator in live line method.	01-Feb-2024	8:00	29-Feb-2024	18:00	AR disable
14	65	PLANNED	OCC_575	WTPL	400KV-ALKUD-SOLAPUR-1	D	AR disable for replacement of insulator in live line method.	01-Feb-2024	8:00	29-Feb-2024	18:00	AR disable
15	66	PLANNED	OCC_575	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	AR disable for replacement of insulator in live line method.	01-Feb-2024	8:00	29-Feb-2024	18:00	AR disable
16	76	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	The OPGW (48F) installation work by replacing existing Earthwire in live condition on 400kv Babhaleshwar-Padge (Single Circuit) from tower No. 851 to 998 and hence AR out is required.	01-Feb-2024	08:00	29-Feb-2024	18:00	400kV Babhaleshwar-Padghe Ckt 1 with AR enable will be available.
17	78	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01-Feb-2024	09:00	14-Feb-2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
18	79	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	01-Feb-2024	09:00	14-Feb-2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
19	80	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID testing by Hotline method	01-Feb-2024	09:00	29-Feb-2024	17:30	-
20	81	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID testing by Hotline work	01-Feb-2024	09:00	29-Feb-2024	17:30	-
21	82	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID testing works.	01-Feb-2024	09:00	29-Feb-2024	18:00	-
22	83	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing works.	01-Feb-2024	09:00	29-Feb-2024	18:00	-
23	84	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For PID work, Shifting of auto reclose switch to non auto mode	01-Feb-2024	11:00	29-Feb-2024	15:00	For PID work
24	92	PLANNED	OCC_575	POWERGRID_WR1	400KV/220KV PUNE-PG-ICT-1	D	For AMP Work	01-Feb-2024	8:00	01-Feb-2024	18:00	
25	105	PLANNED	OCC_575	POWERGRID_WR1	400KV-PARLI NEW-PARLI-M-2	C	For ongoing project of "Upgradation of 400 KV Line bay Parli -2 at MSETCL from existing current rating of 2000 A to 3150 A to suit the reconductoring with twin HTLS under WRES XXX"	01-Feb-2024	7:00	10-Feb-2024	18:00	
26	116	PLANNED	OCC_575	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-2	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01-Feb-2024	7:00	29-Feb-2024	18:00	
27	117	PLANNED	OCC_575	POWERGRID_WR1	400KV-KHANDWA-DHULE-MS-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS by POWERGRID	01-Feb-2024	7:00	29-Feb-2024	18:00	
28	118	PLANNED	OCC_575	LVTPL-Sterlite	704 Main Bay of 765 kV Lakadia Vadodara Line 02 @Lakadia	D	Bay Signals checks and SCADA Signals testing	02-Feb-2024	10:00	02-Feb-2024	18:30	Bay Signals checks and SCADA Signals testing
29	119	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	Erection of newly proposed 3 No.s QD Tower in between Location no. 168 to 170 for the work of height rising for NHSRL. 1) Before availing the outage ERS Towers will be erected near to the proposed locations for height raising. 2) During the proposed outage the line will be diverted on the ERS tower & line will be charged through ERS towers till erection of 3 No.s of QD Tower in between Location no. 168 to 170 & its stringing along with dismantling of old towers by 12.02.2024 .	02-Feb-2024	0:15	02-Feb-2024	9:00	1) Before availing the outage ERS Towers will be erected near to the proposed locations for height raising. 2) During the proposed outage the line will be diverted on the ERS tower & line will be charged through ERS towers till erection of 3 No.s of QD Tower in between Location no. 168 to 170 & its stringing along with dismantling of old towers by 12.02.2024 .

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
30	120	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	Erection of newly proposed 3 No.s QD Tower in between Location no. 168 to 170 for the work of height rising for NHRCL. 1) Before availing the outage ERS Towers will be erected near to the proposed locations for height raising. 2) During the proposed outage the line will be diverted on the ERS tower & line will be charged through ERS towers till erection of 3 No.s of QD Tower in between Location no. 168 to 170 & its stringing along with dismantling of old towers by 12.02.2024 .	02-Feb-2024	0:15	02-Feb-2024	9:00	1) Before availing the outage ERS Towers will be erected near to the proposed locations for height raising. 2) During the proposed outage the line will be diverted on the ERS tower & line will be charged through ERS towers till erection of 3 No.s of QD Tower in between Location no. 168 to 170 & its stringing along with dismantling of old towers by 12.02.2024 .
31	123	PLANNED	OCC_575	POWERGRID_WR2	220KV-KHANDWA-NEPANAGAR-1	D	PU Installation and LBB testing	02-Feb-2024	7:00	02-Feb-2024	18:00	PG-WR2-KHANDWA
32	124	PLANNED	OCC_575	POWERGRID_WR2	400KV/220KV REWA-ICT-3	D	CSD commissioning work in Tie breaker, and AMP of ICT (Dia to be kept open)	02-Feb-2024	7:00	02-Feb-2024	18:00	PG-WR2- REWA-SS
33	154	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-BMAIN BAY OF 220KV-BOISAR-BOISAR-M-3 AND BOISAR-M - 220KV - BUS 1 @BOISAR-M - 220KV at BOISAR-M - 220KVOISAR-	D	CB Overhauling Work after shifting the line on TBC.	02-Feb-2024	07:00	02-Feb-2024	22:00	CB Overhauling Work after shifting the line on TBC at 220 kV Boisar(M) S/s.
34	155	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-2	D	Outage required for making 220kV half bus dead for jumpering of 220kV bus sectionaliser.	02-Feb-2024	08:00	02-Feb-2024	18:00	-
35	156	PLANNED	OCC_575	MSLDC_OUTAGE	TIE BAY - 400KV-WARORA-CHANDRAPU-II-2 AND 400KV-TIRODA-WARORA-1 at WARORA - 400KV	D	Routine maintenance and IR Values, Testing works and isolater maintenance work .	02-Feb-2024	09:00	02-Feb-2024	17:00	only Tie CB 412 is in OFF condition, respective ckt charged through its own main CB.
36	157	PLANNED	OCC_575	MSLDC_OUTAGE	BUS COUPLER BAY - AURANGABAD-M (WALUJ) - 400KV - BUS 1 AND AURANGABAD-M (WALUJ) - 400KV - BUS 2 at Aurangabad-M (Waluj) - 400KV	D	1) Auxiliary/TCS relay replacement work. 2) Maintenance work.	02-Feb-2024	10:00	02-Feb-2024	18:00	1) Outage on 400kV Bus Coupler bay. 2) Auxiliary/TCS relay replacement work will be carried out by M/s. Ajaydeep.
37	159	PLANNED	OCC_575	MSLDC_OUTAGE	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	C	Breaker Mechanism Overhauling work, Routine Maintenance & Testing Work	02-Feb-2024	08:00	04-Feb-2024	18:00	Breaker Mechanism Overhauling work,
38	160	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For PID Work & Bird guard Connect for Shifting of auto reclose switch to non auto mode.	02-Feb-2024	08:00	28-Feb-2024	18:00	--
39	162	PLANNED	OCC_575	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-1	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS. AR OF CKT#2 IN NON AUTO MODE	02-Feb-2024	7:00	02-Feb-2024	13:00	Line Outages of both 400kV Akola-Aurangabad-1 and 2 are required one after another for replacemmnt of insulators along with associated Busbar without which work cannot be completed.
40	163	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 765KV-AURANGABAD-SOLAPUR-2 AND AURANGABAD - 765KV - BUS 1 at AURANGABAD - 765KV	D	For AMP	02-Feb-2024	7:00	02-Feb-2024	18:00	
41	165	PLANNED	OCC_575	POWERGRID_WR1	SOLAPUR - 765KV - BUS 2	D	765kV Bus#2 AMP Works	02-Feb-2024	7:00	02-Feb-2024	18:00	
42	166	PLANNED	OCC_575	POWERGRID_WR1	AKOLA - 400KV - BUS 1	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS	02-Feb-2024	7:00	02-Feb-2024	20:00	Line Outages of both 400kV Akola-Aurangabad-1 and 2 are required one after another for replacemmnt of insulators along with associated Busbar without which work cannot be completed.
43	179	PLANNED	OCC_575	POWERGRID_WR1	400KV-AKOLA-AURANGABAD-2	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS. AR OF CKT#1 IN NON AUTO MODE	02-Feb-2024	13:00	02-Feb-2024	20:00	Line Outages of both 400kV Akola-Aurangabad-1 and 2 are required one after another for replacemmnt of insulators along with associated Busbar without which work cannot be completed.
44	182	PLANNED	OCC_575	MUML-Sterlite	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-1	C	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	03-Feb-2024	21:00	04-Feb-2024	5:00	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML
45	183	PLANNED	OCC_575	MUML-Sterlite	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-2	C	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	03-Feb-2024	21:00	04-Feb-2024	5:00	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
46	184	PLANNED	OCC_575	MSLDC_OUTAGE	BUS COUPLER BAY - BABLESHWAR - 400KV - BUS 1 AND BABLESHWAR - 400KV - BUS 2 at BABLESHWAR - 400KV	C	CB pole overhauling work	03-Feb-2024	09:00	06-Feb-2024	18:00	400 KV Main Bus I and II will be separated
47	195	PLANNED	OCC_575	WTPL	220KV-SOLAPUR-JEUR-1	D	Annual Manitenance	03-Feb-2024	8:00	03-Feb-2024	18:00	Outage
48	196	PLANNED	OCC_575	WTPL	400KV-SOLAPUR-M-SOLAPUR-1	D	AR disable for annual maintenance in 220 KV Solapur - Jeur -1	03-Feb-2024	8:00	03-Feb-2024	18:00	AR disable
49	217	PLANNED	OCC_575	MSLDC_OUTAGE	Pole-1 Non base AC filter Z3 (120 MVAR) @PADGHE HVDC (ELEMENT NOT FOUND)	C	1. CB Pole alongwith interrupter & mechanisum box overhauling work. 2. Capcitor jumper replacement work with new.	03-Feb-2024	08:00	04-Feb-2024	08:00	B-ph CB Pole alongwith interrupter & mechanisum box is due for overhauling work. 2. Filter jumper old aged need to replace for avoiding hot spots.
50	218	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	Bay Maintenance & Equipment Testing.	03-Feb-2024	07:00	03-Feb-2024	13:00	Bay Maintenance & Equipment Testing.
51	219	PLANNED	OCC_575	MEGPTCL	KORADI-III - 765KV - BUS 1	D	Annual Maintenance of Bus Equipment at Koradi-III SS.	03-Feb-2024	09:00	03-Feb-2024	18:00	Bus Outage
52	220	PLANNED	OCC_575	POWERGRID_WR1	400KV-WARDHA-AKOLA-1	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS. AR OF CKT#2 IN NON AUTO MODE	03-Feb-2024	7:00	03-Feb-2024	13:00	Line Outages of both 400kV Akola-Wardha-1 and 2 are required one after another for replacemmnt of insulators along with associated Busbar without which work cannot be completed.
53	225	PLANNED	OCC_575	POWERGRID_WR1	AKOLA - 400KV - BUS 2	D	For Replacement of Old BHEL Insulators on gantries of element	03-Feb-2024	7:00	03-Feb-2024	20:00	Line Outages of both 400kV Akola-Wardha-1 and 2 are required one after another for replacemmnt of insulators along with associated Busbar without which work cannot be completed.
54	229	PLANNED	OCC_575	POWERGRID_WR1	400KV-WARDHA-AKOLA-2	D	For Replacement of Old BHEL Insulators on gantries of element at Akola SS. AR OF CKT#1 IN NON AUTO MODE	03-Feb-2024	13:00	03-Feb-2024	20:00	Line Outages of both 400kV Akola-Wardha-1 and 2 are required one after another for replacemmnt of insulators along with associated Busbar without which work cannot be completed.
55	232	PLANNED	OCC_575	MUML-Sterlite	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-1	C	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	04-Feb-2024	21:00	05-Feb-2024	5:00	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML
56	233	PLANNED	OCC_575	MUML-Sterlite	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-2	C	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	04-Feb-2024	21:00	05-Feb-2024	5:00	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML
57	234	PLANNED	OCC_575	POWERGRID_WR2	220KV-BOISAR-PANCHALI-1	D	AMP WORK	04-Feb-2024	7:00	04-Feb-2024	17:30	PG-WR2-BOISAR
58	237	PLANNED	OCC_575	WTPL	400KV-SOLAPUR-M-SOLAPUR-1	D	Annual Manitenance	04-Feb-2024	8:00	04-Feb-2024	18:00	Outage
59	238	PLANNED	OCC_575	WTPL	220KV-SOLAPUR-JEUR-1	D	AR disable for annual maintenance in 400 KV Solapur-M- Solapur-1	04-Feb-2024	8:00	04-Feb-2024	18:00	AR disable
60	242	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	SSN to DSN insulator string Conversion work & and installation of fridge wedge connector at mid-span joint.	04-Feb-2024	08:00	04-Feb-2024	18:00	SSN to DSN insulator string Conversion work & and installation of fridge wedge connector at mid-span joint.
61	243	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-2	D	Half yearly maintenance	04-Feb-2024	09:00	04-Feb-2024	17:00	-
62	244	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	H/W tightening and cleaning	04-Feb-2024	09:00	04-Feb-2024	18:00	Load managed on 400kv parli-karjat ckt 2
63	245	PLANNED	OCC_575	PGCIL SR-1	765KV-NIZAMABAD-WARDHA-2	C	Replacement of flash over CB,CT & DSES(71189A) of Tie bay of Wardha2 and ICT-3	04-Feb-2024	6:00	05-Feb-2024	22:00	ATC Curtailment of 550 MW in SR Import
64	252	PLANNED	OCC_575	MEGPTCL	765KV-AKOLA (2)-KORADI-III-1	D	Annual Maintenace of line	04-Feb-2024	08:00	04-Feb-2024	18:00	Line Outage
65	254	PLANNED	OCC_575	POWERGRID_WR1	400KV-CHAKAN-PUNE-PG-1	D	For AMP Work	04-Feb-2024	9:00	04-Feb-2024	18:00	Line Owned By MSETCL Trans

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
66	268	PLANNED	OCC_575	WTPL	400KV-ALKUD-SOLAPUR-1	D	AR disable for annual maintenance in 400KV Kolhapur - MS- Solapur Line -2	05-Feb-2024	8:00	05-Feb-2024	18:00	AR disable
67	269	PLANNED	OCC_575	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	AR disable for annual maintenance in 400KV Kolhapur - MS- Solapur Line -2	05-Feb-2024	8:00	05-Feb-2024	18:00	AR disable
68	270	PLANNED	OCC_575	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Annual Manitenance	05-Feb-2024	8:00	05-Feb-2024	18:00	Outage
69	291	PLANNED	OCC_575	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	*1.For Replacement of Flashover Disc 2.Diagnostic testing & Routine Maintenance of Line	05-Feb-2024	09:00	05-Feb-2024	17:00	Outage
70	292	PLANNED	OCC_575	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	05-Feb-2024	09:00	05-Feb-2024	18:00	During 400KV Busbar Protection Relay testing works Outage , (1). 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work (2)The 400KV Busbar Relay will be tested Online by taking necesaary
71	293	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	1) Distance M1 & M2 relays retrofitting work. (2) Routine maintenance work. 2)String replacement work	05-Feb-2024	09:00	05-Feb-2024	18:00	-
72	294	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	05-Feb-2024	09:00	05-Feb-2024	18:00	PID testing of insulator A/R function required to be in non auto mode
73	297	PLANNED	OCC_575	NPCIL, TAPS 1&2	220 kV-Tarapur1&2 – Boisar	C	220 kV-Tarapur1&2 – Boisar outage is required to carry out routine annual maintenance of feeder	05-Feb-2024	8:00	07-Feb-2024	20:00	220 kV-Tarapur1&2 – Boisar outage is required to carry out routine annual maintenance of feeder equipments
74	313	PLANNED	OCC_575	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	1. For attending the high CRM problem of CB by excuting the pole overhauling work. 2.Measurement of tandelta & capacitance of CT. 3. Bay routine maintenance work	05-Feb-2024	08:00	12-Feb-2024	18:00	1. During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 1, 400KV PARLI CKT-3, 400KV CHANDRAPUR-PGCIL Bhadrawati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be in service. 2.For 400KV CHANDRAPUR-1 Busbar
75	316	PLANNED	OCC_575	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-1	C	Stringing of diversion work of 400kV Tarapur-Phadge	05-Feb-2024	7:00	13-Feb-2024	18:00	PG-WR2-BOISAR TLM
76	317	PLANNED	OCC_575	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-2	C	Stringing of diversion work of 400kV Tarapur-Phadge	05-Feb-2024	7:00	13-Feb-2024	18:00	PG-WR2-BOISAR TLM
77	319	PLANNED	OCC_575	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	D	Cable Replacement of Bushing CTs for R, Y and B ph Reactor at Ektuni SS. (non- switchable Reactor at Ektuni SS.)	05-Feb-2024	10:00	05-Feb-2024	18:00	Line Outage
78	320	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 765KV-AURANGABAD-PADGHE-PG-2 AND AURANGABAD - 765KV - BUS 1 at AURANGABAD - 765KV	D	For AMP	05-Feb-2024	7:00	05-Feb-2024	18:00	
79	322	PLANNED	OCC_575	POWERGRID_WR1	TIE BAY - 400KV/220KV SOLAPUR-ICT-1 AND 400KV-KARAD-SOLAPUR-1 at Solapur - 400KV	D	Y.Ph CT Oil sampling work.	05-Feb-2024	8:00	05-Feb-2024	12:00	
80	323	PLANNED	OCC_575	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Line Bay AMP and relay testing	05-Feb-2024	8:00	05-Feb-2024	18:00	Outage required on line for Line bay equipment AMP works
81	336	PLANNED	OCC_575	TAPS-3&4	400 KV TARAPUR-PADGHE CK-2	C	Preventive Maintenance checks	06-Feb-2024	9:00	08-Feb-2024	19:00	Sample Remarks
82	352	PLANNED	OCC_575	WTPL	400KV-ALKUD-SOLAPUR-1	D	Annual Manitenance	06-Feb-2024	8:00	06-Feb-2024	18:00	Outage
83	353	PLANNED	OCC_575	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for annual maintenance in 400KV Alkud -MS- Solapur Line -1	06-Feb-2024	8:00	06-Feb-2024	18:00	AR disable
84	375	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-1	D	Replacement of faulty distance protection relay	06-Feb-2024	09:00	06-Feb-2024	20:00	-
85	376	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Routine maintenance work	06-Feb-2024	10:00	06-Feb-2024	13:00	--

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
86	377	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY OF 400KV-TAPTHITHANDA-EKTUNI-1 AND EKTUNI - 400KV - BUS 1 @EKTUNI - 400KV at EKTUNI - 400KV	D	Testing and Diagnostic Testing work	06-Feb-2024	10:00	06-Feb-2024	18:00	Outage required for routine testing and maintenance work.
87	378	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-ALKUD-SOLAPUR-1	D	Routine maintenance work	06-Feb-2024	10:00	06-Feb-2024	18:00	Load will be managed on 400kv Kolhapur line
88	379	PLANNED	OCC_575	MSLDC_OUTAGE	TIE BAY - 400KV-ALKUD-SOLAPUR-1 AND 400KV/220KV ALKUD-ICT-2 at ALKUD - 400KV	D	Routine maintenance work	06-Feb-2024	14:00	06-Feb-2024	17:00	--
89	391	PLANNED	OCC_575	RGPPL	MAIN BAY OF 400KV/15KV RGPPL-GT-1B AND RGPPL - 400KV - BUS 1 @RGPPPL - 400KV at RGPPPL - 400KV	C	Attending SF6 leakages and gasket replacement	06-Feb-2024	8:00	08-Feb-2024	18:00	Attending SF6 leakages and gasket replacement on 431 breaker
90	393	PLANNED	OCC_575	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-2	C	CB pole overhauling work	06-Feb-2024	09:00	09-Feb-2024	18:00	400/220 KV ICT II HV will be in service through TBC
91	394	PLANNED	OCC_575	MSLDC_OUTAGE	TIE BAY (405) OF SWITCHING SS CKT - 2 & NANDED - 1 @ CHANDRAPUR 2 (ELEMENT NOT FOUND)	C	Replacement of non-PIR CB by with PIR CB	06-Feb-2024	09:00	13-Feb-2024	18:00	Outage will be on continous basis and lines will be in service through their respective main Bays
92	396	PLANNED	OCC_575	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	D	Annual Maintenace of line	06-Feb-2024	08:00	06-Feb-2024	18:00	Line Outage
93	400	PLANNED	OCC_575	POWERGRID_WR1	400KV-WARORA-PG-WARORA-1	D	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	06-Feb-2024	7:00	06-Feb-2024	18:00	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme
94	401	PLANNED	OCC_575	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	D	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	06-Feb-2024	7:00	06-Feb-2024	18:00	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme
95	409	PLANNED	OCC_575	POWERGRID_WR1	400KV-ALKUD-SOLAPUR-1	C	PRV NC contact modification works of line Reactor at Solapur end.	06-Feb-2024	8:00	06-Feb-2024	18:00	Line will also be under shutdown
96	434	PLANNED	OCC_575	WTPL	400KV-KOLHAPUR-MS-ALKUD-1	D	Annual Maintenance	07-Feb-2024	8:00	07-Feb-2024	18:00	Outage
97	435	PLANNED	OCC_575	WTPL	400KV-KOLHAPUR-MS-SOLAPUR-2	D	AR disable for annual maintenance in 400KV Kolhapur - MS- Alkud Line -1	07-Feb-2024	8:00	07-Feb-2024	18:00	AR disable
98	450	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work	07-Feb-2024	08:00	07-Feb-2024	18:00	--
99	451	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	07-Feb-2024	08:00	07-Feb-2024	18:00	NA
100	452	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Routine Maintenance & Dignostic testing work .	07-Feb-2024	09:00	07-Feb-2024	17:00	400KV WARORA-IEPL Line is in ckt
101	453	PLANNED	OCC_575	MSLDC_OUTAGE	TIE BAY OF 400KV-TIRODA-WARORA-2 AND 400KV-WARORA-CHANDRAPU-II-2 @WARORA - 400KV at WARORA - 400KV	D	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	07-Feb-2024	09:00	07-Feb-2024	17:00	only Tie CB 415 is in OFF condition, respective ckt charged through its own main CB.
102	454	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Maintenance work	07-Feb-2024	09:00	07-Feb-2024	17:00	The said work is very important
103	455	PLANNED	OCC_575	MSLDC_OUTAGE	BUS COUPLER BAY - KORADI - 400KV - BUS 1 AND KORADI - 400KV - BUS 2 at Koradi - 400KV	D	DIGNOSTIC TESTING OF CT, DCRM, CB TIMING, CRM	07-Feb-2024	09:00	07-Feb-2024	18:00	NA
104	456	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHVAR-1	D	Routine Maint. Work	07-Feb-2024	09:00	07-Feb-2024	18:00	NA

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
105	457	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	Outage is required for Restranging at TL 202-203. Banana farm coming in induction zone when line is loaded. Restranging needs to be done from CP 196 to CP 210.	07-Feb-2024	09:00	07-Feb-2024	18:00	Breaker of PGCIL line at Jeur End will be made off
106	458	PLANNED	OCC_575	MSLDC_OUTAGE	JEUR - 220KV - BUS 1	D	Outage is required for Quarterly Maintenance	07-Feb-2024	09:00	07-Feb-2024	18:00	Breaker of PGCIL line at Jeur End will be made off
107	459	PLANNED	OCC_575	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	Routine Maint. Work	07-Feb-2024	09:00	07-Feb-2024	18:00	NA
108	460	PLANNED	OCC_575	MSLDC_OUTAGE	KOLHAPUR-MS - 400KV B/R 2	D	1. Annual testing work 2. SFRA & DFRA Testing work	07-Feb-2024	09:00	07-Feb-2024	20:00	Reactor will be in OFF condition for voltage control.
109	469	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND ALKUD - 400KV - BUS 1 at ALKUD - 400KV	D	Routine maintenance work	07-Feb-2024	8:00	07-Feb-2024	13:00	--
110	470	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-ALKUD-1	D	Routine maintenance work	07-Feb-2024	8:00	07-Feb-2024	17:00	Load will be managed on 400kv Solapur line
111	471	PLANNED	OCC_575	MSLDC_OUTAGE	TIE BAY - 400KV-KOLHAPUR-MS-ALKUD-1 AND FUTURE	D	Routine maintenance work	07-Feb-2024	8:00	07-Feb-2024	17:00	--
112	488	PLANNED	OCC_575	APTCL	400KV-AKOLA-AKOLA (2)-1	C	Routine maintenance & testing work	07-Feb-2024	09:00	07-Feb-2024	18:00	yelwan ckt-02 will be in service
113	489	PLANNED	OCC_575	POWERGRID_WR1	400KV-WARORA-PG-WARORA-1	C	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme	07-Feb-2024	7:00	08-Feb-2024	18:00	Earth wire Peak Strengtening work for Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated with Bus-splitting Scheme
114	490	PLANNED	OCC_575	POWERGRID_WR1	400KV-WARDHA-WARORA-PG-1	C	Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated	07-Feb-2024	7:00	08-Feb-2024	18:00	Diamond Crossing of Earthwire / OPGW over 400kV Mauda-Wardha Line for TL Diversion/Re-routing works associated
115	522	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	08-Feb-2024	08:00	08-Feb-2024	18:00	NA
116	523	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work.	08-Feb-2024	08:00	08-Feb-2024	18:00	--
117	526	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	(1) CT testing. (2) Bay maintenance work. (3) String cold washing & spacer replacement work	08-Feb-2024	09:00	08-Feb-2024	18:00	-
118	527	PLANNED	OCC_575	MSLDC_OUTAGE	ALKUD - 400KV B/R 1	D	Routine maintenance work	08-Feb-2024	10:00	08-Feb-2024	17:00	--
119	528	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1	D	Testing and Diagnostic Testing work	08-Feb-2024	10:00	08-Feb-2024	18:00	Outage required for routine testing and maintenance work.
120	529	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-LONIKHAND-PUNE-PG-1	D	PID detected insulator string replacement and cold line washing of insulator strings.	08-Feb-2024	10:00	08-Feb-2024	18:00	-
121	536	PLANNED	OCC_575	MSLDC_OUTAGE	Pole-2 Non base AC filter Z3 (120 MVAR) @ PADGHE HVDC (ELEMENT NOT FOUND)	C	1. R-ph CB Pole,interrupter & Mechanisum box overhauling work. 2. Capacitor jumper replacement work.	08-Feb-2024	08:00	09-Feb-2024	08:00	CB Pole alongwith interrupter & mechanisum box is due for overhauling work. 2. Filter jumper old aged need to replace for avoiding hot spots.
122	553	PLANNED	OCC_575	POWERGRID_WR1	WARDHA - 220KV - BUS 2	C	For Replacement of Old BHEL Insulators on gantries of element	08-Feb-2024	7:00	08-Feb-2024	20:00	Insulator replacement work is proposaed to be done at 220kv Bus-2 at section above 220kv Bhugaon & above 220kv Pusad Line
123	554	PLANNED	OCC_575	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	C	For Replacement of Old BHEL Insulators on gantries of element	08-Feb-2024	7:00	08-Feb-2024	20:00	Insulator replacement work is proposaed to be done at 220kv Bus-2 at section above 220kv Bhugaon & above 220kv Pusad Line
124	555	PLANNED	OCC_575	POWERGRID_WR1	220KV-WARDHA-BHUGAON-1	C	For Replacement of Old BHEL Insulators on gantries of element	08-Feb-2024	7:00	08-Feb-2024	20:00	Insulator replacement work is proposaed to be done at 220kv Bus-2 at section above 220kv Bhugaon & above 220kv Pusad Line
125	599	Planned	OCC_575	MSLDC_OUTAGE	400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1	D	Routine Line maintenance work	09-Feb-2024	08:00	09-Feb-2024	18:00	400kV Bhusawal,400kV Dhule ckt I&II, Ektuni I&II will be in service
126	600	Planned	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintainance work	09-Feb-2024	08:00	09-Feb-2024	18:00	NA
127	601	Planned	OCC_575	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-2	D	Outage required for making 220kV half bus dead for jumpering of 220kV bus sectionalisser.	09-Feb-2024	08:00	09-Feb-2024	18:00	-

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
128	602	Planned	OCC_575	MSLDC_OUTAGE	400KV-TARAPUR 3-4-PADGHE-1	D	1)H/T required for safety proposed for removing of Gantry Jumper between 400kV Tarapur-I & II by	09-Feb-2024	09:00	09-Feb-2024	12:00	1.Weather Condition should be clear 2. Hot line team will be present on site.
129	603	Planned	OCC_575	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Dignostic testing work .	09-Feb-2024	09:00	09-Feb-2024	17:00	400 KV WARORA - DEOLI 2 Line is in ckt
130	604	Planned	OCC_575	MSLDC_OUTAGE	CHANDRAPUR SWITCHING STATION - 400KV - BUS 1	D	Diagnostic testing & allied bay maintenance work	09-Feb-2024	09:00	09-Feb-2024	18:00	Diagnostic testing & allied bay maintenance work
131	605	Planned	OCC_575	MSLDC_OUTAGE	TIE BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 765KV B/R 1	D	Testing and Diagnostic Testing work	09-Feb-2024	10:00	09-Feb-2024	19:00	Outage required for routine testing and maintenance work.
132	610	Planned	OCC_575	RGPPPL	TIE BAY OF 400KV/15.7KV RGPPPL-GT-2B AND 400KV/15.7KV RGPPPL-GT-2A @RGPPPL - 400KV at RGPPPL - 400KV	C	Attending SF6 leakages and gasket replacement	09-Feb-2024	8:00	11-Feb-2024	18:00	Attending SF6 leakages and gasket replacement on 452 breaker
133	611	Planned	OCC_575	MSLDC_OUTAGE	400KV-TARAPUR 3-4-PADGHE-2	C	1)H/t requires for replacement B Bus Conductor between 500MVA ICT-5 & 400kV Tarapur-II of Sec-I.	09-Feb-2024	05:00	11-Feb-2024	23:00	Weather Condition Should be clear.
134	612	Planned	OCC_575	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV PADGHE-ICT-5 AND PADGHE - 400KV - BUS 1 @PADGHE - 400KV at PADGHE - 400KV	C	1) B bus sec-1 Bus conductor replacement work between 500MVA ICT-5 & 400kV Tarapur-II 2) 500MVA ICT-5 in service through TBC	09-Feb-2024	05:00	11-Feb-2024	23:00	weather condition should be clear.
135	613	Planned	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	PID work	09-Feb-2024	08:00	23-Feb-2024	18:00	only A/R out of service during PID work.
136	617	PLANNED	OCC_575	MEGPTCL	KORADI-III - 765KV - BUS 2	D	Annual Maintenance of Bus Equipment at Koradi-III SS.	09-Feb-2024	09:00	09-Feb-2024	18:00	Bus Outage
137	621	PLANNED	OCC_575	POWERGRID_WR1	400KV-KARAD-SOLAPUR-1	C	Line terminal equipments AMP at 765kV Solapur Substation * Line disconnected from dead end tower. Dia to be kept open during AMP works.	09-Feb-2024	7:00	09-Feb-2024	18:00	
138	622	PLANNED	OCC_575	POWERGRID_WR1	400KV/220KV WARDHA-ICT-2	C	For Amp of ICT	09-Feb-2024	7:00	09-Feb-2024	20:00	
139	623	PLANNED	OCC_575	POWERGRID_WR1	WARDHA - 220KV - BUS 2	C	For Replacement of Old BHEL Insulators on gantries of element	09-Feb-2024	7:00	09-Feb-2024	20:00	Replacement of Old BHEL Insulators on gantries at intersection of both the Busses.
140	624	PLANNED	OCC_575	POWERGRID_WR1	WARDHA - 220KV - BUS 1	C	For Replacement of Old BHEL Insulators on gantries of element	09-Feb-2024	7:00	09-Feb-2024	20:00	Replacement of Old BHEL Insulators on gantries at intersection of both the Busses.
141	625	PLANNED	OCC_575	POWERGRID_WR1	KOLHAPUR-MS - 400KV B/R 2	C	Bay AMP	09-Feb-2024	8:00	09-Feb-2024	18:00	Outage required on CB only. Bus reactor can be kept in service through TBC.
142	635	PLANNED	OCC_575	NPCIL, TAPS 1&2	220 kV-Tarapur1&2 – Bhilad	C	220 kV-Tarapur1&2 – Bhilad outage is required to carry out routine annual maintenance and replacement of 220kV Lightning arresters.	10-Feb-2024	8:00	13-Feb-2024	20:00	Feeder outage is required to carry out routine annual maintenance and replacement of 220kV Lightning arresters
143	637	Planned	OCC_575	POWERGRID_WR2	220KV-BHILAD-VAPI-2	D	For busbar relay and LBB retrofitting work at Vapi PGCIL end.	10-Feb-2024	7:00	10-Feb-2024	18:00	PG-WR2-VAPI
144	658	Planned	OCC_575	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-2	D	PID Faulty string replacement work Cold line washing work	10-Feb-2024	09:00	10-Feb-2024	18:00	PID Faulty string replacement work Cold line washing work
145	662	PLANNED	OCC_575	MEGPTCL	KORADI-III - 400KV - BUS 2	C	Annual Maintenance of Bus Equipment at Koradi-III SS.	10-Feb-2024	09:00	10-Feb-2024	18:00	Bus Outage
146	682	Planned	OCC_575	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	H/W tightening and cleaning	11-Feb-2024	09:00	11-Feb-2024	18:00	load will managed on 400kv parli-karjat ckt-1
147	683	Planned	OCC_575	MSLDC_OUTAGE	400KV-TARAPUR 3-4-PADGHE-1	D	1)H/T required for safety proposed for re connection of Gantry Jumper between 400kV Tarapur-I & II by Hot line Method.	11-Feb-2024	14:00	11-Feb-2024	15:00	1.Weather condition should be clear. 2.Hot line team will be present on site.
148	687	Planned	OCC_575	MSLDC_OUTAGE	400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1	C	CB pole overhauling work	11-Feb-2024	09:00	14-Feb-2024	18:00	400 KV Aurangabad will be in service through TBC
149	692	PLANNED	OCC_575	POWERGRID_WR1	400KV-KOLHAPUR GIS-MAPUSA-2	C	AMP Works. AR IN NON AUTO MODE OF CKT#1	11-Feb-2024	7:00	11-Feb-2024	18:00	
150	694	PLANNED	OCC_575	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	C	Changeover of spare Reactor with R ph (765 KV Akola - Ektuni Line-02 reactor) for Cable replacement of mechanical protection and CTs for R ph (Akola - Ektuni line-02 non-switchable Reactor) at Ektuni SS.	11-Feb-2024	10:00	11-Feb-2024	18:00	Line Outage
151	695	PLANNED	OCC_575	ATIL	400KV-TIRODA-WARORA-1	C	Annual Maintenance of line	11-Feb-2024	08:00	12-Feb-2024	18:00	Line Outage

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
152	696	Planned	OCC_575	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	for removing ERS between Loc no. 168 to 170 used for Erection of newly proposed 3 No.s QD Tower in between Location no. 168 to 170 for the work of height rising for NHSRCL	12-Feb-2024	0:15	12-Feb-2024	9:00	During the outage destringing of ERS & removal of ERS towers will be carried out & stringing of conductor between newly erected and existing towers will be carried out and line will be charged.
153	697	Planned	OCC_575	MSLDC_OUTAGE	400KV-KALWA-PUNE-PG-1	D	for removing ERS between Loc no. 168 to 170 used for Erection of newly proposed 3 No.s QD Tower in between Location no. 168 to 170 for the work of height rising for NHSRCL	12-Feb-2024	0:15	12-Feb-2024	9:00	During the outage destringing of ERS & removal of ERS towers will be carried out & stringing of conductor between newly erected and existing towers will be carried out and line will be charged.
154	723	PLANNED	OCC_575	APML	400KV/11.5KV TIRODA-ST-1	D	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	12-Feb-2024	9:00	12-Feb-2024	18:00	400KV Line-1 will be in service on main bay
155	733	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintainance work	12-Feb-2024	08:00	12-Feb-2024	18:00	NA
156	734	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	"1.For Replacement of Flashover Disc 2.Diagnostic testing of Line Bay at Badnera S/s"	12-Feb-2024	09:00	12-Feb-2024	17:00	Outage
157	754	PLANNED	OCC_575	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	C	OPGW repairing work.	12-Feb-2024	08:00	13-Feb-2024	18:00	AR IN NON-AUTO AR in Non-auto mode
158	755	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	C	For AMP	12-Feb-2024	7:00	12-Feb-2024	18:00	
159	762	PLANNED	OCC_575	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV B/R 1 at KORADI-III - 765KV	C	Annual Maintenance of CB at Koradi-III SS.	12-Feb-2024	09:00	12-Feb-2024	18:00	Bay Outage
160	765	PLANNED	575	APML	400KV/11.5KV TIRODA-ST-1	D	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	12-Feb-2024	9:00	12-Feb-2024	18:00	400KV Line-1 will be in service on main bay
161	766	PLANNED	575	ATIL-TW	400KV-TIRODA-WARORA-2	D	Annual Maintenance of line	12-Feb-2024	8:00	12-Feb-2024	18:00	Line Outage
162	794	Planned	OCC_575	MSLDC_OUTAGE	KORADI - 400KV - BUS 1	D	MEASUREMENT OF CVT TAN DELTA	13-Feb-2024	05:00	13-Feb-2024	18:00	NA
163	796	Planned	OCC_575	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-AKOLA-2 AND 400KV-AKOLA-NANDGAONPETH-1 at AKOLA - 400KV	D	Routine Maintenance & testing work	13-Feb-2024	09:00	13-Feb-2024	18:00	Main Bay 411 wardha ckt -02 & Main bay 413 Nandgaon Ckt will be in service
164	798	Planned	OCC_575	APML	MAIN BAY - TIRODA - 765KV B/R 1 AND TIRODA - 765KV - BUS 1 at TIRODA - 765KV	C	706-52CB SF6 gas leakage attending	13-Feb-2024	9:00	14-Feb-2024	18:00	765KV BR-1 will be available with tie bay
165	803	Planned	OCC_575	MSLDC_OUTAGE	Pole-2 Non base AC filter Z3 (120 MVAR) @ PADGHE HVDC (ELEMENT NOT FOUND)	C	1. Y-ph CB Pole alongwith interrupter & mechanisum box overhauling work.. 2. Filter jumper replacement work.	13-Feb-2024	08:00	14-Feb-2024	08:00	CB Pole alongwith interrupter & mechanisum box is due for overhauling work. 2. Filter jumper old aged need to replace for avoiding hot spots.
166	807	PLANNED	OCC_575	MEGPTCL	KORADI-III - 400KV - BUS 1	D	Annual Maintenance of Bus Equipment at Koradi-III SS.	13-Feb-2024	09:00	13-Feb-2024	18:00	Bus Outage
167	808	PLANNED	OCC_575	POWERGRID_WR1	DHULE-MS - 400KV B/R 1	C	For AMP	13-Feb-2024	7:00	13-Feb-2024	18:00	
168	823	PLANNED	575	APML	MAIN BAY - TIRODA - 765KV B/R 1 AND TIRODA - 765KV - BUS 1 at TIRODA - 765KV	C	706-52CB SF6 gas leakage attending	13-Feb-2024	9:00	14-Feb-2024	18:00	765KV BR-1 will be available with tie bay
169	847	Planned	OCC_575	MSLDC_OUTAGE	400KV-KARAD-NEW KOYNA-2	D	Diagnostic testing & Relay testing work , Routine maint. Work	14-Feb-2024	08:00	14-Feb-2024	17:00	---
170	848	Planned	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	14-Feb-2024	08:00	14-Feb-2024	18:00	--
171	849	Planned	OCC_575	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Maintenance work	14-Feb-2024	09:00	14-Feb-2024	17:00	The said work is very important
172	850	Planned	OCC_575	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	D	H/W tightening and cleaning	14-Feb-2024	09:00	14-Feb-2024	18:00	Load managed on 400kv lamboti-Parli line
173	851	Planned	OCC_575	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	Routine Maint. Work	14-Feb-2024	09:00	14-Feb-2024	18:00	NA
174	861	Planned	OCC_575	RGPPPL	400KV-RGPPPL-NEW KOYNA-1	C	Attending SF6 leakages and gasket replacement	14-Feb-2024	8:00	16-Feb-2024	18:00	Line shutdown on continous basis is required to accommodate the crane for safe working from New Koyna-1 Line Jumper.

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
175	862	Planned	OCC_575	MSLDC_OUTAGE	400KV/220KV CHANDRAPUR-ICT-1	C	1. Maintenance of ICT 2. Measurement and alignment of Isolators 2. Bay routine maintenance work	14-Feb-2024	08:00	16-Feb-2024	18:00	1. During outage, 400KV ICT-2 & 220KV Chandrapur-2 will be in service.
176	863	Planned	OCC_575	MSLDC_OUTAGE	400KV/220KV KHAPARKHEDA-ICT-2	C	Replacement of Neutral Bushing of R & Y Ph Unit	14-Feb-2024	08:00	16-Feb-2024	18:00	NA
177	872	PLANNED	OCC_575	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	C	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)	14-Feb-2024	8:00	26-Feb-2024	18:00	
178	873	PLANNED	OCC_575	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	C	Diversion of 765 KV Aurangabad Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)	14-Feb-2024	8:00	26-Feb-2024	18:00	
179	874	PLANNED	OCC_575	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-1	C	AMP of Line Equipment at MSETCL Kudus substation and Autoreclosure scheme checking at Padghe SS. AR IN NON AUTO MODE OF CKT#2	14-Feb-2024	8:00	14-Feb-2024	17:00	
180	875	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - DHULE-MS - 400KV B/R 1 AND DHULE-MS - 400KV - BUS 1 at DHULE-MS - 400KV	C	For AMP	14-Feb-2024	7:00	14-Feb-2024	18:00	
181	882	PLANNED	OCC_575	POWERGRID_WR1	TIE BAY - 400KV-LONIKHAND-PUNE-PG-1 AND PUNE-PG - 400KV B/R 1 at PUNE-PG - 400KV	C	For AMP Work	14-Feb-2024	9:00	14-Feb-2024	17:30	
182	884	PLANNED	OCC_575	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND FUTURE at KORADI-III - 400KV	C	Annual Maintenance of Bay Equipments at Koradi-III SS.	14-Feb-2024	09:00	14-Feb-2024	18:00	Bay Outage
183	885	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	15-Feb-2024	09:00	29-Feb-2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
184	886	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KARAD-KOLHAPUR-MS-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	15-Feb-2024	09:00	29-Feb-2024	17:00	Permission for Auto Reclose to be kept in Non auto mode for PID testing work
185	887	Planned	OCC_575	MUML-Sterlite	400KV-PADGHE-NAGOTHANE-1	D	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	15-Feb-2024	9:00	16-Feb-2024	18:00	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML
186	888	Planned	OCC_575	MUML-Sterlite	400KV-PADGHE-NAGOTHANE-2	D	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	15-Feb-2024	9:00	16-Feb-2024	18:00	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML
187	925	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	15-Feb-2024	08:00	15-Feb-2024	18:00	--
188	926	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	(1) CT & CVT testing. (2) Bay maintenance work. (3) String cold washing & spacer replacement work	15-Feb-2024	09:00	15-Feb-2024	18:00	-
189	927	PLANNED	OCC_575	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	1. Bay CT PT testing 2. Annual relay testing work 3. QM of Bay	15-Feb-2024	09:00	15-Feb-2024	20:00	Line is ideally charged form Chikkodi end.
190	928	PLANNED	OCC_575	MSLDC_OUTAGE	400KV/220KV JEJURI-ICT-2	D	For Maintenance & Testing work	15-Feb-2024	09:30	15-Feb-2024	18:00	ICT-1 & ICT-3 will continue to remain in service
191	929	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-CHAKAN-PUNE-PG-1	D	For Installation of SF6 Gauge to a CB pole. DT and Routine Maintenance. PID detected insulator string replacement and cold line washing of insulator strings.	15-Feb-2024	10:00	15-Feb-2024	18:00	-
192	930	PLANNED	OCC_575	APML	TIE BAY OF 765KV/21KV TIRODA-GT-5 AND 765KV-TIRODA-KORADI-III-1 @TIRODA - 765KV at TIRODA - 765KV	C	708-52CB SF6 gas leakage attending	15-Feb-2024	9:00	16-Feb-2024	18:00	765KV/21KV GT-5 & 765KV-TIRODA-KORADI-III-1 will be available with main bay
193	934	PLANNED	OCC_575	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-3	C	Rapid Restoration Scheme work;DFRA;Quarterly bay maintenance work	15-Feb-2024	09:00	17-Feb-2024	18:00	315 MVA ICT I and II and 501 MVA ICT IV will be in service
194	935	PLANNED	OCC_575	SCEKAPS34	220KV/6.6KV KAKRAPAR 1&2-ST-4	C	PM of Transformer (Cleaning, HOC and testing), CTs, CVTs, isolators.	15-Feb-2024	8:00	27-Feb-2024	20:00	
195	938	PLANNED	OCC_575	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2 L/R@ AURANGABAD - 765KV	C	Drive Mechanism Inspection Work by OEM & AMP	15-Feb-2024	7:00	16-Feb-2024	18:00	707LR
196	939	PLANNED	OCC_575	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	C	Drive Mechanism Inspection Work by OEM & AMP of LR CB. Drive Mechanism Inspection Work by OEM & AMP of LR CB. Line outage is proposed as per the requirement of RLDC.	15-Feb-2024	7:00	16-Feb-2024	18:00	707L

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
197	940	PLANNED	OCC_575	POWERGRID_WR1	400KV-KALA-KUDUS-2	C	AMP of 401L at MSETCL Kudus Substation. Ckt-1 A/R off	15-Feb-2024	8:30	15-Feb-2024	17:00	
198	943	PLANNED	OCC_575	POWERGRID_WR1	400KV-DHARIWAL-PARLI-2	C	Reactor Leakage to be checked. AR in non auto mode of 400KV Bhadrawati-Parli is required.	15-Feb-2024	7:00	15-Feb-2024	18:00	
199	955	PLANNED	OCC_575	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	C	Annual Maintenance of CB at Koradi-III SS.	15-Feb-2024	09:00	15-Feb-2024	18:00	Bay Outage
200	956	PLANNED	OCC_575	POWERGRID_WR1	400KV-BHILAI-KORADI-I	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box, Fixed Contact and MOM Box of Transfer Bus, Keeping Bhilai Line Out of Service.	15-Feb-2024	7:00	16-Feb-2024	20:00	
201	957	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 400KV-BHILAI-KORADI-I AND KORADI - 400KV - BUS 1 at Koradi - 400KV	C	Overhauling of BHI CGL CB at Koradi SS, 400kv Koradi-Bhilai Line	15-Feb-2024	7:00	20-Feb-2024	20:00	
202	958	PLANNED	575	APML	TIE BAY OF 765KV/21KV TIRODA-GT-5 AND 765KV-TIRODA-KORADI-III-1 @TIRODA - 765KV at TIRODA - 765KV	C	708-52CB SF6 gas leakage attending	15-Feb-2024	9:00	16-Feb-2024	18:00	765KV/21KV GT-5 & 765KV-TIRODA-KORADI-III-1 will be available with main bay
203	989	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-2	D	Outage required for making 220kV half bus dead for jumpering of 220kV bus sectionaliser.	16-Feb-2024	08:00	16-Feb-2024	18:00	-
204	990	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPU-II-1	D	Relay testing work & routine maintenace work.	16-Feb-2024	09:00	16-Feb-2024	17:00	Load manage on 400KV Chandrapur 2 Ckt 2 ,parallel ckt
205	991	PLANNED	OCC_575	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For Replacement of Flashover Disc by Hot Line Method Shifting of auto reclose switch to non auto mode	16-Feb-2024	09:00	16-Feb-2024	17:00	Hot Line Work
206	997	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	D	PID testing	16-Feb-2024	09:00	29-Feb-2024	17:00	No outage required
207	1041	PLANNED	OCC_575	POWERGRID_WR1	TIE BAY - 400KV-KALA-KUDUS-2 AND FUTURE at KUDUS - 400KV	C	AMP of 402 bay at MSETCL Kudus	17-Feb-2024	8:00	17-Feb-2024	18:00	
208	1046	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 220KV-TALEGAON-PUNE-PG-1 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	C	For AMP Work	17-Feb-2024	9:00	17-Feb-2024	17:30	Before S/D of 202 Bay same bay load will shift on TBC Bay (204)
209	894	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.	17-Feb-2024	08:00	17-Feb-2024	17:00	Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.
210	895	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	Outage required for attending defects identified in PID testing, Monkey/Drone Patrolling and Cold washing of Dust polluted Insulator Strings.	17-Feb-2024	08:00	17-Feb-2024	18:00	400kV Babhaleshwar-Padghe Ckt -2 will be available.
211	1066	PLANNED	OCC_575	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	C	Changeover of Rph Reactor with Y ph (765 KV Akola - Ektuni Line-02 non-switchable reactor) for Cable replacement of mechanical protection and CTs for Y ph (Akola - Ektuni line-02 non-switchable Reactor) at Ektuni.	18-Feb-2024	10:00	18-Feb-2024	18:00	Line Outage
212	903	PLANNED	OCC_575	POWERGRID_WR2	400KV/220KV BOISAR-ICT-3	D	AMP WORK, Dia to be Kept open at both sides.	18-Feb-2024	7:00	18-Feb-2024	21:00	PG-WR2-BOISAR
213	913	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	D	Outage required for attending defects identified in PID testing, Monkey/Drone Patrolling and Cold washing of Dust polluted Insulator Strings.	18-Feb-2024	08:00	18-Feb-2024	18:00	400kV Babhaleshwar-Padghe ckt-1 will be available.
214	1437	PLANNED	OCC_575	POWERGRID_WR1	765KV/400KV PADGHE-PG-ICT-2	D	SPARE NORMALIZATION, TAKING R-Ph IN & Spare OUT	18-Feb-2024	9:00	18-Feb-2024	13:00	ICT-2 was handtrip on 11.04.2023 due to PD in R ph. ICT-2 was charged on 11.04.2023 with spare in place of R ph.

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
215	1603	PLANNED	OCC_575	MEGPTCL	765KV-AKOLA (2)-EKTUNI-2	C	Changeover of Rph Reactor with Y ph (765 KV Akola - Ektuni Line-02 non-switchable reactor) for Cable replacement of mechanical protection and CTs for Y ph (Akola - Ektuni line-02 non-switchable Reactor) at Ektuni.	18-Feb-2024	10:00	18-Feb-2024	18:00	Line Outage
216	1090	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For Replacement of Flashover Disc by Hot Line Method Shifting of auto reclose switch to non auto mode	19-Feb-2024	09:00	19-Feb-2024	17:00	Hot Line Work
217	1091	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintainance work	19-Feb-2024	10:00	19-Feb-2024	18:00	NA
218	1096	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-2	D	for hotline washing work (jaigad-newkoyna ckt 2 AR Out)	19-Feb-2024	09:00	29-Feb-2024	18:00	for hotline washing work (jaigad-newkoyna ckt 2 AR Out)
219	1097	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-1	D	for Hotline washing work (jaigad-newkoyna ckt 1 AR Out)	19-Feb-2024	09:00	29-Feb-2024	18:00	for Hotline washing work (jaigad-newkoyna ckt 1 AR Out)
220	1110	PLANNED	OCC_575	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	C	Annual testing of bay equipments	19-Feb-2024	09:00	19-Feb-2024	18:00	765KV TIRODA KORADI-III-2 WILL BE IN SERVICE ON TIE BAY
221	950	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For Replacement of Flashover Disc by Hot Line Method Shifting of auto reclose switch to non auto mode	19-Feb-2024	09:00	19-Feb-2024	17:00	Hot Line Work
222	951	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintainance work	19-Feb-2024	10:00	19-Feb-2024	18:00	NA
223	957	PLANNED	OCC_575	MSLDC_OUTAGE	TIE BAY (411) OF DHARIWAL CKT - 2 & NANDED CKT @ CHANDRAPUR - 2(ELEMENT NOT FOUND)	C	Replacement of non-PIR CB by with PIR CB	19-Feb-2024	09:00	26-Feb-2024	17:00	Outage will be on continous basis and lines will be in service through their respective main Bays
224	958	PLANNED	OCC_575	POWERGRID_WR2	400KV-ITARSI-INDORE-MP-2 L/R@ INDORE-MP - 400KV	D	FOR OIL FILTRATION OF REACTORS (SWITCHABLE LR) DUE TO HIGH MOISTURE IN OIL (OFF LINE DRY OUT WORK)	19-Feb-2024	7:00	29-Feb-2024	18:00	PG-WR2-INDORE
225	959	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-2	D	for hotline washing work (jaigad-newkoyna ckt 2 AR Out)	19-Feb-2024	09:00	29-Feb-2024	18:00	for hotline washing work (jaigad-newkoyna ckt 2 AR Out)
226	960	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-JAIGAD-NEW KOYNA-1	D	for Hotline washing work (jaigad-newkoyna ckt 1 AR Out)	19-Feb-2024	09:00	29-Feb-2024	18:00	for Hotline washing work (jaigad-newkoyna ckt 1 AR Out)
227	1617	PLANNED	OCC_575	MEGPTCL	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND TIRODA - 765KV - BUS 2 at TIRODA - 765KV	C	Annual testing of bay equipments	19-Feb-2024	09:00	19-Feb-2024	18:00	765KV TIRODA KORADI-III-2 WILL BE IN SERVICE ON TIE BAY
228	1143	PLANNED	OCC_575	MSLDC_OUTAGE	BUS COUPLER BAY OF DHULE - 400KV - BUS 1 AND DHULE - 400KV - BUS 2 @DHULE - 400KV at DHULE - 400KV	D	Routine Circuit Breaker DCRM & CT Testing & Maint of bay	20-Feb-2024	09:00	20-Feb-2024	18:00	Routine Circuit Breaker DCRM & CT Testing & Maint of bay
229	1144	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 400KV - BUS 2 at EKTUNI - 400KV	D	Testing and Diagnostic Testing work	20-Feb-2024	10:00	20-Feb-2024	18:00	Outage required for routine testing and maintenance work.
230	1145	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintainace work	20-Feb-2024	10:00	20-Feb-2024	18:00	NA
231	1149	PLANNED	OCC_575	APML	400KV/11.5KV TIRODA-ST-5	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	20-Feb-2024	9:00	22-Feb-2024	18:00	ST-3 will be in service with main bay
232	1150	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Cold Washing Work, Earthwire replacement, Diagnostic testing & Relay testing work , Routine maint. Work	20-Feb-2024	08:00	22-Feb-2024	18:00	----
233	1151	PLANNED	OCC_575	MSLDC_OUTAGE	400KV/220KV CHANDRAPUR-ICT-2	C	1. Maintenance of ICT 2. Measurement and alignment of Isolators 3. Bay routine maintenance work	20-Feb-2024	08:00	22-Feb-2024	18:00	1. During outage, 400KV ICT-1 & 220KV Chandrapur-2 will be in service.
234	1173	PLANNED	OCC_575	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-2	C	Relay replacement works at Bhadrawati SS	20-Feb-2024	7:00	20-Feb-2024	20:00	
235	1184	PLANNED	OCC_575	MEGPTCL	765KV/400KV KORADI-III-ICT-1	C	Annual Maintenance of ICT at Koradi-III SS.	20-Feb-2024	09:00	20-Feb-2024	18:00	ICT Outage.
236	1192	PLANNED	575	APML	400KV/11.5KV TIRODA-ST-5	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	20-Feb-2024	9:00	22-Feb-2024	18:00	ST-3 will be in service with main bay

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
237	1002	PLANNED	OCC_575	MSLDC_OUTAGE	BUS COUPLER BAY OF DHULE - 400KV - BUS 1 AND DHULE - 400KV - BUS 2 @DHULE - 400KV at DHULE - 400KV	D	Routine Circuit Breaker DCRM & CT Testing & Maint of bay	20-Feb-2024	09:00	20-Feb-2024	18:00	Routine Circuit Breaker DCRM & CT Testing & Maint of bay
238	1005	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY - 765KV/400KV EKTUNI-ICT-2 AND EKTUNI - 400KV - BUS 2 at EKTUNI - 400KV	D	Testing and Diagnostic Testing work	20-Feb-2024	10:00	20-Feb-2024	18:00	Outage required for routine testing and maintenance work.
239	1006	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintainace work	20-Feb-2024	10:00	20-Feb-2024	18:00	NA
240	1011	PLANNED	OCC_575	APML	400KV/11.5KV TIRODA-ST-5	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	20-Feb-2024	9:00	22-Feb-2024	18:00	ST-3 will be in service with main bay
241	1012	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Cold Washing Work, Earthwire replacement, Diagnostic testing & Relay testing work , Routine	20-Feb-2024	08:00	22-Feb-2024	18:00	----
242	1013	PLANNED	OCC_575	MSLDC_OUTAGE	400KV/220KV CHANDRAPUR-ICT-2	C	1. Maintenance of ICT 2. Measurement and alignment of Isolators 2. Bay routine maintenance work	20-Feb-2024	08:00	22-Feb-2024	18:00	1. During outage, 400KV ICT-1 & 220KV Chandrapur-2 will be in service.
243	1625	PLANNED	OCC_575	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-2	C	Relay replacement works at Bhadrawati SS	20-Feb-2024	7:00	20-Feb-2024	20:00	
244	1754	PLANNED	575	APML	400KV/11.5KV TIRODA-ST-5	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	20-Feb-2024	9:00	22-Feb-2024	18:00	ST-3 will be in service with main bay
245	1193	PLANNED	OCC_575	POWERGRID_WR2	BOISAR - 220KV - BUS 1	D	AMP WORK	21-Feb-2024	9:00	21-Feb-2024	18:00	PG-WR2-BOISAR
246	1219	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work	21-Feb-2024	08:00	21-Feb-2024	18:00	--
247	1220	PLANNED	OCC_575	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	Routine maintenance and diagnostic testing such as CVT tan delta & maintenance work	21-Feb-2024	09:00	21-Feb-2024	17:00	1) 400KV MAIN BUS-2 WILL BE IN SERVICE. 2) 400KV,125MVAR reactor kept off position during outage.
248	1221	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line/Substation maintenance	21-Feb-2024	09:00	21-Feb-2024	17:30	-
249	1222	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	H/W tightening and cleaning	21-Feb-2024	09:00	21-Feb-2024	18:00	load will managed on 220kv jeur-tembhurni line
250	1223	PLANNED	OCC_575	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	Routine Maint. Work	21-Feb-2024	09:00	21-Feb-2024	18:00	NA
251	1224	PLANNED	OCC_575	MSLDC_OUTAGE	TIE BAY - 400KV-WARORA-CHANDRAPU-II-2 AND FUTURE at CHANDRAPUR-II - 400KV	D	Diagnostic testing & allied bay maintenance work	21-Feb-2024	10:00	21-Feb-2024	17:00	Diagnostic testing & allied bay maintenance work
252	1243	PLANNED	OCC_575	MEGPTCL	765KV/400KV KORADI-III-ICT-1	C	Testing of Metering CT of ICT-1 at Koradi-III SS.	21-Feb-2024	09:00	21-Feb-2024	18:00	ICT Outage.
253	5	PLANNED	OCC_575	POWERGRID_WR2	BOISAR - 220KV - BUS 1	D	AMP WORK	21-Feb-2024	9:00	21-Feb-2024	18:00	PG-WR2-BOISAR
254	1059	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-1	D	Maintenance work	21-Feb-2024	08:00	21-Feb-2024	18:00	--
255	1060	PLANNED	OCC_575	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	Routine maintenance and diagnostic testing such as CVT tan delta & maintenance work	21-Feb-2024	09:00	21-Feb-2024	17:00	1) 400KV MAIN BUS-2 WILL BE IN SERVICE. 2) 400KV,125MVAR reactor kept off position during outage.
256	1061	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line/Substation maintenance	21-Feb-2024	09:00	21-Feb-2024	17:30	-
257	1062	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-SOLAPUR-JEUR-1	D	H/W tightening and cleaning	21-Feb-2024	09:00	21-Feb-2024	18:00	load will managed on 220kv jeur-tembhurni line
258	1063	PLANNED	OCC_575	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	Routine Maint. Work	21-Feb-2024	09:00	21-Feb-2024	18:00	NA
259	1064	PLANNED	OCC_575	MSLDC_OUTAGE	TIE BAY - 400KV-WARORA-CHANDRAPU-II-2 AND FUTURE at CHANDRAPUR-II - 400KV	D	Diagnostic testing & allied bay maintenance work	21-Feb-2024	10:00	21-Feb-2024	17:00	Diagnostic testing & allied bay maintenance work
260	1658	PLANNED	OCC_575	MEGPTCL	765KV/400KV KORADI-III-ICT-1	C	Testing of Metering CT of ICT-1 at Koradi-III SS.	21-Feb-2024	09:00	21-Feb-2024	18:00	ICT Outage.
261	1271	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work.	22-Feb-2024	08:00	22-Feb-2024	18:00	--
262	1273	PLANNED	OCC_575	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	22-Feb-2024	09:00	22-Feb-2024	17:00	The said work is very important

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
263	1274	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	22-Feb-2024	09:00	22-Feb-2024	17:00	The said work is very important
264	1275	PLANNED	OCC_575	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	22-Feb-2024	09:00	22-Feb-2024	18:00	During 400KV Busbar Protection Relay testing works Outage , (1). 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work (2)The 400KV Busbar Relay will be tested Online by taking necessary precautions of 400KV Bus-I/Bus-II Bays ,respective Bays CT shorting arrangement and isolation of respective 400KV Bays Busbar Relays trippings etc. as per requirement prior to testing. (3) During the outage , On 400KV Bus I , Ckt's connected on Bus I i.e.,400KV Adani ckt. 1 & 2 ,PGCIL-Nagari,IEPL and 400KV Bus Reactor remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened during the said outage . (4) During the outage , On 400KV Bus II , Ckt's connected on Bus II i.e.,400KV Cpur-II ckt-1 & 2 , 400KV Future Line-1/2 and ICT-1 remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened during the outage . (5) All 400KV Bays Tie CBs/Isolators will be in service. No 400KV Tie Bus CBs/Isolators will be isolated/denosed.
265	1276	PLANNED	OCC_575	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-1	D	Testing and Diagnostic Testing work	22-Feb-2024	09:00	22-Feb-2024	20:00	Outage required for routine testing and maintenance work.
266	1277	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	D	Q/M of bay	22-Feb-2024	09:00	22-Feb-2024	23:00	load will be managed on 400 kV Kolhapur PG ckt 2
267	1278	PLANNED	OCC_575	MSLDC_OUTAGE	BUS COUPLER BAY OF CHAKAN - 400KV BUS-I AND CHAKAN	D	Replacement of 89A and 89B 400kV PG Isolator	22-Feb-2024	10:00	22-Feb-2024	18:00	-
268	1282	PLANNED	OCC_575	MUML-Sterlite	765KV-AURANGABAD-PADGHE-PG-1	D	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	22-Feb-2024	9:00	23-Feb-2024	18:00	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML
269	1283	PLANNED	OCC_575	MUML-Sterlite	765KV-AURANGABAD-PADGHE-PG-2	D	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	22-Feb-2024	9:00	23-Feb-2024	18:00	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML
270	1284	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Cold Washing Work,Diagnostic testing & Relay testing work , Routine maint. Work	22-Feb-2024	08:00	23-Feb-2024	18:00	----
271	1285	PLANNED	OCC_575	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-4	C	Rapid Restoration Scheme work; LV LBB relay,LV CT tan D, Bushing tan D, DFRA;Quarterly bay maintenance work	22-Feb-2024	09:00	24-Feb-2024	18:00	315 MVA ICT I and II and 501 MVA ICT III will be in service
272	1296	PLANNED	OCC_575	MEGPTCL	765KV/400KV KORADI-III-ICT-2	C	Annual Maintenance of ICT at Koradi-III SS.	22-Feb-2024	09:00	22-Feb-2024	18:00	ICT Outage.
273	1297	PLANNED	OCC_575	POWERGRID_WR1	400KV-KORADI-SATPURA-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box, Fixed Contact and MOM Box of Transfer Bus, Keeping Sami Line Out of Service.	22-Feb-2024	7:00	23-Feb-2024	20:00	
274	1299	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 400KV-KORADI-SATPURA-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV	C	Overhauling of SRN CGL CB at Koradi SS, 400kv Koradi-Sami Line	22-Feb-2024	7:00	27-Feb-2024	20:00	
275	1105	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work.	22-Feb-2024	08:00	22-Feb-2024	18:00	--
276	1107	PLANNED	OCC_575	MSETCL	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	22-Feb-2024	09:00	22-Feb-2024	17:00	The said work is very important
277	1108	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-TALANGADE(MS)-CHIKKODI-II-1	D	Maintenance work	22-Feb-2024	09:00	22-Feb-2024	17:00	The said work is very important

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
278	1109	PLANNED	OCC_575	MSLDC_OUTAGE	WARORA - 400KV - BUS 1	D	For 400KV Numerical Busbar Relay Make SIFANG CSC150 testing works	22-Feb-2024	09:00	22-Feb-2024	18:00	During 400KV Busbar Protection Relay testing works Outage , (1). 400KV Bus-I and 400KV Bus-II protection will be kept out of service during testing work (2)The 400KV Busbar Relay will be tested Online by taking necessary precautions of 400KV Bus-I/Bus-II Bays ,respective Bays CT shorting arrangement and isolation of respective 400KV Bays Busbar Relays trippings etc. as per requirement prior to testing. (3) During the outage , On 400KV Bus I , Ckt's connected on Bus I i.e.,400KV Adani ckt. 1 & 2 ,PGCIL-Nagari,IEPL and 400KV Bus Reactor remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened during the said outage . (4) During the outage , On 400KV Bus II , Ckt's connected on Bus II i.e.,400KV Cpur-II ckt-1 & 2 , 400KV Future Line-1/2 and ICT-1 remains charged through their respective Main CBs .No any CB or Isolator will be isolated /opened during the outage . (5) All 400KV Bays Tie CBs/Isolators will be in service. No any 400KV Tie Bay CBs/Isolator will be isolated /opened
279	1110	PLANNED	OCC_575	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-1	D	Testing and Diagnostic Testing work	22-Feb-2024	09:00	22-Feb-2024	20:00	Outage required for routine testing and maintenance work.
280	1111	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	D	Q/M of bay	22-Feb-2024	09:00	22-Feb-2024	23:00	load will be managed on 400 kV Kolhapur PG ckt 2
281	1112	PLANNED	OCC_575	MSLDC_OUTAGE	BUS COUPLER BAY OF CHAKAN - 400KV - BUS 1 AND CHAKAN - 400KV - BUS 2 @CHAKAN - 400KV at CHAKAN - 400	D	Replacement of 89A and 89B 400kv PG Isolator scissors, Routine maintenance and DT.	22-Feb-2024	10:00	22-Feb-2024	18:00	-
282	1116	PLANNED	OCC_575	MUML-Sterlite	765KV-AURANGABAD-PADGHE-PG-1	D	For crossing of under construction 400kv D/C Padghe - Kharghar Transmission line of MUML	22-Feb-2024	9:00	23-Feb-2024	18:00	For crossing of under construction 400kv D/C Padghe - Kharghar Transmission line of MUML
283	1117	PLANNED	OCC_575	MUML-Sterlite	765KV-AURANGABAD-PADGHE-PG-2	D	For crossing of under construction 400kv D/C Padghe - Kharghar Transmission line of MUML	22-Feb-2024	9:00	23-Feb-2024	18:00	For crossing of under construction 400kv D/C Padghe - Kharghar Transmission line of MUML
284	1119	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Cold Washing Work,Diagnostic testing & Relay testing work , Routine maint. Work	22-Feb-2024	08:00	23-Feb-2024	18:00	----
285	1121	PLANNED	OCC_575	MSLDC_OUTAGE	400KV/220KV BABLESHWAR-ICT-4	C	Rapid Restoration Scheme work; LV LBB relay,LV CT tan D, Bushing tan D,	22-Feb-2024	09:00	24-Feb-2024	18:00	315 MVA ICT I and II and 501 MVA ICT III will be in service
286	1662	PLANNED	OCC_575	POWERGRID_WR1	765KV-PUNE-GIS-SOLAPUR-1	C	PRV NC contact modification in all 3 units of Reactor. Line outage is proposed as per the requirement of RLDC	22-Feb-2024	7:00	22-Feb-2024	20:00	Line will be in service
287	1663	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 400KV-BHILAI-KORADI-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV	C	For Bay Amp works	22-Feb-2024	7:00	22-Feb-2024	20:00	
288	1669	PLANNED	OCC_575	POWERGRID_WR1	PUNE-PG - 220KV - BUS 2	C	For AMP Work	22-Feb-2024	9:00	22-Feb-2024	17:30	Before S/D of 220kv BUS_2, ALL Load on 220 Kv BUS_2 will shift on 220 Kv BUS_1 by closing respective bay 89A Isolator and Opening the respective Bay 89B Isolator and while work on Respective Bay of 89B Isolator/ BUS clamps same bay will shift on TBC 204 Bay for Electrical clearance
289	1670	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 765KV-BILASPUR-RAJNANDGAON-RRWTL-1 AND BILASPUR - 765KV - BUS 1 at BILASPUR - 765KV	C	AMP works	22-Feb-2024	9:00	22-Feb-2024	18:00	BAY-710
290	1671	PLANNED	OCC_575	MEGPTCL	765KV/400KV KORADI-III-ICT-2	C	Annual Maintenance of ICT at Koradi-III SS.	22-Feb-2024	09:00	22-Feb-2024	18:00	ICT Outage.
291	1672	PLANNED	OCC_575	POWERGRID_WR1	400KV-KORADI-SATPURA-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box, Fixed Contact and MOM Box of Transfer Bus, Keeping Sami Line Out of Service.	22-Feb-2024	7:00	23-Feb-2024	20:00	
292	1677	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 400KV-KORADI-SATPURA-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV	C	Overhauling of SRN CGL CB at Koradi SS, 400kv Koradi-Sami Line	22-Feb-2024	7:00	27-Feb-2024	20:00	

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
293	1329	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPUR-II-2	D	LINE CT TAN DELTA ,IR VALUE and Diagnostic testing work maintenance work etc	23-Feb-2024	09:00	23-Feb-2024	17:00	Load will managed by 400KV WARORA-CHANDRAPUR 2 CKT. 1 Bay no 413.
294	1333	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 400KV-KORADI-SATPURA-1 AND KORADI - 400KV -	C	For Bay Amp works	23-Feb-2024	7:00	23-Feb-2024	20:00	
295	1344	PLANNED	OCC_575	MEGPTCL	765KV/400KV KORADI-III-ICT-2	C	Testing of Metering CT of ICT-2 at Koradi-III SS.	23-Feb-2024	09:00	23-Feb-2024	18:00	ICT Outage.
296	1346	PLANNED	OCC_575	ATIL	TIRODA - 400KV B/R 2	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	23-Feb-2024	09:00	24-Feb-2024	18:00	BR-1 will be in service with main bay
297	1137	PLANNED	OCC_575	POWERGRID_WR2	400KV/220KV BOISAR-ICT-4	D	AMP WORK, Dia to be Kept open at both sides.	23-Feb-2024	7:00	23-Feb-2024	21:00	PG-WR2-BOISAR
298	1161	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-WARORA-CHANDRAPUR-II-2	D	LINE CT TAN DELTA ,IR VALUE and Diagnostic testing work maintenance work etc	23-Feb-2024	09:00	23-Feb-2024	17:00	Load will managed by 400KV WARORA-CHANDRAPUR 2 CKT. 1 Bay no 413.
299	1162	PLANNED	OCC_575	MSLDC_OUTAGE	400KV/220KV PADGHE-ICT-4	C	1) Oil filtration of all Phase unit due to low BDV and increase in Key Gases . 2) Replacement of Diff Realy 3) wiring work in CP & RP for remote operation from CR 4) Diagnostic Testing work. 5) Replacement of Faulty WTI & OTI 6) Bay Maint work 7) MTAMC work	23-Feb-2024	06:00	25-Feb-2024	23:59	weather condition should be clear .
300	1681	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 400KV-KORADI-SATPURA-1 AND KORADI - 400KV - BUS 1 at Koradi - 400KV	C	For Bay Amp works	23-Feb-2024	7:00	23-Feb-2024	20:00	
301	1691	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 220KV-TALEGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	C	For AMP Work	23-Feb-2024	9:00	23-Feb-2024	17:30	Beffore S/D of 207 Bay same bay load will shift on TBC Bay (204)
302	1694	PLANNED	OCC_575	MEGPTCL	765KV/400KV KORADI-III-ICT-2	C	Testing of Metering CT of ICT-2 at Koradi-III SS.	23-Feb-2024	09:00	23-Feb-2024	18:00	ICT Outage.
303	1695	PLANNED	OCC_575	POWERGRID_WR1	MAIN BAY - 765KV/400KV TAMNAR-ICT-3 AND TAMNAR - 765KV - BUS 1	C	CT cleaning	23-Feb-2024	8:30	24-Feb-2024	17:30	709
304	1696	PLANNED	OCC_575	ATIL	TIRODA - 400KV B/R 2	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	23-Feb-2024	09:00	24-Feb-2024	18:00	BR-1 will be in service with main bay
305	1760	PLANNED	OCC_575	ATIL-TW	TIRODA - 400KV B/R 2	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	23-Feb-2024	9:00	24-Feb-2024	18:00	BR-1 will be in service with main bay
306	1378	PLANNED	OCC_575	POWERGRID_WR1	400KV-KORADI-SATPURA-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box and MOM Box for Bus-1 & Bus-2, Keeping Sarni line on TBC Bay.	24-Feb-2024	7:00	27-Feb-2024	20:00	
307	1192	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 12 to Bay No. 14) for:- 1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S.	24-Feb-2024	07:00	24-Feb-2024	18:00	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 12 to Bay No. 14) for:- 1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S.
308	1193	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	C	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 13 to Bay No. 12) for:- Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S.	24-Feb-2024	22:00	25-Feb-2024	22:00	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 13 to Bay No. 12) for:- Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S.
309	1697	PLANNED	OCC_575	POWERGRID_WR1	SOLAPUR - 400KV B/R 1	C	PRV NC contact modification	24-Feb-2024	7:00	24-Feb-2024	18:00	
310	1709	PLANNED	OCC_575	POWERGRID_WR1	400KV-KORADI-SATPURA-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box and MOM Box for Bus-1 & Bus-2, Keeping Sarni line on TBC Bay.	24-Feb-2024	7:00	27-Feb-2024	20:00	
311	1379	PLANNED	OCC_575	MEGPTCL	765KV/400KV AKOLA (2)-ICT-1	C	Annual maintenance of ICT	25-Feb-2024	10:00	25-Feb-2024	18:00	ICT OUTAGE
312	1198	PLANNED	OCC_575	POWERGRID_WR2	BOISAR - 220KV - BUS 1	D	AMP WORK	25-Feb-2024	9:00	25-Feb-2024	17:30	PG-WR2-BOISAR

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
313	1199	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work & and installation of fridge wedge connector at mid-span joint	25-Feb-2024	09:00	25-Feb-2024	18:00	SSN to DSN insulator string Conversion work & and installation of fridge wedge connector at mid-span joint
314	1710	PLANNED	OCC_575	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 L/R@ AURANGABAD-M (WALUJ) - 400KV	C	For LR AMP	25-Feb-2024	7:00	25-Feb-2024	18:00	
315	1711	PLANNED	OCC_575	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	C	For Taking LR Out & In service	25-Feb-2024	7:00	25-Feb-2024	18:00	
316	1712	PLANNED	OCC_575	POWERGRID_WR1	400KV-KHARGHAR-PUNE-PG-1	C	For AMP Work	25-Feb-2024	9:00	25-Feb-2024	17:30	Line Owned By MSETCL Trans
317	1713	PLANNED	OCC_575	MEGPTCL	765KV/400KV AKOLA (2)-ICT-1	C	Annual maintenance of ICT	25-Feb-2024	10:00	25-Feb-2024	18:00	ICT OUTAGE
318	1392	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	REPLACEMENT OF FAULTY STRINGS AND LINES MAINT WPRKS	26-Feb-2024	06:00	26-Feb-2024	18:00	NA
319	1393	PLANNED	OCC_575	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	26-Feb-2024	09:00	26-Feb-2024	17:00	The said work is very important
320	1395	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Cold Washing Work	26-Feb-2024	08:00	27-Feb-2024	18:00	---
321	1403	PLANNED	OCC_575	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	C	For Line Bay Amp Works	26-Feb-2024	7:00	26-Feb-2024	20:00	
322	1407	PLANNED	OCC_575	ATIL	TIRODA - 400KV B/R 1	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	26-Feb-2024	09:00	27-Feb-2024	18:00	BR-2 will be in service with main bay
323	1214	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	REPLACEMENT OF FAULTY STRINGS AND LINES MAINT WPRKS	26-Feb-2024	06:00	26-Feb-2024	18:00	NA
324	1215	PLANNED	OCC_575	MSETCL	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	26-Feb-2024	09:00	26-Feb-2024	17:00	The said work is very important
325	1216	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	26-Feb-2024	09:00	26-Feb-2024	17:00	The said work is very important
326	1219	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Cold Washing Work	26-Feb-2024	08:00	27-Feb-2024	18:00	---
327	1223	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	PID testing of insulator A/R function required to be in non auto mode.	26-Feb-2024	09:00	28-Feb-2024	18:00	PID testing of insulator A/R function required to be in non auto mode.
328	1717	PLANNED	OCC_575	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	C	For Line Bay Amp Works	26-Feb-2024	7:00	26-Feb-2024	20:00	
329	1721	PLANNED	OCC_575	ATIL	TIRODA - 400KV B/R 1	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	26-Feb-2024	09:00	27-Feb-2024	18:00	BR-2 will be in service with main bay
330	1761	PLANNED	OCC_575	ATIL-TW	TIRODA - 400KV B/R 1	C	Annual Maintenance & Testing Transformer. Annual maintenance of main bay and tie bay equipments.	26-Feb-2024	9:00	27-Feb-2024	18:00	BR-2 will be in service with main bay
331	1409	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	AR disable for replacement of insulator in live line method.	27-Feb-2024	8:00	29-Feb-2024	18:00	AR disable
332	1410	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	AR disable for replacement of insulator in live line method.	27-Feb-2024	8:00	29-Feb-2024	18:00	AR disable
333	1413	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KALWA-KHARGHAR-1	D	PID testing of insulator A/R function required to be in non auto mode.	27-Feb-2024	09:00	29-Feb-2024	18:00	PID testing of insulator A/R function required to be in non auto mode.
334	1436	PLANNED	OCC_575	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Bus CVT tan D testing	27-Feb-2024	08:00	27-Feb-2024	18:00	All feeders and ICT on Main Bus II will be shifted on Main Bus I through TBC
335	1437	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	27-Feb-2024	09:00	27-Feb-2024	17:00	Line will be charged through Tie CB 428.
336	1438	PLANNED	OCC_575	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-2	D	Testing and Diagnostic Testing work	27-Feb-2024	09:00	27-Feb-2024	19:00	Outage required for routine testing and maintenance work.
337	1447	PLANNED	OCC_575	POWERGRID_WR1	400KV-PUNE-GIS-PARLI-1	C	For AMP	27-Feb-2024	9:00	27-Feb-2024	18:00	
338	1448	PLANNED	OCC_575	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 L/R@ AURANGABAD-M (WALUJ) - 400KV	D	For LR AMP	27-Feb-2024	7:00	27-Feb-2024	18:00	
339	1449	PLANNED	OCC_575	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	For Taking LR Out & In service	27-Feb-2024	7:00	27-Feb-2024	18:00	
340	1450	PLANNED	OCC_575	POWERGRID_WR1	220KV-PARLI-PARLI-M-2	D	AMP WORK	27-Feb-2024	7:00	27-Feb-2024	18:00	
341	1253	PLANNED	OCC_575	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 2	D	Bus CVT tan D testing	27-Feb-2024	08:00	27-Feb-2024	18:00	All feeders and ICT on Main Bus II will be shifted on Main Bus I through TBC

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
342	1254	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	27-Feb-2024	09:00	27-Feb-2024	17:00	Line will be charged through Tie CB 428.
343	1255	PLANNED	OCC_575	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-2	D	Testing and Diagnostic Testing work	27-Feb-2024	09:00	27-Feb-2024	19:00	Outage required for routine testing and maintenance work.
344	1256	PLANNED	OCC_575	POWERGRID_WR2	MAIN BAY - 400KV-INDORE-MP-ASOJ-1 AND ASOJ - 400KV - BUS 1 at ASOJ - 400KV	C	SF6 leakage attending work, line will remain inservice through TBC bay	27-Feb-2024	7:00	28-Feb-2024	18:00	PG-WR2-VADODARA
345	1257	PLANNED	OCC_575	MUML-Sterlite	400KV-LONIKHAND-PUNE-PG-1	D	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	27-Feb-2024	9:00	28-Feb-2024	18:00	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML
346	1722	PLANNED	OCC_575	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 L/R@ AURANGABAD-M (WALUJ) - 400KV	D	For LR AMP	27-Feb-2024	7:00	27-Feb-2024	18:00	
347	1723	PLANNED	OCC_575	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	D	For Taking LR Out & In service	27-Feb-2024	7:00	27-Feb-2024	18:00	
348	1724	PLANNED	OCC_575	POWERGRID_WR1	220KV-PARLI-PARLI-M-2	D	AMP WORK	27-Feb-2024	7:00	27-Feb-2024	18:00	
349	1460	PLANNED	OCC_575	GETCO	220kV Navsari-Nashik line no.1	D	PMM work	28-Feb-2024	9:00	28-Feb-2024	18:00	
350	1474	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	28-Feb-2024	08:00	28-Feb-2024	18:00	--
351	1475	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	28-Feb-2024	09:00	28-Feb-2024	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
352	1476	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line/Substation maintenance	28-Feb-2024	09:00	28-Feb-2024	17:30	-
353	1477	PLANNED	OCC_575	APML	TIRODA - 765KV B/R 1	C	Annual Maintenance & Testing Reactor. Annual maintenance of main bay and tie bay equipments.	28-Feb-2024	9:00	29-Feb-2024	18:00	765KV-TIRODA-KORADI-III-2 will be available on main bay
354	1478	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Cold Washing Work	28-Feb-2024	08:00	29-Feb-2024	18:00	----
355	1480	PLANNED	OCC_575	MSLDC_OUTAGE	PADGHE - 400KV - BUS 1	C	1) Replacement of Hanger Assembly of 29 A Bus All PG Isolator by Hotline method.	28-Feb-2024	09:30	04-Mar-2024	17:00	Weather condition should be clear.
356	1481	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY OF 400KV-PADGHE-NAGOTHANE-2 AND NAGOTHANE - 400KV - BUS 1 @NAGOTHANE - 400KV at NAGOTHANE - 400KV	C	1)Replacement of 29 A Bus All Phase PG Isolator under LES Scheme. 2) Line will be in service on TBC. 3) CB Maintenance work.	28-Feb-2024	09:30	04-Mar-2024	18:30	Weather Condition Should be Clear.
357	1483	PLANNED	OCC_575	POWERGRID_WR1	765KV-PUNE-GIS-AURANGABAD-1	C	Drive Mechanism Inspection Work by OEM & AMP of LR CB. Line outage is proposed as per the requirement of RLDC.	28-Feb-2024	7:00	28-Feb-2024	18:00	710L
358	1486	PLANNED	OCC_575	POWERGRID_WR1	765KV-AURANGABAD-SOLAPUR-2	D	AR in non auto mode	28-Feb-2024	7:00	28-Feb-2024	18:00	
359	1487	PLANNED	OCC_575	POWERGRID_WR1	765KV-AURANGABAD-SOLAPUR-1	D	For replacement of porcelain insulator to polymer insulator at Loc. No. 313. Note: 765kV Aurangabad-2 line AR to be kept in Non-Auto Mode.	28-Feb-2024	7:00	28-Feb-2024	18:00	
360	1493	PLANNED	OCC_575	APML	TIRODA - 765KV B/R 1	C	Annual Maintenance & Testing Reactor. Annual maintenance of main bay and tie bay equipments.	28-Feb-2024	9:00	29-Feb-2024	18:00	765KV-TIRODA-KORADI-III-2 will be available on main bay
361	1275	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-YAWATMAL-2	D	Maintenance work	28-Feb-2024	08:00	28-Feb-2024	18:00	--
362	1276	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	28-Feb-2024	09:00	28-Feb-2024	17:00	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
363	1277	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	Line/Substation maintenance	28-Feb-2024	09:00	28-Feb-2024	17:30	-
364	1279	PLANNED	OCC_575	APML	TIRODA - 765KV B/R 1	C	Annual Maintenance & Testing Reactor. Annual maintenance of main bay and tie bay equipments.	28-Feb-2024	9:00	29-Feb-2024	18:00	765KV-TIRODA-KORADI-III-2 will be available on main bay
365	1280	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Cold Washing Work	28-Feb-2024	08:00	29-Feb-2024	18:00	----
366	1282	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-2	C	CB pole overhauling work	28-Feb-2024	09:00	02-Mar-2024	18:00	400 KV Padghe II will be in service through TBC
367	1283	PLANNED	OCC_575	MSLDC_OUTAGE	PADGHE - 400KV - BUS 1	C	1) Replacement of Hanger Assembly of 29 A Bus All PG Isolator by Hotline method.	28-Feb-2024	09:30	04-Mar-2024	17:00	Weather condition should be clear.

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
368	1284	PLANNED	OCC_575	MSLDC_OUTAGE	MAIN BAY OF 400KV-PADGHE-NAGOTHANE-2 AND NAGOTHANE - 400KV - BUS 1 @NAGOTHANE - 400KV at NAGOTHANE - 400KV	C	1)Replacement of 29 A Bus All Phase PG Isolator under LES Scheme. 2) Line will be in service on TBC. 3) CB Maintenance work.	28-Feb-2024	09:30	04-Mar-2024	18:30	Weather Condition Should be Clear.
369	1734	PLANNED	OCC_575	POWERGRID_WR1	765KV-AURANGABAD-SOLAPUR-2	D	AR in non auto mode	28-Feb-2024	7:00	28-Feb-2024	18:00	
370	1735	PLANNED	OCC_575	POWERGRID_WR1	765KV-AURANGABAD-SOLAPUR-1	D	For replacement of porcelain insulator to polymer insulator at Loc. No. 313. Note: 765kV Aurangabad-2 line AR to be kept in Non-Auto Mode.	28-Feb-2024	7:00	28-Feb-2024	18:00	
371	1757	PLANNED	575	APML	TIRODA - 765KV B/R 1	C	Annual Maintenance & Testing Reactor. Annual maintenance of main bay and tie bay equipments.	28-Feb-2024	9:00	29-Feb-2024	18:00	765KV-TIRODA-KORADI-III-2 will be available on main bay
372	1496	PLANNED	OCC_575	GETCO	220kV Navsari-Nashik line no.2	D	PMM work	29-Feb-2024	9:00	29-Feb-2024	18:00	
373	1511	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	DT Work & Bay Maintenance, 29 D Isolator MB Repairing Work	29-Feb-2024	08:00	29-Feb-2024	18:00	-
374	1512	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	29-Feb-2024	08:00	29-Feb-2024	18:00	--
375	1513	PLANNED	OCC_575	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	29-Feb-2024	09:00	29-Feb-2024	17:00	Line will be charged through Main CB 429.
376	1514	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	D	Q/M of bay	29-Feb-2024	09:00	29-Feb-2024	23:00	Load will be managed on 400 kV Kolhapur PG ckt 1
377	1517	PLANNED	OCC_575	POWERGRID_WR1	400KV-KORADI-SATPURA-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	7:00	29-Feb-2024	13:00	
378	1518	PLANNED	OCC_575	POWERGRID_WR1	400KV/220KV SOLAPUR-ICT-2	D	PRV NC contact modification	29-Feb-2024	7:00	29-Feb-2024	18:00	
379	1519	PLANNED	OCC_575	POWERGRID_WR1	KORADI - 400KV - BUS 1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	7:00	29-Feb-2024	20:00	
380	1523	PLANNED	OCC_575	POWERGRID_WR1	400KV-KORADI-SATPURA-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	14:00	29-Feb-2024	20:00	
381	1098	PLANNED	OCC_575	GETCO	220kV Navsari-Nashik line no.2	D	PMM work	29-Feb-2024	9:00	29-Feb-2024	18:00	
382	1285	PLANNED	OCC_575	GETCO	400KV-HADALA-CHORANIA-1	D	A/R Out For Spacer and repair sleeve providing work in 400 kV Hadala - Amreli line.	29-Feb-2024	7:00	29-Feb-2024	15:00	
383	1286	PLANNED	OCC_575	POWERGRID_WR2	400KV/220KV RAJGARH-ICT-1	D	FOR AMP WORKS, Dia to be Kept open at both sides	29-Feb-2024	7:00	29-Feb-2024	17:30	PG-WR2-RAJGARH
384	1287	PLANNED	OCC_575	POWERGRID_WR2	765KV-VADODARA-DHULE-1	D	Spare reactor free from Y ph , Dia to be Kept open at both ends	29-Feb-2024	7:00	29-Feb-2024	18:00	PG-WR2-VADODARA
385	1288	PLANNED	OCC_575	POWERGRID_WR2	765KV-VADODARA-DHULE-1 L/R@ VADODARA - 765KV	D	Spare reactor free from Y ph	29-Feb-2024	7:00	29-Feb-2024	18:00	PG-WR2-VADODARA
386	1298	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-LONIKHAND-CHAKAN-1	D	DT Work & Bay Maintenance, 29 D Isolator MB Repairing Work	29-Feb-2024	08:00	29-Feb-2024	18:00	-
387	1299	PLANNED	OCC_575	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Maintenance work	29-Feb-2024	08:00	29-Feb-2024	18:00	--
388	1300	PLANNED	OCC_575	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	29-Feb-2024	09:00	29-Feb-2024	17:00	Line will be charged through Main CB 429.
389	1301	PLANNED	OCC_575	MSLDC_OUTAGE	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	D	Q/M of bay	29-Feb-2024	09:00	29-Feb-2024	23:00	Load will be managed on 400 kV Kolhapur PG ckt 1
390	1741	PLANNED	OCC_575	POWERGRID_WR1	400KV-KORADI-SATPURA-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	7:00	29-Feb-2024	13:00	

Sr. No.	OCC M Sr. No.	Request Type	OCC Number	Name of Requesting Agency	Element Name	D/ C	Reason	From Date	From Time	To Date	To Time	Remarks
391	1742	PLANNED	OCC_575	POWERGRID_WR1	400KV-BHILAI-KORADI-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	7:00	29-Feb-2024	13:00	
392	1743	PLANNED	OCC_575	POWERGRID_WR1	400KV/220KV SOLAPUR-ICT-2	D	PRV NC contact modification	29-Feb-2024	7:00	29-Feb-2024	18:00	
393	1744	PLANNED	OCC_575	POWERGRID_WR1	KORADI - 400KV - BUS 1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	7:00	29-Feb-2024	20:00	
394	1745	PLANNED	OCC_575	POWERGRID_WR1	KORADI - 400KV - BUS 2	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	7:00	29-Feb-2024	20:00	
395	1749	PLANNED	OCC_575	POWERGRID_WR1	400KV-KORADI-SATPURA-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	14:00	29-Feb-2024	20:00	
396	1750	PLANNED	OCC_575	POWERGRID_WR1	400KV-BHILAI-KORADI-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	14:00	29-Feb-2024	20:00	

Monthly Outage list NOT CONSIDER in WRLDC OCCM for the Month of February 2024

Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks	Tag	EntityType	OCC-Remarks
59	PLANNED	OCC_575	MSLDC_OUT AGE	PADGHE - 400KV - BUS 2	C	1.Replacement of Hanger Assembly of B Bus PG Isolator of BBLR-2 by Hot Line Method. 2.All Feeders on B Bus will be in service.	01-Feb-2024	09:30	07-Feb-2024	18:30	Weather condition should be clear for Hot Line Work. Hot Line Team will be present on site.			In view of approved outage of 400 kV TAPS-Padghe-D/c
64	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing	01-Feb-2024	08:00	14-Feb-2024	18:00	to carry PID work			In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
65	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	01-Feb-2024	8:00	15-Feb-2024	18:00	AR disable	AR To Non Auto	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
66	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	01-Feb-2024	8:00	15-Feb-2024	18:00	AR disable	AR To Non Auto	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
70	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-KALWA-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	01-Feb-2024	09:00	17-Feb-2024	18:00	PID testing of insulator A/R function required to be in non auto mode			In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
210	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-KALWA-PADGHE-1	D	1.Bay Maintenance Work. 2.MTAMC Work. 3.Diagnostic Testing Work. 4.Replacement of 29 C Bus PG Isolator under LES Scheme. 5.Replacement of all phase CT with new Ratio of 3000/1 A. 6.Distance Relay & Over Voltage Relay	04-Feb-2024	09:30	04-Feb-2024	18:30	Weather condition should be clear.			In view of approved outage of 400 kV TAPS-Padghe-D/c
258	PLANNED	OCC_575	MSLDC_OUT AGE	BABLESHWAR - 400KV - BUS 1	D	Connection of 501 MVA ICT V isolator jumps to Main Bus 1 by Hotline method	05-Feb-2024	09:00	05-Feb-2024	13:00	Work will be done online through Hotline method			In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe
263	PLANNED	OCC_575	MSLDC_OUT AGE	BABLESHWAR - 400KV - BUS 2	D	Connection of 501 MVA ICT V isolator jumps to Main Bus II by Hotline method	05-Feb-2024	13:00	05-Feb-2024	18:00	Work will be done online through Hotline method			In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe & 765kV Aurangabad-Pune. Plan in the next month
284	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-KALWA-PADGHE-2	C	For Erection of 3 No QD Tower in between Location No. 1096 -1099.	05-Feb-2024	8:00	13-Feb-2024	18:00				In view of approved outages in Mumbai/Pune area
1405	PLANNED	OCC_575	MEGPTCL	765KV-AKOLA (2)-EKTUNI-1	D	Cable Replacement of Bushing CTs for R, Y and B ph Reactor at Ektuni SS. (non- switchable Reactor at Ektuni SS.)	05-Feb-2024	10:00	05-Feb-2024	18:00	Line Outage			Duplicate entry
1422	PLANNED	OCC_575	POWERGRID_WRI	400KV-PUNE-GIS-PUNE-PG-4	C	For attending SF6 gas leakage	05-Feb-2024	9:00	07-Feb-2024	18:00		OUTAGE	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe-D/c
422	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-BABLESHWAR-PADGHE-1	C	Shifting of 400 KV Babhaleshwar- Padghe Ckt-1 on 400 KV Bableshwar-Padghe ckt-2 (Dead Ckt). Outage No.2 on Ckt	07-Feb-2024	22:00	08-Feb-2024	6:00	400kV Bhabhleshwar-Padghe d/c for line shifting infringing in Samruddhi highway crossing under ORC for 400kV			In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe
475	PLANNED	OCC_575	MUML-Sterlite	400KV-KHARGHAR-PUNE-PG-1	D	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	08-Feb-2024	9:00	09-Feb-2024	18:00	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	A/R OFF	ISTS	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe
476	PLANNED	OCC_575	MUML-Sterlite	400KV-KALWA-KHARGHAR-1	D	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	08-Feb-2024	9:00	09-Feb-2024	18:00	For crossing of under construction 400kV D/C Padghe - Kharghar Transmission line of MUML	A/R OFF	ISTS	In view of approved outages in Mumbai/Pune area
562	Planned	OCC_575	MSLDC_OUT AGE	220KV-BOISAR-BOISAR-M-1	D	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.	10-Feb-2024	08:00	10-Feb-2024	17:00	work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.			In view of approved outages in Mumbai/Pune area

Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks	Tag	EntityType	OCC-Remarks
563	Planned	OCC_575	MSLDC_OUT AGE	400KV-BABLESHWAR-PADGHE-1	D	Routine Line maintenance work;Distance Main I and II relay testing, LBB relay testing	10-Feb-2024	08:00	10-Feb-2024	18:00	400kV Padghe II will be in service			In view of approved outages in Mumbai/Pune area
570	Planned	OCC_575	POWERGRID_ WR2	400KV/220KV BOISAR-ICT-2	D	AMP WORK, Dia to be Kept open at both sides.	11-Feb-2024	7:00	11-Feb-2024	21:00	PG-WR2-BOISAR	Outage	TRANSFORMER	In view of approved outages in Mumbai/Pune area
573	Planned	OCC_575	MSLDC_OUT AGE	BOISAR-M - 220KV - BUS 1	D	220kV A-Bus Isolator R/M Works. 1) During the outage, all elements / lines will be in service through 220kV B-Bus. 2) Due to A-Bus Isolator alignment issue of 220kV PGCIL - Boisar Line No. 3, 220kV A-Bus outage is required prior to 220kV B-Bus.	11-Feb-2024	05:00	11-Feb-2024	20:00	MAIN BUS - 1 @ BOISAR II has following elements: 220kV Viraj 220kV Tarapur PGCIL-2 200MA ICT-2 50MVA PTR 1 150MVA ICT-2			In view of approved outages in Mumbai/Pune area
574	Planned	OCC_575	MSLDC_OUT AGE	400KV-BABLESHWAR-PADGHE-2	D	Routine Line maintenance work;Distance Main II and CVT tan D testing	11-Feb-2024	08:00	11-Feb-2024	18:00	400kV Padghe I will be in service			In view of approved outages in Mumbai/Pune area
575	Planned	OCC_575	MSLDC_OUT AGE	400KV-KALWA-KHARGHAR-1	D	SSN to DSN insulator string Conversion work & and installation of fridge wedge connector at mid-span joint.	11-Feb-2024	08:00	11-Feb-2024	18:00	SSN to DSN insulator string Conversion work & and installation of fridge wedge connector at mid-span joint.			In view of approved outages in Mumbai/Pune area
1758	PLANNED	575	ATIL-TW	400KV-TIRODA-WARORA-1	D	Annual Maintanence of line	11-Feb-2024	8:00	11-Feb-2024	18:00	Line Outage	Outage	AC TRANSMISSION LINE CIRCUIT	Duplicate entry
649	PLANNED	OCC_575	POWERGRID_ WR2	220KV-BOISAR-BOISAR-M-1	D	AMP WORK	13-Feb-2024	7:00	13-Feb-2024	17:30	PG-WR2-BOISAR	Outage	AC TRANSMISSION LINE CIRCUIT	In view of approved outages in Mumbai/Pune area
53	PLANNED	OCC_575	TAPS-3&4	400 KV Main Bus -2 (TARAPUR 3&4)	C	Preventive Maintenance checks	14-Feb-2024	9:00	17-Feb-2024	19:00	Sample Remarks	Voltage Regulation	AC TRANSMISSION LINE CIRCUIT;Switch yard equipments	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
744	Planned	OCC_575	MSLDC_OUT AGE	400KV-KALWA-PADGHE-1	C	For Erection of 3 No QD Tower in between Location No. 1113 -1116.	14-Feb-2024	8:00	24-Feb-2024	18:00				In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe & 765kV Aurangabad-Pune. Plan in the next month
793	PLANNED	OCC_575	MSLDC_OUT AGE	220KV-TALANGADE(MS)- CHIKKODI-II-1	D	1. Bay CT PT testing 2. Annual relay testing work 3. OM of Bay	15-Feb-2024	09:00	15-Feb-2024	20:00	Line is ideally charged form Chikkodi end.			Duplicate entry
795	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-EKTUNI-BABLESHWAR-2	D	Diagnostic Testing and Routine Maintanaince Work	15-Feb-2024	10:00	15-Feb-2024	18:00	Diagnostic Testing and Routine Maintanaince Work			In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe & 765kV Aurangabad-Pune. Plan in the next month
807	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-BABLESHWAR-PADGHE-2	D	PID testing	15-Feb-2024	08:00	29-Feb-2024	18:00	To carry out PID testing work			In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe & 765kV Aurangabad-Pune. Plan in the next month.
1568	PLANNED	OCC_575	POWERGRID_ WR1	220KV-TALEGAON-PUNE-PG-2	C	For AMP Work	15-Feb-2024	9:00	15-Feb-2024	17:30	Line Owned By MSETCL Trans		AC TRANSMISSION LINE CIRCUIT	In view of 765 kV Aurangabad-Padghe & Pune-Padghe
1576	PLANNED	OCC_575	POWERGRID_ WR1	400KV-PUNE-GIS-PUNE-PG-3	C	For attending SF6 gas leakage	15-Feb-2024	9:00	17-Feb-2024	18:00		OUTAGE	AC TRANSMISSION LINE CIRCUIT	In view of 765 kV Aurangabad-Padghe & Pune-Padghe
808	PLANNED	OCC_575	POWERGRID_ WR2	220KV-BOISAR-BOISAR-M-3	D	AMP WORK	16-Feb-2024	7:00	16-Feb-2024	17:30	PG-WR2-BOISAR	Outage	AC TRANSMISSION LINE CIRCUIT	In view of approved outages in Mumbai/Pune area
848	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-BABLESHWAR-PADGHE-1	D	1.Bay Maintenance work. 2.Diagnostic Testing work. 3.Replacement of over voltage distance relay. 4.MTAMC work. 5.Replacement of 29C Isolator under LES Scheme	16-Feb-2024	10:00	16-Feb-2024	18:00	Weather Condition should be clear.			In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe & 765kV Aurangabad-Pune. Plan in the next month
854	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-KALWA-PADGHE-1	C	Replacement of existing conductor by HTLS conductor.	16-Feb-2024	06:00	19-Feb-2024	06:00	Replacement of existing conductor by HTLS conductor.			In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-
1590	PLANNED	OCC_575	POWERGRID_ WR1	400KV-BHILAI-KORADI-1	C	For Dismantling, Overhauling and Restoration of Isolators Sissor Contact, Gear Box and MOM Box for Bus-1 & Bus-2, Keeping Bhilai line on	16-Feb-2024	7:00	20-Feb-2024	20:00		OUTAGE	AC TRANSMISSION LINE CIRCUIT	Repeat entry

Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks	Tag	EntityType	OCC-Remarks
875	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual Manitenance	17-Feb-2024	8:00	17-Feb-2024	18:00	Outage	Outage	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-
876	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual Manitenance	17-Feb-2024	8:00	17-Feb-2024	18:00	Outage	Outage	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV
894	PLANNED	OCC_575	MSLDC_OUT AGE	220KV-BOISAR-BOISAR-M-1	D	Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by	17-Feb-2024	08:00	17-Feb-2024	17:00	Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by			In view of approved outages in Mumbai/ Pune area
895	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-BABLESHWAR-PADGHE-1	D	Outage required for attending defects identified in PID testing, Monkey /Drone Patrolling and Cold washing of Dust polluted Insulator Strings.	17-Feb-2024	08:00	17-Feb-2024	18:00	400kV Babhaleshwar-Padghe Ckt -2 will be available.			In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe & 765kV Aurangabad-Pune. Plan in the next month
903	PLANNED	OCC_575	POWERGRID_WR2	400KV/ 220KV BOISAR-ICT-3	D	AMP WORK, Dia to be Kept open at both sides.	18-Feb-2024	7:00	18-Feb-2024	21:00	PG-WR2-BOISAR	Outage	TRANSFORMER	In view of approved outages in Mumbai/ Pune area
904	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-1	D	Annual Manitenance	18-Feb-2024	8:00	18-Feb-2024	18:00	Outage	Outage	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
905	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-2	D	Annual Maintenance	18-Feb-2024	8:00	18-Feb-2024	18:00	Outage	Outage	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
911	PLANNED	OCC_575	MSLDC_OUT AGE	BOISAR-M - 220KV - BUS 2	D	220kV B-Bus Isolator R/M Works. MAIN BUS - 2 @ BOISAR II has following elements: 220kV Ghodbunder 220kV Borivali 220kV Versova PGCIL-1 200MA ICT-1 100MVA PTR 2 PGCIL-3	18-Feb-2024	05:00	18-Feb-2024	20:00	During the outage, all elements / lines will be in service through 220kV A-Bus.			In view of approved outages in Mumbai/ Pune area
912	PLANNED	OCC_575	MSLDC_OUT AGE	220KV-BOISAR-BOISAR-M-1	D	Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.	18-Feb-2024	08:00	18-Feb-2024	17:00	Work for replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.			In view of approved outages in Mumbai/ Pune area
914	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-KALWA-PADGHE-2	D	1.Bay Maintenance Work. 2.MTAMC Work. 3.Diagnostic Testing Work. 4.Replacement of 29 C Bus PG Isolator under LES Scheme. 5.Replacement of all phase CT	18-Feb-2024	10:00	18-Feb-2024	18:30	Weather condition should be clear.			In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe & 765kV Aurangabad-Pune. Plan in the next month
922	PLANNED	OCC_575	MSLDC_OUT AGE	MAIN BAY OF 400KV-BABLESHWAR-PADGHE-1 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work. 400 KV Padghe I will be in service through TBC	18-Feb-2024	08:00	21-Feb-2024	18:00	400 KV Padghe I will be in service through TBC			In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe & 765kV Aurangabad-Pune. Plan in the next month
1602	PLANNED	OCC_575	POWERGRID_WR1	PUNE-PG - 400KV - BUS 1	C	For AMP Work	18-Feb-2024	9:00	18-Feb-2024	17:30			BUS	In view of 765 kV Aurangabad-Padghe & Pune-Padghe
1669	PLANNED	OCC_575	POWERGRID_WR1	PUNE-PG - 220KV - BUS 2	C	For AMP Work	22-Feb-2024	9:00	22-Feb-2024	17:30	Before S/D of 220kV BUS_2, ALL Load on 220 Kv BUS_2 will shift on 220 Kv BUS_1 by closing respective bay 89A Isolator and Opening the respective Bay 89B Isolator and while work on Respective Bay of 89B Isolator/ BUS clamps same bay will shift on TBC 204 Bay for Electrical clearance		BUS	In view of 765 kV Aurangabad-Padghe & Pune-Padghe
1137	PLANNED	OCC_575	POWERGRID_WR2	400KV/220KV BOISAR-ICT-4	D	AMP WORK, Dia to be Kept open at both sides.	23-Feb-2024	7:00	23-Feb-2024	21:00	PG-WR2-BOISAR	Outage	TRANSFORMER	In view of approved outages in Mumbai/ Pune area
1138	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Manitenance	23-Feb-2024	8:00	23-Feb-2024	18:00	Outage	Outage	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.

Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks	Tag	EntityType	OCC-Remarks
1139	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Maintenance	23-Feb-2024	8:00	23-Feb-2024	18:00	Outage	Outage	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
1162	PLANNED	OCC_575	MSLDC_OUT AGE	400KV/220KV PADGHE-ICT-4	C	1) Oil filtration of all Phase unit due to low BDV and increase in Key Gases . 2) Replacement of Diff Realy 3) wiring work in CP & RP for remote operation from CR 4) Diagnostic Testing work 5) Replacement of Faulty WTI & OTI 6) Bay Maint work 7) MTAMC work	23-Feb-2024	06:00	25-Feb-2024	23:59	weather condition should be clear .			In view of 765kV Aurnagabad Padghe and 765 kV Pune Padghe outage
1688	PLANNED	OCC_575	POWERGRID_WR1	765KV-PUNE-GIS-SOLAPUR-1	C	Line Reactor Spare changeover. Line outage is proposed as per the requirement of RLDC	23-Feb-2024	9:00	23-Feb-2024	13:00		OUTAGE	AC TRANSMISSION LINE CIRCUIT	In view of 765 kV Aurangabad-Padghe & Pune-Padghe
1176	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Manitenance	24-Feb-2024	8:00	24-Feb-2024	18:00	Outage	Outage	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
1177	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Manitenance	24-Feb-2024	8:00	24-Feb-2024	18:00	Outage	Outage	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV
1192	PLANNED	OCC_575	MSLDC_OUT AGE	220KV-BOISAR-BOISAR-M-1	D	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 12 to Bay No. 14) for:- 1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S.	24-Feb-2024	07:00	24-Feb-2024	18:00	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 12 to Bay No. 14) for:- 1) Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S.			In view of approved outages in Mumbai/Pune area
1193	PLANNED	OCC_575	MSLDC_OUT AGE	220KV-BOISAR-BOISAR-M-3	C	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 13 to Bay No. 12) for:- Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S.	24-Feb-2024	22:00	25-Feb-2024	22:00	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 13 to Bay No. 12) for:- Work under the scheme of "Providing permanent second source from 400kV PGCIL (Boisar) S/S to 220kV Nalasopara S/S.			In view of approved outages in Mumbai/Pune area
1706	PLANNED	OCC_575	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4	C	For AMP Work	24-Feb-2024	9:00	24-Feb-2024	17:30	Line Owned By ADANI Trans	OUTAGE	AC TRANSMISSION LINE CIRCUIT	In view of 765 kV Aurangabad-Padghe & Pune-Padghe
1196	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	Annual Manitenance	25-Feb-2024	8:00	25-Feb-2024	18:00	Outage	Outage	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
1197	PLANNED	OCC_575	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	Annual Manitenance	25-Feb-2024	8:00	25-Feb-2024	18:00	Outage	Outage	AC TRANSMISSION LINE CIRCUIT	In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
1199	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-KHARGHAR-PUNE-PG-1	D	SSN to DSN insulator string Conversion work & and installation of fridge wedge connector at mid-span joint	25-Feb-2024	09:00	25-Feb-2024	18:00	SSN to DSN insulator string Conversion work & and installation of fridge wedge connector at mid-span joint			In view of 400 kV Tarapur-Padghe D/C and 765 kV Aurangabad-Padghe & Pune-Padghe.
1710	PLANNED	OCC_575	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 L/R@ AURANGABAD-M (WALUJ) - 400KV	C	For LR AMP	25-Feb-2024	7:00	25-Feb-2024	18:00		OUTAGE	LINE REACTOR	In view of 765 kV Aurangabad-Padghe & Pune-Padghe
1711	PLANNED	OCC_575	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	C	For Taking LR Out & In service	25-Feb-2024	7:00	25-Feb-2024	18:00		OUTAGE	AC TRANSMISSION LINE CIRCUIT	In view of 765 kV Aurangabad-Padghe & Pune-Padghe
1712	PLANNED	OCC_575	POWERGRID_WR1	400KV-KHARGHAR-PUNE-PG-1	C	For AMP Work	25-Feb-2024	9:00	25-Feb-2024	17:30	Line Owned By MSETCL Trans	OUTAGE	AC TRANSMISSION LINE CIRCUIT	In view of 765 kV Aurangabad-Padghe & Pune-Padghe
1216	PLANNED	OCC_575	MSLDC_OUT AGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	26-Feb-2024	09:00	26-Feb-2024	17:00	The said work is very important			Repeated entry
1244	PLANNED	OCC_575	POWERGRID_WR2	MAIN BAY - 400KV-PADGHE-BOISAR-1 AND BOISAR - 400KV - BUS 1 at BOISAR - 400KV	D	AMP WORK	27-Feb-2024	9:00	27-Feb-2024	17:30	PG-WR2-BOISAR	Outage	Bay	In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe & 765kV Aurangabad-Pune. Plan in the next month

Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D	reason	From	time	to	Time	Remarks	Tag	EntityType	OCC-Remarks
1282	PLANNED	OCC_575	MSLDC_OUT AGE	400KV-BABLESHWAR-PADGHE-2	C	CB pole overhauling work	28-Feb-2024	09:00	02-Mar-2024	18:00	400 KV Padghe II will be in service through TBC			In view of approved outage of 400 kV Tarapur Padghe D/C and 765 kV Aurangabad-Padghe & 765kV Aurangabad-Pune, Plan in the next month
1742	PLANNED	OCC_575	POWERGRID_ WR1	400KV-BHILAI-KORADI-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	7:00	29-Feb-2024	13:00		OUTAGE	AC TRANSMISSION LINE CIRCUIT	Plan in the next month
1745	PLANNED	OCC_575	POWERGRID_ WR1	KORADI - 400KV - BUS 2	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	7:00	29-Feb-2024	20:00		BUS-2	BUS	Plan in the next month
1750	PLANNED	OCC_575	POWERGRID_ WR1	400KV-BHILAI-KORADI-1	D	For Dismantling and Restoration of Isolators Fixed Contact of Bus-1 PG isolators of 400kv Koradi-Sarni & Bhilai Line Keeping Sarni & Bhilai Line on TBC Bay each for half day.	29-Feb-2024	14:00	29-Feb-2024	20:00		OUTAGE	AC TRANSMISSION LINE CIRCUIT	Plan in the next month

State Element outage list for the month of FEBRUARY 2024

Sr.No .	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400 KV	JEJURI - KARAD	01-Feb-24	09:30	01-Feb-24	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	During outage 400 kV Jejuri-Lonikand ckt-1 , 400 kV Jejuri-Lonikand ckt-2 , 400 kV Jejuri-Koyana Stg-4 will be in service.
2	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	01-Feb-24	10:30	01-Feb-24	18:00	Daily	Annual bay maintenance & Diagnostic Testing work	MSETCL	MSETCL	Testing & Maintenance work
3	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	01-Feb-24	10:00	01-Feb-24	17:00	Daily	Diagnostic testing of Bushing & winding	MSETCL	MSETCL	NA
4	400 KV	500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	02-Feb-24	10:00	03-Feb-24	18:00	Continuous	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
5	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	02-Feb-24	10:00	02-Feb-24	17:00	Daily	Diagnostic testing of Bushing & winding	MSETCL	MSETCL	NA
6	400 KV	AKOLA - KHADKA (BHUSAWAL)	02-Feb-24	09:00	02-Feb-24	18:00	Daily	Diagnostic testing & routine maintenance work	MSETCL	MSETCL	Nandgaon ckt will be in service
7	400 KV	CHANDRAPUR - KHAPERKHEDA	02-Feb-24	08:00	02-Feb-24	18:00	Daily	1. Measurement of tandelta & capacitance of Line CVT. 2. Relay Testing work. 2. Bay routine maintenance work	MSETCL	MSETCL	During outage, 400KV CHANDRAPUR-1 - CHANDRAPUR-2 Ckt. No.- 1, 400KV PARLI CKT-3, 400KV CHANDRAPUR-PGCIL Bhadrawati Ckt. No- 1, 2, 3 & 4 and HVDC Ckt. No- 1 & 2 will be in service.
8	400 KV	WARORA - IEPL	03-Feb-24	09:00	03-Feb-24	17:00	Daily	Line CT, CVT Tan delta, IR values & Routine maintenance and and isolater maintenance work .	MSETCL	MSETCL	Both Main & Tie Bay is in OFF condition.
9	400 KV	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	03-Feb-24	09:00	03-Feb-24	18:00	Daily	DFRA,SFRA Testing and Quarterly bay maintenance work	MSETCL	MSETCL	315 MVA ICT II and 501 MVA ICT IIII and IV will be in service
10	400 KV	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	03-Feb-24	10:00	03-Feb-24	18:00	Daily	Inspection of SERGI NIFPS Fire system for ICT No.1 in the view of overhauling, Repairing and Overhauling of 89B PG isolators, Replacement of R phase 220kV IV CT, Routine Maintenance and DT.	MSETCL	MSETCL	-
11	400 KV	500 MVA 400/220 KV ICT - 2 @ CHANDRAPUR 2	05-Feb-24	10:00	06-Feb-24	17:00	Continuous	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
12	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	05-Feb-24	09:00	05-Feb-24	23:59	Daily	1. Relay Testing work 2. PT selection relay wiring & modification work 3.220kV CB Testing work 4. QM of ICT, HV & LV Bays.	MSETCL	MSETCL	1.Monday is load staggering day for Kolhapur. 2. Load will be managed on 500 MVA Ict 1 & 500mVA ICT 3
13	400 KV	400/220/33 KV 500 MVA ICT - 1 @ KOLHAPUR	05-Feb-24	09:00	05-Feb-24	23:00	Daily	Q/M of bay	MSETCL	MSETCL	Load will be managed on ICT 2& ICT 3
14	400 KV	KHADKA-AURANGABAD (WALUJ)	05-Feb-24	08:00	05-Feb-24	18:00	Daily	For qarterly bay Maintenance work	MSETCL	MSETCL	as per annual plan

Sr.No .	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
15	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	05-Feb-24	08:00	05-Feb-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
16	400 KV	JAIGAD - KARAD CKT - 1	06-Feb-24	09:00	06-Feb-24	18:00	Daily	Bay equipment maintenance work at jaigad	JSWEL	JSWEL	Bay equipment maintenance work at jaigad
17	400 KV	TIE BAY (418) OF IEPL AND FUTURE LINE-1 @ WARORA	06-Feb-24	09:00	06-Feb-24	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	only Tie CB 418 is in OFF condition, respective ckt charged through its own main CB.
18	400 KV	JAIGAD - KARAD CKT - 2	07-Feb-24	09:00	07-Feb-24	18:00	Daily	Bay equipment maintenance work at jaigad	JSWEL	JSWEL	Bay equipment maintenance work at jaigad
19	400 KV	KHADKA - BABLESHWAR	07-Feb-24	08:00	07-Feb-24	18:00	Daily	For quareterly bay maintenance work	MSETCL	MSETCL	as per plan
20	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	07-Feb-24	10:00	07-Feb-24	17:00	Daily	Diagnostic testing of Bushing & winding	MSETCL	MSETCL	501MVA 400/220/33kV ICT-I will in service
21	400 KV	400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	07-Feb-24	10:00	07-Feb-24	17:00	Daily	RRS Scheme Work of ICT	MSETCL	MSETCL	NA
22	400 KV	NEW KOYNA-KARAD CKT - 1	07-Feb-24	08:00	07-Feb-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
23	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	08-Feb-24	10:30	08-Feb-24	18:00	Daily	Annual bay maintenance & CT Oil leakage problem attended	MSETCL	MSETCL	testing & maintenance work
24	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	08-Feb-24	09:30	08-Feb-24	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-2 & ICT-3 will continue to remain in service
25	400 KV	CHANDRAPUR-PARLI CKT-3	08-Feb-24	09:00	08-Feb-24	18:00	Daily	Disc Repalcement work loc.no.495,496,583	MSETCL	MSETCL	-
26	400 KV	LONIKAND I - KOYNA STAGE-IV	08-Feb-24	08:00	08-Feb-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
27	400 KV	LONIKAND I - KOYNA STAGE-IV	08-Feb-24	08:00	08-Feb-24	18:00	Daily	Cold washing of Insulator Strings	MSETCL	MSETCL	-
28	400 KV	NEW KOYNA - STAGE IV CKT - 1	08-Feb-24	08:00	08-Feb-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
29	400 KV	WARORA - IEPL	08-Feb-24	09:00	08-Feb-24	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
30	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT - 2	08-Feb-24	10:00	08-Feb-24	18:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
31	400 KV	400/220 KV 167MVA SPARE ICT @ LONIKAND 2	08-Feb-24	08:00	08-Feb-24	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
32	400 KV	MAIN BAY (401) OF BUS REACTOR @ ALKUD	08-Feb-24	10:00	08-Feb-24	13:00	Daily	Routine maintenance work	MSETCL	MSETCL	--

Sr.No	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
33	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	08-Feb-24	10:00	08-Feb-24	17:00	Daily	Diagnostic testing of Bushing & winding	MSETCL	MSETCL	501MVA 400/220/33kV ICT-I will in service
34	400 KV	400/220/33 KV 315 MVA ICT - 1 @ DHULE	08-Feb-24	09:00	08-Feb-24	18:00	Daily	Routine Maint, Testing & NIFPS system testing	MSETCL	MSETCL	During the outage period 501MVA ICT-2 & 3 is in service
35	400 KV	FUTURE CKT - 1 @ WARORA	08-Feb-24	09:00	08-Feb-24	17:00	Daily	Relay testing work & routine maintenance work.	MSETCL	MSETCL	In Dia the 400KV IEPL ckt charged on its Main Bay CB
36	400 KV	400 KV FUTURE BAY II @ WARORA	09-Feb-24	09:00	09-Feb-24	17:00	Daily	Relay testing work & routine maintenace work.	MSETCL	MSETCL	In Dia the 400KV PGCIL (NAGRI) ckt charged on its Main Bay CB.
37	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KHARGHAR	09-Feb-24	08:00	09-Feb-24	18:00	Daily	Routine Maintenance & Testing Work	MSETCL	MSETCL	ICT-1 & ICT-3 will be in service
38	400 KV	400/220/33 KV 315MVA ICT - 2 @ AKOLA	09-Feb-24	09:00	09-Feb-24	18:00	Daily	Diagnostic testing & Routine maintenance work	MSETCL	MSETCL	Load will shifted on ICT-01 & ICT-03
39	400 KV	400/220/33 KV 500 MVA ICT - 2 @ DHULE	09-Feb-24	09:00	09-Feb-24	18:00	Daily	Routine Maint, Testing & NIFPS system testing	MSETCL	MSETCL	During the outage period 315MVA ICT-1 & 501MVA ICT-3 is in service
40	400 KV	NEW KOYNA-KARAD CKT - 1	09-Feb-24	08:00	09-Feb-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
41	400 KV	400/220/33 KV 315 MVA ICT - 2 @ WALUJ	09-Feb-24	10:00	09-Feb-24	18:00	Daily	Diagnostic Testing and routine maintenance work.	MSETCL	MSETCL	NIL
42	400 KV	400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	12-Feb-24	09:00	12-Feb-24	23:00	Daily	Q/ M work	MSETCL	MSETCL	outage required for Q/M work
43	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	12-Feb-24	08:00	12-Feb-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	----
44	400 KV	400/220/33 KV 500 MVA ICT - 3 @ DHULE	12-Feb-24	09:00	13-Feb-24	18:00	Continuous	RRS Scheme /project work & NIFPS system testing	MSETCL	MSETCL	During the outage period 315MVA ICT-1 & 501MVA ICT-2 is in service
45	400 KV	TBC @ CHAKAN	12-Feb-24	10:00	12-Feb-24	18:00	Daily	Replacement of 89A 400kV PG Isolator scissors, Routine maintenance and DT.	MSETCL	MSETCL	-
46	400 KV	KARAD - TALANDGE CKT - 1	12-Feb-24	09:00	12-Feb-24	18:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
47	400 KV	MAIN BAY (403) of 500 MVA ICT @ ALKUD	13-Feb-24	10:00	13-Feb-24	13:00	Daily	Routine maintenance work	MSETCL	MSETCL	---
48	400 KV	KARAD - TALANDGE CKT - 2	13-Feb-24	09:00	13-Feb-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
49	400 KV	DEEPNAGAR - AURANGABAD (WALUJ)	13-Feb-24	09:00	13-Feb-24	18:00	Daily	Line Maintenance Work and Diagnostic testing work	MSETCL	MSETCL	NII
50	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	13-Feb-24	09:00	13-Feb-24	18:00	Daily	1) Distance M1 & M2 relays retrofitting work. (2) Bay maintenance work. 3) Hardware tightening & fitting work	MSETCL	MSETCL	-
51	400 KV	TIE BAY - 402 OF BUS REACTOR @ ALKUD	13-Feb-24	14:00	13-Feb-24	17:00	Daily	Routine maintenance work	MSETCL	MSETCL	---
52	400 KV	TBC @ KOLHAPUR(TALANDGE)	13-Feb-24	09:00	13-Feb-24	18:00	Daily	1. LBB relay testing work 2. QM of Bay	MSETCL	MSETCL	TBC is Free

Sr.No	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
53	400 KV	400/220 KV 500 MVA ICT @ ALKUD	13-Feb-24	10:00	13-Feb-24	17:00	Daily	Routine maintenance work	MSETCL	MSETCL	Load will be managed on 400Kv Talandge and Karad
54	400 KV	400/220KV 167 MVA SPARE ICT @ DHULE	14-Feb-24	09:00	15-Feb-24	18:00	Continuous	RRS scheme /project work	MSETCL	MSETCL	Spare ICT is on NO-LOAD
55	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	14-Feb-24	09:00	14-Feb-24	18:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
56	400 KV	400KV 125MVAR BUS REACTOR @ CHANDRAPUR 2	15-Feb-24	10:00	15-Feb-24	18:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
57	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	15-Feb-24	09:00	15-Feb-24	18:00	Daily	Earthwire Stringing Work loc.no.497-500 & Nut bolt hardware tightening work	MSETCL	MSETCL	-
58	400 KV	KHADKA - BABLESHWAR	15-Feb-24	08:00	15-Feb-24	18:00	Daily	Routine Line maintenance work;LBB relay and CVT tan D testing	MSETCL	MSETCL	400kV Aurangabad ,400kV Dhule ckt I&II, Ektuni I&II will be in service
59	400 KV	LONIKAND - JEJURI CKT - 1	15-Feb-24	08:00	15-Feb-24	18:00	Daily	Cold washing of Insulator Strings	MSETCL	MSETCL	-
60	400 KV	JEJURI- KOYNA STAGE-IV	15-Feb-24	08:00	15-Feb-24	19:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
61	400 KV	400/220KV 105 MVA SPARE ICT @ DHULE	16-Feb-24	09:00	17-Feb-24	18:00	Continuous	Replacement of FCC and DM Box	MSETCL	MSETCL	Spare ICT is on NO-LOAD
62	400 KV	NEW KOYNA - STAGE IV CKT - 2	16-Feb-24	08:00	16-Feb-24	17:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---
63	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	16-Feb-24	08:00	16-Feb-24	18:00	Daily	Routine Maintenance & Testing Work	MSETCL	MSETCL	ICT-1 & ICT-2 will be in service
64	400 KV	KHADKA - BABLESHWAR	16-Feb-24	08:00	16-Feb-24	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Aurangabad ,400kV Dhule ckt I&II, Ektuni I&II will be in service
65	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	16-Feb-24	10:00	16-Feb-24	18:00	Daily	Diagnostic Testing and routine maintenance work	MSETCL	MSETCL	NIL
66	400 KV	400/220KV 315MVA ICT - 3 @ CHAKAN	17-Feb-24	10:00	17-Feb-24	18:00	Daily	DT and relay testing work	MSETCL	MSETCL	-
67	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	17-Feb-24	09:00	29-Feb-24	18:00	Daily	PID testing works.	MSETCL	MSETCL	-
68	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	19-Feb-24	09:00	19-Feb-24	18:00	Daily	1) REF relay & IV CT testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-
69	400 KV	DHULE- - BABLESHWAR CKT - 1	20-Feb-24	09:00	20-Feb-24	17:00	Daily	Distance Main I and II relay testing,Quarterly bay maintenance work	MSETCL	MSETCL	400kV Dhule ckt II will be in service
70	400 KV	WARORA - IEPL	20-Feb-24	09:00	20-Feb-24	17:00	Daily	Routine maintenance and diagnostic testing such as CVT/ CT tandelata, and, isolater maintenance work	MSETCL	MSETCL	Load will be managed on 400KV PGCIL Ckt .
71	400 KV	400 KV TBC @DHULE	21-Feb-24	09:00	21-Feb-24	18:00	Daily	Routine Circuit Breaker DCRM & CT Testing & Maint of bay	MSETCL	MSETCL	Routine Circuit Breaker DCRM & CT Testing & Maint of bay
72	400 KV	KORADI - KHAPERKHEDA CKT - 2	21-Feb-24	10:00	21-Feb-24	17:00	Daily	High Level Jumper Tigteneing Work of all equipments	MSETCL	MSETCL	NA

Sr.No	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
73	400 KV	PARLI - KUMBHARGAON(NANDED) CKT - 2	22-Feb-24	09:00	22-Feb-24	18:00	Daily	(1) CTs testing work. (2) Bay maintenance work. (3) Hardware tightening & fitting work	MSETCL	MSETCL	-
74	400 KV	MAIN BAY - 404 CHD SWITCHING CKT2 @ CHANDRAPUR 2	22-Feb-24	10:00	22-Feb-24	17:00	Daily	Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing & allied bay maintenance work
75	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	22-Feb-24	09:30	22-Feb-24	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-1 & ICT-2 will continue to remain in service
76	400 KV	400KV 125 MVAR BUS REACTOR@400KV DHULE SS	22-Feb-24	09:00	22-Feb-24	18:00	Daily	Routine CB & CT Testing & Maint of bay	MSETCL	MSETCL	Routine CB & CT Testing & Maint of bay
77	400 KV	JEJURI - KARAD	22-Feb-24	08:00	22-Feb-24	17:00	Daily	PID Faulty string replacement work Cold line washing work	MSETCL	MSETCL	PID Faulty string replacement work Cold line washing work
78	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	22-Feb-24	09:00	22-Feb-24	18:00	Daily	Earthwire Stringing Work loc.no.497-500 & Nut bolt hardware tightening work	MSETCL	MSETCL	-
79	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	22-Feb-24	10:30	22-Feb-24	18:00	Daily	Annual Bay maintenance & Relay Diagnostic Testing work	MSETCL	MSETCL	testing & maintenance work
80	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	22-Feb-24	08:00	22-Feb-24	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
81	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 1	22-Feb-24	08:00	22-Feb-24	18:00	Daily	DT Work & Bay Maintenance	MSETCL	MSETCL	-
82	400 KV	TIE BAY 421 OF LONIKAND1 CKT-1 AND LONIKAND1 CKT-2 @LONIKAND 2	22-Feb-24	08:00	22-Feb-24	18:00	Daily	Diagnostic testing and Maintenance	MSETCL	MSETCL	-
83	400 KV	THAPTI TANDA - AURANGABAD (WALUJ)	23-Feb-24	10:00	23-Feb-24	18:00	Daily	Routine Maintenance work and Diagnostic testing work.	MSETCL	MSETCL	NIL
84	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	23-Feb-24	08:00	23-Feb-24	18:00	Daily	Routine Maintenance & Testing Work	MSETCL	MSETCL	ICT-3 & ICT-2 will be in service
85	400 KV	TBC @ BABHALESHWAR	26-Feb-24	09:00	26-Feb-24	16:00	Daily	CB DCRM/Timing testing work	MSETCL	MSETCL	TBC will be free for availing outage
86	400 KV	105 MVA SPARE ICT @ CHAKAN	26-Feb-24	10:00	26-Feb-24	18:00	Daily	Routine maintenance and DT.	MSETCL	MSETCL	-
87	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	26-Feb-24	09:00	26-Feb-24	18:00	Daily	1) NDR & IV backup relays testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-
88	400 KV	KORADI II - IEPL	27-Feb-24	06:00	27-Feb-24	18:00	Daily	LINE MAINT. WORKS	MSETCL	MSETCL	NA
89	400 KV	STATION TF No 4 @ CHANDRAPUR GCR	27-Feb-24	08:00	27-Feb-24	18:00	Daily	1.Measurement of CB timing, CRM, DCRM. 2. STN-4 will be in service via TBC-2	MSETCL	MSETCL	STN-4 will be in service via TBC-2
90	400 KV	400KV KHADKA (400KV)-AKOLA(400KV) CKT LINE REACTOR	27-Feb-24	08:00	27-Feb-24	18:00	Daily	For quarterly bay Maintenance	MSETCL	MSETCL	as per annual plan

Sr.No .	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
91	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	29-Feb-24	10:00	29-Feb-24	18:00	Daily	For Overhauling of SERGI NIFPS Fire system for ICT No.2, Repairing and Overhauling of 89A PG isolators, Routine Maintenance and DT.	MSETCL	MSETCL	-
92	400 KV	JEJURI- KOYNA STAGE-IV	29-Feb-24	08:00	29-Feb-24	18:00	Daily	Cold washing of Insulator Strings	MSETCL	MSETCL	-