

Maharashtra State Load Despatch Centre

Monthly Outage list approved in WRLDC OCCM for the Month of FEBRUARY '2025

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continguous	Reason	From Date	From Time	To Date	To Time	Remarks
1	RQ230830	PLANNED	OCC_587	MSLDC_OUTAGE	400KV/220KV CHANDRAPUR-ICT-2	C	1. Modification of High Velocity Water Spray system. 2. Testing of High Velocity Water spray system. 3. Routine Mainteanance of ICT.	27/Jan/2025	08:00	07/Feb/2025	18:00	
2	RQ232515	PLANNED	OCC_587	POWERGRID_WR1	220KV-AURANGABAD-SHENDRA-2	D	AMP Work / dia will eb kept open at both ends	01/Feb/2025	08:00	01/Feb/2025	18:00	
3	RQ233912	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	C	CB Overhauling Work by External Agency & Bay Maintenance & Equipment Testing.	01/Feb/2025	05:00	02/Feb/2025	17:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
4	RQ234032	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	01/Feb/2025	09:00	01/Feb/2025	18:00	
5	RQ234090	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	01/Feb/2025	09:00	01/Feb/2025	17:30	
6	RQ234118	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	01/Feb/2025	09:00	01/Feb/2025	17:30	
7	RQ233913	PLANNED	OCC_587	MSLDC_OUTAGE	400KV/220KV CHANDRAPUR-ICT-2	C	"1. Modification of High Velocity Water Spray system. 2. Testing of High Velocity Water spray system. 3. Routine Mainteanance of ICT."	01/Feb/2025	08:00	10/Feb/2025	18:00	
8	RQ233911	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-PARLI-M-3	C	(1) Bay equipments replacement work (CT,CVT,LA,WT, PG & HCB isolators) under LES. (2)Reactor testing work.3) Hardware tightening & fitting work	01/Feb/2025	09:00	15/Feb/2025	18:00	
9	RQ234287	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	01/Feb/2025	08:00	01/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
10	RQ234315	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	01/Feb/2025	08:00	01/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
11	RQ233850	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	01/Feb/2025	08:00	01/Feb/2025	18:00	during aurangabad pune padghe/ study/MSLDC consent is required. Subject to no other parallel outages.
12	RQ234486	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM PS-1	D	AR disable require for replacement of earth wire with OPGW	01/Feb/2025	08:00	01/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
13	RQ234496	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM PS-2	D	AR disable require for replacement of earth wire with OPGW	01/Feb/2025	08:00	01/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continous	Reason	From Date	From Time	To Date	To Time	Remarks
14	RQ234075	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID testing	01/Feb/2025	09:00	01/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
15	RQ234060	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID Testing Work	01/Feb/2025	09:00	01/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
16	RQ233745	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	01/Feb/2025	08:00	01/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
17	RQ233773	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	01/Feb/2025	08:00	01/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
18	RQ235110	PLANNED	OCC_587	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-1	C	Simultaneous outage of 400 KV TARAPUR - PADGHE - 1 and 2 is required for Outage required for diversion of transmission line fouling to the Vadodara - Mumbai Expressway	01/Feb/2025	08:00	09/Feb/2025	18:00	separate meeting/ one at a time/ tarapur 3&4 consent required
19	RQ235111	PLANNED	OCC_587	POWERGRID_WR2	400KV-TARAPUR 3&4-PADGHE-2	C	Simultaneous outage of 400 KV TARAPUR - PADGHE - 1 and 2 is required for Outage required for diversion of transmission line fouling to the Vadodara - Mumbai Expressway	01/Feb/2025	08:00	09/Feb/2025	18:00	separate meeting/ one at a time/ tarapur 3&4 consent required
20	RQ233910	PLANNED	OCC_587	MSLDC_OUTAGE	PADGHE - 400KV B/R 1	C	1) Areva CB Pole Overhauling work. 2) A & B Bus PG Isolator Maintenance work.	01/Feb/2025	09:30	08/Feb/2025	18:00	
21	RQ233604	PLANNED	OCC_587	POWERGRID_WR1	TIE BAY - 765KV-PUNE-GIS-PADGHE-PG-1 AND 765KV/400KV PUNE-GIS-ICT-3 at Pune-GIS - 765KV	C	GIB extension works,	01/Feb/2025	09:00	15/Feb/2025	18:00	
22	RQ232543	PLANNED	OCC_587	POWERGRID_WR1	TIE BAY - WARDHA - 765KV B/R 2 AND 765KV-SEONI-WARDHA-2 at Wardha - 765KV	D	For AMP of Bay	01/Feb/2025	08:00	01/Feb/2025	20:00	
23	RQ235154	PLANNED	OCC_587	POWERGRID_WR1	220KV-AURANGABAD-SHENDRA-2	D	For AMP Works	01/Feb/2025	09:00	01/Feb/2025	17:30	Outages punched after 5th Jan 2025
24	RQ233914	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	For safety purpose during Installation of Saver Assembly on 220kV Tarapur - Borivali Line at various Locations.	02/Feb/2025	09:00	02/Feb/2025	17:00	Line bay shifting work-> installation of saver assembly-> maintenance. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
25	RQ234033	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	02/Feb/2025	09:00	02/Feb/2025	18:00	
26	RQ234091	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	02/Feb/2025	09:00	02/Feb/2025	17:30	
27	RQ234119	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	02/Feb/2025	09:00	02/Feb/2025	17:30	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
28	RQ234924	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BORIVALI-1	D	Installation of Saver Assembly at various Locations.	02/Feb/2025	09:00	02/Feb/2025	17:00	
29	RQ235119	PLANNED	OCC_587	POWERGRID_WR2	400KV/220KV BOISAR-ICT-1	D	For 220kV Busbar PU/LBB relay retrofiting	02/Feb/2025	07:00	02/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
30	RQ233915	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	1) Bay Maintenance Work. 2) Diagnostic Testing work. 3) 29 C Bus PG Isolator replacement work under LES Scheme. 4) ETC of TWFL relay.	02/Feb/2025	09:00	02/Feb/2025	20:00	
31	RQ234288	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	02/Feb/2025	08:00	02/Feb/2025	18:00	
32	RQ234316	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	02/Feb/2025	08:00	02/Feb/2025	18:00	
33	RQ233851	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	02/Feb/2025	08:00	02/Feb/2025	18:00	
34	RQ234487	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM PS-1	D	AR disable require for replacement of earth wire with OPGW	02/Feb/2025	08:00	02/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
35	RQ234497	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM PS-2	D	AR disable require for replacement of earth wire with OPGW	02/Feb/2025	08:00	02/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
36	RQ234061	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID Testing Work	02/Feb/2025	09:00	02/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
37	RQ234076	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	02/Feb/2025	09:00	02/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
38	RQ233746	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	02/Feb/2025	08:00	02/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
39	RQ233774	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	02/Feb/2025	08:00	02/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
40	RQ235120	PLANNED	OCC_587	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-2	D	For 220kV Busbar PU/LBB relay retrofiting	03/Feb/2025	07:00	03/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLOC to avail outages on 16 to 28. /to be planned in night hour.
41	RQ234034	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	03/Feb/2025	09:00	03/Feb/2025	18:00	
42	RQ234092	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	03/Feb/2025	09:00	03/Feb/2025	17:30	
43	RQ234120	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	03/Feb/2025	09:00	03/Feb/2025	17:30	
44	RQ234760	PLANNED	OCC_587	TAPS12	220KV-TARAPUR 3&4-TARAPUR 1&2-1	C	1) TAPS 1&2, 220 kV Zone-III main bus outages to carry out annual maintenance of main bus and tie line bay's equipments. 2) Remarks: BS#2 between 220 kV Zone-1 & Zone-III buses will remain open from 0800 hrs on 03/02/2025 to 1800 hrs on 04/02/2025 on daily basis.	03/Feb/2025	08:00	04/Feb/2025	18:00	dates to be revised to (1-3 feb)
45	RQ234481	PLANNED	OCC_587	TAPS34	220KV-TARAPUR 3&4-TARAPUR 1&2-1	C	LINE PM AT TAPS 3 AND 4 END- SIMULTANEOUS OUTAGE OF TAPS 1 AND 2	03/Feb/2025	08:00	04/Feb/2025	23:00	
46	RQ233918	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For replacement of SSN Insulator String into DSN Insulator String along with Hardwares at various Road/River/Nala/Canal crossing locations.	03/Feb/2025	08:00	03/Feb/2025	18:00	
47	RQ232577	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	03/Feb/2025	08:00	03/Feb/2025	20:00	
48	RQ232516	PLANNED	OCC_587	POWERGRID_WR1	400KV/220KV AURANGABAD-ICT-2	D	For AMP Works and Retrofitting of Conventional REF Relay with Numerical REF Relay of Siemens make (Model: 7SJ802). / dia to be kept open at both sides	03/Feb/2025	08:00	03/Feb/2025	18:00	
49	RQ233606	PLANNED	OCC_587	POWERGRID_WR1	400KV/220KV PUNE-GIS-ICT-2	C	For Bus extension	03/Feb/2025	06:00	05/Feb/2025	20:00	
50	RQ234289	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	03/Feb/2025	08:00	03/Feb/2025	18:00	
51	RQ234317	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	03/Feb/2025	08:00	03/Feb/2025	18:00	
52	RQ234146	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	03/Feb/2025	09:00	03/Feb/2025	15:00	
53	RQ233852	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	03/Feb/2025	08:00	03/Feb/2025	18:00	
54	RQ233297	PLANNED	OCC_587	POWERGRID_WR1	400KV-PADGHE-PG-KUDUS-2	D	AMP of Line Equipment	03/Feb/2025	09:00	03/Feb/2025	18:00	
55	RQ234488	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM PS-1	D	AR disable require for replacement of earth wire with OPGW	03/Feb/2025	08:00	03/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
56	RQ234498	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM PS-2	D	AR disable require for replacement of earth wire with OPGW	03/Feb/2025	08:00	03/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
57	RQ234062	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID Testing Work	03/Feb/2025	09:00	03/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kv Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kv Parli-PG- Kallam- Pune GIS corridor/C. 400 kv Pune - Pune lines) subject to no other outages in parallel.
58	RQ234077	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID testing	03/Feb/2025	09:00	03/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kv Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kv Parli-PG- Kallam- Pune GIS corridor/C. 400 kv Pune - Pune lines) subject to no other outages in parallel.
59	RQ233916	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	(1) CT tesing work. (2) Bay maintenance work.3) Hardware tightening & fitting work	03/Feb/2025	09:00	03/Feb/2025	18:00	
60	RQ233747	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	03/Feb/2025	08:00	03/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kv Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kv Parli-PG- Kallam- Pune GIS corridor/C. 400 kv Pune - Pune lines) subject to no other outages in parallel.
61	RQ233775	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	03/Feb/2025	08:00	03/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kv Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kv Parli-PG- Kallam- Pune GIS corridor/C. 400 kv Pune - Pune lines) subject to no other outages in parallel.
62	RQ233917	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	C	Chemical Washing work & Cold washing work	03/Feb/2025	06:00	07/Feb/2025	18:00	
63	RQ234465	PLANNED	OCC_587	RGPPL	400KV-RGPPL-NEW KOYNA-1	D	ATTENDING SF6 LEAKAGE FROM 421 BREAKER	03/Feb/2025	09:00	03/Feb/2025	20:00	
64	RQ234152	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	03/Feb/2025	07:00	03/Feb/2025	18:00	
65	RQ232470	PLANNED	OCC_587	POWERGRID_WR1	KOLHAPUR GIS - 400KV B/R 1	C	Reactor AMP and turret CT oil leakage attending	03/Feb/2025	08:00	04/Feb/2025	18:00	
66	RQ233354	PLANNED	OCC_587	MEGPCTL	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	03/Feb/2025	09:00	03/Feb/2025	18:00	
67	RQ234408	PLANNED	OCC_587	RGPPL	MAIN BAY OF 400KV-RGPPL-NEW KOYNA-1 AND RGPPL - 400KV - BUS 1 @RGPPL - 400KV at RGPPL - 400KV	C	ATTENDING SF6 LEAKAGE	03/Feb/2025	09:00	04/Feb/2025	20:00	
68	RQ234963	PLANNED	OCC_587	MSLDC_OUTAGE	MAIN BAY OF 400KV-WARDHA-WARORA-1 AND WARORA - 400KV - BUS 1 @WARORA - 400KV at WARORA - 400KV	C	CB DCRM/CRM/Timing, CT C & Tan Delta work to be carried out.	03/Feb/2025	08:00	08/Feb/2025	22:00	
69	RQ235121	PLANNED	OCC_587	POWERGRID_WR2	220KV-BOISAR-PANCHALI-1	D	For 220kv Busbar PU/LBB relay retrofitting	04/Feb/2025	07:00	04/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
70	RQ234035	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	04/Feb/2025	09:00	04/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continous	Reason	From Date	From Time	To Date	To Time	Remarks
71	RQ234093	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	04/Feb/2025	09:00	04/Feb/2025	17:30	
72	RQ234121	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	04/Feb/2025	09:00	04/Feb/2025	17:30	
73	RQ232578	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	04/Feb/2025	08:00	04/Feb/2025	20:00	
74	RQ232664	PLANNED	OCC_587	POWERGRID_WR1	400KV-CHAKAN-PUNE-PG-1	D	FOR AMP WORK	04/Feb/2025	09:00	04/Feb/2025	17:00	MSLDC consent is required/Subject to no other outages in parallel.
75	RQ233919	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-1	D	Line maintenance works	04/Feb/2025	10:00	04/Feb/2025	17:00	
76	RQ234290	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	04/Feb/2025	08:00	04/Feb/2025	18:00	
77	RQ234318	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	04/Feb/2025	08:00	04/Feb/2025	18:00	
78	RQ234147	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	04/Feb/2025	09:00	04/Feb/2025	15:00	
79	RQ235259	PLANNED	OCC_587	POWERGRID_WR2	400KV-KORADI-SATPURA-1	C	Line CVT replacement works under ADD CAP works at Sarni MPPGCL & Bay AMP works at Sarni MPPGCL	04/Feb/2025	07:00	07/Feb/2025	23:00	
80	RQ233853	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	04/Feb/2025	08:00	04/Feb/2025	18:00	
81	RQ234489	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM P5-1	D	AR disable require for replacement of earth wire with OPGW	04/Feb/2025	08:00	04/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
82	RQ234490	PLANNED	OCC_588	MEGPTCL	400KV-PARLI-KALLAM P5-2	D	AR disable require for replacement of earth wire with OPGW	05/Feb/2025	08:01	05/Feb/2025	18:01	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
83	RQ234063	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID Testing Work	04/Feb/2025	09:00	04/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
84	RQ234078	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID testing	04/Feb/2025	09:00	04/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
85	RQ233748	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	04/Feb/2025	08:00	04/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
86	RQ233776	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	04/Feb/2025	08:00	04/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
87	RQ234466	PLANNED	OCC_587	RGPPL	400KV-RGPPL-NEW KOYNA-1	D	ATTENDING SF6 LEAKAGE FROM 421 BREAKER	04/Feb/2025	09:00	04/Feb/2025	20:00	
88	RQ234153	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	04/Feb/2025	07:00	04/Feb/2025	18:00	
89	RQ233920	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-WARORA-PG-WARORA-1	D	Routine Maintenance & Dignostic testing work .	04/Feb/2025	09:00	04/Feb/2025	17:00	
90	RQ233292	PLANNED	OCC_587	POWERGRID_WR1	765KV/400KV PADGHE-PG-ICT-3	D	Spare Changoover of ICT#3, Taking Yph IN service & Spare OUT of Service & Fine tuning of CSD of ICT	04/Feb/2025	09:00	04/Feb/2025	18:00	
91	RQ233231	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 400KV-ALKUD-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 at Solapur - 400KV	D	Bay AMP works	04/Feb/2025	08:00	04/Feb/2025	18:00	
92	RQ233924	PLANNED	OCC_587	MSLDC_OUTAGE	132KV-PENCH-KANHAN-1	D	For routine maintenance work	05/Feb/2025	09:00	05/Feb/2025	18:00	
93	RQ235122	PLANNED	OCC_587	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-1	D	For 220kV Busbar PU/LBB relay retrofiting	05/Feb/2025	07:00	05/Feb/2025	21:00	At 220 kV Boisar M, 16-28 maharashtra outages/ 1-15 Powergrid outages/ either night hour/no other outages at boisar/
94	RQ233923	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PANDURNA-KALMESHWAR-1	D	For routine maintenance work	05/Feb/2025	09:00	05/Feb/2025	18:00	
95	RQ234036	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	05/Feb/2025	09:00	05/Feb/2025	18:00	
96	RQ234094	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	05/Feb/2025	09:00	05/Feb/2025	17:30	
97	RQ234122	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	05/Feb/2025	09:00	05/Feb/2025	17:30	
98	RQ233925	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-TILLARI-AMONA-1	D	Maintenance work	05/Feb/2025	09:00	05/Feb/2025	18:00	
99	RQ232579	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	05/Feb/2025	08:00	05/Feb/2025	20:00	
100	RQ232665	PLANNED	OCC_587	POWERGRID_WR1	400KV/220KV PUNE-PG-ICT-1	D	FOR AMP WORK	05/Feb/2025	09:00	05/Feb/2025	17:00	Plan on 28th Feb 2025

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
101	RQ233921	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-CHANDRAPUR-KHAPARKHEDA-1	C	Monopole tower erection work between tower No.34 &35	05/Feb/2025	06:00	15/Feb/2025	22:00	
102	RQ234291	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	05/Feb/2025	08:00	05/Feb/2025	18:00	
103	RQ234319	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	05/Feb/2025	08:00	05/Feb/2025	18:00	
104	RQ234148	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	05/Feb/2025	09:00	05/Feb/2025	15:00	
105	RQ233854	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	05/Feb/2025	08:00	05/Feb/2025	18:00	
106	RQ234490	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM P5-1	D	AR disable require for replacement of earth wire with OPGW	05/Feb/2025	08:00	05/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
107	RQ234500	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM P5-2	D	AR disable require for replacement of earth wire with OPGW	05/Feb/2025	08:00	05/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
108	RQ234064	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID Testing Work	05/Feb/2025	09:00	05/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
109	RQ234079	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	05/Feb/2025	09:00	05/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
110	RQ233749	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	05/Feb/2025	08:00	05/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
111	RQ233777	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	05/Feb/2025	08:00	05/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
112	RQ234154	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	05/Feb/2025	07:00	05/Feb/2025	18:00	
113	RQ233352	PLANNED	OCC_587	MEGPTCL	400KV-TIRODA-WARORA-1	D	Annual maintenance of line	05/Feb/2025	08:00	05/Feb/2025	18:00	
114	RQ233922	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-WARDHA-KORADI-II-1	D	Routine Maintenance & Dignostic testing work .	05/Feb/2025	09:00	05/Feb/2025	17:00	
115	RQ233291	PLANNED	OCC_587	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	WTI replacement in Yph LR of 765KV Pune-Padghe Line at Padghe SS	05/Feb/2025	10:00	05/Feb/2025	12:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
116	RQ234409	PLANNED	OCC_587	RGPPL	MAIN BAY OF 400KV-RGPPL-NEW KOYNA-2 AND RGPPL - 400KV - BUS 1 @RGPPL - 400KV at RGPPL - 400KV	C	ATTENDING SF6 LEAKAGE	05/Feb/2025	09:00	06/Feb/2025	20:00	
117	RQ233355	PLANNED	OCC_587	MEGPTCL	TIE BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	05/Feb/2025	09:00	05/Feb/2025	18:00	
118	RQ234037	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	06/Feb/2025	09:00	06/Feb/2025	18:00	
119	RQ234095	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	06/Feb/2025	09:00	06/Feb/2025	17:30	
120	RQ234123	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	06/Feb/2025	09:00	06/Feb/2025	17:30	
121	RQ235123	PLANNED	OCC_587	POWERGRID_WR2	220KV-TARAPUR 3&4-BOISAR-1	D	For 220kV Busbar PU/LBB relay retrofitting	06/Feb/2025	07:00	06/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
122	RQ232580	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	06/Feb/2025	08:00	06/Feb/2025	20:00	
123	RQ233928	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	1) For replacement of existing SSN to DSN & STN to DTN at various location under LES scheme. 2) ORC WORK -Diversion of 220KV Deoli PG-Pusad line at loc 250-251 due to four lanning of NH-361 (Butibori-Tuljapur)- shifting of line on ERS thereof.	06/Feb/2025	08:00	06/Feb/2025	18:00	
124	RQ233608	PLANNED	OCC_587	POWERGRID_WR1	400KV/220KV PUNE-GIS-ICT-2	C	For Bus extension	06/Feb/2025	06:00	08/Feb/2025	20:00	
125	RQ233927	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-EKTUNI-BABLESHWAR-2	D	Line maintenance works	06/Feb/2025	10:00	06/Feb/2025	17:00	
126	RQ234292	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	06/Feb/2025	08:00	06/Feb/2025	18:00	
127	RQ234320	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	06/Feb/2025	08:00	06/Feb/2025	18:00	
128	RQ234149	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	06/Feb/2025	09:00	06/Feb/2025	15:00	
129	RQ233855	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	06/Feb/2025	08:00	06/Feb/2025	18:00	
130	RQ234491	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM P5-1	D	AR disable require for replacement of earth wire with OPGW	06/Feb/2025	08:00	06/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
131	RQ234501	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM P5-2	D	AR disable require for replacement of earth wire with OPGW	06/Feb/2025	08:00	06/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
132	RQ233926	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	C	Hardware tightening and cold line washing	06/Feb/2025	22:00	07/Feb/2025	06:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
133	RQ234065	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID Testing Work	06/Feb/2025	09:00	06/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhhand-II-Lonikhhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
134	RQ234080	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID testing	06/Feb/2025	09:00	06/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhhand-II-Lonikhhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
135	RQ233750	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	06/Feb/2025	08:00	06/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhhand-II-Lonikhhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
136	RQ233778	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	06/Feb/2025	08:00	06/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhhand-II-Lonikhhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
137	RQ234155	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	06/Feb/2025	07:00	06/Feb/2025	18:00	
138	RQ233290	PLANNED	OCC_587	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-2	D	AMP of Line Equipment	06/Feb/2025	09:00	06/Feb/2025	18:00	
139	RQ233353	PLANNED	OCC_587	MEGPTCL	400KV-TIRODA-WARORA-2	D	Annual maintenance of line	06/Feb/2025	08:00	06/Feb/2025	18:00	
140	RQ235115	PLANNED	OCC_587	POWERGRID_WR2	MAIN BAY - 220KV-BOISAR-BOISAR-M-1 AND BOISAR - 220KV - BUS 1 at BOISAR - 220KV	D	BAY AMP WORK	06/Feb/2025	06:00	06/Feb/2025	18:00	
141	RQ233930	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-1	D	For taking in service - 220kV Hybrid Bus Sectionlizer	07/Feb/2025	10:00	07/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
142	RQ233931	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-AURANGABAD-CHITEGAON-2	D	For taking in service - 220kV Hybrid Bus Sectionlizer	07/Feb/2025	10:00	07/Feb/2025	18:00	
143	RQ233934	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-1	D	Line Bay shifting at 220kV Boisar-II S/S. (From Bay No. 12 to Bay No. 14)	07/Feb/2025	06:00	07/Feb/2025	19:00	At 220 kV Boisar M, 16-28 maharashtra outages/ 1-15 Powergrid outages/ either night hour/no other outages at boisar/. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28.
144	RQ234038	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	07/Feb/2025	09:00	07/Feb/2025	18:00	
145	RQ234096	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	07/Feb/2025	09:00	07/Feb/2025	17:30	
146	RQ234124	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	07/Feb/2025	09:00	07/Feb/2025	17:30	
147	RQ232581	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	07/Feb/2025	08:00	07/Feb/2025	20:00	
148	RQ233933	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	For replacement of existing SSN to DSN & STN to DTN at various location under LES scheme.	07/Feb/2025	08:00	07/Feb/2025	18:00	
149	RQ235124	PLANNED	OCC_587	POWERGRID_WR2	400KV/220KV BOISAR-ICT-3	D	For 220kV Busbar PU/LBB relay retrofitting	07/Feb/2025	07:00	07/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
150	RQ234293	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	07/Feb/2025	08:00	07/Feb/2025	18:00	
151	RQ234321	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	07/Feb/2025	08:00	07/Feb/2025	18:00	
152	RQ234150	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	07/Feb/2025	09:00	07/Feb/2025	15:00	
153	RQ233856	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	07/Feb/2025	08:00	07/Feb/2025	18:00	
154	RQ234492	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM PS-1	D	AR disable require for replacement of earth wire with OPGW	07/Feb/2025	08:00	07/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
155	RQ234502	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM PS-2	D	AR disable require for replacement of earth wire with OPGW	07/Feb/2025	08:00	07/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
156	RQ234066	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID Testing Work	07/Feb/2025	09:00	07/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
157	RQ234081	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	07/Feb/2025	09:00	07/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
158	RQ233751	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	07/Feb/2025	08:00	07/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kv Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kv Parli-PG- Kallam- Pune GIS corridor/C. 400 kv Pune - Pune lines) subject to no other outages in parallel.
159	RQ233779	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	07/Feb/2025	08:00	07/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kv Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kv Parli-PG- Kallam- Pune GIS corridor/C. 400 kv Pune - Pune lines) subject to no other outages in parallel.
160	RQ234156	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	07/Feb/2025	07:00	07/Feb/2025	18:00	
161	RQ233298	PLANNED	OCC_587	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-1	D	AMP of Line Equipment	07/Feb/2025	09:00	07/Feb/2025	18:00	
162	RQ233929	PLANNED	OCC_587	MSLDC_OUTAGE	BUS COUPLER BAY - PARLI-M - 400KV - BUS 1 AND PARLI-M - 400KV - BUS 2 at PARLI-M - 400KV	D	1) CT testing work. (2) Bay maintenance work.	07/Feb/2025	09:00	07/Feb/2025	18:00	
163	RQ233932	PLANNED	OCC_587	MSLDC_OUTAGE	CHITEGAON - 220KV - BUS 1	D	For taking in service - 220kv Hybrid Bus sectionalizer	07/Feb/2025	10:00	07/Feb/2025	17:00	
164	RQ232471	PLANNED	OCC_587	POWERGRID_WR1	KOLHAPUR-MS - 400KV B/R 1	D	Reactor AMP Works	07/Feb/2025	08:00	07/Feb/2025	18:00	
165	RQ232513	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AURANGABAD - 400KV - BUS 1 at AURANGABAD - 400KV	D	AMP Work	07/Feb/2025	08:00	07/Feb/2025	18:00	
166	RQ232666	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 400KV-KALWA-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	FOR AMP WORK	07/Feb/2025	09:00	07/Feb/2025	17:00	
167	RQ233234	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 400KV-KARAD-SOLAPUR-1 AND SOLAPUR - 400KV - BUS 2 at Solapur - 400KV	D	Bay AMP works	07/Feb/2025	08:00	07/Feb/2025	18:00	
168	RQ233356	PLANNED	OCC_587	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	07/Feb/2025	09:00	07/Feb/2025	18:00	
169	RQ234964	PLANNED	OCC_587	MSLDC_OUTAGE	MAIN BAY OF 400KV-TAPTHITHANDA-DEEPNAGAR-1 AND TAPTHITHANDA - 400KV - BUS 1 @TAPTHITHANDA - 400KV at TAPTHITHANDA - 400KV	D	Routine maintenance and CB diagnostic testing work	07/Feb/2025	11:00	07/Feb/2025	18:00	
170	RQ233442	PLANNED	OCC_587	MEGPTCL	MAIN BAY OF AKOLA (2) - 765KV B/R 1 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	Annual Maintenance of Bay Equipment at Akola-II SS.	07/Feb/2025	09:00	07/Feb/2025	18:00	
171	RQ234445	PLANNED	OCC_587	RGPPL	TIE BAY OF 400KV/15.7KV RGPPL-GT-2B AND 400KV/15.7KV RGPPL-GT-2A @RGPPL - 400KV at RGPPL - 400KV	C	ATTENDING SF6 LEAKAGE	07/Feb/2025	09:00	08/Feb/2025	20:00	
172	RQ233935	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	C	Line Bay shifting at 220kv Boisar-II S/S. (From Bay No. 13 to Bay No. 12)	08/Feb/2025	06:00	09/Feb/2025	17:00	Line bay shifting work-> installation of saver assembly-> maintenance. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
173	RQ234039	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	08/Feb/2025	09:00	08/Feb/2025	18:00	
174	RQ234097	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	08/Feb/2025	09:00	08/Feb/2025	17:30	
175	RQ234125	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	08/Feb/2025	09:00	08/Feb/2025	17:30	
176	RQ232582	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	08/Feb/2025	08:00	08/Feb/2025	20:00	
177	RQ234294	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	08/Feb/2025	08:00	08/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continous	Reason	From Date	From Time	To Date	To Time	Remarks
178	RQ234322	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	08/Feb/2025	08:00	08/Feb/2025	18:00	
179	RQ233940	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-KARJAT-LONIKHAND-II-1	D	Cold Washing of Insulator strings	08/Feb/2025	08:00	08/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
180	RQ234151	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-KHARGHAR-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	08/Feb/2025	09:00	08/Feb/2025	15:00	
181	RQ233937	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-1	D	1. 400kV nago-I H/T required for 03 hrs for safety purpose for removing of gantry jumper between nago-I & II by hot line method.	08/Feb/2025	08:30	08/Feb/2025	11:30	
182	RQ233938	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-2	C	1. 400kV nago-II H/T required for two days for safety purpose for bus conductor replacement work of Sec-II between Tarapur-I and Nago-II.	08/Feb/2025	06:00	09/Feb/2025	22:00	
183	RQ233857	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	08/Feb/2025	08:00	08/Feb/2025	18:00	
184	RQ234493	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM PS-1	D	AR disable require for replacement of earth wire with OPGW	08/Feb/2025	08:00	08/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
185	RQ234503	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM PS-2	D	AR disable require for replacement of earth wire with OPGW	08/Feb/2025	08:00	08/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
186	RQ234067	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID Testing Work	08/Feb/2025	09:00	08/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
187	RQ234082	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	08/Feb/2025	09:00	08/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
188	RQ233941	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	C	Hardware tightening and cold line washing	08/Feb/2025	22:00	09/Feb/2025	06:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continous	Reason	From Date	From Time	To Date	To Time	Remarks
189	RQ233752	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	08/Feb/2025	08:00	08/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
190	RQ233780	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	08/Feb/2025	08:00	08/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
191	RQ234925	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-TARAPUR 3&4-PADGHE-1	C	1. 400KV Tarapur-I on TBC for B bus conductor replacement work of Sec-II between tarapur-I & Nago-II. 2. 400KV Tarapur-I hand trip required for 02 hrs on day one for gantry jumper opening by cold line method due to stub bus crossing.	08/Feb/2025	05:00	09/Feb/2025	23:59	
192	RQ234927	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCL	08/Feb/2025	07:00	08/Feb/2025	19:00	Priority/other outage at Pune node to be deferred.
193	RQ233358	PLANNED	OCC_587	MEGPTCL	765KV-AKOLA (2)-KORADI-III-1	D	Annual maintenance of line	08/Feb/2025	08:00	08/Feb/2025	18:00	
194	RQ233488	PLANNED	OCC_587	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	08/Feb/2025	07:00	08/Feb/2025	18:00	
195	RQ233480	PLANNED	OCC_587	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	08/Feb/2025	07:00	08/Feb/2025	18:00	
196	RQ232975	PLANNED	OCC_587	POWERGRID_WR1	BUS COUPLER BAY - PUNE-PG - 220KV - BUS 1 AND PUNE-PG - 220KV - BUS 2 at PUNE-PG - 220KV	D	FOR AMP WORK	08/Feb/2025	09:00	08/Feb/2025	17:00	
197	RQ233235	PLANNED	OCC_587	POWERGRID_WR1	BUS COUPLER BAY - SOLAPUR - 220KV - BUS 1 AND SOLAPUR - 220KV - BUS 2 at Solapur - 220KV	D	Bay AMP works	08/Feb/2025	08:00	08/Feb/2025	18:00	
198	RQ232667	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 220KV-TALEGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	FOR AMP WORK	08/Feb/2025	09:00	08/Feb/2025	17:00	
199	RQ233936	PLANNED	OCC_587	MSLDC_OUTAGE	PADGHE - 400KV - BUS 2	C	1) Partially Bus outage for replacement of B Bus conductor of Sec-II between 400kV tarapur-I and nagothane-II. 2) 400kV Tarapur-I in service through TBC. 3) 400kV Nago-II hand trip required for 2 days for bus conductor replacement. 4) 400kV Nago-I H/t required for 3 hrs for safety purposed for removing and reconnection of jumper by Hot line method on day one and day two.	08/Feb/2025	05:00	09/Feb/2025	23:59	
200	RQ233943	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	For safety purpose during installation of Saver Assembly on 220kV Tarapur - Boisar Line at various Locations.	09/Feb/2025	09:00	09/Feb/2025	17:00	Line bay shifting work-> installation of saver assembly-> maintenance. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
201	RQ234040	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	09/Feb/2025	09:00	09/Feb/2025	18:00	
202	RQ234098	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	09/Feb/2025	09:00	09/Feb/2025	17:30	
203	RQ234126	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	09/Feb/2025	09:00	09/Feb/2025	17:30	
204	RQ233944	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-TALEGAON-PUNE-PG-2	D	1) For chemical washing of insulator strings at various locations. 2) DT work at 220kV Talegaon SS end.	09/Feb/2025	09:00	09/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
205	RQ234926	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-TARAPUR 3&4-BOISAR-1	D	Installation of Saver Assembly at various Locations.	09/Feb/2025	09:00	09/Feb/2025	17:00	220KV-TARAPUR 3&4-BOISAR-1 line is tap 1&2 to Boisar M. Line bay shifting work-> installation of saver assembly-> maintenance. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28.
206	RQ232583	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	09/Feb/2025	08:00	09/Feb/2025	20:00	
207	RQ234295	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	09/Feb/2025	08:00	09/Feb/2025	18:00	
208	RQ234323	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	09/Feb/2025	08:00	09/Feb/2025	18:00	
209	RQ233942	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-KALWA-PADGHE-2	D	1) R & Y Phase Wave Trap replacement. 2) Bay Maintenance Work. 3) Diagonostic Testing work.	09/Feb/2025	09:00	09/Feb/2025	18:30	
210	RQ233939	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PADGHE-NAGOTHANE-1	D	1. 400kv nago-I H/T required for 03 hrs for safety purpose for reconnection of gantry jumper between nago-I & II by hot line method.	09/Feb/2025	14:00	09/Feb/2025	17:00	
211	RQ233858	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	09/Feb/2025	08:00	09/Feb/2025	18:00	
212	RQ234494	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM P5-1	D	AR disable require for replacement of earth wire with OPGW	09/Feb/2025	08:00	09/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhanda-II-Lonikhanda corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
213	RQ234504	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM P5-2	D	AR disable require for replacement of earth wire with OPGW	09/Feb/2025	08:00	09/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhanda-II-Lonikhanda corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
214	RQ234068	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID Testing Work	09/Feb/2025	09:00	09/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhanda-II-Lonikhanda corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
215	RQ234083	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	09/Feb/2025	09:00	09/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhanda-II-Lonikhanda corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
216	RQ233753	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	09/Feb/2025	08:00	09/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
217	RQ233781	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	09/Feb/2025	08:00	09/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
218	RQ234480	PLANNED	OCC_587	TAPS34	400KV-TARAPUR 3&4-BOISAR-1	C	LINE PM AT TAPS 3 AND 4 END	09/Feb/2025	08:00	11/Feb/2025	18:00	subject to no other parallel outages in boisar PG/ subject to no other critical outages
219	RQ234928	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCL	09/Feb/2025	07:00	09/Feb/2025	19:00	
220	RQ233359	PLANNED	OCC_587	MEGPTCL	765KV-AKOLA (2)-KORADI-III-2	D	Annual maintenance of line	09/Feb/2025	08:00	09/Feb/2025	18:00	
221	RQ233489	PLANNED	OCC_587	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	09/Feb/2025	07:00	09/Feb/2025	18:00	
222	RQ233481	PLANNED	OCC_587	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	09/Feb/2025	07:00	09/Feb/2025	18:00	
223	RQ235127	PLANNED	OCC_587	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-3	D	For 220kV Busbar PU/LBB relay retrofitting	10/Feb/2025	07:00	10/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
224	RQ234041	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	10/Feb/2025	09:00	10/Feb/2025	18:00	
225	RQ234099	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	10/Feb/2025	09:00	10/Feb/2025	17:30	
226	RQ234127	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	10/Feb/2025	09:00	10/Feb/2025	17:30	
227	RQ233236	PLANNED	OCC_587	POWERGRID_WR1	220KV-SOLAPUR-KUMBARI-2	D	Line terminal equipments AMP at 765kV Solapur Substation	10/Feb/2025	07:00	10/Feb/2025	18:00	
228	RQ234346	PLANNED	OCC_587	TAPS12	220KV-TARAPUR 1&2-BORIVALI-1	C	1) TAPS 1&2, 220kV Zone-II main bus outages to carry out annual maintenance of main bus and bay's equipments. 2) Remarks: During outage period BS#1 between 220 KV Zone-1 & Zone-II will remain open from 0800 hrs of 10/02/2025 to 1800 hrs of 15/02/2025.	10/Feb/2025	08:00	15/Feb/2025	18:00	subject to no other outages at Borivali
229	RQ234345	PLANNED	OCC_587	TAPS12	220KV-TARAPUR 1&2-VAPI-1	C	1) TAPS 1&2, 220kV Zone-II main bus outages to carry out annual maintenance of main bus and bay's equipments. 2) Remarks: During outage period BS#1 between 220 KV Zone-1 & Zone-II will remain open from 0800 hrs of 10/02/2025 to 1800 hrs of 15/02/2025	10/Feb/2025	08:00	15/Feb/2025	18:00	no rep
230	RQ233946	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	For replacement of SSN Insulator String into DSN Insulator String along with Hardwares at various Road/River/Nala/Canal crossing locations.	10/Feb/2025	08:00	10/Feb/2025	18:00	
231	RQ232584	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-BADNERA-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	10/Feb/2025	08:00	10/Feb/2025	20:00	
232	RQ233343	PLANNED	OCC_587	POWERGRID_WR1	400KV-BHILAI-KORADI-1	C	For Construction Work of 400 KV D/C (QUAD) RAIPUR POOL - DHAMTARI TRANSMISSION LINE	10/Feb/2025	08:00	11/Feb/2025	18:00	
233	RQ234296	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	10/Feb/2025	08:00	10/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continous	Reason	From Date	From Time	To Date	To Time	Remarks
234	RQ234324	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	10/Feb/2025	08:00	10/Feb/2025	18:00	
235	RQ232472	PLANNED	OCC_587	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-1	D	Line Bay AMP work	10/Feb/2025	08:00	10/Feb/2025	18:00	
236	RQ233859	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	10/Feb/2025	08:00	10/Feb/2025	18:00	
237	RQ234495	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM P5-1	D	AR disable require for replacement of earth wire with OPGW	10/Feb/2025	08:00	10/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
238	RQ234505	PLANNED	OCC_587	MEGPTCL	400KV-PARLI-KALLAM P5-2	D	AR disable require for replacement of earth wire with OPGW	10/Feb/2025	08:00	10/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
239	RQ234069	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID Testing Work	10/Feb/2025	09:00	10/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
240	RQ234084	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID testing	10/Feb/2025	09:00	10/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
241	RQ233754	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	10/Feb/2025	08:00	10/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
242	RQ233782	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	10/Feb/2025	08:00	10/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
243	RQ233945	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	C	Chemical Washing work & Cold washing work	10/Feb/2025	06:00	14/Feb/2025	18:00	
244	RQ234157	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	10/Feb/2025	07:00	10/Feb/2025	18:00	
245	RQ234929	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCL	10/Feb/2025	07:00	10/Feb/2025	19:00	
246	RQ233490	PLANNED	OCC_587	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	10/Feb/2025	07:00	10/Feb/2025	18:00	
247	RQ232506	PLANNED	OCC_587	POWERGRID_WR1	765KV-AURANGABAD-SOLAPUR-2 L/R@ AURANGABAD - 765KV	D	AMP Work	10/Feb/2025	08:00	10/Feb/2025	18:00	
248	RQ233482	PLANNED	OCC_587	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	10/Feb/2025	07:00	10/Feb/2025	18:00	
249	RQ233947	PLANNED	OCC_587	MSLDC_OUTAGE	MAHALAXMI(KONALKATTA) - 220KV - BUS 1	D	For Bus Insulator washing and Isolator Maintenance.	10/Feb/2025	09:00	10/Feb/2025	17:00	
250	RQ233443	PLANNED	OCC_587	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)- EKTUNI-2 AND AKOLA - 765KV - BUS 1 at AKOLA (2) - 765KV	D	Annual Maintenance of Bay Equipment at Akola-II SS.	10/Feb/2025	09:00	10/Feb/2025	18:00	
251	RQ233357	PLANNED	OCC_587	MEGPTCL	MAIN BAY - KORADI-III - 765KV B/R 1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	10/Feb/2025	09:00	10/Feb/2025	18:00	
252	RQ235117	PLANNED	OCC_587	POWERGRID_WR2	MAIN BAY OF 220KV-BOISAR-BOISAR-M-3 AND BOISAR - 220KV - BUS 1 @BOISAR - 220KV at BOISAR - 220KV	D	BAY AMP WORK	10/Feb/2025	09:00	10/Feb/2025	17:30	
253	RQ234446	PLANNED	OCC_587	RGPPL	MAIN BAY OF 400KV/15.7KV RGPPL-GT-3A AND RGPPL - 400KV - BUS 2 @RGPPL - 400KV at RGPPL - 400KV	C	ATTENDING SF6 LEAKAGE	10/Feb/2025	09:00	11/Feb/2025	20:00	
254	RQ234965	PLANNED	OCC_587	MSLDC_OUTAGE	MAIN BAY OF 400KV-WARORA-CHANDRAPU-II-1 AND WARORA - 400KV - BUS 2 @WARORA - 400KV at WARORA - 400KV	C	Mechanism overhauling Work. of CB DCRM/CRM/Timing, CT C & Tan Delta work to be carried out.	10/Feb/2025	09:00	14/Feb/2025	18:00	
255	RQ234347	PLANNED	OCC_587	TAPS12	TARAPUR 1&2 - 220KV - BUS 2	C	1) TAPS 1&2, 220KV Zone-II main bus outages to carry out annual maintenance of main bus and bay's equipments. 2) Remarks: i) During outage period BS#1 between 220 KV Zone-1 & Zone-II will remain open from 0800 hrs of 10/02/2025 to 1800 hrs of 15/02/2025. ii) During outage period 220KV-TARAPUR 1&2-VAPI-1 and 220KV-TARAPUR 1&2-BORIVALI-1 will remain out.	10/Feb/2025	08:00	15/Feb/2025	18:00	no rep
256	RQ234042	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	11/Feb/2025	09:00	11/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continous	Reason	From Date	From Time	To Date	To Time	Remarks
257	RQ234100	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	11/Feb/2025	09:00	11/Feb/2025	17:30	
258	RQ234128	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	11/Feb/2025	09:00	11/Feb/2025	17:30	
259	RQ233949	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-WARDHA-BHUGAON-1	D	Routine line maintenance work	11/Feb/2025	08:00	11/Feb/2025	18:00	
260	RQ235128	PLANNED	OCC_587	POWERGRID_WR2	400KV/220KV BOISAR-ICT-2	D	For 220kV Busbar PU/LBB relay retrofitting	11/Feb/2025	07:00	11/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
261	RQ232554	PLANNED	OCC_587	POWERGRID_WR1	400KV-BHILAI-KORADI-1	D	For Amp of Line Bay & Reactor Bay	11/Feb/2025	08:00	11/Feb/2025	20:00	
262	RQ234297	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	11/Feb/2025	08:00	11/Feb/2025	18:00	
263	RQ234325	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	11/Feb/2025	08:00	11/Feb/2025	18:00	
264	RQ233860	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	11/Feb/2025	08:00	11/Feb/2025	18:00	
265	RQ234070	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID Testing Work	11/Feb/2025	09:00	11/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
266	RQ234071	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	D	PID Testing Work	12/Feb/2025	09:01	12/Feb/2025	18:01	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
267	RQ233755	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	11/Feb/2025	08:00	11/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
268	RQ233756	PLANNED	OCC_588	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	12/Feb/2025	08:01	12/Feb/2025	18:01	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
269	RQ234158	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	11/Feb/2025	07:00	11/Feb/2025	18:00	
270	RQ234930	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCL	11/Feb/2025	07:00	11/Feb/2025	19:00	
271	RQ233491	PLANNED	OCC_587	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	11/Feb/2025	07:00	11/Feb/2025	18:00	
272	RQ233483	PLANNED	OCC_587	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	11/Feb/2025	07:00	11/Feb/2025	18:00	
273	RQ232668	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 220KV-TALEGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	D	FOR AMP WORK	11/Feb/2025	09:00	11/Feb/2025	17:00	
274	RQ234966	PLANNED	OCC_587	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	11/Feb/2025	09:00	11/Feb/2025	17:00	
275	RQ233953	PLANNED	OCC_587	MSLDC_OUTAGE	132KV-MANSAR-MS-KANHAN-1	D	For routine maintenance work	12/Feb/2025	09:00	12/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continous	Reason	From Date	From Time	To Date	To Time	Remarks
276	RQ233955	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	D	Maintenance work	12/Feb/2025	09:00	12/Feb/2025	18:00	
277	RQ234043	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	12/Feb/2025	09:00	12/Feb/2025	18:00	
278	RQ233954	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	LINE/ s/s maintenance	12/Feb/2025	09:00	12/Feb/2025	17:30	
279	RQ234101	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	12/Feb/2025	09:00	12/Feb/2025	17:30	
280	RQ234129	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	12/Feb/2025	09:00	12/Feb/2025	17:30	
281	RQ233952	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	Routine line maintenance work	12/Feb/2025	08:00	12/Feb/2025	18:00	
282	RQ232586	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	12/Feb/2025	08:00	12/Feb/2025	20:00	
283	RQ233460	PLANNED	OCC_587	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-1	D	LBB ABB/RAICA Model relay will be upgraded to Numerical relay under technology upgradation AT MSETCL END	12/Feb/2025	09:00	12/Feb/2025	18:00	
284	RQ234298	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	12/Feb/2025	08:00	12/Feb/2025	18:00	
285	RQ234326	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	12/Feb/2025	08:00	12/Feb/2025	18:00	
286	RQ232556	PLANNED	OCC_587	POWERGRID_WR1	400KV-KORADI-SATPURA-1	D	For AMP of Line Bay	12/Feb/2025	08:00	12/Feb/2025	20:00	
287	RQ233861	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	12/Feb/2025	08:00	12/Feb/2025	18:00	
288	RQ234071	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID Testing Work	12/Feb/2025	09:00	12/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
289	RQ234072	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID Testing Work	13/Feb/2025	09:01	13/Feb/2025	18:01	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
290	RQ233950	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-SOLAPUR-M-1	D	Hardware tightening and cold line washing	12/Feb/2025	09:00	12/Feb/2025	18:00	
291	RQ233756	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	12/Feb/2025	08:00	12/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
292	RQ233784	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	12/Feb/2025	08:00	12/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
293	RQ234159	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	12/Feb/2025	07:00	12/Feb/2025	18:00	
294	RQ234444	PLANNED	OCC_587	TAPS34	400KV-TARAPUR 3&4-BOISAR-2	C	LINE PM AT TAPS 3 AND 4 END	12/Feb/2025	08:00	14/Feb/2025	18:00	subjet to no other parallel outages in boisar PG/ subject to no other critical outages
295	RQ234931	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCIL	12/Feb/2025	07:00	12/Feb/2025	19:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continguous	Reason	From Date	From Time	To Date	To Time	Remarks
296	RQ233293	PLANNED	OCC_587	POWERGRID_WR1	765KV/400KV PADGHE-PG-ICT-1	D	Spare Changoover of ICT, Taking Rph OUT of service & Spare IN Service & Fine tuning of CSD of ICT	12/Feb/2025	09:00	12/Feb/2025	18:00	
297	RQ233492	PLANNED	OCC_587	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	12/Feb/2025	07:00	12/Feb/2025	18:00	
298	RQ233484	PLANNED	OCC_587	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	12/Feb/2025	07:00	12/Feb/2025	18:00	
299	RQ232539	PLANNED	OCC_587	MEGPTCL	765KV-SASAN-VINDHYACHAL(PS)-2	D	As per annual maintenance schedule of 765kv S/c Sasan-Vindhyachal	12/Feb/2025	09:00	12/Feb/2025	17:00	
300	RQ235454	PLANNED	OCC_587	POWERGRID_WR2	BOISAR - 220KV - BUS 1	C	Continuous outage of 220kV Bus-1 for Bus-bar relay retrofitting & testing	12/Feb/2025	07:00	18/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
301	RQ233951	PLANNED	OCC_587	MSLDC_OUTAGE	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	12/Feb/2025	09:00	12/Feb/2025	17:00	
302	RQ233441	PLANNED	OCC_587	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	12/Feb/2025	09:00	12/Feb/2025	18:00	
303	RQ234459	PLANNED	OCC_587	RGPPL	MAIN BAY OF 400KV/11.9KV RGPPL-ST-2 AND RGPPL - 400KV - BUS 2 @ RGPPL - 400KV at RGPPL - 400KV	C	ATTENDING SF6 LEAKAGE	12/Feb/2025	09:00	13/Feb/2025	20:00	
304	RQ232535	PLANNED	OCC_587	MEGPTCL	MORENA - 400KV - BUS 1	D	ANNUAL MAINTENANCE WORKS	12/Feb/2025	10:00	12/Feb/2025	18:00	
305	RQ232339	PLANNED	OCC_587	POWERGRID_WR1	SOLAPUR - 220KV - BUS 1	D	AMP work Note Before shutdown All the elements connected with 220kV Bus1 shall be shifted to 220kV Bus2 Note 2 Each element shall be shifted to TBC one by one for maintenance of Bus1 isolators	12/Feb/2025	07:00	12/Feb/2025	18:00	
306	RQ233444	PLANNED	OCC_587	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA (2) - 765KV	D	Annual Maintenance of Bay Equipment at Akola-II SS.	12/Feb/2025	09:00	12/Feb/2025	18:00	
307	RQ235130	PLANNED	OCC_587	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-1	D	Simultaneous outage of 220kV Bus-1 and line for busbar relay retrofitting and testing	13/Feb/2025	07:00	13/Feb/2025	21:00	At 220 kV Boisar M, 16-28 maharashtra outages/ 1-15 Powergrid outages/ either night hour/no other outages at boisar/At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
308	RQ233957	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-NASIK-NAVSARI-1	C	1. LILO connection on 220kV Eklhare-Navsari line ckt-1 for CPRI S/s 2. PLCC re-arrangement/re-turrning from Eklhare navsari into Eklhare CPRI-Navsari setup. 3. Setting up Modem on PLCC for shifting of SCADA from cPRI to Navsari (remote) substation thru PLCC 4. And Charging of CPRI S/s Bus	13/Feb/2025	09:00	19/Feb/2025	19:00	
309	RQ234044	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	13/Feb/2025	09:00	13/Feb/2025	18:00	
310	RQ234102	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	13/Feb/2025	09:00	13/Feb/2025	17:30	
311	RQ234130	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	13/Feb/2025	09:00	13/Feb/2025	17:30	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continous	Reason	From Date	From Time	To Date	To Time	Remarks
312	RQ233959	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-WARDHA-PUSAD-1	D	ORC WORK -Diversion of 220KV Deoli PG-Pusad line at loc 250-251 due to four lanning of NH-361 (Butibori-Tuljapur)-shifting of line from ERS to newly erected tower thereof.	13/Feb/2025	08:00	13/Feb/2025	18:00	
313	RQ233961	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-WARDHA-WARDHA-M-1	D	Routine line maintainance work	13/Feb/2025	08:00	13/Feb/2025	18:00	
314	RQ233461	PLANNED	OCC_587	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-2	D	LBB ABB/RAICA Model relay will be upgraded to Numerical relay under technology upgradation AT MSETCL END	13/Feb/2025	09:00	13/Feb/2025	18:00	
315	RQ234299	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	13/Feb/2025	08:00	13/Feb/2025	18:00	
316	RQ234327	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	13/Feb/2025	08:00	13/Feb/2025	18:00	
317	RQ232473	PLANNED	OCC_587	POWERGRID_WR1	400KV-KOLHAPUR-MS-KOLHAPUR GIS-2	D	Line Bay AMP work	13/Feb/2025	08:00	13/Feb/2025	18:00	
318	RQ234542	PLANNED	OCC_587	POWERGRID_WR2	400KV-MAGARWADA-BOISAR-1	D	attending S/D nature defect in line, Line Terminal Equipment AMP works,A/R off of ckt 2 is required. Dia to be kept open at both ends.	13/Feb/2025	07:00	13/Feb/2025	18:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
319	RQ233862	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	13/Feb/2025	08:00	13/Feb/2025	18:00	
320	RQ234072	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID Testing Work	13/Feb/2025	09:00	13/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
321	RQ234087	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-1	D	PID testing	13/Feb/2025	09:00	13/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
322	RQ234088	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-PARLI-M-KARIAT-2	D	PID testing	14/Feb/2025	09:01	14/Feb/2025	17:01	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
323	RQ233757	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	13/Feb/2025	08:00	13/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
324	RQ233785	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	13/Feb/2025	08:00	13/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
325	RQ234160	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	13/Feb/2025	07:00	13/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continous	Reason	From Date	From Time	To Date	To Time	Remarks
326	RQ234932	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCL	13/Feb/2025	07:00	13/Feb/2025	19:00	
327	RQ233980	PLANNED	OCC_587	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-1	D	Diagnostic Testing and Routine Maintenance Works	13/Feb/2025	16:00	13/Feb/2025	23:00	
328	RQ233295	PLANNED	OCC_587	POWERGRID_WR1	765KV/400KV PADGHE-PG-ICT-3	C	Attending Punch point of ICT#3 by M/s BHEL & M/s KEC	13/Feb/2025	09:00	14/Feb/2025	18:00	
329	RQ233493	PLANNED	OCC_587	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	13/Feb/2025	07:00	13/Feb/2025	18:00	
330	RQ233485	PLANNED	OCC_587	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	13/Feb/2025	07:00	13/Feb/2025	18:00	
331	RQ233609	PLANNED	OCC_587	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	Tie bay LBB testing	13/Feb/2025	06:00	13/Feb/2025	20:00	
332	RQ233962	PLANNED	OCC_587	MSLDC_OUTAGE	CHAKAN - 400KV - BUS 2	D	Routine Maintenance and DT	13/Feb/2025	00:00	13/Feb/2025	18:00	
333	RQ233973	PLANNED	OCC_587	MSLDC_OUTAGE	MAIN BAY - 765KV/400KV EKTUNI-ICT-1 AND EKTUNI - 765KV - BUS 2 at EKTUNI - 765KV	D	Diagnostic Testing and Routine Maintenance Works	13/Feb/2025	10:00	13/Feb/2025	18:00	
334	RQ233445	PLANNED	OCC_587	MEGPTCL	MAIN BAY OF 765KV-AKOLA (2)-KORADI-III-2 AND AKOLA (2) - 765KV - BUS 2 at AKOLA (2) - 765KV	D	Annual Maintenance of Bay Equipment at Akola-II SS.	13/Feb/2025	09:00	13/Feb/2025	18:00	
335	RQ233960	PLANNED	OCC_587	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	D	Routine Maintenance & Dignostic testing work .	13/Feb/2025	09:00	13/Feb/2025	17:00	
336	RQ235132	PLANNED	OCC_587	POWERGRID_WR2	220KV-BOISAR-BORIVALI-1	D	Simultaneous outage of 220KV Bus-1 and line for busbar relay retrofitting and testing	14/Feb/2025	07:00	14/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
337	RQ234045	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	14/Feb/2025	09:00	14/Feb/2025	18:00	
338	RQ234103	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	14/Feb/2025	09:00	14/Feb/2025	17:30	
339	RQ234131	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	14/Feb/2025	09:00	14/Feb/2025	17:30	
340	RQ233963	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-WARDHA-BADNERA-1	D	Routine line maintainance work	14/Feb/2025	08:00	14/Feb/2025	18:00	
341	RQ232588	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	14/Feb/2025	08:00	14/Feb/2025	20:00	
342	RQ235131	PLANNED	OCC_587	POWERGRID_WR2	400KV/220KV BOISAR-ICT-3	D	Simultaneous outage of 220KV Bus-1 and ICT-1 for busbar relay retrofitting and testing	14/Feb/2025	07:00	14/Feb/2025	21:00	on weekends/ if feasible/nigh hour/ dahanu unit outage is also planned/ separate meeting. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
343	RQ235133	PLANNED	OCC_587	POWERGRID_WR2	400KV-AURANGABAD-BOISAR-2	D	Insulator replacement works, A/R off of ckt 1 is required. Dia to be kept open at both ends.	14/Feb/2025	07:00	14/Feb/2025	18:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
344	RQ233458	PLANNED	OCC_587	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-3	D	LBB ABB/RAICA Model relay will be upgraded to Numerical relay under technology upgradation AT MSETCL END	14/Feb/2025	09:00	14/Feb/2025	18:00	
345	RQ234300	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	14/Feb/2025	08:00	14/Feb/2025	18:00	
346	RQ234328	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	14/Feb/2025	08:00	14/Feb/2025	18:00	
347	RQ233863	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	14/Feb/2025	08:00	14/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continous	Reason	From Date	From Time	To Date	To Time	Remarks
348	RQ234073	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID Testing Work	14/Feb/2025	09:00	14/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhhand-II-Lonikhhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
349	RQ234088	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-1	D	PID testing	14/Feb/2025	09:00	14/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhhand-II-Lonikhhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
350	RQ233614	PLANNED	OCC_587	POWERGRID_WR1	400KV-PUNE-GIS-PARLI-1	D	Kallam I Line Reactor AMP works	14/Feb/2025	09:00	14/Feb/2025	18:00	
351	RQ233758	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	14/Feb/2025	08:00	14/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhhand-II-Lonikhhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
352	RQ233786	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	14/Feb/2025	08:00	14/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhhand-II-Lonikhhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
353	RQ234161	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	14/Feb/2025	07:00	14/Feb/2025	18:00	
354	RQ234933	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCL	14/Feb/2025	07:00	14/Feb/2025	19:00	
355	RQ233494	PLANNED	OCC_587	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	14/Feb/2025	07:00	14/Feb/2025	18:00	
356	RQ233486	PLANNED	OCC_587	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	14/Feb/2025	07:00	14/Feb/2025	18:00	
357	RQ234968	PLANNED	OCC_587	MSLDC_OUTAGE	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-1	D	For testing of Reactive Power Control in compliance to Clause 28(3) & 28 (4) and in accordance with clause 40 of the Indian Electricity Grid Code, 2023 notified by the Central Electricity Regulatory Commission	14/Feb/2025	08:00	14/Feb/2025	17:00	
358	RQ234967	PLANNED	OCC_587	MSLDC_OUTAGE	MAIN BAY - EKTUNI - 765KV B/R 1 AND EKTUNI - 765KV - BUS 1 at EKTUNI - 765KV	D	Diagnostic Testing and Routine Maintenance Works	14/Feb/2025	10:00	14/Feb/2025	18:00	
359	RQ232536	PLANNED	OCC_587	MEGPTCL	MORENA - 400KV - BUS 2	D	ANNUAL MAINTENANCE WORKS	14/Feb/2025	10:00	14/Feb/2025	18:00	
360	RQ233967	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-2	D	For safety purpose during Installation of Saver Assembly at various Locations of 220KV PGCL - Panchali Line.	15/Feb/2025	05:00	15/Feb/2025	09:00	Line bay shifting work> installation of saver assembly> maintenance. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continous	Reason	From Date	From Time	To Date	To Time	Remarks
361	RQ235135	PLANNED	OCC_587	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-3	D	Simultaneous outage of 220KV Bus-1 and line for busbar relay retrofitting and testing	15/Feb/2025	07:00	15/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
362	RQ233969	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	For chemical cleaning of disc insulator strings at TL No. 185, 186, 191, 192, 196, 197, 198, 199, 200, 201, 208, 214, 220 & 221.	15/Feb/2025	09:00	15/Feb/2025	18:00	Line bay shifting work> installation of saver assembly> maintenance. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
363	RQ233968	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	Installation of Saver Assembly at various Locations.	15/Feb/2025	05:00	15/Feb/2025	09:00	Line bay shifting work> installation of saver assembly> maintenance. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
364	RQ234046	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	15/Feb/2025	09:00	15/Feb/2025	18:00	
365	RQ234104	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	15/Feb/2025	09:00	15/Feb/2025	17:30	
366	RQ234132	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	15/Feb/2025	09:00	15/Feb/2025	17:30	
367	RQ234948	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-TARAPUR 1&2-BORIVALI-1	D	For chemical cleaning of disc insulator strings at TL No. 185, 186, 191, 192, 196, 197, 198, 199, 200, 201, 208, 214, 220 & 221.	15/Feb/2025	09:00	15/Feb/2025	18:00	
368	RQ232589	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	15/Feb/2025	08:00	15/Feb/2025	20:00	
369	RQ233617	PLANNED	OCC_587	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	C	Outdoor GIB erection	15/Feb/2025	06:00	16/Feb/2025	20:00	
370	RQ233459	PLANNED	OCC_587	POWERGRID_WR1	400KV-CHANDRAPUR-BHADRAWATI-4	D	LBB ABB/RAICA Model relay will be upgraded to Numerical relay under under technology upgradation AT MSETCL END	15/Feb/2025	09:00	15/Feb/2025	18:00	
371	RQ234301	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	15/Feb/2025	08:00	15/Feb/2025	18:00	
372	RQ234329	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	15/Feb/2025	08:00	15/Feb/2025	18:00	
373	RQ234543	PLANNED	OCC_587	POWERGRID_WR2	400KV-MAGARWADA-BOISAR-2	D	attending S/D nature defect in line, Line Terminal Equipment AMP works,A/R off of ckt 1 is required. Dia to be kept open at both ends.	15/Feb/2025	07:00	15/Feb/2025	18:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
374	RQ233864	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	15/Feb/2025	08:00	15/Feb/2025	18:00	
375	RQ234074	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID Testing Work	15/Feb/2025	09:00	15/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
376	RQ234089	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	D	PID testing	15/Feb/2025	09:00	15/Feb/2025	17:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
377	RQ233616	PLANNED	OCC_587	POWERGRID_WR1	400KV-PUNE-GIS-PARLI-2	D	Kallam II Line Reactor AMP works	15/Feb/2025	09:00	15/Feb/2025	18:00	
378	RQ233759	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	15/Feb/2025	08:00	15/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
379	RQ233787	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	15/Feb/2025	08:00	15/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
380	RQ234934	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCL	15/Feb/2025	07:00	15/Feb/2025	19:00	
381	RQ233495	PLANNED	OCC_587	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	15/Feb/2025	07:00	15/Feb/2025	18:00	
382	RQ233288	PLANNED	OCC_587	POWERGRID_WR1	765KV-AURANGABAD-PADGHE-PG-2	C	Diversion of 765 KV Aurangabad Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)	15/Feb/2025	09:00	28/Feb/2025	18:00	
383	RQ233289	PLANNED	OCC_587	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	C	Diversion of 765 KV Pune Padghe Line for Nagpur Mumbai Samridhi Express Highway. (New construction works)	15/Feb/2025	09:00	28/Feb/2025	18:00	parallel outages will be rescheduled/
384	RQ233487	PLANNED	OCC_587	POWERGRID_WR1	765KV-PUNE-GIS-PADGHE-PG-1	D	AUTO RECLOSE IN NON-AUTO MODE FOR OPGW ERECTION WORKS	15/Feb/2025	07:00	15/Feb/2025	18:00	
385	RQ233964	PLANNED	OCC_587	MSLDC_OUTAGE	BHUSAWAL - 400KV - BUS 1	D	For diagnostic testing work of CVT	15/Feb/2025	06:00	15/Feb/2025	18:00	
386	RQ233966	PLANNED	OCC_587	MSLDC_OUTAGE	BOISAR-M - 220KV - BUS 1	C	220kV A-Bus Isolator R/M Works.	15/Feb/2025	07:00	16/Feb/2025	20:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
387	RQ234969	PLANNED	OCC_587	MSLDC_OUTAGE	HVDC500KV-CHANDRAPUR HVDC-PADGHE HVDC-2	D	For testing of Reactive Power Control as per Clause 28(3) & 28 (4) and in accordance with clause 40 of the Indian Electricity Grid Code, 2023 notified by the Central Electricity Regulatory Commission	15/Feb/2025	08:00	15/Feb/2025	17:00	
388	RQ233618	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 AND PUNE-GIS - 400KV - BUS 1 at Pune-GIS - 400KV	C	Outdoor GIB erection	15/Feb/2025	06:00	16/Feb/2025	20:00	
389	RQ232672	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 400KV-LONIKHAND-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	CB Testing	15/Feb/2025	09:00	15/Feb/2025	17:00	
390	RQ233303	PLANNED	OCC_587	POWERGRID_WR1	PADGHE-PG - 765KV - BUS 1	C	For Conducting Impulse Test on Extended Main Bus without link connection.	15/Feb/2025	09:00	16/Feb/2025	18:00	
391	RQ233956	PLANNED	OCC_587	MSLDC_OUTAGE	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at WARORA - 400KV	D	CB DCRM/CRM/Timing , CT C & Tan Delta work to be carried out.	15/Feb/2025	08:00	15/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
392	RQ233379	PLANNED	OCC_587	MEGPTCL	TIE BAY -765KV-AKOLA (2)-KORADI-III-2 AND 765KV-TIRODA-KORADI-III-1 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	15/Feb/2025	09:00	15/Feb/2025	18:00	
393	RQ233965	PLANNED	OCC_587	MSLDC_OUTAGE	TIE BAY OF 400KV-TIRODA-WARORA-2 AND 400KV-WARORA-CHANDRAPU-II-2 @WARORA - 400KV at WARORA - 400KV	D	CB DCRM/CRM/Timing, CT C & Tan Delta work to be carried out.	15/Feb/2025	09:00	15/Feb/2025	17:00	
394	RQ235190	PLANNED	OCC_587	POWERGRID_WR2	220KV-BOISAR-BOISAR-M-2	D	Simultaneous outage of 220KV Bus-1 and line for busbar relay retrofitting and testing	16/Feb/2025	07:00	16/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
395	RQ233971	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-BOISAR-BOISAR-M-3	D	Bay Maintenance & Equipment Testing.	16/Feb/2025	06:00	16/Feb/2025	19:00	Line bay shifting work> installation of saver assembly> maintenance. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
396	RQ233972	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-BOISAR-BORIVALI-1	D	For safety purpose during Installation of Saver Assembly at various Locations on 220kv Tarapur - Boisar Line.	16/Feb/2025	10:00	16/Feb/2025	18:00	Line bay shifting work> installation of saver assembly> maintenance. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
397	RQ233970	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-BOISAR-PANCHALI-1	D	Bus Maintenance and Diagnostic Testing.	16/Feb/2025	09:00	16/Feb/2025	15:00	Line bay shifting work> installation of saver assembly> maintenance. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
398	RQ234047	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	16/Feb/2025	09:00	16/Feb/2025	18:00	
399	RQ234105	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	16/Feb/2025	09:00	16/Feb/2025	17:30	
400	RQ234133	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	16/Feb/2025	09:00	16/Feb/2025	17:30	
401	RQ234949	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-TARAPUR 3&4-BOISAR-1	D	Installation of Saver Assembly at various Locations.	16/Feb/2025	10:00	16/Feb/2025	18:00	Line bay shifting work> installation of saver assembly> maintenance. At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
402	RQ232590	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	16/Feb/2025	08:00	16/Feb/2025	20:00	
403	RQ235136	PLANNED	OCC_587	POWERGRID_WR2	400KV/220KV BOISAR-ICT-4	D	Simultaneous outage of 220KV Bus-1 and ICT-1 for busbar relay retrofitting and testing	16/Feb/2025	07:00	16/Feb/2025	21:00	on weekends/ if feasible/night hour/ At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
404	RQ234162	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing Work	16/Feb/2025	08:00	16/Feb/2025	18:00	
405	RQ234302	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	16/Feb/2025	08:00	16/Feb/2025	18:00	
406	RQ234330	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	16/Feb/2025	08:00	16/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
407	RQ233865	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	16/Feb/2025	08:00	16/Feb/2025	18:00	
408	RQ233760	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	16/Feb/2025	08:00	16/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kv Parli- M- Karjat- Lonikhand-II- Lonikhand corridor/B. 400 kv Parli- PG- Kallam- Pune GIS corridor/C. 400 kv Pune - Pune lines) subject to no other outages in parallel.
409	RQ233788	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	16/Feb/2025	08:00	16/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kv Parli- M- Karjat- Lonikhand-II- Lonikhand corridor/B. 400 kv Parli- PG- Kallam- Pune GIS corridor/C. 400 kv Pune - Pune lines) subject to no other outages in parallel.
410	RQ234935	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCIL	16/Feb/2025	07:00	16/Feb/2025	19:00	
411	RQ234970	PLANNED	OCC_587	MSLDC_OUTAGE	HVDC500KV-CHANDRAPUR HVDC- PADGHE HVDC-1	D	For testing of Reactive Power Control as per Clause 28(3) & 28 (4) and in accordance with clause 40 of the Indian Electricity Grid Code, 2023 notified by the Central Electricity Regulatory Commission	16/Feb/2025	08:00	16/Feb/2025	17:00	
412	RQ234971	PLANNED	OCC_587	MSLDC_OUTAGE	HVDC500KV-CHANDRAPUR HVDC- PADGHE HVDC-2	D	For testing of Reactive Power Control as per Clause 28(3) & 28 (4) and in accordance with clause 40 of the Indian Electricity Grid Code, 2023 notified by the Central Electricity Regulatory Commission	16/Feb/2025	08:00	16/Feb/2025	17:00	
413	RQ233976	PLANNED	OCC_587	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode	17/Feb/2025	08:00	17/Feb/2025	18:00	
414	RQ235192	PLANNED	OCC_587	POWERGRID_WR2	220KV-BOISAR-PANCHALI-1	D	Simultaneous outage of 220KV Bus-1 and line for busbar relay retrofitting and testing	17/Feb/2025	07:00	17/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
415	RQ233978	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-MUDSHINGI-CHIKKODI-II-1	D	Maintenance work	17/Feb/2025	09:00	17/Feb/2025	18:00	
416	RQ234048	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	17/Feb/2025	09:00	17/Feb/2025	18:00	
417	RQ234106	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	17/Feb/2025	09:00	17/Feb/2025	17:30	
418	RQ234134	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	17/Feb/2025	09:00	17/Feb/2025	17:30	
419	RQ235193	PLANNED	OCC_587	POWERGRID_WR2	220KV-TARAPUR 3&4-BOISAR-1	D	Simultaneous outage of 220KV Bus-1 and line for busbar relay retrofitting and testing	17/Feb/2025	07:00	17/Feb/2025	21:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
420	RQ232591	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-WARDHA-M-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	17/Feb/2025	08:00	17/Feb/2025	20:00	
421	RQ233619	PLANNED	OCC_587	POWERGRID_WR1	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	C	Outdoor GIB erection	17/Feb/2025	06:00	18/Feb/2025	20:00	
422	RQ234163	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing Work	17/Feb/2025	08:00	17/Feb/2025	18:00	
423	RQ234303	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	17/Feb/2025	08:00	17/Feb/2025	18:00	
424	RQ234331	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	17/Feb/2025	08:00	17/Feb/2025	18:00	
425	RQ233567	PLANNED	OCC_587	POWERGRID_WR1	400KV-KOLHAPUR GIS-MAPUSA-1	D	AMP	17/Feb/2025	08:00	17/Feb/2025	18:00	
426	RQ232474	PLANNED	OCC_587	POWERGRID_WR1	400KV-KOLHAPUR-MS-ALKUD-1	D	Line Bay AMP works	17/Feb/2025	08:00	17/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continous	Reason	From Date	From Time	To Date	To Time	Remarks
427	RQ233299	PLANNED	OCC_587	POWERGRID_WR1	400KV-PADGHE-BOISAR-1	C	Retrofitting and Testing of Numerical LBB Protection	17/Feb/2025	09:00	17/Feb/2025	18:00	At Boisar, Powergrid to avail outages from 1 to 15 and MSLDC to avail outages on 16 to 28. /to be planned in night hour.
428	RQ233866	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	17/Feb/2025	08:00	17/Feb/2025	18:00	
429	RQ233974	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARIJAT-1	C	(1) Reactor tesing work. (2) Bay maintenance work.3) Hardware tightening & fitting work	17/Feb/2025	20:00	18/Feb/2025	05:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
430	RQ233761	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	17/Feb/2025	08:00	17/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
431	RQ233622	PLANNED	OCC_587	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-3	C	For attending SF6 Gas leakage work	17/Feb/2025	06:00	19/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
432	RQ233789	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	17/Feb/2025	08:00	17/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
433	RQ234175	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	17/Feb/2025	07:00	17/Feb/2025	18:00	
434	RQ233975	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NEW KOYNA-2	C	Chemical Washing work, Cold washing work & Diagnostic testing & Relay testing work , Routine maint. Work. A/R scheme will be introduce. Insulator replacement.	17/Feb/2025	06:00	21/Feb/2025	18:00	
435	RQ234936	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCL	17/Feb/2025	07:00	17/Feb/2025	19:00	
436	RQ234950	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	17/Feb/2025	09:00	17/Feb/2025	18:00	Priority
437	RQ233446	PLANNED	OCC_587	MEGPTCL	AKOLA (2) - 765KV - BUS 2	D	Annual Maintenance of Bus Equipment at Akola-II SS.	17/Feb/2025	09:00	17/Feb/2025	18:00	
438	RQ233979	PLANNED	OCC_587	MSLDC_OUTAGE	BABLESHWAR - 400KV - BUS 1	D	CVT Tandelta testing work	17/Feb/2025	08:00	17/Feb/2025	18:00	
439	RQ233977	PLANNED	OCC_587	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 2	D	1) Maintenance of isolator of all feeders connected to Main Bus 2	17/Feb/2025	10:00	17/Feb/2025	17:00	
440	RQ233620	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 AND PUNE-GIS - 400KV - BUS 1 at Pune-GIS - 400KV	C	Outdoor GIB erection	17/Feb/2025	06:00	18/Feb/2025	20:00	
441	RQ233621	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-3 AND PUNE-GIS - 400KV - BUS 1 at Pune-GIS - 400KV	C	For attending SF6 Gas leakage work	17/Feb/2025	06:00	19/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Contino us	Reason	From Date	From Time	To Date	To Time	Remarks
442	RQ233380	PLANNED	OCC_587	MEGPTCL	MAIN BAY - 765KV-AKOLA (2)-KORADI-III-2 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	17/Feb/2025	09:00	17/Feb/2025	18:00	
443	RQ233989	PLANNED	OCC_587	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode	18/Feb/2025	08:00	18/Feb/2025	18:00	
444	RQ234049	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	18/Feb/2025	09:00	18/Feb/2025	18:00	
445	RQ234107	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	18/Feb/2025	09:00	18/Feb/2025	17:30	
446	RQ234135	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	18/Feb/2025	09:00	18/Feb/2025	17:30	
447	RQ232562	PLANNED	OCC_587	POWERGRID_WR1	220KV-WARDHA-PUSAD-1	D	AMP of Line Bay & O/H of CB, Line to be shifted on TBC for 7 days	18/Feb/2025	08:00	18/Feb/2025	20:00	
448	RQ233986	PLANNED	OCC_587	MSLDC_OUTAGE	400KV/11.5KV CHANDRAPUR-GCR-ST-4	C	1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 2. Nut Bolts and hardware tightening work.	18/Feb/2025	12:00	19/Feb/2025	12:00	
449	RQ233984	PLANNED	OCC_587	MSLDC_OUTAGE	400KV/21KV CHANDRAPUR-GT-6	C	1. Replacement of old damaged quadraple Bus conductor of '400KV Main Bus-2' in span of 'HVDC CKT-1 to GTR-6' 2. GTR-6 will be in service via TBC-2	18/Feb/2025	04:00	20/Feb/2025	18:00	plan to be submitted by MSLDC
450	RQ234164	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing Work	18/Feb/2025	08:00	18/Feb/2025	18:00	
451	RQ233985	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-1	C	Outage required for Main Bus -2 outage work.	18/Feb/2025	04:00	20/Feb/2025	18:00	plan to be submitted by MSLDC
452	RQ233987	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-CHANDRAPUR-BHADRAWATI-2	C	Outage required for Main Bus -2 outage work.	18/Feb/2025	04:00	20/Feb/2025	18:00	plan to be submitted by MSLDC
453	RQ233988	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	C	1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 3. Nut Bolts and hardware tightening work.	18/Feb/2025	12:00	19/Feb/2025	15:00	To be planned in staggered manner
454	RQ233981	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	C	1. Replacement of old damaged quadraple Bus conductor in span of 'HVDC CKT-1 to GTR-6' 2. Outage is required to disconnect the Bus jumpers and reconnect the same after completion of work. 2. Nut Bolts and hardware tightening work.	18/Feb/2025	12:00	19/Feb/2025	15:00	To be planned in staggered manner
455	RQ234304	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	18/Feb/2025	08:00	18/Feb/2025	18:00	
456	RQ234332	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	18/Feb/2025	08:00	18/Feb/2025	18:00	
457	RQ235281	PLANNED	OCC_587	POWERGRID_WR2	400KV-KORADI-SATPURA-1	C	Line Isolator replacement works under ADD CAP works at Sarni MPPGCL, Dia to be kept open at both ends.	18/Feb/2025	07:00	20/Feb/2025	23:00	
458	RQ233867	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	18/Feb/2025	08:00	18/Feb/2025	18:00	
459	RQ233762	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	18/Feb/2025	08:00	18/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kv Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kv Parli-PG- Kallam- Pune GIS corridor/C. 400 kv Pune - Pune lines) subject to no other outages in parallel.

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
460	RQ233790	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	18/Feb/2025	08:00	18/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
461	RQ234176	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	18/Feb/2025	07:00	18/Feb/2025	18:00	
462	RQ233300	PLANNED	OCC_587	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-1	C	Retrofitting and Testing of Numerical LBB Protection	18/Feb/2025	09:00	18/Feb/2025	18:00	
463	RQ234937	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCL	18/Feb/2025	07:00	18/Feb/2025	19:00	
464	RQ234951	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	18/Feb/2025	09:00	18/Feb/2025	18:00	
465	RQ233982	PLANNED	OCC_587	MSLDC_OUTAGE	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	C	Outage required for Main Bus -2 outage work.	18/Feb/2025	04:00	20/Feb/2025	18:00	
466	RQ233983	PLANNED	OCC_587	MSLDC_OUTAGE	CHANDRAPUR-GCR - 400KV - BUS 2	C	1.Replacement of cable of BUS-2 CVT from CVT MB to Control panel (for measurement of Ex-Bus energy at CSTPS Genco end). 2. Replacement of old damaged quadruple Bus conductor in span of 'HVDC CKT-1 to GTR-6'. 3. Nut Bolts and hardware tightening work. 4.Hardware tightning of Main Bus-2 and Bus CVT.	18/Feb/2025	04:00	20/Feb/2025	18:00	
467	RQ233990	PLANNED	OCC_587	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 2	D	1) Maintenance of isolator of all feeders connected to Main Bus 2	18/Feb/2025	10:00	18/Feb/2025	17:00	
468	RQ232673	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 400KV-KHARGHAR-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 2 at PUNE-PG - 400KV	D	CB Testing	18/Feb/2025	09:00	18/Feb/2025	17:00	
469	RQ234961	PLANNED	OCC_587	MSLDC_OUTAGE	MAIN BAY OF 400KV/220KV BABLESHWAR-ICT-2 AND BABLESHWAR - 400KV - BUS 1 @BABLESHWAR - 400KV at BABLESHWAR - 400KV	C	CB pole overhauling work.400/220 KV ICT II HV will be in service through TBC	18/Feb/2025	08:00	22/Feb/2025	18:00	
470	RQ234962	PLANNED	OCC_587	MSLDC_OUTAGE	MAIN BAY OF 400KV-WARORA-CHANDRAPU-II-2 AND WARORA - 400KV - BUS 2 @WARORA - 400KV at WARORA - 400KV	C	Mechanism overhauling Work. of CB DCRM/CRM/Timing, CT C & Tan Delta work to be carried out.	18/Feb/2025	08:00	22/Feb/2025	18:00	
471	RQ233991	PLANNED	OCC_587	MSLDC_OUTAGE	132KV-DHARNI-NEPANAGAR-1	D	For PID work, Shifting of auto reclose switch to non auto mode	19/Feb/2025	08:00	19/Feb/2025	18:00	
472	RQ233992	PLANNED	OCC_587	MSLDC_OUTAGE	132KV-MANSAR-MS-PENCH-1	D	For routine maintenance work	19/Feb/2025	09:00	19/Feb/2025	18:00	
473	RQ233328	PLANNED	OCC_587	POWERGRID_WR1	220KV-AURANGABAD-CHITEGAON-2	D	AMP Work	19/Feb/2025	08:00	19/Feb/2025	18:00	
474	RQ234050	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	19/Feb/2025	09:00	19/Feb/2025	18:00	
475	RQ234108	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	19/Feb/2025	09:00	19/Feb/2025	17:30	
476	RQ234136	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	19/Feb/2025	09:00	19/Feb/2025	17:30	
477	RQ234165	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing Work	19/Feb/2025	08:00	19/Feb/2025	18:00	
478	RQ234305	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	19/Feb/2025	08:00	19/Feb/2025	18:00	
479	RQ234333	PLANNED	OCC_587	WTPL	400KV-KALLAM PS-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	19/Feb/2025	08:00	19/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/ Continous	Reason	From Date	From Time	To Date	To Time	Remarks
480	RQ233868	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	19/Feb/2025	08:00	19/Feb/2025	18:00	
481	RQ233763	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	19/Feb/2025	08:00	19/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
482	RQ233791	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	19/Feb/2025	08:00	19/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat-Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
483	RQ234177	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	19/Feb/2025	07:00	19/Feb/2025	18:00	
484	RQ233993	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-SOLAPUR-M-SOLAPUR-1	D	Hardware tightening and cold line washing	19/Feb/2025	09:00	19/Feb/2025	18:00	
485	RQ233301	PLANNED	OCC_587	POWERGRID_WR1	400KV-TARAPUR 3&4-PADGHE-2	C	Retrofitting and Testing of Numerical LBB Protection	19/Feb/2025	09:00	19/Feb/2025	18:00	
486	RQ234938	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	96F OPGW work by MTCIL	19/Feb/2025	07:00	19/Feb/2025	19:00	
487	RQ234952	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	19/Feb/2025	09:00	19/Feb/2025	18:00	
488	RQ233381	PLANNED	OCC_587	MEGPTCL	MAIN BAY - 765KV/400KV KORADI-III-ICT-1 AND KORADI-III - 400KV - BUS 1 at KORADI-III - 400KV	D	Annual Maintenance of Bay Equipment at Koradi-III SS.	19/Feb/2025	09:00	19/Feb/2025	18:00	
489	RQ233305	PLANNED	OCC_587	POWERGRID_WR1	PADGHE-PG - 765KV - BUS 2	C	For installation of Connecting Chamber without Link for Extension of Main BUS, HV and PDM Test	19/Feb/2025	09:00	21/Feb/2025	18:00	
490	RQ232674	PLANNED	OCC_587	POWERGRID_WR1	TIE BAY - 400KV-LONIKHAND-PUNE-PG-1 AND PUNE-PG - 400KV B/R 1 at PUNE-PG - 400KV	D	CB Testing	19/Feb/2025	09:00	19/Feb/2025	17:00	
491	RQ234051	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-HARANGUL-1	D	PID TESTING WORK	20/Feb/2025	09:00	20/Feb/2025	18:00	
492	RQ234109	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-OSMANABAD-M-1	D	PID Testing Hotline Work	20/Feb/2025	09:00	20/Feb/2025	17:30	
493	RQ233996	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	LINE/ s/s maintenance	20/Feb/2025	09:00	20/Feb/2025	17:30	
494	RQ234137	PLANNED	OCC_587	MSLDC_OUTAGE	220KV-PARLI-PARLI-M-2	D	PID Testing Hotline Work	20/Feb/2025	09:00	20/Feb/2025	17:30	
495	RQ234406	PLANNED	OCC_587	TAPS12	220KV-TARAPUR 1&2-BORIVALI-1	C	Outage is required for annual maintenance of feeder equipments.	20/Feb/2025	08:00	22/Feb/2025	18:00	
496	RQ234166	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-BABLESHWAR-PADGHE-1	D	PID Testing Work	20/Feb/2025	08:00	20/Feb/2025	18:00	
497	RQ234306	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-1	D	AR disable require for replacement of earth wire with OPGW	20/Feb/2025	08:00	20/Feb/2025	18:00	
498	RQ234334	PLANNED	OCC_587	WTPL	400KV-KALLAM P5-PUNE-GIS-2	D	AR disable require for replacement of earth wire with OPGW	20/Feb/2025	08:00	20/Feb/2025	18:00	
499	RQ233997	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-KARAD-SOLAPUR-1	D	Hardware tightening and cold line washing	20/Feb/2025	09:00	20/Feb/2025	18:00	
500	RQ232475	PLANNED	OCC_587	POWERGRID_WR1	400KV-KOLHAPUR-MS-SOLAPUR-2	D	Line Bay AMP works	20/Feb/2025	08:00	20/Feb/2025	18:00	
501	RQ233869	PLANNED	OCC_587	MUML	400KV-PADGHE-PG-KHARGHAR-1	D	For OPGW Replacement/Rectification works.	20/Feb/2025	08:00	20/Feb/2025	18:00	

SL	OCCM Sr. No	Request Type	OCC Number	Name of Requesting Agency	Element Name	Daily/Continuous	Reason	From Date	From Time	To Date	To Time	Remarks
502	RQ233995	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-PARLI-M-KARJAT-2	C	(1) Reactor back up tesing work. (2) Bay maintenance work.3) Hardware tightening & fitting work	20/Feb/2025	20:00	21/Feb/2025	06:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
503	RQ233764	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-3	D	AR disable for replacement of insulator in live line method.	20/Feb/2025	08:00	20/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
504	RQ233792	PLANNED	OCC_587	WTPL	400KV-PUNE-GIS-PUNE-PG-4	D	AR disable for replacement of insulator in live line method.	20/Feb/2025	08:00	20/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
505	RQ233624	PLANNED	OCC_587	POWERGRID_WR1	400KV-PUNE-GIS-PUNE-PG-4	C	For attending SF6 Gas leakage work	20/Feb/2025	06:00	22/Feb/2025	18:00	only one outage to be facilitated at a time (A. 400 kV Parli- M- Karjat- Lonikhand-II-Lonikhand corridor/B. 400 kV Parli-PG- Kallam- Pune GIS corridor/C. 400 kV Pune - Pune lines) subject to no other outages in parallel.
506	RQ234178	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-1	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	20/Feb/2025	07:00	20/Feb/2025	18:00	
507	RQ234179	PLANNED	OCC_588	MSLDC_OUTAGE	400KV-RGPPL-NAGOTHANE-2	D	Permission for Auto Reclose to be kept in Non auto mode for PID testing work	21/Feb/2025	07:01	21/Feb/2025	18:01	
508	RQ234953	PLANNED	OCC_587	MSLDC_OUTAGE	400KV-VIKHROLI-PUNE-PG-1	D	PID testing of insulator A/R function required to be in non auto mode	20/Feb/2025	09:00	20/Feb/2025	18:00	
509	RQ233948	PLANNED	OCC_587	MSLDC_OUTAGE	765KV/400KV EKTUNI-ICT-2	D	Diagnostic Testing and Routine Maintenance Works	20/Feb/2025	16:00	20/Feb/2025	23:00	
510	RQ233994	PLANNED	OCC_587	MSLDC_OUTAGE	KORADI-II - 400KV - BUS 2	D	1) Maintenance of isolator of all feeders connected to Main Bus 2	20/Feb/2025	10:00	20/Feb/2025	17:00	
511	RQ232675	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 400KV-CHAKAN-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	D	CB Testing	20/Feb/2025	09:00	20/Feb/2025	17:00	
512	RQ233623	PLANNED	OCC_587	POWERGRID_WR1	MAIN BAY - 400KV-PUNE-GIS-PUNE-PG-4 AND PUNE-GIS - 400KV - BUS 1 at Pune-GIS - 400KV	C	For attending SF6 Gas leakage work	20/Feb/2025	06:00	22/Feb/2025	18:00	
513	RQ233625	PLANNED	OCC_587	POWERGRID_WR1	PUNE-GIS - 400KV - BUS 1	D	For HV test and PD measurement	20/Feb/2025	06:00	20/Feb/2025	20:00	MSLDC consent is required/Subject to no other outages in parallel.

Maharashtra State Load Despatch Centre	
---	--

Monthly Outage list Not Considered in WRLDC OCCM for the Month of FEBRUARY '2025	
1	2
3	4
5	6
7	8
9	10
11	12
13	14
15	16
17	18
19	20
21	22
23	24
25	26
27	28
29	30
31	32
33	34
35	36
37	38
39	40
41	42
43	44
45	46
47	48
49	50
51	52
53	54
55	56
57	58
59	60
61	62
63	64
65	66
67	68
69	70
71	72
73	74
75	76
77	78
79	80
81	82
83	84
85	86
87	88
89	90
91	92
93	94
95	96
97	98
99	100

Reference Number	OCC Number	Name of Requesting Agency	Element Name	Daily/Continuous	Reason	Requested From Date	Requested From Time	Requested To Date	Requested To Time	Requester Remarks	Pre_OCC comments
------------------	------------	---------------------------	--------------	------------------	--------	---------------------	---------------------	-------------------	-------------------	-------------------	------------------

State Element outage list for the month of FEBRUARY '2025

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	CIRCLE
1	400 KV	LONIKAND - JEJURI CKT - 2	01-Feb-25	10:00	28-Feb-25	18:00	Daily	PID Work	MSETCL	MSETCL	Only A/R out required	CHANDRAPUR
2	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	01-Feb-25	06:00	01-Feb-25	18:00	Daily	For diagnostic testing and back relay retrofitting work	MSETCL	MSETCL	Subject to availability of Relay Engineer	PARLI
3	400 KV	MAIN BAY (406) OF NANDED CKT - 1 @ CHANDRAPUR 2	01-Feb-25	10:00	01-Feb-25	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work	PARLI
4	400 KV	400/220/20 KV 500MVA ICT - 3 @ KALWA	02-Feb-25	08:00	02-Feb-25	20:00	Daily	Bay maintenance & Diagnostic testing work.	MSETCL	MSETCL	Bay maintenance & Diagnostic testing work.	PARLI
5	400 KV	400 KV AUX BUS @ CHANDRAPUR	03-Feb-25	08:00	03-Feb-25	18:00	Daily	1. Replacement of faulty disc insulator of 02No. Insulator string of Auxilliary Bus (Section-1) in span of 400/220/33KV ICT-2 bay. 2. Hardware tightning work of Aux Bus Section-1 in a span of 400/220/33KV ICT-2 bay.	MSETCL	MSETCL	1. Replacement of 02No. faulty disc insulator of Auxilliary Bus (Section-1) in span of 400/220/33KV ICT-2 bay. 2. Disc Insulator 02No.s string found faulty during PID testing work.	JPTL
6	400 KV	STATION TF-3 @ KORADI 2	03-Feb-25	10:00	04-Feb-25	17:00	Continuous	Installation, Testing & comissioning of dedicated metering CT & IVT	MSETCL	MSETCL	Station transformer-I & Station Transformer-II will be in service as alternate source	JPTL
7	400 KV	JAIGAD - NEW KOYNA CKT - 2	03-Feb-25	08:00	03-Feb-25	23:00	Daily	Routine maint. Work of caesar	MSETCL	MSETCL	Routine maint. Work of caesar TBC Shifting	JPTL
8	400 KV	STATION TF No 4 @ CHANDRAPUR GCR	04-Feb-25	08:00	04-Feb-25	18:00	Daily	1. Measurement of tandelta & C of CT. 3. Maintenance and alignment of Isolators. 4. Bay routine maintenance work.	MSETCL	MSETCL	1. 400KV STN TF-5 will be in service. 2. Diagnostic Testing and routine maintenance of various equipment.	JPTL
9	400 KV	400 KV AUX BUS @ CHANDRAPUR	04-Feb-25	08:00	04-Feb-25	18:00	Daily	1. Replacement of faulty disc insulator of 02No. Insulator string of Auxilliary Bus (Section-1) in span of 400/220/33KV ICT-2 bay. 2. Hardware tightning work of Aux Bus Section-1 in a span of 400/220/33KV ICT-2 bay.	MSETCL	MSETCL	1. Replacement of 02No. faulty disc insulator of Auxilliary Bus (Section-1) in span of 400/220/33KV ICT-2 bay. 2. Disc Insulator 02No.s string found faulty during PID testing work.	PUNE
10	400 KV	500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2	04-Feb-25	10:00	04-Feb-25	18:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work	BHUSWAL
11	400 KV	JAIGAD - NEW KOYNA CKT - 2	04-Feb-25	08:00	04-Feb-25	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---	HVDC-HVDC Chandrapur

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	CIRCLE
12	400 KV	TBC @ KHARGHAR	04-Feb-25	09:00	04-Feb-25	18:00	Daily	Diagnostic testing and Routine maintenance	MSETCL	MSETCL	400/220/33kV ICT-2 HV CB Via TBC ICT 2 will be in service through TBC.	KALWA
13	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	05-Feb-25	10:00	05-Feb-25	17:00	Daily	Outage is required to carry out the Diagnostic Testing of equipments and routine maintenance work.	MSETCL	MSETCL	Load will be managed on ICT-I	HVDC-HVDC Chandrapur
14	400 KV	PADGHE - NAGOTHANE CKT - 2	05-Feb-25	09:00	05-Feb-25	21:00	Daily	1) Replacement of old CT & CVT MK Box. 2) Bay Maintenance Work. 3)MTAMC Work.	MSETCL	MSETCL	Weather Condition should be clear.	NAGPUR
15	400 KV	500 MVA 400/220 KV ICT - 2 @ CHANDRAPUR 2	06-Feb-25	10:00	06-Feb-25	18:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work	KARAD
16	400 KV	95 MVA STN TF - II @KORADI 2	06-Feb-25	10:00	07-Feb-25	17:00	Continuous	Installation, Testing & comissioning of dedicated metering CT & IVT	MSETCL	MSETCL	Station transformer-I & Station Transformer-III will be in service as alternate source	HVDC-HVDC Chandrapur
17	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	06-Feb-25	10:00	06-Feb-25	18:00	Daily	LINE, BUS,TIE CT TESTING & BAY MAINTENANCE WORK	MSETCL	MSETCL	-	HVDC-HVDC Chandrapur
18	400 KV	JAIGAD - NEW KOYNA CKT - 1	06-Feb-25	08:00	06-Feb-25	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---	HVDC-HVDC Chandrapur
19	400 KV	400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR	06-Feb-25	06:00	06-Feb-25	18:00	Daily	Diagnostic testing and Routine maintenance	MSETCL	MSETCL	ICT 1 & 2 will be in service	KARAD
20	400 KV	400/220/33KV 315MVA ICT - 3 @ LONIKAND	06-Feb-25	08:00	06-Feb-25	18:00	Daily	Healthiness check for NIFPS & Bay Maintenance	MSETCL	MSETCL	-	PANVEL
21	400 KV	TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	06-Feb-25	09:00	06-Feb-25	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-	SOLAPUR
22	400 KV	LONIKAND - JEJURI CKT - 1	06-Feb-25	09:30	06-Feb-25	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	400 kV Jejuri-Lonikand Ckt- 2, 400 kV Jejuri-Karad & 400 kV Jejuri-Koyna ST-IV will continue to remain in service	HVDC-HVDC Chandrapur
23	400 KV	400/220/33 KV 315MVA ICT - 2 @ CHAKAN	06-Feb-25	10:00	06-Feb-25	18:00	Daily	Routine maintenance and DT.	MSETCL	MSETCL	-	NAGPUR
24	400 KV	MAIN BAY - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	06-Feb-25	09:00	06-Feb-25	17:00	Daily	Diagnostic testing and Half Yearly Maintenance	MSETCL	MSETCL	-	PARLI
25	400 KV	WARORA - IEPL	07-Feb-25	09:00	07-Feb-25	17:00	Daily	Routine Maintenance & Dignostic testing work .	MSETCL	MSETCL	NA	KARAD
26	400 KV	400KV KORADI-BHUSAWAL (Koradi end)	07-Feb-25	09:00	07-Feb-25	18:00	Daily	BREAKER TESTING (CRM, DCRM, TIMING); ROUTINE BAY MNTC WORK	MSETCL	MSETCL	NIL	PANVEL

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	CIRCLE
27	400 KV	400/220 KV 3X105 MVA ICT - 1 @ PADGHE	07-Feb-25	09:00	07-Feb-25	20:00	Daily	1) Bay Maintenance Work. 2) Diagnostic Testing work. 3) MTAMC Work. 4) RTV Coating to IPS tube & Tertiary Bushing. 5) Replacement of Old WTI /OTI (Mercury) with New WTI/OTI (Switch Type).	MSETCL	MSETCL	Weather condition should be clear.	PUNE
28	400 KV	400/220/33 KV 315MVA ICT - 3 @ KHADKA	08-Feb-25	06:00	08-Feb-25	18:00	Daily	For diagnostic testing and back relay retrofitting work	MSETCL	MSETCL	Subject to availability of Relay Engineer	PUNE
29	400 KV	JAIGAD - NEW KOYNA CKT - 1	10-Feb-25	09:00	15-Feb-25	18:00	Daily	FOR HOTLINE WASHING (JAIGAD NEWKOYNA CKT 1 -AR OUT)	JPTL	JPTL	FOR HOTLINE WASHING (JAIGAD NEWKOYNA CKT 1 -AR OUT)	PUNE
30	400 KV	JAIGAD - NEW KOYNA CKT - 2	10-Feb-25	09:00	15-Feb-25	18:00	Daily	FOR HOTLINE WASHING WORK (JAIGAD NEWKOYNA CKT-2)	JPTL	JPTL	FOR HOTLINE WASHING WORK (JAIGAD NEWKOYNA CKT-2)	PUNE
31	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	10-Feb-25	10:00	10-Feb-25	17:00	Daily	High insulation coating of tertiary side IPS tube provided for RRS	MSETCL	MSETCL	load will be shifted to ICT-II	PUNE
32	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	10-Feb-25	08:00	10-Feb-25	18:00	Daily	Diagnostic testing & Relay testing work , Routine maint. Work	MSETCL	MSETCL	---	NAGPUR
33	400 KV	400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	11-Feb-25	09:00	11-Feb-25	16:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work	BHUSWAL
34	400 KV	TBC 1 @ CHANDRAPUR GCR	11-Feb-25	08:00	11-Feb-25	19:00	Daily	1. Measurement of CB Timing, CRM & DCRM. 2. Measurement of tandelta & C of CT. 3. Maintenance and alignment of Isolators. 4. Bay routine maintenance work.	MSETCL	MSETCL	Diagnostic Testing and routine maintenance of various equipment.	PADGHE
35	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	11-Feb-25	10:00	11-Feb-25	17:00	Daily	High insulation coating of tertiary side IPS tube provided for RRS	MSETCL	MSETCL	load will be shifted to ICT-II	PADGHE
36	400 KV	400KV NANDED(KUMBHARGAON)-PARLY CKT 2	12-Feb-25	10:00	12-Feb-25	18:00	Daily	LINE, BUS,TIE CT TESTING & BAY MAINTENANCE WORK	MSETCL	MSETCL	-	NAGPUR
37	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	12-Feb-25	10:00	12-Feb-25	17:00	Daily	High insulation coating of tertiary side IPS tube provided for RRS	MSETCL	MSETCL	load will be shifted to ICT-II	KARAD
38	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	12-Feb-25	10:00	12-Feb-25	17:00	Daily	Outage is required to carry out the Diagnostic Testing of equipments and routine maintenance work.	MSETCL	MSETCL	Load will be managed on ICT-1	HVDC-HVDC Chandrapur
39	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 2	13-Feb-25	08:00	13-Feb-25	18:00	Daily	1. Measurement of CB Timing, CRM & DCRM. 2. Feeder will be in service via 400KV TBC-1.	MSETCL	MSETCL	Feeder will be in service via 400KV TBC-1	HVDC-HVDC Chandrapur

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	CIRCLE
40	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	13-Feb-25	10:00	13-Feb-25	17:00	Daily	High insulation coating of tertiary side IPS tube provided for RRS	MSETCL	MSETCL	load will be shifted to ICT-I	NAGPUR
41	400 KV	JEJURI- KOYNA STAGE-IV	13-Feb-25	08:00	13-Feb-25	18:00	Daily	Cold Washing of Insulator strings	MSETCL	MSETCL	-	NAGPUR
42	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	13-Feb-25	09:30	13-Feb-25	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-I & ICT-II will continue to remain in service	SOLAPUR
43	400 KV	LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	13-Feb-25	08:00	13-Feb-25	18:00	Daily	DT, Relay Testing & Bay Maintenance	MSETCL	MSETCL	-	HVDC-HVDC Chandrapur
44	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	14-Feb-25	09:00	14-Feb-25	18:00	Daily	Disc Repalcement work loc.no.432,455	MSETCL	MSETCL	-	NAGPUR
45	400 KV	400KV 125MVAR BUS REACTOR @ CHANDRAPUR 2	14-Feb-25	09:00	14-Feb-25	18:00	Daily	Diagnostic testing and allied bay maintenance work	MSETCL	MSETCL	Diagnostic testing and allied bay maintenance work	PUNE
46	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	14-Feb-25	10:00	14-Feb-25	17:00	Daily	High insulation coating of tertiary side IPS tube provided for RRS	MSETCL	MSETCL	load will be shifted to ICT-I	PUNE
47	400 KV	125 MVAR BUS REACTOR @ KALWA-400 kv	14-Feb-25	08:00	14-Feb-25	20:00	Daily	Fire wall & ICT Painting work & diagnostic testing work.	MSETCL	MSETCL	Fire wall & ICT Painting work & diagnostic testing work.	PUNE
48	400 KV	400/220 KV 500 MVA ICT - 5 @ PADGHE	14-Feb-25	07:00	14-Feb-25	23:00	Daily	1. For safety purpose 500MVA ICT-6 gantry and equipment foundation excavation below ICT-5 interconnecting line. Erection of gantry and equipment structure below ICT-5 interconnecting line.	MSETCL	MSETCL	Weather condition should be clear.	HVDC-HVDC Chandrapur
49	400 KV	400/220/33 KV 500MVA ICT - 2 @ KORADI 2	15-Feb-25	10:00	15-Feb-25	17:00	Daily	High insulation coating of tertiary side IPS tube provided for RRS	MSETCL	MSETCL	load will be shifted to ICT-I	NAGPUR
50	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	15-Feb-25	08:00	15-Feb-25	18:00	Daily	For restoration ICT -IV from RRS Scheme after verification	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT III & V will be in service	KALWA
51	400 KV	400/220 KV 3X200 MVA ICT - 2 @ KALWA	16-Feb-25	08:00	16-Feb-25	17:00	Daily	Bay maintenance along with CB, isolator A & B maintenance & Diagnostic testing work.	MSETCL	MSETCL	400/220 KV 3X200 MVA ICT - 2 @ KALWA will be in service through TBC.	PADGHE
52	400 KV	JAIGAD - KARAD CKT - 2	17-Feb-25	09:00	22-Feb-25	18:00	Daily	FOR HOTLINE WASHING WORK (JAIGAD KARAD CKT-2 AR OUT)	JPTL	JPTL	FOR HOTLINE WASHING WORK (JAIGAD KARAD CKT-2 AR OUT)	NAGPUR
53	400 KV	JAIGAD - KARAD CKT - 1	17-Feb-25	09:00	22-Feb-25	18:00	Daily	FOR HOTLINE WASHING WORK (JAIGAD KARAD CKT-1 AR OUT)	JPTL	JPTL	FOR HOTLINE WASHING WORK (JAIGAD KARAD CKT-1 AR OUT)	NASHIK
54	400 KV	400/220/33KV SPARE ICT @ KORADI 2	17-Feb-25	10:00	17-Feb-25	17:00	Daily	1) Maintenance of isolator connected to Main Bus 2	MSETCL	MSETCL	1)Spare ICT is on no load, Space ICT is to be handtripped for Bus -II outage	KALWA
55	400 KV	400/220/33 KV 500MVA ICT - 1 @ WARORA	18-Feb-25	09:00	19-Feb-25	19:00	Continuous	Axillary protection trials as new ICT work	MSETCL	MSETCL	400/220/33kv ICT 1 erection completed	NAGPUR
56	400 KV	400/220/33KV SPARE ICT @ KORADI 2	18-Feb-25	10:00	18-Feb-25	17:00	Daily	1) Maintenance of isolator connected to Main Bus 2	MSETCL	MSETCL	1)Spare ICT is on no load, Space ICT is to be handtripped for Bus -II outage	CHANDRAPUR

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	CIRCLE
57	400 KV	400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	18-Feb-25	10:00	18-Feb-25	18:00	Daily	DFRA TESTING WORKS	MSETCL	MSETCL	NIL	NAGPUR
58	400 KV	400/220/33KV SPARE ICT @ KORADI 2	20-Feb-25	10:00	20-Feb-25	17:00	Daily	1) Maintenance of isolator connected to Main Bus 2	MSETCL	MSETCL	1)Spare ICT is on no load, Space ICT is to be handtripped for Bus -II outage	NAGPUR
59	400 KV	CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	20-Feb-25	09:00	20-Feb-25	18:00	Daily	Earthwire Stringing Work loc.no.497-500 & Nut bolt hardware tightning work	MSETCL	MSETCL	-	NAGPUR
60	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	20-Feb-25	09:30	20-Feb-25	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	ICT-II & ICT-III will continue to remain in service	PARLI
61	400 KV	LONIKAND - JEJURI CKT - 2	20-Feb-25	10:00	20-Feb-25	18:00	Daily	Yearly DT and maintenance	MSETCL	MSETCL	-	PUNE
62	400 KV	400/220/33 KV 500 MVA ICT - 3 @ PARLI	21-Feb-25	09:00	21-Feb-25	18:00	Daily	1) LV Back up , REF & NDR relay testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-	PUNE
63	400 KV	TBC @ KALWA	21-Feb-25	08:00	21-Feb-25	20:00	Daily	Fire wall, ICT Painting work & Diagnostic testing work.	MSETCL	MSETCL	Fire wall, ICT Painting work & Diagnostic testing work.	PARLI
64	400 KV	DHULE- - BABLESHWAR CKT - 2	21-Feb-25	08:00	21-Feb-25	18:00	Daily	Routine Line maintenance work	MSETCL	MSETCL	400kV Dhule I will be in in service	KALWA
65	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	21-Feb-25	08:00	21-Feb-25	18:00	Daily	HV CB DCRM/ Timing SFRA	MSETCL	MSETCL	315 MVA ICT I, II and 501 MVA ICT IV & V will be in service	NASHIK
66	400 KV	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	21-Feb-25	08:00	21-Feb-25	18:00	Daily	Diagnostic testing and Routine maintenance	MSETCL	MSETCL	Diagnostic testing and Routine maintenance	NASHIK
67	400 KV	400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	22-Feb-25	08:00	22-Feb-25	18:00	Daily	Diagnostic Testing ICT and HV CT C & Tan D	MSETCL	MSETCL	Load will be managed on 315 MVA ICT-I&2, 501 MVA ICT-3,5	PANVEL
68	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	24-Feb-25	09:00	24-Feb-25	18:00	Daily	1)LV CB , Winding tan delta & winding resistance testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-	NASHIK
69	400 KV	DHULE- - BABLESHWAR CKT - 1	24-Feb-25	09:00	25-Feb-25	18:00	Continuous	Replacement of Grading Capacitor	MSETCL	MSETCL	Line will be in service through TBC	PARLI
70	400 KV	KORADI II - IEPL	25-Feb-25	06:00	25-Feb-25	18:00	Daily	LINE MAINT. WORKS	MSETCL	MSETCL	NA	NASHIK
71	400 KV	DHULE- - BABLESHWAR CKT - 2	26-Feb-25	09:00	27-Feb-25	18:00	Continuous	Replacement of Grading Capacitor	MSETCL	MSETCL	Line will be in service through TBC	NAGPUR
72	400 KV	CHANDRAPUR-PARLI CKT-3	27-Feb-25	09:00	27-Feb-25	18:00	Daily	Nut bolt hardware tightning work/ Spacer Repalcement &loc. No.474,631,657 Broken Disc Repalcement work	MSETCL	MSETCL	-	NASHIK

Sr.no.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.	CIRCLE
73	400 KV	400/220/33 KV 315 MVA ICT - 1 @ PARLI	27-Feb-25	09:00	27-Feb-25	18:00	Daily	1) Differential and HV Backup relay testing work.2) Bay Maintenance work.	MSETCL	MSETCL	-	PARLI
74	400 KV	LONIKAND - JEJURI CKT - 2	27-Feb-25	09:30	27-Feb-25	18:00	Daily	For Maintenance & Testing work	MSETCL	MSETCL	400 kV Jejuri-Lonikand Ckt-1, 400 kV Jejuri-Karad & 400 kV Jejuri-Koyna ST-IV will continue to remain in service	PUNE