

TRANSMISSION ELEMENTS OUTAGES LIST FOR THE MONTH OF MARCH 2017

Sr.no.	492nd OCCM Sr.No.	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	Site	WRLDC Comments
				Date	Time	Date	Time							
1	15	400	Simultaneously Non auto code on 400 Boisar-Vapi, Boisar-Padghe, Boisar-Tarapur Ckt. I & II	1-Mar-17	9:00	12-Mar-17	18:00	Daily	Hotline Powerline crossing work of Aurangabad-Boisar line	POWERGRID/ TAPS/MSETCL /GUJARAT	WR-II	C	Boisar	
2	28	400	400 Khandwa Dhule 1&2	1-Mar-17	8:00	31-Mar-17	18:00	Daily	Online permit for PID testing of insulator strings. A/R for both circuits to be kept into non auto mode during PID testing.	POWERGRID	WR-II	C	KHANDWA	
3	34	400	Parli - Wardha Ckt-I	1-Mar-17	6:00	31-Mar-17	18:00	Daily	Online OPGW work. A/R to be kept in Non auto mode	WRTS-I	WRTS-I	C	AR	
4	35	765	Aurangabad-Wardha-1	1-Mar-17	6:00	31-Mar-17	18:00	Daily	Online replacement of E/W with OPGW. A/R shall be kept in non auto mode	WRTS-I	WRTS-I	C	AR	Subject to restoration of ckt-4
5	37	400	400 BHILAI-KORADI	1-Mar-17	9:00	31-Mar-17	17:00	Daily	Online PID Works . A/R to be kept in Non Auto mode	WRTS-I	WRTS-I	C	AR	Only one ckt at a time from Bhilai
6	38	400	400 KORADI-SATPURA	1-Mar-17	9:00	31-Mar-17	17:00	Daily	Online PID Works . A/R to be kept in Non Auto mode	WRTS-I	WRTS-I	C	AR	
7	39	400	400 BHADRAVATI-CHANDRAPUR I & II	1-Mar-17	9:00	31-Mar-17	17:00	Daily	Online PID Works . A/R to be kept in Non Auto mode	WRTS-I	WRTS-I	C	AR	
8	47	400	400 PARLI(PG)-PARLI(MSETCL) II	1-Mar-17	10:00	1-Mar-17	16:00	Daily	For collection of CT Oil Sample (DGA Test) at MSETCL end/Line AMP works. Other Ckt is in Non Auto Mode	WRTS-I	WRTS-I	R	Line	Shall be availed on 21 march along with line
9	50	400	765 KV Seoni-Wardha # 1	1-Mar-17	9:00	31-Mar-17	18:00	Daily	Autoreclosure to be kept OFF for OPGW work	WRTS-I	WRTS-I	C	AR	
10	51	765	765 KV Bus # 1 at Wardha	1-Mar-17	9:00	1-Mar-17	18:00	Continuous	For extension to 765 KV Nizamabad bays	WRTS-I	WRTS-I	C	Bus	
11	54	220	220 KV BHUGAON-PGCIL Wardha LINE	1-Mar-17	10:00	1-Mar-17	17:00	DAILY	DAMAGE DISC INSULATOR REPLACEMENT	MSETCL	MSETCL			
12	55	220	220 Pusa-Deoli (PGCIL) Line	1-Mar-17	10:00	4-Mar-17	17:00	Daily	For PID Work.Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
13	56	765/400	3*500 MVA ICT-2 @ Ektuni	1-Mar-17	10:00	2-Mar-17	18:00	Continuous	Alignment of Isolators (406-89B, 406-89T & 405-89B)	MSETCL	MSETCL			Load will be managed on 3*500MVA ICT 1
14	57	400	Main Bus B @ Kalwa	1-Mar-17	6:00	4-Mar-17	22:00	Continuous	Old Rusted Bus Conductor Replacement	MSETCL	MSETCL			
15	58	400	Bus Coupler @Kalwa	1-Mar-17	6:00	2-Mar-17	22:00	Continuous	Old Rusted Bus Conductor Replacement	MSETCL	MSETCL			
16	59	400	400 Chandrapur- Parali Ckt-III	1-Mar-17	9:00	31-Mar-17	16:00	Daily	Tightening of Earth wire clamp, Nut bolt. A/R in Non Auto mode .	MSETCL	MSETCL			At a time Wardha-Parli-I or Chandrapur-Parli-I
17	60	400	400 TBC @ Khadka	1-Mar-17	8:35	2-Mar-17	18:00	Continuous	For alignment of BUS-1 & 2 PG isolator AND DIAGNOSTIC TESTING WORK OF CB AND CT	MSETCL	MSETCL			
18	61	400	400 Dhule- BTDCL-I & Bays at Dhule	1-Mar-17	8:00	1-Mar-17	18:00	Daily	Bay maintenance & routine testing	MSETCL	MSETCL			
19	65	400	400 WARDHA-AKOLA D/C	1-Mar-17	8:00	2-Mar-17	18:00	Continuous	Powerline crossing works of 765 D/C Hyderabad-Wardha between tower location Nos 61/0 & 62/0 (Wardha-Akola Tr Line tower nos.10 to 11) & Routine Maintenance & testing work of line and bays Equipments	WRTS-I	RTS-I/MSET	C	Line	
20	LP-1	400	SSP - Dhule -1	1/Mar/17	8:00	2/Mar/17	22:00	Continuous	Relay testing & New relay Retrofitting	SSP	NCA	R		
21	70	400	404 main bay of 765/400 ICT-2 at Dhule	2-Mar-17	9:00	2-Mar-17	18:00	Daily	For AMP Works	BDTCL	BDTCL	R		
22	87	765	765 KV Koradi-III-Akola-II Ckt-I @Koradi III SS	2-Mar-17	8:00	2-Mar-17	18:00	Daily	Annual Maintenance of Line Equipments	MEGPTCL	MEGPTCL			
23	88	400	400 Bus- Coupler @ Lonikand 1	2-Mar-17	9:00	2-Mar-17	15:00	Daily	Half yearly Bay maint.	MSETCL	MSETCL			
24	89	400	Talange-Karad Ckt-2 @ Talange	2-Mar-17	9:00	2-Mar-17	18:00	Daily	Annual Maintenance & Dignostic testing work	MSETCL	MSETCL			
25	94	765	765 KV Bus # 2 at Wardha	2-Mar-17	9:00	2-Mar-17	18:00	Continuous	For extension to 765 KV Nizamabad bays	WRTS-I	WRTS-I	C	Bus	
26	96	765	765 KV Seoni # Wardha # 1& 2 Line	3-Mar-17	9:00	10-Mar-17	18:00	Continuous	Swapping of 765 KV Seoni line to 765 KV Nizamabad bays for Erection of Towers and Stringing work at Wardha.	WRTS-I	WRTS-I	C	Line	
27	97	765	765 KV Tie Bay 711 of Bus Reactor # 2 at Wardha	3-Mar-17	9:00	10-Mar-17	18:00	Continuous	Construction activities for new Nizamabad bays	WRTS-I	WRTS-I	C	Bay	
28	101	400	400 Bus Reactor Main Bay 418 at Wardha	3-Mar-17	9:00	3-Mar-17	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	R	Bay	
29	114	400	BUS REACTOR 400 125MVAR AURANGABAD	3-Mar-17	9:00	3-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	BR	
30	116	400	407 Bay (Main Bay of 400 Talegaon GIS Line # 2) at Pune Telegaon	3-Mar-17	9:00	3-Mar-17	18:00	Daily	For AMP works - Telegaon	WRTS-I	WRTS-I	R	Bay	
31	122	400	400 PUNE(GIS)-PUNE(TALEGOAN) 4	3-Mar-17	9:00	3-Mar-17	12:00	Daily	For AMP work & other Ckt is non Auto Mode	WRTS-I	WRTS-I	R	LINE	
32	126	400	400 WARDHA-MAUDA II	3-Mar-17	9:00	3-Mar-17	18:00	Daily	For Changing of CT ratio at wardha end	WRTS-I	WRTS-I	C	Line	
33	127	220	220 KV BHUGAON-PGCIL wardha LINE	3-Mar-17	10:00	3-Mar-17	17:00	DAILY	DAMAGE DISC INSULATOR REPLACEMENT	MSETCL	MSETCL			
34	128	400/220	315MVA ICT-1 @Nagothane	3-Mar-17	9:00	3-Mar-17	17:00	Daily	To carry out Bushing Tandelta and winding and CT Tandelta	MSETCL	MSETCL			
35	129	400	ICT III @ Kalwa 400/220 KV 500 MVA	3-Mar-17	6:00	4-Mar-17	22:00	Continuous	Old Rusted Bus Conductor Replacement	MSETCL	MSETCL			
36	130	400	400 Khadka Akola Ckt @ Khadka	3-Mar-17	8:00	3-Mar-17	18:00	Daily	PG Isolator alignment work & CVT Testing	MSETCL	MSETCL			
37	138	400	405 Tie bay of 400 Dhule(BDTCL)-Dhule(MSETCL) Line-1 at BDTCL-Dhule	3-Mar-17	9:00	3-Mar-17	18:00	Daily	For AMP Works	BDTCL	BDTCL	R		
38	LP-5	400	SSP - Dhule -2	3/Mar/17	8:00	4/Mar/17	22:00	Continuous	Relay testing & New relay Retrofitting	SSP	NCA	R		
39	140	400	400 Dhule- Dhule BDTCL -II & bays at Dhule BDTCL	4-Mar-17	8:00	4-Mar-17	18:00	Daily	Bay maintenance & routine testing	MSETCL/BDTCL	MSETCL/BDTCL			
40	152	765	B/R TER(BUS REACTOR)240 MVAR MAIN BAY-701 at Aurangabad	4-Mar-17	9:00	4-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay	
41	154	400	412 Bay (Main Bay of ICT # 2) at Pune Telegaon	4-Mar-17	9:00	4-Mar-17	18:00	Daily	For AMP works - Telegaon	WRTS-I	WRTS-I	R	Bay	
42	155	765	SWITCHABLE LR_765_RAICHUR 2_SOLAPUR at Solapur	4-Mar-17	9:00	4-Mar-17	18:00	DAILY	AMP WORKS AND REPLACEMENT OF FAULTY AUX. SWITCH AND LIMIT SWITCHES	WRTS-I	WRTS-I	R	LR	
43	157	765	765 WARDHA - AURANGABAD(PG) I & II	4-Mar-17	8:00	5-Mar-17	18:00	Daily	Powerline crossing works of 765 D/C Hyderabad-Wardha between tower location Nos 55/0 & 55/1 (765 D/C Wardha -Aurangabad Transmission line tower nos.14 to 15)	WRTS-I	WRTS-I	C	Line	subjected to ckt-4 restoration/ by hot line works
44	158	400	Buscoupler @ BBLR	4-Mar-17	9:00	4-Mar-17	17:00	Daily	Maintenance work	MSETCL	MSETCL			
45	159	400	400/220 KV, 315 MVA ICT @ Khadka	4-Mar-17	8:35	11-Mar-17	18:00	Continuous	FOR REPLACEMENT OF B PH UNIT OF 315 MVA ICT with new repaired Single phase 105 MVA UNIT	MSETCL	MSETCL			
46	160	400	400 Dhule-SSNNL Ckt-I	4-Mar-17	8:00	4-Mar-17	17:00	Daily	Bay maintenance	MSETCL	MSETCL			
47	165	400	400 Koyna Stage IV-Lonikand Line	5-Mar-17	8:00	12-Mar-17	18:00	Daily	Replacement of Normal Disc Insulators by Antifog Insulators Under LE Scheme MBR 92/8	MSETCL	MSETCL			
48	169	400/220/33	315MVA ICT-3 @ Padgha	5-Mar-17	8:00	5-Mar-17	18:00	Daily	Routine R&M work and Dignostic Testing work and OLTC servicing.	MSETCL	MSETCL			

Sr.no.	492nd OCCM Sr.No.	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	Site	WRLDC Comments
				Date	Time	Date	Time							
49	170	400	400 Kalwa-Kharghar Line	5-Mar-17	9:00	5-Mar-17	18:00	Daily	Annual Maintenance Work/Earth Wire replacement one span,one side	MSETCL	MSETCL			
50	171	400	408 Tie bay of 400 Dhule(BDTCL)-Dhule(MSETCL) Line-2 at BDTCL-Dhule	5-Mar-17	9:00	5-Mar-17	18:00	Daily	For AMP Works	BDTCL	BDTCL	R		
51	172	400	400 Khadka-Akola Line	6-Mar-17	6:00	9-Mar-17	18:00	Daily	PID testing. Auto-reclose of the ckt will be made Off from both side of the ckt	MSETCL	MSETCL			
52	173	220	220 BUS # 2 at Pune Telegaon	6-Mar-17	9:00	6-Mar-17	18:00	Daily	For AMP works - Telegaon	WRTS-I	WRTS-I	R	BUS	Maharashtra consent required
53	174	400	400 Parli-Chandrapur ckt III bay @ Parli	6-Mar-17	9:00	6-Mar-17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
54	175	400	315MVA ICT-II @Kharghar	6-Mar-17	9:00	6-Mar-17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
55	176	400	400 ICT # 2 at Wardha	6-Mar-17	9:00	6-Mar-17	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	R	ICT	
56	191	765	SWITCHABLE LR_765_PADGHE2(Solapur- J) AURANGABAD at Aurangabad.	6-Mar-17	9:00	6-Mar-17	18:00	Daily	for RTV coating on HV Bushings	WRTS-I	WRTS-I	R	LR	
57	194	400	413 Bay (Main Bay of 400 Talegaon Lonikand Line) at Telegaon	6-Mar-17	9:00	6-Mar-17	18:00	Daily	For AMP works - Telegaon	WRTS-I	WRTS-I	R	Bay	
58	195	765	SWITCHABLE LR_765_RAICHUR 1_SOLAPUR	6-Mar-17	9:00	6-Mar-17	18:00	DAILY	AMP WORKS AND REPLACEMENT OF FAULTY AUX. SWITCH AND LIMIT SWITCHES	WRTS-I	WRTS-I	R	LR	
59	196	765	SWITCHABLE LR_765_WARDHA 1 at Seoni	6-Mar-17	9:00	7-Mar-17	18:00	Daily	For RTV Coating of HV bushing/AMP Works	WRTS-I	WRTS-I	R	Reactor	
60	199	765	765 KV Bus Reactor # 2 at Wardha	6-Mar-17	9:00	7-Mar-17	18:00	Continuous	for auxiliary bus construction work	WRTS-I	WRTS-I	C	Reactor	subjected to voltage condition
61	200	765	765 kV Akola-II to Aurangabad Ckt-I @Akola II SS	6-Mar-17	8:00	7-Mar-17	18:00	Daily	Annual Maintenance Line	MEGPTCL	MEGPTCL			
62	201	400	400 Bus 2 @ Tiroda Plant	6-Mar-17	9:00	6-Mar-17	21:00	Daily	Bus and Bus Connected Equipment Maintenance	ATIL	ATIL			
63	202	400	400 Karad- Talandge(Kolhapur) -I @ Karad	6-Mar-17	10:00	6-Mar-17	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL			
64	203	400	413-Bay (Main Bay of Wardha(PGCIL)-Koradi-2 S/st) at Wardha(PGCIL) Substation	6-Mar-17	10:00	6-Mar-17	14:00	Daily	CRM of CB will be carried out.	MSETCL	MSETCL			
65	204	220	220 kv PGCIL Wardha-PUSAD LINE	6-Mar-17	10:00	6-Mar-17	17:00	DAILY	DAMAGE DISC INSULATOR REPLACEMENT	MSETCL	MSETCL			
66	205	400	Chandrapur GCR - Parali Ckt III	6-Mar-17	8:00	7-Mar-17	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
67	206	400	Chandrapur II - Nanded line	6-Mar-17	8:00	7-Mar-17	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
68	207	220	220 Pusad-Deoli (PGCIL) Line	6-Mar-17	10:00	11-Mar-17	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
69	208	220	220 kV Badnera-Devli(PGCIL) Line	6-Mar-17	9:00	6-Mar-17	17:00	Daily	1)Routine Maintenance of equipments.	MSETCL	MSETCL			
70	209	400/220	501MVA, ICT 3 @ Talandge	6-Mar-17	9:00	6-Mar-17	18:00	Daily	Annual Maintenance & Dignostic testing work	MSETCL	MSETCL			
71	210	400	400 DHL- SNNL Line Ckt-I & II	6-Mar-17	9:00	7-Mar-17	17:00	Daily	PID testing. Auto-reclose of the ckt will be made Off from both side of the ckt	MSETCL	MSETCL			
72	218	400	400 Sholapur-1 Main Bay (409) at Parli	7-Mar-17	10:00	7-Mar-17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	Bay	
73	234	765	SWITCHABLE LR_765_PADGHE1(Solapur 2) AURANGABAD at Aurangabad	7-Mar-17	9:00	7-Mar-17	18:00	Daily	for RTV coating on HV Bushings	WRTS-I	WRTS-I	R	LR	
74	237	765/400	ICT1_765/400_PUNE(GIS)	7-Mar-17	9:00	7-Mar-17	17:00	Daily	For instalation of pressure transducer for CSD	WRTS-I	WRTS-I	R	ICT	
75	238	400	415 Bay (Main bay of Bus reator) at Telegaon	7-Mar-17	9:00	7-Mar-17	18:00	Daily	For AMP works - Telegaon	WRTS-I	WRTS-I	R	Bay	
76	239	765	SOLAPUR_713_MAIN BAY_765 RAICHUR#2	7-Mar-17	9:00	7-Mar-17	18:00	DAILY	AMP WORKS AND REPLACEMENT OF FAULTY AUX. SWITCH AND LIMIT SWITCHES	WRTS-I	WRTS-I	R	BAY	
77	243	220	220 KV Wardha- Wardha line	7-Mar-17	9:00	7-Mar-17	18:00	Daily	Line CT AMP work and Relay test work	WRTS-I	WRTS-I	R	Line	
78	244	765	765 KV Wardha-Aurangabad # 1	7-Mar-17	9:00	7-Mar-17	18:00	Daily	Installation of OPGW work	WRTS-I	WRTS-I	R	Line	
79	245	400/220	400/220 KV 315MVA, ICT 3 @ Karad	7-Mar-17	10:00	7-Mar-17	18:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL			
80	246	400	315MVA ICT-III @ Kharghar	7-Mar-17	9:00	7-Mar-17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
81	247	400	400/220/33KV, 315MVA ICT-I & Its Bay @Chandrapur II	7-Mar-17	8:00	8-Mar-17	18:00	daily	1) Measurement of Tan Delta & Capacitance of bushings of ICT. 2) Commisioning of energy meter to 220 side of ICT. 3)Maintenance of PG isolator & CB Isolator	400 AC	MSETCL			
82	248	400	407 Main bay of 765/400 ICT-1 at Dhule	7-Mar-17	9:00	7-Mar-17	18:00	Daily	For AMP Works	BDTCL	BDTCL	R		
83	255	400/220	501MVA ICT-III @ Waluj	8-Mar-17	10:00	8-Mar-17	17:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL	anaged on	ICT 1 and ICT 3	
84	256	400	400 Parli-2 (MSETCL) Main Bay (418) at Parli	8-Mar-17	10:00	8-Mar-17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	Bay	Shall be availed on 21 march along with line
85	274	765/400	ICT1_765/400_AURANGABAD	8-Mar-17	9:00	8-Mar-17	18:00	Daily	for RTV coating on HV Bushings	WRTS-I	WRTS-I	R	ICT	
86	276	765/400	ICT2_765/400_PUNE(GIS)	8-Mar-17	9:00	8-Mar-17	17:00	Daily	For instalation of pressure transducer for CSD	WRTS-I	WRTS-I	R	ICT	
87	277	220	209 Bay (220 Side of ICT # 3) at Telegaon	8-Mar-17	9:00	8-Mar-17	10:45	Daily	To take CT oil sample for testing - Talegaon (ICT will remain in service through Transfer Bus)	WRTS-I	WRTS-I	R	Bay	
88	278	400	418 Bay (Main Bay of ICT # 3) at Telegaon	8-Mar-17	9:00	8-Mar-17	18:00	Daily	For AMP works - Telegaon	WRTS-I	WRTS-I	R	Bay	
89	280	765	SOLAPUR_714_TIE BAY_765 RAICHUR#2- Future at Solapur	8-Mar-17	9:00	8-Mar-17	18:00	DAILY	AMP WORKS AND REPLACEMENT OF FAULTY AUX. SWITCH AND LIMIT SWITCHES	WRTS-I	WRTS-I	R	BAY	
90	281	765	SWITCHABLE LR_765_WARDHA-2 at Seoni	8-Mar-17	9:00	9-Mar-17	18:00	Daily	For RTV Coating of HV bushing/AMP Works	WRTS-I	WRTS-I	R	Reactor	
91	282	220	220 KV Wardha- Bhugaon line	8-Mar-17	9:00	8-Mar-17	18:00	Daily	CT sampling work and AR testing work	WRTS-I	WRTS-I	R	Line	
92	283	220	220 KV Wardha- Pusad line	8-Mar-17	9:00	8-Mar-17	18:00	Daily	CT sampling work and AR testing work	WRTS-I	WRTS-I	R	Line	
93	284	765	Main Bay (704) of ICT-2 at Koradi III Sub Station.	8-Mar-17	8:00	8-Mar-17	18:00	Daily	Annual Maintenance of bays equipment	MEGPTCL	MEGPTCL			
94	285	400	400 Karad-Solapur(PGCIL)@ Karad	8-Mar-17	10:00	8-Mar-17	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL			
95	286	400	400 Warora-PGCILWardha ckt	8-Mar-17	10:00	8-Mar-17	13:30	Daily	Routine Line Maintenance B/W Loc-31-32 and line signature Analysis	MSETCL	MSETCL			
96	287	400	Ektuni-Thapti-Tanda ckt-1 @ Ektuni	8-Mar-17	10:00	9-Mar-17	18:00	Continuous	Alignment of Isolators (404-89L, 404-89B & 405-89A)	MSETCL	MSETCL			
97	288	400/220	315MVA ICT-2 @Nagothane	8-Mar-17	9:00	8-Mar-17	17:00	Daily	To carry out Bushing Tandelta and winding and CT Tandelta	MSETCL	MSETCL			
98	289	400/220	167MVA, SPARE ICT @ Talandge	8-Mar-17	9:00	8-Mar-17	18:00	Daily	Annual Maintenance & Dignostic testing work	MSETCL	MSETCL			
99	290	400/220	501 MVA ICT-II @ Solapur	8-Mar-17	10:00	8-Mar-17	18:00	Daily	Maintenance work, Diagnostic Testing Work.	MSETCL	MSETCL			

Sr.no.	492nd OCCM Sr.No.	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	Site	WRLDC Comments
				Date	Time	Date	Time							
100	291	400	400 Switching ckt-I (Main Bay-404 & Tie Bay-405) @ Chandrapur-II S/S	8-Mar-17	9:00	8-Mar-17	18:00	Daily	Diagnostic Testing & allied bay maintenance work	MSETCL	MSETCL			
101	292	400	400 Parli-Solapur-S/c line	8-Mar-17	10:00	8-Mar-17	14:00	Daily	Line Signature Analysis	MSETCL	MSETCL			
102	303	400	SOLAPUR BAY 429 TIE BAY 765 ICT#2	9-Mar-17	9:00	9-Mar-17	18:00	DAILY	COMMISSIONING OF 400 NTPC#4	WRTS-I	WRTS-I	C	BAY	
103	304	400	SOLAPUR 400 BUS#2	9-Mar-17	9:00	9-Mar-17	20:00	DAILY	COMMISSIONING OF 400 NTPC#4	WRTS-I	WRTS-I	C	BUS	
104	309	400	400 Akola-Wardha Ckt-1 with Bay 408 & 409 at 400 RS Akola	9-Mar-17	10:00	9-Mar-17	17:00	Daily	Routine Maintenance & testing work of line and bays Equipments	MSETCL	MSETCL			
105	321	765/400	ICT2 765/400 AURANGABAD	9-Mar-17	9:00	9-Mar-17	18:00	Daily	for RTV coating on HV Bushings	WRTS-I	WRTS-I	R	ICT	
106	323	400	400 Bus-II at Parli	9-Mar-17	10:00	9-Mar-17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	Bus	Maharashtra consent required
107	324	400	402 Bay (Tie Bay of 400 Talegaon Chakan Line & 400 Talegaon Kharghar Line	9-Mar-17	9:00	9-Mar-17	10:00	Daily	To take CT oil sample for testing - Talegaon	WRTS-I	WRTS-I	R	Bay	
108	325	400	404 Bay (Main Bay of 400 Talegaon GIS Line # 1) at Talegaon	9-Mar-17	10:00	9-Mar-17	11:00	Daily	To take CT oil sample for testing - Talegaon	WRTS-I	WRTS-I	R	Bay	
109	326	765	SOLAPUR_705_TIE BAY_765/400 ICT#2	9-Mar-17	9:00	9-Mar-17	18:00	DAILY	AMP WORKS AND REPLACEMENT OF FAULTY AUX. SWITCH AND LIMIT SWITCHES	WRTS-I	WRTS-I	R	BAY	
110	330	220	220 KV Bus # 2 at Wardha	9-Mar-17	9:00	9-Mar-17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	Bay	
111	340	400	Main Bus-II & 410-Bay (Main Bay of 3*500MVA ICT-1) @ Ektuni	10-Mar-17	10:00	10-Mar-17	18:00	Daily	Alignment of Isolators (410-89A)	MSETCL	MSETCL	SERVICE THROUGH TIE BAY.		
112	341	400	400 Parli-Parli Ckt-1	10-Mar-17	9:00	10-Mar-17	18:00	Daily	Bay maintenance work/For Bay AMP works at Parli	PGCIL	MSETCL/WR-I			
113	342	400	Ektuni-Thapti-Tanda ckt-2 @ Ektuni	10-Mar-17	10:00	11-Mar-17	18:00	Continuous	Alignment of Isolators (401-89L, 401-89B & 402-89A)	MSETCL	MSETCL			
114	354	765	765 WARDHA - AURANGABAD(PG) II	10-Mar-17	9:00	10-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay	
115	355	220	ICT1_315MVA (Bay-201) at Aurangabad	10-Mar-17	9:00	10-Mar-17	18:00	Daily	For AMP Works at Aurangabad(ICT Will Remain in Service through TBC)	WRTS-I	WRTS-I	R	Bay	
116	356	220	205 Bay (220 Side of ICT # 2) at Talegaon	10-Mar-17	9:00	10-Mar-17	10:00	Daily	For AMP works - Talegaon. ICT will remain in service through Transfer Bus	WRTS-I	WRTS-I	R	Bay	
117	362	400	400 125 MVar Bus Reactor bay No.402 at 400 Warora	10-Mar-17	10:00	10-Mar-17	17:00	Daily	Routine bay maintenance work at 400 125 MVar Bus Reactor at 400 S.stn. Warora.	MSETCL	MSETCL			
118	363	400/220	500MVA, ICT 3 @ BBLR	10-Mar-17	9:00	10-Mar-17	17:00	Daily	Maintenance work	MSETCL	MSETCL			
119	364	400	Talandge-Solapur Ckt-2 @ Talandge	10-Mar-17	9:00	10-Mar-17	18:00	Daily	Annual Maintenance & Dignostic testing work	MSETCL	MSETCL			
120	365	400/220	315MVA ICT-1 @Padgha	10-Mar-17	8:00	10-Mar-17	18:00	Daily	Routine R&M work and Dignostic Testing work.	MSETCL	MSETCL			
121	366	400	400 Chandrapur 2- Parali Ckt-I@ Parali	10-Mar-17	9:00	10-Mar-17	17:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL			
122	367	400/220	315MVA, ICT I at 400 R.S. Dhule	10-Mar-17	8:00	10-Mar-17	18:00	Daily	Maintenance work	MSETCL	MSETCL			
123	368	400	400/220 ICT - I at 400 Deepnagar	10-Mar-17	9:00	10-Mar-17	17:00	Daily	Diagnostic testing of ICT units and routine maintenance	MSETCL	MSETCL	-		
124	376	765	765 KV ICT # 1 at Wardha	11-Mar-17	9:00	11-Mar-17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	ICT	
125	379	400	400 BUS-2 at 400 RS Akola	11-Mar-17	10:00	11-Mar-17	17:00	Daily	Routine Maintenance ,Testing Work and new ICT Equipments erection & Jumpering works	MSETCL	MSETCL			
126	380	400	Main Bus-II & 406-Bay (Main Bay of 3*500MVA ICT-2) @ Ektuni	11-Mar-17	10:00	11-Mar-17	18:00	Daily	Alignment of Isolators (406-89A)	MSETCL	MSETCL	nservice through Tie bay .		
127	382	400	400 Bus Reactor-2 & Parli-2 (MSETCL) Tie Bay (417) at Parli	11-Mar-17	10:00	11-Mar-17	18:00	Daily	For Bay AMP works at Parli	WRTS-I	WRTS-I	R	Bay	
128	384	400	400 Chandrapur 2 - Parali Ckt-I@ Parali	11-Mar-17	9:00	11-Mar-17	17:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL			
129	385	765	765 WARDHA - AURANGABAD(PG) I	11-Mar-17	9:00	11-Mar-17	18:00	Daily	for erection of 400 Wardha-A'bad Tower at Aurangabad	WRTS-I	WRTS-I	C	Line	
130	391	220	202 Bay (220Talegaon MSETCL Line # 1) Line will remain in service through Transfer Bus at Pune Talegaon	11-Mar-17	9:00	11-Mar-17	18:00	Daily	For AMP works - Talegaon	WRTS-I	WRTS-I	R	Bay	SLDC Maharashtra consent required.
131	392	765	SOLAPUR_706_MAIN BAY_765 ICT#2 MAIN BAY	11-Mar-17	9:00	11-Mar-17	18:00	DAILY	REPLACEMENT OF FAULTY AUX. SWITCH AND LIMIT SWITCHES	WRTS-I	WRTS-I	R	BAY	
132	393	765	765 WARDHA - AURANGABAD(PG) II	11-Mar-17	9:00	11-Mar-17	18:00	Daily	for erection of 400 Wardha-A'bad Tower at Aurangabad	WRTS-I	WRTS-I	C	Line	
133	394	400	TIE WARDHA II AURANGABAD(MSETCL)1 (TIE-411) at Aurangabad	11-Mar-17	9:00	11-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay	
134	395	400	315MVA, ICT II at 400 R.S. Dhule	11-Mar-17	8:00	11-Mar-17	18:00	Daily	Maintenance work	MSETCL	MSETCL			
135	399	400	400 Khadka-Koradi Line	12-Mar-17	6:00	12-Mar-17	18:00	Daily	PID testing, Auto-reclose of the ckt will be made Off from both side of the ckt	MSETCL	MSETCL			
136	401	400	Main Bus-I & 404-Bay (Main Bay of 400 Thapti-Tanda ckt-1) @ Ektuni	12-Mar-17	10:00	12-Mar-17	18:00	Daily	Alignment of Isolators (404-89A)	MSETCL	MSETCL	kt 1 will be I/S via Tie Bay.		
137	403	400	400 BUS-2 at 400 RS Akola	12-Mar-17	10:00	12-Mar-17	17:00	Daily	Routine Maintenance ,Testing Work and new ICT Equipments erection & Jumpering works	MSETCL	MSETCL			
138	407	400	400 Bus # 2 at Wardha	13-Mar-17	9:00	13-Mar-17	18:00	Daily	AMP work at Wardha end	WRTS-I	WRTS-I	R	BUS	
139	410	400	400 Koyna Stage IV-Jejuri Line	13-Mar-17	10:00	13-Mar-17	18:00	Daily	Replacement of Normal Disc Insulators by Antifog Insulators Under LE Scheme MBR 92/8	MSETCL	MSETCL			
140	414	400	400 Bus # 2 at Wardha	13-Mar-17	9:00	14-Mar-17	18:00	Continuous	for extension of 400 Wardha-Aurangabad bays	WRTS-I	WRTS-I	C	BUS	
141	415	765	765 kv Bus Reactor Main and Tie Bay @ Tiroda Plant	13-Mar-17	9:00	13-Mar-17	20:00	Daily	Bus Reactor and Its Bay Equipment Testing and Maintenance. Bus Reactor already in out condition but equipment of main and tie bay need to be tested along with the reactors.	APML	APML			
142	416	400	400 Akola- Nandgaonpeth Line	13-Mar-17	12:00	15-Mar-17	18:00	Daily	PID testing of insulator strings by Hot line Unt Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL			
143	417	220	220 Pusad-Deoli (PGCL) Line	13-Mar-17	10:00	18-Mar-17	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
144	418	400/220	315MVA, ICT 1 @ Talandge	13-Mar-17	9:00	13-Mar-17	18:00	Daily	Annual Maintenance & Dignostic testing work	MSETCL	MSETCL			
145	419	400	400 NewKoyna-Stage 4 Koyna Ckt 2 @ NewKoyna	13-Mar-17	8:00	13-Mar-17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
146	422	400	Babhaleshwar-Ektuni-Ckt-1 @BBLR	14-Mar-17	9:00	14-Mar-17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
147	423	400	400 Bus # 1 at Wardha	14-Mar-17	9:00	15-Mar-17	18:00	Continuous	for extension of 400 Wardha-Aurangabad bays	WRTS-I	WRTS-I	C	BUS	

Sr.no.	492nd OCCM Sr.No.	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	Site	WRLDC Comments
				Date	Time	Date	Time							
148	425	400	400 Deepnagar-Thapti-Tanda Line	14-Mar-17	6:00	14-Mar-17	18:00	Daily	PID testing. Auto-reclose of the ckt will be made Off from both side of the ckt	MSETCL	MSETCL			
149	426	400	400 Deepnagar-Waluj Line	14-Mar-17	6:00	14-Mar-17	18:00	Daily	PID testing. Auto-reclose of the ckt will be made Off from both side of the ckt	MSETCL	MSETCL			
150	427	400	400 Koyna Stage IV-Jejuri Line	14-Mar-17	10:00	14-Mar-17	18:00	Daily	Replacement of Normal Disc Insulators by Antifog Insulators Under LE Scheme MBR 92/8	MSETCL	MSETCL			
151	434	765	Vadodara Dhule Line	14-Mar-17	10:00	14-Mar-17	18:00	Daily	For Bushing RTV Cotting	POWERGRID	WR-II	C	Vadodara	
152	435	400	400 Chandrapur-2 and B/R tie bay (408 bay) at Bhadrawati	14-Mar-17	9:00	17-Mar-17	18:00	Daily	ABB make CT Replacement by BHEL work under R&M	WRTS-I	WRTS-I	C	Bay	
153	436	765	SOLAPUR 765 BUS#1	14-Mar-17	9:00	14-Mar-17	18:00	DAILY	AMP WORKS	WRTS-I	WRTS-I	R	BUS	
154	438	765	765 WARDHA - AURANGABAD(PG) III	14-Mar-17	9:00	14-Mar-17	18:00	Daily	for erection of 400 Wardha-A'bad Tower at Aurangabad	WRTS-I	WRTS-I	C	Line	
155	444	400	400 Boisar-Vapi and Boisar-Padghe Simultaneously	15-Mar-17	9:00	16-Mar-17	18:00	Daily	Powerline crossing work of Aurangabad-Boisar line	POWERGRID	WR-II	C	Boisar	
156	445	400	400 Deepnagar-Khadka Ckt-I	15-Mar-17	6:00	16-Mar-17	18:00	Daily	PID testing. Auto-reclose of the ckt will be made Off from both side of the ckt	MSETCL	MSETCL			
157	446	400	400 Deepnagar-Khadka Ckt-II	15-Mar-17	6:00	16-Mar-17	18:00	Daily	PID testing. Auto-reclose of the ckt will be made Off from both side of the ckt	MSETCL	MSETCL			
158	448	400	Main Bus-1 & 401-Bay (Main Bay of 400 Thapti-Tanda ckt-2) @ Ektuni	15-Mar-17	10:00	15-Mar-17	18:00	Daily	Alignment of Isolators (401-89A)	MSETCL	MSETCL			
159	449	400	400 DHL- SSNNL Ckt-I alongwith Ckt-II in N/a mode	15-Mar-17	9:00	15-Mar-17	17:00	Daily	PMM work & PID testing.	MSETCL	SETCL/GETCO			
160	453	400	400 Boisar-Padghe	15-Mar-17	9:00	15-Mar-17	18:00	Daily	Powerline crossing work of Aurangabad-Boisar line	POWERGRID	WR-II	C	Boisar	
161	463	400	SWITCHABLE LR_400_WARDHA1_AURANGABAD	15-Mar-17	9:00	15-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	LR	
162	464	400	404 Bay (Main Bay of 400 Talegaon GIS Line # 1)	15-Mar-17	9:00	15-Mar-17	18:00	Daily	For AMP works - Telegaon	WRTS-I	WRTS-I	R	Bay	
163	466	765	765 WARDHA - AURANGABAD(PG) IV	15-Mar-17	9:00	15-Mar-17	18:00	Daily	for erection of 400 Wardha-A'bad Tower at Aurangabad	WRTS-I	WRTS-I	C	Line	
164	467	400	Talandge-Kolhapur PG Ckt-1 @ Talandge	15-Mar-17	9:00	15-Mar-17	18:00	Daily	Annual Maintenance & Dignostic testing work	MSETCL	MSETCL			
165	468	400	400 Parli -Lonikand Ckt-1 @ Parli	15-Mar-17	9:00	16-Mar-17	17:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL			
166	469	400	410 Main bay of HVDC Line-2 at Dhule	15-Mar-17	9:00	15-Mar-17	18:00	Daily	For AMP Works	BDTCL	BDTCL	R		
167	473	400	400KV SSNL-Dhule-2 along with Ckt-I in N/a mode	15-Mar-17	8:00	15-Mar-17	18:00	Daily	PMM work	PGCIL	GETCO			PID & Outage to be clubbed
168	LP-21	400	400KV S/C Bhilai-Koradi Line	15/Mar/17	8:00	15/Mar/17	18:00	Daily	Line Crossing by 765KV D/C Rajnandgaon- Warora dkt	PGCIL WR-I	RRWTPL	Construction		
169	479	400	AURANGABAD(MSETCL)1 (MAIN BAY-412) at Aurangabad	16-Mar-17	9:00	16-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay	
170	489	400	405 Bay (Tie Bay of 400 Talegaon GIS Line # 1 & ICT # 1) at Pune Telegaon	16-Mar-17	9:00	16-Mar-17	18:00	Daily	For AMP works - Telegaon	WRTS-I	WRTS-I	R	Bay	
171	491	765	ICT2 765/400 SOLAPUR	16-Mar-17	9:00	16-Mar-17	18:00	DAILY	COMMISSIONING OF OLTC PARALLEL OPERATION	WRTS-I	WRTS-I	R	ICT	
172	492	765	ICT1 765/400 SOLAPUR	16-Mar-17	9:00	16-Mar-17	18:00	DAILY	COMMISSIONING OF OLTC PARALLEL OPERATION	WRTS-I	WRTS-I	R	ICT	
173	493	400	400 Karad-Jaigad -2 @ Karad	16-Mar-17	10:00	16-Mar-17	17:00	Daily	Quarterly Maint. work	MSETCL	MSETCL			
174	494	400	Main Bus-1 @ BBLR	16-Mar-17	9:00	16-Mar-17	17:00	Daily	Maintenance work	MSETCL	MSETCL			
175	495	400/220	500MVA ICT-3 @ Nagothane	16-Mar-17	9:00	16-Mar-17	17:00	Daily	To carry out Bushing Tandelta and winding and CT Tandelta	MSETCL	MSETCL			
176	496	400	400 TBC @ Lonikand 1	16-Mar-17	9:00	16-Mar-17	15:00	Daily	Half yearly Bay maint.	MSETCL	MSETCL			
177	497	400	400 Koyna Stage IV-Jejuri Line	16-Mar-17	10:00	16-Mar-17	18:00	Daily	Replacement of Normal Disc Insulators by Antifog Insulators Under LE Scheme MBR 92/8	MSETCL	MSETCL			
178	498	400	411 Tie bay of HVDC Line-3/2 at Dhule	16-Mar-17	9:00	16-Mar-17	18:00	Daily	For AMP Works	BDTCL	BDTCL	R		
179	512	220	220 Main Bus-I of Boisar PG	17-Mar-17	9:00	17-Mar-17	18:00	Daily	AMP Work	POWERGRID	WR-II	R	Boisar	Maharashtra consent required
180	515	765	AURANGABAD(PG) DHULE MAIN BAY 704 at Aurangabad	17-Mar-17	9:00	17-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay	
181	526	400	400 Mapusa #2 - Kudgi#1 Tie bay (Bay No:402) at Kolhapur GIS	17-Mar-17	10:00	17-Mar-17	18:00	Daily	Timing and DCRM for 402 bay.	WRTML/ WRTS-I	WRTS-I	R	Bay	
182	527	400	400 Parli (PG)-2 Main Bay(412) at MSETCL Girawli	17-Mar-17	10:00	17-Mar-17	18:00	Daily	For Bay AMP works at MSETCL Girawli	WRTS-I	WRTS-I	R	Bay	Shall be availed on 21 march along with line
183	528	400	406 Bay (Main Bay of ICT # 1) at Pune Telegaon	17-Mar-17	9:00	17-Mar-17	18:00	Daily	For AMP works - Telegaon	WRTS-I	WRTS-I	R	Bay	
184	530	220	SOLAPUR 220 KUMBAHRI#1	17-Mar-17	9:00	17-Mar-17	18:00	DAILY	AMP WORKS	WRTS-I	WRTS-I	R	LINE	
185	531	765	765 KV 719 bay Wardha-Aurangabad# 3 Main bay at Wardha	17-Mar-17	9:00	17-Mar-17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	Bay	
186	532	400	400 Akola-Wardha Ckt-2 with Bay 411 & 412 at 400 RS Akola	17-Mar-17	10:00	17-Mar-17	17:00	Daily	Routine Maintenance & testing work of line and bays Equipments	MSETCL	MSETCL			D/C outage by PGCIL is laso required and planned for 16 and 17
187	533	400	Talandge-Kolhapur PG Ckt-2 @ Talandge	17-Mar-17	9:00	17-Mar-17	18:00	Daily	Annual Maintenance & Dignostic testing work	MSETCL	MSETCL			
188	534	400	Babhaleswar Padghe 2 @Padghe	17-Mar-17	8:00	17-Mar-17	18:00	Daily	Routine R&M work	MSETCL	MSETCL			
189	535	220	Aurangabad (PGCIL) Ckt -I @ 220 KV Shendra	17-Mar-17	10:00	17-Mar-17	13:00	Daily	Tan delta measurment, Routine mentenance , Relay testing	MSETCL	MSETCL			
190	536	220	Aurangabad (PGCIL) Ckt -II @ 220 KV Shendra	17-Mar-17	14:00	17-Mar-17	17:00	Daily	Tan delta measurment, Routine mentenance , Relay testing	MSETCL	MSETCL			
191	537	400	400/220 ICT - II at 400 Deepnagar	17-Mar-17	9:00	17-Mar-17	17:00	Daily	Diagnostic testing of ICT units and routine maintenance	MSETCL	MSETCL	-		
192	538	400	400 main Bus -1 @ Khadka	17-Mar-17	6:00	17-Mar-17	18:00	Daily	CVT Tan delta test CB DCRM Test	MSETCL	MSETCL			
193	539	400	412 Main bay of HVDC Line-3 at Dhule	17-Mar-17	9:00	17-Mar-17	18:00	Daily	For AMP Works	BDTCL	BDTCL	R		
194	548	400	400 Akola-Aurangabad Ckt-1 with Bay 403 & 404 at 400 RS Akola	18-Mar-17	10:00	18-Mar-17	17:00	Daily	Routine Maintenance & testing work of line and bays Equipments	MSETCL	MSETCL			
195	550	400	400 Akola-Aurangabad-II Main Bay 407 at Akola MSETCL	18-Mar-17	9:00	18-Mar-17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	Bay	Ckt-1 is planned by SLDC Maharashtra for 18th
196	551	400	400 Akola Aurangabad # 1	18-Mar-17	9:00	18-Mar-17	18:00	Daily	Line CT Tan delta measurement and Reactor AMP	WRTS-I	WRTS-I	R	Line	

Sr.no.	492nd OCCM Sr.No.	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	Site	WRLDC Comments
				Date	Time	Date	Time							
197	552	400	Chandrapur GCR - Parali Ckt III	18-Mar-17	8:00	18-Mar-17	18:00	Daily	Earth wire replacement work	MSETCL	/S Nimdeokar			
198	554	400	400 Warora ckt-II (Main Bay-425 & Tie Bay-426) @400 Chandrapur-II S/S	18-Mar-17	9:00	18-Mar-17	18:00	Daily	Diagnostic Testing & allied bay maintenance work	MSETCL	MSETCL			
199	556	220	220 Main Bus-II of Boisar PG	18-Mar-17	9:00	18-Mar-17	18:00	Daily	AMP Work	POWERGRID	WR-II	R	Boisar	Maharashtra consent required
200	561	400	ICT2 315MVA (Main Bay-404) at Aurangabad	18-Mar-17	9:00	18-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay	
201	563	220	201 Bay (220 Side of ICT # 1) at Telegaon	18-Mar-17	9:00	18-Mar-17	18:00	Daily	For AMP works - Telegaon . ICT will remain in service through TBC	WRTS-I	WRTS-I	R	Bay	
202	564	220	SOLAPUR 220 KUMBAHRI#2	18-Mar-17	9:00	18-Mar-17	18:00	DAILY	AMP WORKS	WRTS-I	WRTS-I	R	LINE	
203	565	400	TBC @ BBLR	18-Mar-17	9:00	18-Mar-17	17:00	Daily	Maintenance work	MSETCL	MSETCL	TBC is free		
204	566	400	400 Nagothane-Padghe-1 Line @Nagothane	18-Mar-17	9:00	18-Mar-17	17:00	Daily	Relay Testing work	MSETCL	MSETCL			
205	567	400	400 New Koyna -Stage 4 Koyna ckt 1@ NewKoyna	18-Mar-17	8:00	18-Mar-17	18:00	Daily	Routine Maintenance & Relay testing work	MSETCL	MSETCL			
206	568	400	400 main Bus -2 @ Khadka	18-Mar-17	6:00	18-Mar-17	18:00	Daily	CVT Tan delta test	MSETCL	MSETCL			
207	574	765	SOLAPUR 765 BUS#2	19-Mar-17	9:00	19-Mar-17	18:00	DAILY	AMP WORKS	WRTS-I	WRTS-I	R	BUS	
208	575	400	400 Akola Aurangabad # 2	19-Mar-17	9:00	19-Mar-17	18:00	Daily	Line CT Tan delta measurement and Reactor AMP	WRTS-I	WRTS-I	R	Line	
209	581	400	400 Koyna Stage IV-Jejuri Line	19-Mar-17	10:00	19-Mar-17	18:00	Daily	Replacement of Normal Disc Insulators by Antifog Insulators Under LE Scheme MBR 92/8	MSETCL	MSETCL			
210	584	400	Main Bus-II & 402 Bay (TIE Bay of Thapti-Tanda Ckt-II) @ Ektuni	20-Mar-17	10:00	20-Mar-17	18:00	Daily	Alignment of Isolators (402-89B)	MSETCL	MSETCL			
211	585	400	400 PARLI-PUNE(GIS)_2	20-Mar-17	9:00	20-Mar-17	17:00	Daily	Line / Bay AMP works Both line (400 AURANGABAD(MSETCL)-PUNE(GIS) I & 400 PARLI-PUNE(GIS)_2) is in MC. & other Ckt is in Non Auto mode	WRTS-I	RTS-I/MSET	R	Line	
212	587	220	220 Transfer Bus at Boisar	20-Mar-17	9:00	20-Mar-17	18:00	Daily	AMP Work	POWERGRID	WR-II	R	Boisar	
213	599	400	400 HVDC-2 & Cpur-1 Tie bay bay 405 Tie bay at Bhadrawati	20-Mar-17	9:00	22-Mar-17	18:00	Daily	BHEL CT Replacement By BHEL work under R&M	WRTS-I	WRTS-I	C	Bay	
214	601	400	ICT2 400/220 SOLAPUR	20-Mar-17	9:00	20-Mar-17	18:00	DAILY	AMP WORKS	WRTS-I	WRTS-I	R	ICT	
215	602	765	765 KV 718 bay Wardha-Durg # 1 Main bay at Wardha	20-Mar-17	9:00	20-Mar-17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	Bay	
216	603	400/11.5	Station Transformer-1 @Tiroda Plant	20-Mar-17	7:00	21-Mar-17	18:00	Daily	Station transformer and its bay connected Equipment Maintenance	APML	APML			
217	604	220	220 Pusad-Deoli (PGCIL) Line	20-Mar-17	10:00	25-Mar-17	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
218	605	400	400 Nagothane-Padghe-2 Line @Nagothane	20-Mar-17	9:00	20-Mar-17	17:00	Daily	Relay Testing work	MSETCL	MSETCL			
219	606	400	400 NewKoyna-Dabhol Ckt-1 @ NewKoyna	20-Mar-17	8:00	20-Mar-17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
220	607	400	Jaigad-Karad Ckt-1	20-Mar-17	8:00	20-Mar-17	18:00	Daily	Replacement of insulator string, Coldline washing & Maintenance work	JPTL	JPTL			
221	608	400	400 khadka-Akola ckt @ TBC at 400 khadka	20-Mar-17	8:00	20-Mar-17	17:00	Daily	CB DCRM	MSETCL	MSETCL			
222	LP-24	765	704 Main Bay of Aurangabad at BDTC, Dhule	20/Mar/17	8:00	21/Mar/17	18:00	Daily	AMP Works	BDTCL	BDTCL	R		
223	618	400	400 Parli-Parli ckt 2 @ Parli	21-Mar-17	9:00	21-Mar-17	18:00	Daily	Bay maintenance work	PGCIL	MSETCL/WR-I			
224	620	400	Chandrapur II - Nanded line	21-Mar-17	8:00	21-Mar-17	18:00	Daily	Earth wire replacement work	MSETCL	/S Nimdeokar			
225	623	400	AURANGABAD(PG) 400-BUS 2	21-Mar-17	9:00	21-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bus	
226	625	400	400 Koradi- Bhusawal Line	21-Mar-17	12:00	23-Mar-17	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL			
227	626	400	315MVA, 400/220/33kV ICT -1 at 400 RS Akola	21-Mar-17	9:00	21-Mar-17	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL			
228	627	400	400 DHL- BBLR Ckt-I & II	21-Mar-17	9:00	22-Mar-17	17:00	Daily	PID testing. Auto-reclose of the ckt will be made Off from both side of the ckt	MSETCL	MSETCL			
229	630	400	400 Boisar-Kala	21-Mar-17	9:00	22-Mar-17	18:00	Daily	To attend construction defect	POWERGRID	WR-II	R	Boisar	
230	637	400	AURANGABAD(MSETCL)2 (MAIN-409) at Aurangabad	21-Mar-17	9:00	21-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay	
231	639	400	SOLAPUR 412 MAIN BAY, 400 KARAD-SOLAPUR	21-Mar-17	9:00	21-Mar-17	18:00	DAILY	AMP WORKS AND SF6 LEAKAGE	WRTS-I	WRTS-I	R	BAY	
232	642	765	765 KV 714 bay Wardha-Aurangabad# 2 Tie bay at Wardha	21-Mar-17	9:00	21-Mar-17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	Bay	
233	643	400	BUS COULPER @ Talandge	21-Mar-17	9:00	21-Mar-17	18:00	Daily	Annual Maintenance & Dignostic testing work	MSETCL	MSETCL	-----		
234	644	400	Jaigad-Karad Ckt-1	21-Mar-17	8:00	21-Mar-17	18:00	Daily	Replacement of insulator string, Coldline washing & Maintenance work	JPTL	JPTL			
235	645	400	400 Parli -Lonikand-2 Ckt- II @ Parli	21-Mar-17	9:00	21-Mar-17	17:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL			
236	654	400	400 AURANGABAD(MSETCL)-PUNE(GIS) I	22-Mar-17	9:00	22-Mar-17	17:00	Daily	Line / Bay AMP works Both line (400 AURANGABAD(MSETCL)-PUNE(GIS) I & 400 PARLI-PUNE(GIS)_2) is in MC. & other Ckt is in Non Auto mode	WRTS-I	WRTS-I	R	Line	
237	655	400	Chandrapur GCR - Parali Ckt III	22-Mar-17	8:00	22-Mar-17	18:00	Daily	Earth wire replacement work	MSETCL	/S Nimdeokar			
238	665	400	TIE AURANGABAD(MSETCL)2 _JCT 3(FUTUTE) (MAIN-408) at Aurangabad	22-Mar-17	9:00	22-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay	
239	668	400	SOLAPUR 415 MAIN BAY, 400 KOLHAPUR-SOLAPUR#1	22-Mar-17	9:00	22-Mar-17	18:00	DAILY	AMP WORKS AND SF6 LEAKAGE	WRTS-I	WRTS-I	R	BAY	
240	672	765	765 KV 713 bay Wardha-Aurangabad# 2 Main bay at Wardha	22-Mar-17	9:00	22-Mar-17	18:00	Daily	AMP work	WRTS-I	WRTS-I	R	Bay	
241	673	400	400 Akola-Nandagaon Ckt with Bay 412 & 413 at 400 RS Akola	22-Mar-17	10:00	22-Mar-17	17:00	Daily	Routine Maintenance & testing work of line and bays Equipments	MSETCL	MSETCL			
242	674	400	400 NewKoyna-Dabhol Ckt-2 @ NewKoyna	22-Mar-17	8:00	22-Mar-17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
243	675	400	Tie Bay-429 only (400 Warora ckt-I) @400 Chandrapur-II S/S	22-Mar-17	9:00	22-Mar-17	18:00	Daily	Diagnostic Testing & allied bay maintenance work	MSETCL	MSETCL			
244	676	400	Jaigad-Karad Ckt-2	22-Mar-17	8:00	22-Mar-17	18:00	Daily	Replacement of insulator string, Coldline washing & Maintenance work	JPTL	JPTL			

Sr.no.	492nd OCCM Sr.No.	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	Site	WRLDC Comments
				Date	Time	Date	Time							
245	677	400	400 khadka-koradi ckt@ TBC at 400 khadka	22-Mar-17	8:00	22-Mar-17	17:00	Daily	CB DCRM	MSETCL	MSETCL			
246	LP-27	765	706 Main Bay of ICT-2 at BDTCL, Dhule	22/Mar/17	8:00	23/Mar/17	18:00	Daily	AMP Works	BDTCL	BDTCL	R		
247	685	400	400 Parli (PG)-1 Main Bay(411) at MSETCL Girawli	23-Mar-17	10:00	23-Mar-17	18:00	Daily	For Bay AMP works at MSETCL Girawli	WRTS-I	WRTS-I	R	Bay	
248	686	400	400 Parli -Solapur bay @ Parli	23-Mar-17	9:00	23-Mar-17	18:00	Daily	Bay maintenance work	MSETCL	MSETCL			Line shall be in service with TBC bay
249	687	400	400 Nanded-Parali @ Parli	23-Mar-17	9:00	23-Mar-17	17:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL			
250	690	400	400 Boisar-Magarwada	23-Mar-17	9:00	24-Mar-17	18:00	Daily	To attend construction defect	POWERGRID	WR-II	R	Boisar	
251	698	400	SOLAPUR_ 407 MAIN BAY_ 400 ICT#2	23-Mar-17	9:00	23-Mar-17	18:00	DAILY	AMP WORKS AND SF6 LEAKAGE	WRTS-I	WRTS-I	R	BAY	
252	700	400	400 TBC @ Karad	23-Mar-17	10:00	23-Mar-17	17:00	Daily	Quarterly. Maint. work	MSETCL	MSETCL			
253	701	400	400 Main Bus No. - I(402,403,406,411,414,417&420) @Warora	23-Mar-17	10:00	23-Mar-17	17:00	Daily	Bay maintenance & diagnostic testing related work will be carried	MSETCL	MSETCL			
254	702	400	80MVAR BUS REACTOR @ Talandge	23-Mar-17	9:00	23-Mar-17	18:00	Daily	Annual Maintenance & Dignostic testing work	MSETCL	MSETCL	-----		
255	703	400	Jaigad-Karad Ckt-2	23-Mar-17	8:00	23-Mar-17	18:00	Daily	Replacement of insulator string, Coldline washing & Maintenance work	JPTL	JPTL			
256	704	400/220	404-Bay Main Bay & 403 TIE Bay 501MVA ICT-1 Kumbharghaon	23-Mar-17	11:00	23-Mar-17	17:00	Daily	Routine Maintenance & Dignostic testing work.	MSETCL	MSETCL			Load Management plan shall be furnished by Maharashtra
257	705	400	400 Koyna Stage IV-Jejuri Line	23-Mar-17	10:00	23-Mar-17	18:00	Daily	Replacement of Normal Disc Insulators by Antifog Insulators Under LE Scheme MBR 92/8	MSETCL	MSETCL			
258	710	400	Chandrapur GCR - Parali Ckt III	24-Mar-17	8:00	24-Mar-17	18:00	Daily	Earth wire replacement work	MSETCL	/S Nimdeokar			
259	719	220	ICT1_315MVA (Bay-201) at Aurangabad	24-Mar-17	9:00	24-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bay	ICT sahl be in service with TBC bay
260	720	765	SWITCHABLE LR_765_AURANGABAD_1_SOLAPUR	24-Mar-17	9:00	24-Mar-17	18:00	DAILY	AMP WORKS	WRTS-I	WRTS-I	R	LR	
261	723	400	400 Bhadravati-Parli # 1 along with A/r in N/a of Dhariwal Parli	24-Mar-17	9:00	24-Mar-17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for Ckt-II will be required during above period	WRTS-I	WRTS-I	R	Line	
262	724	400	400 Akola- Bhusawal Line along with bays at Akola	24-Mar-17	10:00	24-Mar-17	17:00	Daily	Routine Maintenance & testing work of line and bays Equipments	MSETCL	MSETCL			
263	725	400	Babhaleshwar-Ektuni-Ckt-2 @BBLR	24-Mar-17	9:00	24-Mar-17	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
264	726	400	Jaigad-Newkoyna Ckt-1	24-Mar-17	8:00	24-Mar-17	18:00	Daily	Replacement of insulator string, Coldline washing & Maintenance work	JPTL	JPTL			
265	727	400	Babhaleshwar Padghe 1 @Padghe	24-Mar-17	8:00	24-Mar-17	18:00	Daily	Routine R&M work	MSETCL	MSETCL			
266	728	400	400/11kV STN-4B at 400 Deepnagar	24-Mar-17	9:00	24-Mar-17	17:00	Daily	Bay routine maintenance	MSETCL	MSETCL	-		
267	729	400	400 khadka-Aurangabad ckt @ TBC at 400 khadka	24-Mar-17	8:00	24-Mar-17	17:00	Daily	CB DCRM	MSETCL	MSETCL			
268	LP-29	765	705 Tie Bay of Aurangabad & ICT-2 at BDTCL, Dhule	24/Mar/17	8:00	24/Mar/17	18:00	Daily	AMP Works	BDTCL	BDTCL	R		
269	733	400	400 Chandrapur 2 - Nanded@ Nanded	25-Mar-17	9:00	25-Mar-17	17:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL			
270	741	400	400 Kalwa-Padghe Line 1	25-Mar-17	9:00	25-Mar-17	18:00	Daily	Replacement of faulty insulator and AMC work	MSETCL				
271	742	400	Jaigad-Newkoyna Ckt-2	25-Mar-17	8:00	25-Mar-17	18:00	Daily	Replacement of insulator string, Coldline washing & Maintenance work	JPTL	JPTL			
272	743	400/132	200 MVA ICT-1 @ 400 side TBC at 400 khadka	25-Mar-17	8:00	25-Mar-17	17:00	Daily	CB DCRM	MSETCL	MSETCL			
273	748	400	400 DHARIWAL TPP-PARLI II	26-Mar-17	9:00	27-Mar-17	18:00	DAILY	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for Ckt-I will be required during above period	WRTS-I	WRTS-I	R	LINE	
274	753	400/220	500MVA ICT-3 @Nagothane	26-Mar-17	9:00	26-Mar-17	17:00	Daily	Relay Testing work	MSETCL	MSETCL			
275	754	400	400 Koyna Stage IV-Jejuri Line	26-Mar-17	10:00	26-Mar-17	18:00	Daily	Replacement of Normal Disc Insulators by Antifog Insulators Under LE Scheme MBR 92/8	MSETCL	MSETCL			
276	763	765	SOLAPUR_ 707_ MAIN BAY_ AURANGABAD#1	27-Mar-17	9:00	27-Mar-17	18:00	DAILY	AMP WORKS	WRTS-I	WRTS-I	R	BAY	
277	766	400	400 BUS-1 at 400 RS Akola	27-Mar-17	10:00	27-Mar-17	17:00	Daily	Routine Maintenance and Testing Work	MSETCL	MSETCL	5-2 will be in service		
278	767	220	220 Pusad-Deoli (PGCIL) Line	27-Mar-17	10:00	31-Mar-17	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
279	768	400	315MVA 400/220 KV ICT-1 @ NewKoyna	27-Mar-17	8:00	27-Mar-17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
280	769	400/132	200 MVA ICT-2 @ 400 side TBC at 400 khadka	27-Mar-17	8:00	27-Mar-17	17:00	Daily	CB DCRM	MSETCL	MSETCL			
281	770	400	400 DHL- BBLR Ckt-I & II	27-Mar-17	9:00	27-Mar-17	17:00	Daily	PID testing. Auto-reclose of the ckt will be made Off from both side of the ckt	MSETCL	MSETCL			
282	774	400	400 Bhadravati-Parli # 1	28-Mar-17	9:00	28-Mar-17	18:00	Daily	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for Ckt-II will be required during above period	WRTS-I	WRTS-I	R	Line	
283	779	765	AURANGABAD(PG)_ 765-BUS_1	28-Mar-17	9:00	28-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bus	
284	781	400	SWITCHABLE LR_400_KARAD_SOLAPUR	28-Mar-17	7:00	28-Mar-17	16:00	DAILY	COLLECTION OF OIL SAMPLE FROM RPH BUSHING AND TESTING OF BUSHING	WRTS-I	WRTS-I	R	LR	
285	782	765	KORBA# Tie Bay 717 at Bilaspur PS	28-Mar-17	9:00	28-Mar-17	18:00	Daily	CB CRM AMP work	WRTS-I	WRTS-I	R	Bay	
286	783	400	80MVAR BUS Reactor (400 BUS REACTOR) @Nagothane	28-Mar-17	9:00	28-Mar-17	17:00	Daily	To carry out Bushing Tandelta and winding and CT Tandelta & Relay Testing	MSETCL	MSETCL			
287	791	400	Chandrapur GCR - Parali Ckt III	29-Mar-17	8:00	30-Mar-17	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
288	799	400	400 DHARIWAL TPP-PARLI II	29-Mar-17	8:00	29-Mar-17	18:00	DAILY	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for Ckt-I will be required during above period	WRTS-I	WRTS-I	R	LINE	
289	800	765	SOLAPUR_ 708_ MAIN BAY_ AURANGABAD#1	29-Mar-17	9:00	29-Mar-17	11:00	DAILY	COLLECTION OF CT OIL SAMPLES	WRTS-I	WRTS-I	R	BAY	

Sr.no.	492nd OCCM Sr.No.	KV	Line / Element	From		To		Basis	Reason	System	Agency	Type	Site	WRLDC Comments
				Date	Time	Date	Time							
290	801	400	400 Main bay 408 of 400 Akola-Wardha Ckt-1 at 400 RS Akola	29-Mar-17	10:00	29-Mar-17	17:00	Daily	Routine Maintenance and Testing Work	MSETCL	MSETCL			
291	802	400	400 Main Bus-II @Solapur	29-Mar-17	10:00	29-Mar-17	18:00	Daily	Maintenance of bays equipment	MSETCL	MSETCL			
292	803	400	315MVA 400/220 KV ICT-2 @ NewKoyana	29-Mar-17	8:00	29-Mar-17	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL			
293	804	400	Tie Bay-408 only (400 Dhariwal ckt-I & 400 GCR ckt-II) @400 Chandrapur-II S/S	29-Mar-17	9:00	29-Mar-17	18:00	Daily	Diagnostic Testing & allied bay maintenance work	MSETCL	MSETCL			
294	805	400	400 DHL- BBLLR Ckt-I & II	29-Mar-17	9:00	29-Mar-17	17:00	Daily	PID testing. Auto-reclose of the ckt will be made Off from both side of the ckt	MSETCL	MSETCL			
295	812	765	AURANGABAD(PG). 765-BUS_2	30-Mar-17	9:00	30-Mar-17	18:00	Daily	For AMP Works at Aurangabad	WRTS-I	WRTS-I	R	Bus	
296	814	765	SOLAPUR_710_MAIN BAY_AURANGABAD#2	30-Mar-17	11:30	30-Mar-17	13:00	DAILY	COLLECTION OF CT OIL SAMPLES	WRTS-I	WRTS-I	R	BAY	
297	815	400	ICT3_400/220_SOLAPUR	30-Mar-17	9:00	30-Mar-17	18:00	DAILY	CSD COMMISSIONING	WRTS-I	WRTS-I	R	ICT	
298	818	400	TBC @ Talandge	30-Mar-17	9:00	30-Mar-17	18:00	Daily	Annual Maintenance & Dignostic testing work	MSETCL	MSETCL	----		
299	819	400/220	400/220/33KV.500MVA ICT-3 @Parli	30-Mar-17	9:00	30-Mar-17	18:00	Daily	Bay maintenance work	MSETCL	MSETCL			
300	820	400	400 Koyana Stage IV-Jejuri Line	30-Mar-17	10:00	30-Mar-17	18:00	Daily	Replacement of Normal Disc Insulators by Antifog Insulators Under LE Scheme MBR 92/8	MSETCL	MSETCL			
301	821	400	400 Bus Reactor@ Khadka	30-Mar-17	8:00	30-Mar-17	17:00	Daily	Winding & Bushing Tandelta test	MSETCL	MSETCL			
302	827	400	400 DHARIWAL TPP-PARLI II	31-Mar-17	8:00	31-Mar-17	18:00	DAILY	Replacement of Conventional Insulators with Polymer insulators in major crossings line Power, River, N.H., S.H., Railway Crossings for public safety. AR in Non Auto Mode for Ckt-I will be required during above period	WRTS-I	WRTS-I	R	LINE	
303	828	400	400/11KV STN-4A at 400 Deepnagar	31-Mar-17	9:00	31-Mar-17	17:00	Daily	Bay routine maintenance	MSETCL	MSETCL	-		