

Outage planning of transmission elements for the month of March 2018														
504th OCCM SR.No.	Sr. No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments	
				Date	Time	Date	Time							
1	9	400	400KOYNA ST IV Line AT 400JEJURI	01/Mar/18	9:30	01/Mar/18	17:30	Daily	Annual Maint & testing of bays equipment	MSETCL	MSETCL	400Jejuri-Lonikand line will be in service.		
2	18	220	Deoli (PGCIL) - Pusad line	01/Mar/18	7:00	05/Mar/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
3	19	400	400 Kalwa-Padgha Line-2	01/Mar/18	9:00	06/Mar/18	18:00	Daily	PID Testing work of 400Kalwa-Padgha line-2 Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL			
4	23	400	400 New Koyna- Karad Ckt I&II	01/Mar/18	7:00	31/Mar/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL			
5	24	400	400 Jejuri - Lonikand	01/Mar/18	7:00	31/Mar/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL			
6	25	400	400 Warora -Chandrapur I& II	01/Mar/18	7:00	31/Mar/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off		
7	26	400	400 Koradi-1 -Khaperkheda I & II	01/Mar/18	7:00	31/Mar/18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off		
8	34	220	220 Chittegaon - Chittepimpalgaon Ckt.-I @ Chittegaon.	02/Mar/18	9:00	02/Mar/18	18:00	Daily	Routine Maintenance & Isolator alignment work	MSETCL	MSETCL			
9	36	400	400 KORADI (IEPL)-WAROA-II & 400 WARDHA-WARORA I	02/Mar/18	7:00	03/Mar/18	18:00	Continuous	Power Line Crossing of 765 D/C Warora-Parli TL (Part-I)	IEPL&MSETCL	WRTS-I	SLDC Maharashtra consent required.	Name of line to be confirmed.Feasibility based on Koradi -2 Generation	
10	43	400	Bay No-407 Main Bay of 400 Paghe-boisar Line at Boisar	03/Mar/18	9:00	03/Mar/18	18:00	Daily	For CB Compress Base plate and Cover Replacement	POWERGRID	WR-II	Line to be in service with Tie bay.		
11	49	400	400 WARORA-WARDHA Ckt	03/Mar/18	9:00	03/Mar/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Preponed and clubbed with other utility request		
12	52	400	400 Bus-I at Boisar	04/Mar/18	9:00	04/Mar/18	18:00	Daily	AMP	POWERGRID	WR-II	All elements to be in service with Bus-2. SLDC Maharashtra to be informed.	To be availed on Sunday	
13	54	400	400 Kalwa-Padgha Line-2	04/Mar/18	8:00	04/Mar/18	18:00	Daily	Insulator Replacement work	MSETCL	MSETCL	Koyna / Ghatghar Max generation to be available		
14	60	400	400Bus-II at Parli	05/Mar/18	8:00	05/Mar/18	18:00	Daily	For Construction works	WRTS-I	WRTS-I			
15	74	400	400 Akola Main bay (419) at Wardha	05/Mar/18	9:00	05/Mar/18	18:00	Daily	Amp work related to bay	WRTS-I	WRTS-I	Line to be in service with Tie bay		
16	76	400	400 Bus-II at Boisar	05/Mar/18	9:00	05/Mar/18	18:00	Daily	AMP	POWERGRID	WR-II		Monday . to be availed on Sunday.	
17	79	400	417 Bay (Main bay of Yelwan Ckt-2) at 400Akola MSETCL	05/Mar/18	10:00	05/Mar/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL			
18	81	220	Bhugaon - PGCIL line	05/Mar/18	10:00AM	05/Mar/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	Load to be managed by SLDC Maharashtra in case of contingency		
19	82	765	709LR- Akola Line 1 Reactor at Koradi-III SS (Switchable)	05/Mar/18	8:00	05/Mar/18	18:00	Daily	For Maintenance of Line Reactor and related equipments	MEGPTCL	MEGPTCL	if voltage is less than 775kV/ NLDC consent required		
20	84	400	400Khadka-Akola	05/Mar/18	6:00	06/Mar/18	18:00	Daily	PID Testing .	MSETCL	MSETCL	Non Autoreclosure		
21	92	400	400 Dhule-SSNNL Ckt-I @ 400 R.S. Dhule	05/Mar/18	6:00	09/Mar/18	18:00	Daily	String replacement work & Routine Maintenance work	MSETCL	MSETCL	Non Autoreclosure of ckt. II		
22	98	400	400 Bhabaleshwar ckt-I @Ektuni	06/Mar/18	10:00	06/Mar/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	Chandrapur-Padghe-HVDC Bipole to be in service with Full transfer capacity.		
23	99	400	400 PARLI-SOLAPUR I & II	06/Mar/18	7:00	07/Mar/18	18:00	Continuous	Power Line Crossing of 765 D/C Warora-Parli TL Part-III.	Reliance	WRTS-I		To be availed on Wednesday and	
24	100	400	400 WARDHA-MAUDA I & II	06/Mar/18	7:00	07/Mar/18	18:00	Continuous	Power Line Crossing of 765 D/C Gadawara - Warora Tr. Line between Tower No. 152/0 & 153/0 (Existing 400 D/C PGCIL Line Tower Nos. 209 & 210)	WRTS-I	WRTS-I	400KV Mouda-Betul-D/C to be in service with complete dia at both ends with AR enabled. SPS at Mouda to be in service/ Subject to Mouda generation		
25	111	220	220Bus # 1 at Talegaon	06/Mar/18	9:00	06/Mar/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	All elements to be in service with Bus-2. load to be managed by SLDC Maharashtra in case of contingency	Tuesday . To be availed on Thursday .	
26	118	220	Deoli (PGCIL) - Pusad line	06/Mar/18	10:00	06/Mar/18	12:00	Daily	For Diagnostic Work i.e. Line Signature Analysis.	MSETCL	MSETCL			
27	122	400	Ektuni- Babhaleshwar-I	06/Mar/18	12:00	06/Mar/18	15:00	Daily	For carrying out Line signature analysis test	MSETCL	MSETCL			
28	123	400	400 CHD-PGCIL Bhadravati Ckt. No.- II @ 400 S/S Chandrapur	06/Mar/18	8:00	06/Mar/18	18:00	Daily	For isolator maintenance & Alignment works.	MSETCL	MSETCL			
29	124	220	Bugaon - PGCIL line	06/Mar/18	10.00AM	06/Mar/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL			
30	127	400	Jaigad-Newkoyna Ckt- 1 & 2	06/Mar/18	9:00	08/Mar/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL			
31	128	400	428- Bay (Tie Bay of Warora- Wardha ckt at PGCIL Deoli S/Stn)	06/Mar/18	9:00	10/Mar/18	17:00	Continuous	Routine Maintenance & Dignostic testing work, 428 CB Wiring work	MSETCL	MSETCL	Line to be in service with Main bay.		
32	131	400	Babhaleshwar-Ektuni-Ckt-1 @BBLR	06/Mar/18	9:00	06/Mar/18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG Isolators work	MSETCL	MSETCL	Preponed and clubbed with another outage proposal		
33	139	220	Deoli (PGCIL) - Pusad line	07/Mar/18	7:00	31/Mar/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL			
34	143	765	Tie Bay (711) of Tiroda Line 1 and Akola Line 2 at Koradi III SS	07/Mar/18	8:00	07/Mar/18	18:00	Daily	For Maintenance of Bay Equipments	MEGPTCL	MEGPTCL	NLDC Consent required		
35	144	400	Babhaleshwar-Aurangabad - @BBLR	07/Mar/18	9:00	07/Mar/18	9:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG Isolators work	MSETCL	MSETCL	400Bhusawal,Dhule-Ckt-1&2 Ektuni- ckt-2 will be in service		
36	146	220	Kalmeshwar - Pandhurna	07/Mar/18	9:00	07/Mar/18	17:00	Daily	Routine maintenance work	MSETCL	MSETCL	SLDC MP to be informed		
37	151	400	400 MAIN BUS II @ ALKUD	07/Mar/18	9:00	07/Mar/18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	All elements to be in service with Bus-1.		
38	153	400	418 Bay (Tie Bay of Yelwan Ckt-2) at 400Akola MSETCL	07/Mar/18	10:00	07/Mar/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	Line to be in service with Main bay.		
39	158	220	PGCIL - PUSAD LINE	07/Mar/18	10:00	07/Mar/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL			
40	159	220	PGCIL Deoli-Badnera Ckt @Badnera	07/Mar/18	8:00	08/Mar/18	17:00:00PM	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL			
41	164	400	400 Kalwa-Padgha Line-1	07/Mar/18	9:00	10/Mar/18	18:00	Daily	PID Testing work of 400Kalwa-Padgha line-1 Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL			
42	173	220	220Bus # 2 at Talegaon	08/Mar/18	9:00	08/Mar/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	All elements to be in service with Bus-1. SLDC Maharashtra to be informed.	Wednesday . To be availed on Thursday .	
43	176	765	765 TIE-I (702) Bay of 765 Ektuni-Akola Ckt-II @Ektuni	08/Mar/18	10:00	08/Mar/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	NLDC Consent required		

504th OCCM SR.No.	Sr. No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
44	180	400	Lonikand-Jejuri Line	08/Mar/18	8:00	08/Mar/18	18:00	Daily	Routine Sustaion; Line Maintenance & Dignostic testing work	MSETCL	MSETCL		
45	188	400	LONIKAND Line @ 400IEJURI	08/Mar/18	9:30	08/Mar/18	17:30	Daily	Annual Maint & testing of bays equipment	MSETCL	MSETCL	400Jejuri-Koyna st IV line will be in service.	
46	193	220	PGCIL - PUSAD LINE	08/Mar/18	10:00	08/Mar/18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL		
47	197	400	Dhariwal - Chandrapur-II 400Tr. Line Ckt-I	08/Mar/18	8:00	08/Mar/18	18:00:00	Daily	Outage for fixing of line Spacer cum Damper, Suspension Pilot clamp and Jumper Pad n&bs tightening works.	MSETCL	DIL		
48	200	400	400Akola- Bhusawal Line at 400Akola MSETCL	08/Mar/18	12:00	10/Mar/18	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400Koradi- Bhusawal, 400Akola- Nandgaonpeth & 400Koradi- Nandgaonpeth are in service. 765 Ektuni-Akola Ckt-I will be in service through Main (706) Bay & Main Bus-II	
49	213	765	765 TIE-II (705) Bay of 765 Ektuni-Akola Ckt-I @ Ektuni	09/Mar/18	10:00	09/Mar/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL		
50	214	400	Koyna Stage IV-Jejuri	09/Mar/18	10:00	09/Mar/18	18:00	Daily	Cold washing of Insulators	MSETCL	MSETCL	Koyna Stage IV-Lonikand will be in service	
51	216	400	400 Main- Bus - 1 at 400 Koradi s/s	09/Mar/18	6:00	09/Mar/18	18:00	Daily	Bus outage on bus 1. All feeder to be shifted on Bus-2 (06:00 HRS TO 18:00Hrs) Routine Maintenance & 400 CVT Dignostic testing work	MSETCL	MSETCL		
52	217	400	400 125 MVAR Bus Reactor (Bay No. 402 & TIE Bay no 403)@ Warora	09/Mar/18	8:00	09/Mar/18	17:00	Daily	Routine maintenance and diagonastic testing such as CT tandelta,CRM,IR values,isolater maintainance work and DCRM	MSETCL	MSETCL	If voltage is less than 415kV	
53	223	220	Mudshingi -Chikodi @ Mudshingi	09/Mar/18	9:00	09/Mar/18	17:00	Daily	Routine R&M work	MSETCL	MSETCL	NLDC Consent required	
54	224	220	220 Mapusa-Amona line	09/Mar/18	9:00	09/Mar/18	17:30	Daily	For AMP works for line side equipment.	WRTS-I	WRTS-I	SLDC Goa to be informed / All Maharashtra to Goa lines to be inservice	
55	229	400	Bhusawal Ckt with Bay 409 & 410 at 400Akola MSETCL	09/Mar/18	9:00	09/Mar/18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
56	230	220	400/220ICT-1 220side Main bay (201) at Talegaon	09/Mar/18	9:30	09/Mar/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	ICT-1 to be inservice with TBC bay.	
57	233	400	400 Kolhapur (MSETCL)-II Main bay (410) At Kolhapur-GIS	09/Mar/18	10:00	09/Mar/18	18:00	Daily	For bay AMP works.	WRTS-I	WRTS-I		
58	237	132	132 kV Nepanagar-Dharni Line@Dharni	09/Mar/18	10:00	09/Mar/18	15:00:00PM	Daily	For Routine maintenance and Diagnostic Testing	MSETCL	MSETCL	SLDC MP to be informed	
59	238	400	Dhariwal - Chandrapur-II 400Tr. Line Ckt-II	09/Mar/18	8:00	09/Mar/18	18:00:00	Daily	Outage for fixing of line Spacer cum Damper, Suspension Pilot clamps and Jumper Pads n&bs tightening works.	MSETCL	DIL		
60	239	400	Jaigad-Karad Ckt - 1 & 2	09/Mar/18	9:00	10/Mar/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL		
61	241	400	SSP - Dhule - 1	09/Mar/18	8:00	09/Mar/18	18:00	Daily	Line Protection audit & PM work.	SSP	NCA	Preponed and clubbed with another utility request	
62	243	500	500KV HVDC CHANDRAPUR-PADGHE TL	10/Mar/18	7:00	11/Mar/18	18:00	Continuous	Power Line Crossing of 765 D/C Warora-Parli TL (Part-I)	MSETCL	WRTS-I	SLDC Maharashtra consent required.	High Demand .2 days outage .Suggested by hot line
63	245	400	LAMBOTI -PARALI@LAMBOTI	10/Mar/18	8:00	10/Mar/18	17:00	Daily	SERVICING AND OVERHAULING OF ISOLATORS AT LAMBOTI	MSETCL	MSETCL		
64	250	400	400PADGHE-KUDUS I	10/Mar/18	8:00	10/Mar/18	17:00	Daily	For Attending Minor Line Construction Defects/Punch Points.	WRTS-I	WRTS-I		
65	251	400	400 Padghe-1 BAY(415) & TIE BAY(414) AT MSETCL KUDUS	10/Mar/18	8:00	10/Mar/18	17:00	Daily	Line outage availing on same day, Bays outage also required for attending minor bay Issues and Breaker Issues at Kudus (MSETCL).	WRTS-I	WRTS-I		
66	256	400	Parli - Solapur S/C line@ Girwali	10/Mar/18	11:00	10/Mar/18	18:00	Daily	Hardware tightening and fixing work	MSETCL	MSETCL		
67	267	400	400 Bhilal Main bay at Koradi	10/Mar/18	9:00	10/Mar/18	18:00	Daily	Amp work related to bay	WRTS-I	WRTS-I		
68	270	220	220Talegaon MSETCL Line-1 main bay (202) at Talegaon	10/Mar/18	9:30	10/Mar/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	Line to be inservice with TBC bay	
69	273	400	Talegaon-Kalwa Line	10/Mar/18	8:00:00AM	10/Mar/18	18:00	Daily	Routine Line Maintenance work	MSETCL	MSETCL		
70	274	765	765 Bus 2 at Koradi III SS	10/Mar/18	8:00	10/Mar/18	18:00	Daily	For Maintenance of Bus Equipments	MEGPTCL	MEGPTCL	NLDC Consent required / SPS at tiroda / koradi to be inservice	Based on Generation at Tirora
71	291	400	LAMBOTI -PGCIL @LAMBOTI	11/Mar/18	8:00	11/Mar/18	17:00	Daily	SERVICING AND OVERHAULING OF ISOLATORS AT LAMBOTI	MSETCL	MSETCL		
72	293	400	Koyna Stage IV-Jejuri	11/Mar/18	10:00	11/Mar/18	18:00	Daily	Cold washing of Insulators	MSETCL	MSETCL		
73	295	220	220Boisar-Boisar-III Line at Boisar (PGCIL)	11/Mar/18	9:00	11/Mar/18	17:00	Daily	Line Equipment AMP	POWERGRID	WR-II		Monday - To be availed on Sunday.
74	305	400	400 Bus-I at Solapur	12/Mar/18	9:00	14/Mar/18	18:00	Daily	STACOM BAY COMMISSIONING WORKS	WRTS-I	WRTS-I		
75	306	400	Babhaleswar-Padghe -Ckt-2 @BBLR	12/Mar/18	9:00	12/Mar/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	Chandrapur-Padghe-HVDC Bipole to be inservice with Full transfer capacity / Koyna max gen to be available.	
76	310	400	402-Bay (Main Bay of 400 Nanded-Chandrapur ckt-2) at 400 Nanded.	12/Mar/18	11:00	12/Mar/18	18:00	Daily	Line CVT Tan-D Measurement & Bay Equipment Maint.	MSETCL	MSETCL		
77	317	400	ICT2_400/200kv_AURANGABAD	12/Mar/18	9:00	12/Mar/18	18:00	Daily	for providing insulation sleeves on 33kV tertiary	WRTS-I	WRTS-I	SLDC Maharashtra to be informed. Load to be managed by SLDC Maharashtra in case of contingnecy.	
78	322	400	Main Bay (412) of400 Line-1 of Koradi II - Kordai III at Koradi III Sub Station.	12/Mar/18	9:00	12/Mar/18	18:00	Daily	For Maintenance of Bay Equipments	MEGPTCL	MEGPTCL		
79	323	765	ICT1_765/400_PADGHE	12/Mar/18	9:30	12/Mar/18	16:00	Daily	For CSD Commissioning.	WRTS-I	WRTS-I		
80	324	220	400/220ICT-2 220side Main bay (205) at Talegaon	12/Mar/18	9:30	12/Mar/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	ICT to be inservice with TBC bay	
81	332	400	400Khadka-Koradi	12/Mar/18	6:00	13/Mar/18	18:00	Daily	PID Testing .	MSETCL	MSETCL	Non Autoreclosure	
82	334	400	(1) 400 Kalwa-Talegaon Line, (2) 400 Talegaon-Kharghar Line	12/Mar/18	9:00	15/Mar/18	18:00	Daily	PID Testing work of 400Kalwa-Talegaon & 400 Talegaon-Kharghar (D/C) line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL		
83	335	400	400 Dhule-SSNNL Ckt-II @ 400 R.S. Dhule	12/Mar/18	6:00	16/Mar/18	18:00	Daily	String replacement work & Routine Maintenance work	MSETCL	MSETCL	Non Autoreclosure Of ckt. I	
84	347	400	403-Bay (Tie bay of Chandrapur ckt-2 & ICT-1) at 400 Nanded	13/Mar/18	11:00	13/Mar/18	18:00	Daily	Quarterly Maintenance of bays equipment	MSETCL	MSETCL		
85	348	400	400PADGHE-KUDUS II	13/Mar/18	8:00	13/Mar/18	17:00	Daily	For Attending Minor Line Construction Defects/Punch Points.	WRTS-I	WRTS-I		

504th OCCM SR.No.	Sr. No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
86	349	400	400 PADGHE-2 BAY(418) & TIE BAY(417) AT MSETCL KUDUS	13/Mar/18	8:00	13/Mar/18	17:00	Daily	Line outage availing on same day, Bays outage also required for attending minor bay issues and Breaker issues at Kudus (MSETCL).	WRTS-I	WRTS-I		
87	350	765	765 Bus 1 at Tiroda SS	13/Mar/18	9:00	13/Mar/18	21:00	Daily	Bus & Bus Connected equipment maintenance	APML	APML	SPS at Tiroda to be inservice / NLDC Consent required	Based on Generation at Tirora
88	361	220	220Talegaon MSETCL Line-2 Main bay (207) at Talegaon	13/Mar/18	9:30	13/Mar/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I	Line to be inservice with TBC bay	
89	378	765	ICT 1_765/400_PUNE(GIS)	14/Mar/18	9:00	14/Mar/18	18:00	Daily	For Bay extension works- erection of Spare transformer bus module	WRTS-I	WRTS-I	NLDC Consent required	
90	379	400	Dhariwal- Parli 400Tr. Line	14/Mar/18	8:00	14/Mar/18	18:00:00	Daily	Outage for fixing of line Spacer cum Damper, Suspension Pilot clamp and Jumper Pad n&bs tightening works.	WRTS-I	DIL	Dhariwal shall not bid in PX	
91	382	400	400 Girwali-Lonikand ckt 2 @ Girwali	14/Mar/18	9:00	14/Mar/18	17:00	Daily	Bay maintenance work	MSETCL	MSETCL		
92	385	400	400 Kharghar-Talegaon @ Kharghar	14/Mar/18	8:00	14/Mar/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
93	389	400	400 Bus 2 at Tiroda SS	14/Mar/18	9:00	14/Mar/18	21:00	Daily	Bus & Bus Connected equipment maintenance	APML	APML		
94	390	765	ICT2_765/400_PADGHE	14/Mar/18	9:30	14/Mar/18	16:00	Daily	For CSD Commissioning.	WRTS-I	WRTS-I		
95	392	400	400Deepnagar-Khadka-II	14/Mar/18	6:00	14/Mar/18	17:00	Daily	For Fixing of Damaged/Loosed spacers cum vibration damper of Line Routine Maintenance & Diagnostic testing, Relay Testing work at 400 R.S. Deepnagar end	MSETCL	MSETCL		
96	397	220	Jeur - Solapur PG	14/Mar/18	9:00	14/Mar/18	17:00	Daily	Routine R&M work	MSETCL	MSETCL		
97	405	400	Talandge - Kolhapur PG 1 @ Talandge	14/Mar/18	9:00	14/Mar/18	20:00	Daily	Annual Maint	MSETCL	MSETCL		
98	406	400	400 Kharghar Main bay (403) at Talegaon	14/Mar/18	9:30	14/Mar/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		
99	410	765	765 TIE-III (709) Bay of 765 ICT-I Bay @Ektuni	14/Mar/18	10:00	14/Mar/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	765, 1500MVA ICT-I will be in service though it Main (710) Bay & Main Bus-II	
100	412	220	PGCIL Deoli-Badnera Ckt @Badnera	14/Mar/18	8:00	15/Mar/18	17:00:00PM	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL		
101	422	220	Talegaon - Talegaon PG ckt-2	15/Mar/18	8:00	15/Mar/18	18:00	Daily	For Maintenance of Line Equipments	MSETCL	MSETCL		Outage is required on Ckt 2 and on dt 15.02.2018
102	423	400	Babhaleshwar-Padghe-Ckt-1 @BBLR	15/Mar/18	9:00	15/Mar/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Babhaleshwar-Padghe-Ckt-2 will be in service	
103	424	400	400 Bus-II at Solapur	15/Mar/18	9:00	16/Mar/18	18:00	Daily	STACOM BAY COMMISSIONING WORKS	WRTS-I	WRTS-I		
104	426	400	400 Alkud Main bay (415) at Solapur	15/Mar/18	9:00	15/Mar/18	18:00	Daily	AMP	WRTS-I	WRTS-I	Postponed and clubbed with Bus Outage	
105	428	400	400 BUS -2 at 400Akola MSETCL	15/Mar/18	9:00	15/Mar/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
106	430	400	400 Kudgi-II & Mapusa-I Tie bay (405) at Kolhapur-GIS	15/Mar/18	10:00	15/Mar/18	18:00	Daily	For bay AMP works	WRTS-I	WRTS-I		
107	438	220	Talegaon M - Talegaon PG Ckt II @Talegaon M	15/Mar/18	8:00	15/Mar/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
108	439	220	Talegaon - Talegaon PG ckt-2	15/Mar/18	8:00	15/Mar/18	18:00	Daily	For Maintenance of Line Equipments	MSETCL	MSETCL		Repeatation.
109	441	400	400 KORADI-WARDHA Ckt	15/Mar/18	9:00	15/Mar/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
110	447	400	Talandge - Kolhapur PG 2 @ Talandge	15/Mar/18	9:00	15/Mar/18	20:00	Daily	Annual Maint	MSETCL	MSETCL		
111	448	400	400 ICT-2 main bay (412) at Talegaon	15/Mar/18	9:30	15/Mar/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		
112	452	765	765 TIE-IV (712) Bay of 765 ICT-II bay @Ektuni	15/Mar/18	10:00	15/Mar/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	765, 1500MVA ICT-II will be in service though it Main (713) Bay & Main Bus-II	
113	453	400	Koyna Stage IV-Jejuri	15/Mar/18	10:00	15/Mar/18	18:00	Daily	Cold washing of Insulators	MSETCL	MSETCL		
114	454	400	Parli - Lonikand CKT-I line@ Girwali	15/Mar/18	11:00	15/Mar/18	18:00	Daily	Hardware tightening and fixing work	MSETCL	MSETCL		
115	455	400	408-Bay (Main Bay of 400 Nanded-Chandrapur ckt-1) at 400 Nanded.	15/Mar/18	11:00	15/Mar/18	18:00	Daily	Line CVT Tan-D Measurement & Bay Equipment Maint.	MSETCL	MSETCL		
116	458	400	400Akola- Nandgaonpeth Line at 400Akola MSETCL	15/Mar/18	12:00	17/Mar/18	18:00	Daily	PID testing of insulator strings by Hot line Unit Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400Koradi- Bhusawal, 400Akola-Bhusawal & 400Koradi-Nandgaonpeth are in service.	
117	463	400	Ektuni- Babhaleshwar-II	16/Mar/18	12:00	16/Mar/18	15:00	Daily	For carrying out Line signature analysis test	MSETCL	MSETCL		
118	465	400	400 Bhahaleshwar ckt-II @Ektuni	16/Mar/18	10:00	16/Mar/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT & CB	MSETCL	MSETCL	Clubbed with another outage proposal	
119	474	400	400 Main- Bus - 2 at 400 Koradi s/s	16/Mar/18	6:00	16/Mar/18	18:00	Daily	Bus outage on bus 1. All feeder to be shifted on Bus-1 (06:00 HRS TO 18:00Hrs) Routine Maintenance & 400 CVT Dignostic testing work	MSETCL	MSETCL		Based on Generation at Tirora
120	477	400	409-Bay (Tie bay of Chandrapur ckt-1) at 400 Nanded	16/Mar/18	11:00	16/Mar/18	18:00	Daily	Quarterly Maintenance of bays equipment	MSETCL	MSETCL		
121	478	400	Lonikand- PGCIL Line	16/Mar/18	8:00:00AM	16/Mar/18	18:00	Daily	Routine Sustaion; Line Maintenance & Dignostic testing work	MSETCL	MSETCL		
122	479	400	400Khadka-Akola ckt @ Khadka Sstn	16/Mar/18	8:00	16/Mar/18	17:00	Daily	40050 MVar Akola Reactor's Bushing Tan delta, Ckt's Relay Testing(Distance & LBB & O/V) & CB DCRM	MSETCL	MSETCL		
123	480	400	400 Bus Coupler @ Kharghar	16/Mar/18	8:00	16/Mar/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
124	482	220	TAPS - Boisar M @ Boisar (M)	16/Mar/18	8:00	16/Mar/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
125	485	400	400 Parli (Girwali) - CHD Ckt-III Line@ Girwali	16/Mar/18	9:00	16/Mar/18	17:00	Daily	For tightening of earthwire clamp hardware at loc. No.816, 813, 819, 830	MSETCL	MSETCL		
126	486	400	Babhaleshwar-Ektuni-Ckt-2 @BBLR	16/Mar/18	9:00	16/Mar/18	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400Bhusawal, Auranagabad Dhule-Ckt-1&2, Ektuni-ckt-1, will be in service	
127	492	220	Nasik - Navsari Ckt 1 @ Nasik	16/Mar/18	9:00	16/Mar/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
128	493	400	400 Lonikand Line Main bay (413) at Talegaon	16/Mar/18	9:30	16/Mar/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		
129	500	765	765 3*80Mvar Bus Reactor @ Ektuni	16/Mar/18	10:00	16/Mar/18	18:00	Daily	Routine Maintain & Diagnostic Testing of CT, CB & Reactor testing	MSETCL	MSETCL	If voltage less than 775KV	
130	501	765	765 Bus 2 at Tiroda SS	16/Mar/18	9:00	16/Mar/18	21:00	Daily	Bus & Bus Connected equipment maintenance	MEGPTCL	MEGPTCL		
131	504	400	(1) 400 Kalwa-Talegaon Line, (2) 400K V Kalwa-Kharghar Line	16/Mar/18	9:00	20/Mar/18	18:00	Daily	PID Testing work of 400Kalwa-Talegaon & 400 Kalwa-Kharghar (D/C) line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL		

504th OCCM SR.No.	Sr. No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
132	505	400	Chandrapur II- Nanded Ckt- II	16/Mar/18	8:00	31/Mar/18	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	These lines are on DC tower so both lines require on same day A/R out.	
133	506	400	Chandrapur GCR- Parli Ckt-III	16/Mar/18	8:00	31/Mar/18	18:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	These lines are on DC tower so both lines require on same day A/R out.	
134	507	400	400 WARDHA-PARLI I & II	17/Mar/18	7:00	23/Mar/18	18:00	Continuous	400 Wardha-Parli LILO at Warora under construction S/s.	WRTS-I	WRTS-I		
135	511	400	315 MVA ICT-II at Boisar	17/Mar/18	9:00	17/Mar/18	18:00	Daily	AMP	POWERGRID	WR-II		Friday. To be availed on Sunday .
136	514	400	400Waluj- Babhaleshwar	17/Mar/18	10:00	17/Mar/18	16:00	Daily	Line Signarure analysis test by 400 Line maintenance unit Waluj	MSETCL	MSETCL		
137	519	400	400MAIN BUS I @ Lamboti	17/Mar/18	8:00	17/Mar/18	18:00	Daily	SERVICING AND OVERHAULING OF ISOLATORS AT LAMBOTI	MSETCL	MSETCL		
138	523	400	400 Parli (Girwali) - Nanded Ckt-II Line	17/Mar/18	9:00	17/Mar/18	17:00	Daily	For tightening of hardware at loc. No.925, 949, 947	MSETCL	MSETCL		
139	524	400	Bay No-411 Tie Bay of 400 Boisar-Vapi & 400 Boisar-Tarapur ckt- II Line at Boisar	17/Mar/18	9:00	17/Mar/18	18:00	Daily	For CB Compress Base plate and Cover Replacement	POWERGRID	WR-II		
140	525	400	415 Bay (Tie Bay of Yelwan Ckt-1) at 400Akola MSETCL	17/Mar/18	10:00	17/Mar/18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
141	530	400	400 Girwali-Nanded ckt 2@ Girwali	17/Mar/18	9:00	17/Mar/18	17:00	Daily	Bay maintenance work	MSETCL	MSETCL		
142	535	220	Nasik - Navsari Ckt 2 @ Nasik	17/Mar/18	9:00	17/Mar/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
143	543	400	400Waluj-Babhaleshwer @ 400Waluj	17/Mar/18	10:00	17/Mar/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	Preponed and clubbed with another outage proposal	
144	544	220	220Bus-I at Boisar	18/Mar/18	9:00	18/Mar/18	18:00	Daily	AMP	POWERGRID	WR-II		Wednesday . To be availed on Sunday .
145	546	400	Babhaleshwar-Bhusawal -@BBLR	18/Mar/18	9:00	18/Mar/18	9:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 Auranagabad Dhule-Ckt-1&2, Ektuni-ckt-1&2, will be in service	
146	551	400	400 MAIN BUS II @ Lamboti	18/Mar/18	8:00	18/Mar/18	18:00	Daily	SERVICING AND OVERHAULING OF ISOLATORS AT LAMBOTI	MSETCL	MSETCL		
147	557	400	400 Kalwa-Talegaon Line	18/Mar/18	8:00	18/Mar/18	18:00	Daily	Insulator Replacement work	MSETCL	MSETCL		
148	558	400	400D/C Tiroda-Warora Line	18/Mar/18	8:00	18/Mar/18	20:00	Continuous	Power line crossing of 400D/C Tiroda-Warora Line by 765D/C Raipur-Rajnandgaon line at Loc. No. 9/0-9A/0	ATIL	RRWTl	Subject to total Tirora U1,U2,U3 generator availability and overall gen. level at Tirora	Subject to total Tirora U1,U2,U3 generator availability and overall gen. level at Tirora
149	561	400	400 Main Bus -2 along with 400Waluj-Deepnagar line @ 400 R.S. Waluj	19/Mar/18	8:00	19/Mar/18	18:00	Daily	Replacement of Rotary insulator for 400Waluj-Deepnagar line main bus-II Yph.	MSETCL	MSETCL		
150	572	400	400SSNL-Dhule-1	19/Mar/18	8:00	19/Mar/18	18:00	Daily	Maintenance work	PGCIL	GETCO	Non auto reclose code for 400 SSP-Dhule No. 2 is to be required.	
151	580	400	Jaigad-Karad Ckt - 1 & 2	19/Mar/18	9:00	19/Mar/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL		
152	585	765	706 BR Bus Reactor at Koradi III SS	19/Mar/18	8:00	19/Mar/18	14:00	Daily	For Maintenance of Bus Reactor and related equipments	MEGPTCL	MEGPTCL		
153	587	400	400 Khadka-Aurangabad line	19/Mar/18	7:00	20/Mar/18	18:00	Daily	PID Testing .	MSETCL	MSETCL	Non Autoreclosure	
154	589	400	Dabhol-Nagonathane Ckt 1 Line@Dabhol	19/Mar/18	8:00	21/Mar/18	18:00	Daily	For Cold washing , insulator replacement ,Earth wire replacement	MSETCL	MSETCL		
155	603	400	400 Boisar-Padghe at Boisar	20/Mar/18	9:00	20/Mar/18	13:00	Daily	code for Online Main-I relay replacement(Line will be in service through M-2)	POWERGRID	WR-II		
156	606	400	400SSNL-Dhule-2	20/Mar/18	8:00	20/Mar/18	18:00	Daily	Maintenance work	PGCIL	GETCO	Non auto reclose code for 400 SSP-Dhule No. 1 is to be required.	
157	612	400	429- Bay (Main Bay of Warora- Wardha ckt at PGCIL Deoli S/Stn)	20/Mar/18	9:00	20/Mar/18	17:00	Continuous	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
158	613	400	Bus Coupler @ BBLR	20/Mar/18	9:00	20/Mar/18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL	Bus will be seperated	
159	624	400	400 BUSBAR-I & 400 BUSBAR -II at 400 Koradi II s/s	20/Mar/18	10:00	20/Mar/18	17:00	Daily	On line testing of400 BusBar Protection Scheme.	MSETCL	MSETCL	400 Busbar-1 & Busbar-II will remain in service. But the whole busbar relay will be out in case of bus fault back up to busbar scheme will operate.	
160	630	400	Jaigad-Newkoyna Ckt- 1 & 2	20/Mar/18	9:00	23/Mar/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL		
161	631	400/220	315 MVAICT-2 @ 400 Dhule	20/Mar/18	8:00	26/Mar/18	17:00	Continuous	For oil filtration & routine maintenance work	MSETCL	MSETCL		
162	645	400	400warora chandrapur ckt2 bay no 415 and 416 (412 is tie bay of chandrapur2 ckt2 and adani ckt2) @400 s/s warora end	21/Mar/18	8:00	21/Mar/18	17:00	Daily	Routine bay maintenance and relay testing works	MSETCL	MSETCL	Load will be managed on 400 chandrapur Ckt-1 bay no 413	
163	659	400	400 MAIN BUS I @ ALKUD	21/Mar/18	9:00	21/Mar/18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
164	660	400	Nandgaon Ckt with Bay 412 & 413 at 400Akola MSETCL	21/Mar/18	9:00	21/Mar/18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL		
165	661	400	220Chakan MSETCL Line-2 Main bay (211) at Talegaon	21/Mar/18	9:30	21/Mar/18	17:00	Daily	For AMP works	WRTS-I	WRTS-I		
166	672	400	Station Transformer 1 at Tiroda SS	21/Mar/18	9:00	21/Mar/18	21:00	Daily	Transformer & Its Bay Equipment Maintenance, Relay testing	APML	APML		
167	673	220	PGCIL Deoli-Badnera Ckt @Badnera	21/Mar/18	8:00	22/Mar/18	17:00:00PM	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL		
168	675	400	400 Kalwa-Padgha Line-2	21/Mar/18	9:00	24/Mar/18	18:00	Daily	PID Testing work of 400Kalwa-Padgha line-2 Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL		
169	681	220	Talegaon M - Talegaon PG Ckt I @Talegaon M	22/Mar/18	8:00	22/Mar/18	18:00	Daily	Routine R&M work	MSETCL	MSETCL		
170	689	400	125MVAR Reactor @ ALKUD	22/Mar/18	9:00	22/Mar/18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
171	690	400	400D/C Koradi II to Koradi III line ckt-1&2	22/Mar/18	7:00	22/Mar/18	18:00	Daily	For Stringing work of 765 D/C Gadarwara-Warora T/L ,part 2 at power line crossing section	MSETCL	WR-II		Based on Generation at Koradi-2
172	697	400	765 Bus-I at Solapur	22/Mar/18	9:00	24/Mar/18	18:00	Daily	STACOM BAY COMMISSIONING WORKS	WRTS-I	WRTS-I		
173	710	400	Parli - Lonikand 02 Ckt-II line@ Girwali	22/Mar/18	11:00	22/Mar/18	18:00	Daily	Hardware tightening and fixing work	MSETCL	MSETCL		
174	711	400	407-Bay (Main Bay of 501MVA ICT-2) at 400 Nanded.	22/Mar/18	11:00	22/Mar/18	18:00	Daily	Quarterly Maintenance of Bay equipments	MSETCL	MSETCL		
175	712	400	400 Boisar-Padghe at Boisar	22/Mar/18	14:00	22/Mar/18	17:00	Daily	For tripping and A/R Trials of Main-I relay(Line will be in service through M-2)	POWERGRID	WR-II		
176	714	400	New Koyna -Dabhol Ckt 2@Dabhol	22/Mar/18	8:00	24/Mar/18	18:00	Daily	For Cold washing and insulator replacement & Hill cutting work.	MSETCL	MSETCL		

504th OCCM SR.No.	Sr. No	Voltage	Line / Element	From		To		Basis	Reason	System	Agency	REMARKS	SLDC Comments
				Date	Time	Date	Time						
177	718	400	400Koradi- Bhusawal Line	22/Mar/18	12:00	24/Mar/18	18:00	Daily	PID testing of insulator strings by Hot line Uint Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400Akola- Bhusawal, 400Akola- Nandgaonpeth & 400Koradi- Nandgaonpeth are in service.	
178	719	400	(3*105) MVA ICT-II & It's Bay @400 S/S Chandrapur	22/Mar/18	8:00	28/Mar/18	18:00	Continuous	Replacement of B- ph ICT-II By repaired 105 MVA Spare ICT.	400 AC	MSETCL		
179	732	400	400D/C Koradi II to Koradi III line ckt-1&2	23/Mar/18	7:00	23/Mar/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L ,part 2 at power line crossing section	MSETCL	WR-II		Based on Generation at Koradi-2
180	742	400	400 Koradi- RPL(Nandgaonpeth) line	23/Mar/18	9:00	23/Mar/18	18:00	Daily	Relay testing (Distance relay) & Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
181	748	400	Bus Reactor 2 at Tiroda SS	23/Mar/18	9:00	23/Mar/18	21:00	Daily	Transformer & Its Bay Equipment Maintenance, Relay testing	ATIL	ATIL		
182	751	220	220Boisar-Boisar-I Line at Boisar (PGCIL)	24/Mar/18	9:00	24/Mar/18	17:00	Daily	Line Equipment AMP	POWERGRID	WR-II		Saturday . To be availed on Sunday.
183	753	400	400 Bus Reactor-1 & Parli-I Tie Bay (414) at Parli	24/Mar/18	10:00	28/Mar/18	18:00	Continuous	For AMP works at Parli	WRTS-I	WRTS-I	Postponed and clubbed with line Outage	
184	756	220	Boisar- Boisar PG ckt--2	24/Mar/18	8:00	24/Mar/18	18:00	Daily	For Maintenance of Line Equipments	MSETCL	MSETCL		
185	758	400	Chandrapur 2 - Kumbhargaoon (Nanded) Ckt-I	24/Mar/18	8:00	24/Mar/18	17:00	Daily	For Line Signature Test	MSETCL	MSETCL		
186	759	765	765 Bus 1 at Koradi III SS	24/Mar/18	8:00	24/Mar/18	18:00	Daily	For Maintenance of Bus Equipments	MEGPTCL	MEGPTCL		
187	764	400	400 Kalwa-Kharghar Line	24/Mar/18	8:00	24/Mar/18	18:00	Daily	Routine maintenance and diagnostic testing work	MSETCL	MSETCL		
188	773	400	Jaigad-Karad Ckt - 1 & 2	24/Mar/18	9:00	24/Mar/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL		
189	777	765	765/400-ICT at Akola-II SS	24/Mar/18	9:00	24/Mar/18	18:00	Daily	For Maintenance of ICT at Akola-II SS	MEGPTCL	MEGPTCL		
190	778	220	220Bus-II at Boisar	25/Mar/18	9:00	25/Mar/18	18:00	Daily	AMP	POWERGRID	WR-II		
191	785	400	406-Bay (Tie bay of Girwali ckt-2 & ICT-2) at 400 Nanded	25/Mar/18	11:00	25/Mar/18	18:00	Daily	Quarterly Maintenance of bays equipment	MSETCL	MSETCL		
192	786	400	KORADI-WARDHA (PGCL) CKT	25/Mar/18	8:00	25/Mar/18	18:30	Daily	Fixing of Missing &tightening of loose Nut Bolts on conductor hardwares at various locations.	MSETCL	MSETCL		
193	791	765	765/400-ICT -2 at Koradi III SS	25/Mar/18	8:00	25/Mar/18	14:00	Daily	For Maintenance of ICT at Koradi III SS	MEGPTCL	MEGPTCL		
194	800	400	Chandrapur 2 - Warora Ckt I	26/Mar/18	8:00	26/Mar/18	17:00	Daily	Tightening of conductor ,Earthwire Hardware & replacement of faulty Disc Insulator	MSETCL	MSETCL		
195	804	400	413 Bay (Main Bay of PGCL- Koradi Ckt at PGCIL Deoli S/Strn)	26/Mar/18	9:00	26/Mar/18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL		
196	815	400	400 Khadka-Babhaleswar line	26/Mar/18	7:00	27/Mar/18	18:00	Daily	PID Testing .	MSETCL	MSETCL	Non Autoreclosure	
197	818	400/220	501 MVA, ICT 3 @ Talandge	26/Mar/18	9:00	27/Mar/18	18:00	Continuous	Annual Maint.Work & IPS coating work	MSETCL	MSETCL		
198	824	400	Jaigad-Karad Ckt - 1 & 2	26/Mar/18	9:00	29/Mar/18	18:00	Daily	Online permit for Hotline Washing of insulator strings. A/R for both circuits to be kept into non auto mode during Hotline Washing.	JPTL	JPTL		
199	827	400	400 Kalwa-Padgha Line-1	26/Mar/18	9:00	31/Mar/18	18:00	Daily	PID Testing work of 400Kalwa-Padgha line-1 Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL		
200	840	400	400Tiroda - Warora Line-1 @Tirora	27/Mar/18	8:00	27/Mar/18	18:00	Daily	For Maintenance of Line Equipments	ATIL	ATIL		
201	842	400	400S/C Koradi I -India Bull	27/Mar/18	7:00	27/Mar/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L ,part 2 at power line crossing section	MSETCL	WR-II		Tuesday .NOC required from concnerened SE O &M
202	843	220	Navsari - Nashik 1	27/Mar/18	8:00	27/Mar/18	8:00	Daily	Maintenance work	GETCO	GETCO		
203	859	220	PGCIL Deoli-Badnera Ckt @ Badnera	27/Mar/18	8:00	28/Mar/18	17:00	Daily	For PID Work,Shifting of auto reclose switch to non auto mode	MSETCL	MSETCL		
204	862	400	New Koyna -Dabhol Ckt 1 @Dabhol	27/Mar/18	8:00	28/Mar/18	18:00	Daily	For Cold washing and insulator replacement	MSETCL	MSETCL		
205	863	400	Main Bus 1@ Girwali	27/Mar/18	7:00	29/Mar/18	19:00	Daily	Bus maintenance & replacement of scissor (1 no.) of 400 Chandrapur ckt 3 29A Isolator.	MSETCL	MSETCL		
206	876	400	400Tiroda - Warora Line-2 @Tirora	28/Mar/18	8:00	28/Mar/18	18:00	Daily	For Maintenance of Line Equipments	ATIL	ATIL	work to carried during D/C outage	
207	877	400	Satpura - Koradi	28/Mar/18	9:00	28/Mar/18	18:00	Daily	For AMP works of terminal equipments at Sarni MPGENCO SS	POWERGRID	WR-II		
208	878	400	400S/C Koradi I -Bhuswal	28/Mar/18	7:00	28/Mar/18	18:00	Daily	For Stringing work of 765 D/C Gadawara-Warora T/L ,part 2 at power line crossing section	MSETCL	WR-II		NOC required from concnerened SE EHV (O &M)
209	879	220	Navsari - Nashik 2	28/Mar/18	8:00	28/Mar/18	8:00	Daily	Maintenance work	GETCO	GETCO		
210	880	400	400 Aurangabad-Aurangabad-1 along with Main Bus-1 at Msetcl, Waluj SS	28/Mar/18	8:00	28/Mar/18	18:00	Daily	for repairing of damaged strands of Bus conductors & CT drop jumpers replacement, Bus conductor strands got cut near pantograph Isolator and it needs to repair and alignment of Bus Isolator	WRTS-I	WRTS-I		
211	886	400	Talandge - Alkud @ Talandge	28/Mar/18	9:00	28/Mar/18	20:00	Daily	Annual Maint	MSETCL	MSETCL		
212	888	765	765/400-ICT -1 at Koradi III SS	28/Mar/18	10:00	28/Mar/18	14:00	Daily	For Maintenance of ICT at Koradi III SS	MEGPTCL	MEGPTCL		
213	889	400	400 kolhapur(MSETCL)-I Main bay (407) at Kolhapur-GIS	28/Mar/18	10:00	28/Mar/18	18:00	Daily	For bay AMP works	WRTS-I	WRTS-I		
214	901	400	Main Bus 2@ Girwali	29/Mar/18	7:00	29/Mar/18	19:00	Daily	Bus maintenance & replacement of gear boxes (3 no.) of 400 Nanded ckt 1 29B Isolator and bus coupler 29B (1 no.) isolator.	MSETCL	MSETCL		
215	902	400	400 Aurangabad-Aurangabad-1 along with Main Bus-2 at Msetcl, Waluj SS	29/Mar/18	8:00	29/Mar/18	18:00	Daily	line AMP works and for repairing of damaged strands of Bus conductors & CT drop jumpers replacement, Bus conductor strands got cut near pantograph Isolator and it needs to repair and alignment of Bus Isolator	WRTS-I	WRTS-I		
216	910	400	Talandge - Solapur PG @ Talandge	29/Mar/18	9:00	29/Mar/18	20:00	Daily	Annual Maint	MSETCL	MSETCL		
217	914	765	765S/C Akola-II to Aurangabad Ckt-I	29/Mar/18	8:00	29/Mar/18	18:00	Daily	For Maintenance of Line Equipments	MEGPTCL	MEGPTCL		
218	917	400	Dabhol-Nagonathane Ckt 2 @Dabhol	29/Mar/18	8:00	31/Mar/18	18:00	Daily	For Cold washing and insulator replacement	MSETCL	MSETCL		
219	925	400	400 AURANGABAD(PG)-AURANGABAD(MSETCL) II	30/Mar/18	8:00	30/Mar/18	18:00	Daily	Line AMP works & CT drop jumper replacement at Msetcl, waluj S/s	WRTS-I	WRTS-I		
220	930	765	765S/C Akola-II to Aurangabad Ckt-II @Akola	30/Mar/18	8:00	30/Mar/18	18:00	Daily	For Maintenance of Line Equipments	MEGPTCL	MEGPTCL		
221	931	220	Boisar- Boisar PG ckt--1	31/Mar/18	8:00	31/Mar/18	18:00	Daily	For Maintenance of Line Equipments	MSETCL	MSETCL		
222	932	220	Boisar (M) - BOISAR PG CKT 1	31/Mar/18	9:00	31/Mar/18	19:00	Daily	Routine R&M work and Line maint. At Jeur end	MSETCL	MSETCL		

Stae Element outages for the month of March'2018											
Sr. No.	Voltage/Kv	Line/Equipment Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
1	400 KV	N.Koyna-Karad ckt 2	1-Mar-18	10:00	3-Mar-18	18:00	Daily	Cold washing of Insulators	MSETCL	MSETCL	
2	400KV	400KV Stage 4- Jejuri ckt	01-Mar-18	7:00	31-Mar-18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off
3	400KV	400KV Stage 4- Lonikand	01-Mar-18	7:00	31-Mar-18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off
4	400KV	400KV Khadka -Deepnagar	01-Mar-18	7:00	31-Mar-18	19:00	Daily	Taking Auto Reclose in Non AR Mode for stringing of OPGW work	MSETCL	MSETCL	A/R required to be Off
5	400KV	Lonikand-Karad Line	01-Mar-18	8:00:00 AM	01-Mar-18	18:00	Daily	Routine Sustain; Line Maintenance & Dignostic testing work	MSETCL	MSETCL	
6	400/220kv	501MVA, ICT - II @ 400KV Deepnagar	02-Mar-18	8:00	02-Mar-18	18:00	Daily Basis	ICT Bushing, winding tan delta & OLTC continuity testing	MSETCL	MSETCL	
7	400/220KV	500MVA, ICT 3 @ BBLR	03-Mar-18	8:00	03-Mar-18	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	400/220kv 315MVA ICT-I & II, 500MVA ICT-IV will be in service
8	400/220kv	500MVA, ICT II @ Kalwa	04-Mar-18	7:00	04-Mar-18	15:00	Daily	400 KV and 220 KV side 29 C 29 D Isolator O/H work, Bay maintenance and testing Work	MSETCL	MSETCL	
9	400KV	417 Bay (Main bay of Yelwan Ckt-2) at 400 kv Akola MSETCL	05-Mar-18	10:00	05-Mar-18	17:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
10	400 KV	400KV TALANDAGE-II @Karad	05-Mar-18	10:00	05-Mar-18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kv Talandge 2
11	400KV	Babhaleswar-Dhule-Ckt-1 @BBLR	05-Mar-18	9:00	05-Mar-18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG Isolators work	MSETCL	MSETCL	400 kv Bhusawal, Auranagabad Dhule-Ckt-2, Ektuni-ckt-1, Ektuni-ckt-2 will be in service
12	400KV	Talandge - Karad 1 @ Talandge	6-Mar-18	9:00	6-Mar-18	20:00	Daily	Annual Maint & Relay testingWork	MSETCL	MSETCL	
13	220 kv	Bugaon - PGCIL line	06-Mar-18	10.00 AM	06-Mar-18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
14	400	400KV KORADI-II -STATION TRANSFORMER -III MAIN BAY 404 & TIE BAY 405 @ 400KV Koradi II s/s	06-Mar-18	10:00	6-Mar-18	17:00	Daily	Relay testing	MSETCL	MSETCL	400KV Station transformer-I & 400KV Station transformer-II will remain in service through their main & tie bay.
15	400/220/33kv	,500MVA ICT-3 @ Girwali	06-Mar-18	9:00	06-Mar-18	18:00	Daily	IV bus isolator alignment & bay maintenance work	MSETCL	MSETCL	
16	400/220 KV	315 MVA ICT-II @Karad	06-Mar-18	10:00	06-Mar-18	17:00	Daily	Annual Maint. work	MSETCL	MSETCL	Load manage on other Two ICT'S
17	400/220kv	3*105 MVA, ICT -1 @ Kharghar	06-Mar-18	8:00	06-Mar-18	17:00	Daily	Maintenance work	MSETCL	MSETCL	
18	400KV	Talandge - Karad 2 @ Talandge	6-Mar-18	9:00	6-Mar-18	20:00	Daily	Annual Maint & Relay testingWork	MSETCL	MSETCL	
19	400 KV	N.Koyna-Karad ckt 1	7-Mar-18	10:00	8-Mar-18	18:00	Daily	Cold washing of Insulators	MSETCL	MSETCL	N.Koyna-Karad ckt 1 will be in service
20	400/220kv	500MVA, ICT @ Alkud	07-Mar-18	9:00	07-Mar-18	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
21	400/220/33KV	ICT-1 BAY NO 403 & 404 (403 is tie bay of ICT-1) @400kv s/s warora end	07-Mar-18	8:00	07-Mar-18	17:00	Daily	CT/CVTs tan delta testing works and relay testing works	MSETCL	MSETCL	ICT-1 is diverted in April-16, Only ICT-1 Main and Tie CB are get out during outage.
22	400KV	418 Main Bay only (Chandrapur-2- Switching Ckt-1) @ 400KV Chandrapur Switching s/s	7-Mar-18	9:00	7-Mar-18	17:00	Daily	Diagnostic testing work(Main CB DCRM work)	MSETCL	MSETCL	
23	400	KHAPERKHEDE-KORADI 1 CKT	7-Mar-18	11:00	7-Mar-18	14:00	Daily	FOR CARRYING OUT TAN DELTA OF LINE CT	MSETCL	MSETCL	
24	400	400KV Bhusaval (To be shifted on 400KV TBC) at 400KV Koradi s/s	07-Mar-18	8:00	07-Mar-18	17:00	Daily	400KV CB Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
25	220 kv	PGCIL - PUSAD LINE	08-Mar-18	10.00 AM	08-Mar-18	18:00	Daily	FIXING OF VIBRATION DAMPER	MSETCL	MSETCL	
26	400 KV	400KV LONIKAND @Karad	08-Mar-18	10:00	08-Mar-18	17:00	Daily	Annual Maint. work	MSETCL	MSETCL	Load manage on other ckt.
27	400/220kv	3*167 MVA, ICT 2 @ LAMBOTI	08-Mar-18	8:00	08-Mar-18	17:00	Daily	SERVICING AND OVERHAULING OF ISOLATORS AT LAMBOTI	MSETCL	MSETCL	
28	132KV	132 kv Nepanagar-Dharni Line@Dharni	9-Mar-18	10:00	9-Mar-18	15:00:00 PM	Daily	For routine maintenance and Diagnostic Testine	MSETCL	MSETCL	
29	400 KV	400KV JAIGAD -II @Karad	09-Mar-18	10:00	09-Mar-18	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	Load manage on 400 kv JAIGAD -2
30	400/220kv	3*167 MVA, ICT 1 @ LAMBOTI	09-Mar-18	8:00	09-Mar-18	17:00	Daily	SERVICING AND OVERHAULING OF ISOLATORS AT LAMBOTI	MSETCL	MSETCL	
31	400 KV	N.Koyna-Karad ckt 1	9-Mar-18	10:00	10-Mar-18	18:00	Daily	Cold washing of Insulators	MSETCL	MSETCL	
32	400KV	400KV Khadka - Deepnagar Ckt 1	11-Mar-18	8:00	11-Mar-18	17:00	Daily Basis	CB DCRM testing and trouble shooting of TNC switch	MSETCL	MSETCL	
33	400/220kv	500MVA, ICT III @ Kalwa	11-Mar-18	6:00	11-Mar-18	15:00	Daily	400 KV and 220 KV side 29 C 29 D Isolator O/H work, Bay maintenance and testing Work	MSETCL	MSETCL	
34	400/220/33 Kv	315 MVA ICT-2 with Bay 405 & 406 at 400 kv Akola MSETCL	12-Mar-18	8:00	12-Mar-18	18:00	Daily	balance Agency work, Routine Maintenance , testing work & Painting	MSETCL	MSETCL	
35	400kv	400kv Khadka Deepnagar Ckt 2 (On TBC only)	12-Mar-18	8:00	12-Mar-18	17:00	Daily Basis	CB DCRM testing	MSETCL	MSETCL	
36	400KV	400KV WARORA-IEPL Ckt	12-Mar-18	9:00	12-Mar-18	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
37	400KV	Babhaleswar-Dhule-Ckt-2 @BBLR	12-Mar-18	9:00	12-Mar-18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG Isolators work	MSETCL	MSETCL	400 kv Bhusawal, Auranagabad Dhule-Ckt-1, Ektuni-ckt-1, Ektuni-ckt-2 will be in service
38	400KV	Jaigad-Newkoyna Ckt- 1	12-Mar-18	9:00	12-Mar-18	18:00	Daily	Coldline washing & Insulator replacement	JPTL	JPTL	
39	400 KV	Koyna Stage IV-Lonikand	12-Mar-18	10:00	14-Mar-18	18:00	Daily	Cold washing of Insulators	MSETCL	MSETCL	Koyna Stage IV-Jejuri will be in service

Sr. No.	Voltage/Kv	Line/Equipment Name	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark, If any.
40	400KV	400 kv Waluj- Thaptitanda	13-Mar-18	9:00	13-Mar-18	15:00	Daily	Line Signarure analysis test by 400 kv Line maintenance unit Waluj	MSETCL	MSETCL	
41	400KV	Jaigad-Newkoyna Ckt- 2	13-Mar-18	9:00	13-Mar-18	18:00	Daily	Coldline washing & Insulator replacement	JPTL	JPTL	
42	400KV	400 KV Deepnagar-Khadka-II	14-Mar-18	6:00	14-Mar-18	17:00	One Day	For Fixing of Damaged/Loosed spacers cum vibration damper of Line Routine Maintenance & Diagnostic testing, Relay Testing work at 400kv R.S. Deepnagar end	MSETCL	MSETCL	
43	400KV	400KV FUTURE BAY-I BAY NO 418 & 419 (418 is tie bay of 400kv IEPL and 400 kv future-1) @400kv s/s warora end	14-Mar-18	8:00	14-Mar-18	17:00	Daily	Rotuine bay maintainance and relay testing works	MSETCL	MSETCL	400KV Bay No 419 charged on No Load
44	400KV	417 Tie Bay only (Chandrapur-2- Switching Ckt-1) @ 400KV Chandrapur Switching s/s	14-Mar-18	9:00	14-Mar-18	17:00	Daily	Diagnostic testing work(Breaker DCRM Work)	MSETCL	MSETCL	
45	400KV	Jaigad-Karad Ckt - 1	14-Mar-18	9:00	14-Mar-18	18:00	Daily	Coldline washing & Insulator replacement	JPTL	JPTL	
46	400/220 KV	501 MVA ICT I AT 400 KV JEURI	15-Mar-18	9:30	15-Mar-18	17:30	Daily	Annual Maint & testing of bays equipment	MSETCL	MSETCL	400/220 KV 501 MVA ICT II will be in service.
47	400KV	400 kv Deepnagar-Waluj	15-Mar-18	6:00	17-Mar-18	18:00	Daily Basis	For Fixing of Damaged / Loosed spacers cum vibration damper	MSETCL	MSETCL	
48	400KV	Jaigad-Karad Ckt - 2	15-Mar-18	9:00	15-Mar-18	18:00	Daily	Coldline washing & Insulator replacement	JPTL	JPTL	
49	400/220KV	315 MVA, ICT II @WALUJ	16-Mar-18	10:00	16-Mar-18	18:00	Daily	Quarterly Maintenance	MSETCL	MSETCL	
50	400/220KV	ICT-1 at 400KV Koradi s/s	16-Mar-18	9:00	16-Mar-18	18:00	Daily	Relay testing (HV & LV backup, Differential relay) & Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
51	400 KV	Koyna Stage IV-Lonikand	16-Mar-18	10:00	17-Mar-18	18:00	Daily	Cold washing of Insulators	MSETCL	MSETCL	
52	400/132/20 KV	200 MVA ICT-1 @ 400kv Khadka Substation	17-Mar-18	8:00	17-Mar-18	17:00	Daily Basis	Bushing(400 KV & 132 KV) ,winding,SFRA ,Relay Testing(Differential, LBB ,Backup relay),RTCC Panel commissioning	MSETCL	MSETCL	
53	400/220kv	167 MVA ,Spare ICT-2 @ BBLR	17-Mar-18	9:00	17-Mar-18	17:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	NA
54	400KV	400 KV Deepnagar-Tapti-Tanda	18-Mar-18	6:00	20-Mar-18	18:00	Daily Basis	For Fixing of Damaged/Loosed spacers cum vibration damper	MSETCL	MSETCL	
55	400/220/33 kv	315 MVA ICT-1 with Bay 402 & 403 at 400 kv Akola MSETCL	19-Mar-18	8:00	19-Mar-18	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
56	400kv	TBC @ BBLR	19-Mar-18	9:00	19-Mar-18	17:00	Daily	Quarterly Maintenance work & Servicing and allignment of PG isolators work	MSETCL	MSETCL	TBC is free
57	400	400KV Koradi-Khaparkheda-1 Line	21-Mar-18	9:00	21-Mar-18	18:00	Daily	Relay testing (Distance relay) & Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
58	400/220 KV	501 MVA ICT II A @ 400 KV JEURI	22-Mar-18	9:30	22-Mar-18	17:30	Daily	Annual Maint & testing of bays equipment	MSETCL	MSETCL	400/220 KV 501 MVA ICT I will be in service.
59	400kv	Lonikand- Koyana stage -4 Line	22-Mar-18	8:00:00 AM	22-Mar-18	18:00	Daily	Routine Sustaion; Line Maintenance & Dignostic testing work	MSETCL	MSETCL	
60	400/132/20 KV	200 MVA ICT-2 @ 400kv Khadka	24-Mar-18	8:00	24-Mar-18	17:00	Daily Basis	Bushing (400KV & 132 KV) , Relay Testing	MSETCL	MSETCL	
61	400	KORADI-IEPL CKT	24-Mar-18	8:00	24-Mar-18	18:30	Daily	Fixing of Missing & tightening of loose Nut Bolts on conductor hardwares at various locations.	MSETCL	MSETCL	
62	400KV	New Koyna-Stage 4 Ckt-2 @ N.Koyna	25-Mar-18	8:00	26-Mar-18	18:00	Daily	For Cold washing and insulator replacement	MSETCL	MSETCL	
63	400KV	400 KV Chandrapur-2 -GCR Ckt-2 (409 Main Bay & 408 Tie Bay) @ 400KV Chandrapur-2 S/S	28-Mar-18	9:00	28-Mar-18	18:00:00 PM	Daily	For wave trap Jumper Replacement work	MSETCL	MSETCL	
64	400/220kv	315MVA, ICT 3 @ Lonikand-1	29-Mar-18	9:00	29-Mar-18	18:00:00 PM	Daily	Routine Dignostic testing work	MSETCL	MSETCL	
65	400	IEPL-WARORA	30-Mar-18	8:00	30-Mar-18	18:30	Daily	Fixing of Missing & tightening of loose Nut Bolts on conductor hardwares at various locations.	MSETCL	MSETCL	