

Maharashtra State Load Despatch Centre

WRPC OCCM approved Monthly Outage list for the Month of March'2019

Sr.No.	OCCM Sr.No	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Remarks
				Date	Time	Date	Time					
1	2	400	A/r in N/a of CHANDRAPUR 2-KUMBHARGAON (NANDED) CKT-1	1-Mar-19	08:00	14-Mar-19	17:00	Daily	Online PID work	MSETCL	MSETCL	
2	3	400	A/r in N/a of PADGHE-KALWA 1	1-Mar-19	09:00	9-Mar-19	18:00	Daily	PID Testing work of 400 KV Kalwa-Padgha Ckt-1 line Insulator strings at various locations. Auto-Restore function to be out of service	MSETCL	MSETCL	
3	4	220	BOISAR II-PGCL 2 ON TBC @ BOISAR II	1-Mar-19	08:00	3-Mar-19	18:00	Cont.	TBC operation for Breaker Overhauling work. Line will be in service through TBC.	MSETCL	MSETCL	
4	5	400	PADGHE-KALWA 1 ON TBC @ PADGHA	1-Mar-19	09:00	1-Mar-19	18:00	Daily	Diagnostic Test of CB	MSETCL	MSETCL	400KV Kalwa-1 line will be charged through TBC No outage required
5	12	400	400kv AURANGABAD(MSETCL)-PUNE(GIS) II	1-Mar-19	9:00	1-Mar-19	18:00	Daily	For Line AMP works, Both circuits outage required being M/c Towers. A/R of 400KV Parli-Pune(GIS)-2 & A'bad-Pune(GIS)-1 to be kept on Non-auto mode during this period.	WTPL	WRTS-1	
6	16	400	400kv PADGHE(GIS)-KUDUS(PADGHE MSETCL) I	1-Mar-19	10:00	1-Mar-19	14:00	Daily	For taking Oil Sample of Line CT at KUDUS MSETCL SS.	WRTS-1	WRTS-1	
7	17	400	400kv PARLI-PUNE(GIS)_1	1-Mar-19	9:00	1-Mar-19	18:00	Daily	For Line AMP works, Both circuits outage required being M/c Towers. A/R of 400KV Parli-Pune(GIS)-2 & A'bad-Pune(GIS)-1 to be kept on Non-auto mode during this period.	WTPL	WRTS-1	
8	29	220	A/r in N/a of 220KV NASHIK-NAVSARI CKT 1 & 2	1-Mar-19	09:00	31-Mar-19	17:00	Daily	Permission for Auto Reclose to be kept OFF for PID testing work	MSETCL	MSETCL	
9	31	400	A/r in N/a of 400KV NEW KOYNA-KARAD-CKT 1 & 2	1-Mar-19	09:00	31-Mar-19	17:00	Daily	Permission for Auto Reclose to be kept OFF for PID testing work	MSETCL	MSETCL	
10	33	220	A/r in N/a of PUSAD-WARDHA (PG)	1-Mar-19	07:00	31-Mar-19	17:00	Daily	PID WORK	MSETCL	MSETCL	
11	34	400	A/R switch required in NON-Auto mode of KHADKA-DEEPNAGAR CKT 1 & 2	1-Mar-19	06:00	2-Mar-19	18:00	Daily	Proposal for On Line PID By PID Unit,Bhusawal	MSETCL	MSETCL	
12	54	400	400kv AURANGABAD(MSETCL)-PUNE(GIS) I	2-Mar-19	9:00	2-Mar-19	18:00	Daily	For Line AMP works, Both circuits outage required being M/c Towers. A/R of 400KV Parli-Pune(GIS)-1 & A'bad-Pune(GIS)-2 to be kept on Non-auto mode during this period.	WRTS-1	WRTS-1	
13	57	400	400kv PADGHE(GIS)-KUDUS(PADGHE MSETCL) II	2-Mar-19	10:00	2-Mar-19	14:00	Daily	For taking Oil Sample of Line CT at KUDUS MSETCL SS.	WRTS-1	WRTS-1	
14	58	400	400kv PARLI-PUNE(GIS)_2	2-Mar-19	9:00	2-Mar-19	18:00	Daily	For Line AMP works, Both circuits outage required being M/c Towers. A/R of 400KV Parli-Pune(GIS)-1 & A'bad-Pune(GIS)-2 to be kept on Non-auto mode during this period.	WRTS-1	WRTS-1	
15	73	220	BOISAR II-BOISAR (PG) CKT-2	2-Mar-19	7:00	3-Mar-19	19:00	Cont.	For construction of LILO of Boisar II-Boisar(PG) ckt 2 at 220 Borivali s/s	MSETCL	MSETCL	
16	74	400	BUS COUPLER @ BABHALESHWAR	2-Mar-19	09:00	3-Mar-19	17:00	Cont.	Quarterly Maintenance work & Repair of scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	(Hanger dropper assembly of 400KV Bus coupler Bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)
17	75	400	DABHOL-NEW KOYNA CKT-1	2-Mar-19	09:00	2-Mar-19	12:00	Daily	Busbar scheme commissioning work	MSETCL	MSETCL	
18	76	400	DABHOL-NEW KOYNA CKT-2	2-Mar-19	14:00	2-Mar-19	17:00	Daily	Busbar scheme commissioning work	MSETCL	MSETCL	Load can be managed on Dabhol-New koyna CKT-I line
19	82	765	Koradi-III-Akola-II Ckt-2	2-Mar-19	08:00	2-Mar-19	18:00	Daily	Annual Maintenance of Line related Equipment	MEGPTCL	MEGPTCL	
20	83	220	NALASOPARA-BOISAR (PG) CKT & Boisar-Boisar CKT-2	2-Mar-19	7:00	2-Mar-19	19:00	Daily	For construction of LILO of Boisar II-Boisar(PG) ckt 2 at 220 Borivali s/s	MSETCL	MSETCL	
21	84	220	OSMANABAD-PARLY (PG)	2-Mar-19	08:00	2-Mar-19	16:00	Daily	Vibration Damper fixing	MSETCL	MSETCL	
22	86	220	OLD GCR PARLI (MSETCL)-PARLY (PG)	3-Mar-19	08:00	3-Mar-19	16:00	Daily	Quarterly maintenance.	MSETCL	MSETCL	
23	92	220	BOISAR II-BOISAR (PG) CKT-2 alongwith BOISAR II-BOISAR (PG) CKT-3	3-Mar-19	9:00	3-Mar-19	17:00	Daily	For construction of LILO of Boisar II-Boisar(PG) ckt 2 at 220 Borivali s/s	MSETCL	MSETCL	
24	93	400	MAIN BUS-1 @ KORADI-2	3-Mar-19	10:00	3-Mar-19	15:00	Daily	Tan delta measurement of Bus CVT	MSETCL	MSETCL	Load will be shifted to 400KV Main Bus-II
25	94	220	WARDHA-PGCL(DEOLI)	4-Mar-19	10:00	5-Mar-19	17:00	Daily	Maintenance work on line	MSETCL	MSETCL	Not to be given with Wardha-Pusad
26	101	765	707 LR (Aurangabad-ckt-II) Reactor @ AKOLA 2	4-Mar-19	09:00	4-Mar-19	18:00	Daily	Annual Maintenance of Reactor & Reactor Bay Equipment Maintenance	MEGPTCL	MEGPTCL	
27	105	400	A/r in N/a of DHULE--BABHALESHWAR-I & II	4-Mar-19	09:00	5-Mar-19	17:00	Daily	PID testing of insulator	MSETCL	MSETCL	
28	115	400	TBC @ BABHALESHWAR	4-Mar-19	09:00	9-Mar-19	17:00	Cont.	Quarterly Maintenance work & Repair of scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	400 kv TBC Bay is for Repairing of 29A & 29B & 29C P.G isoaltor P.G Isoaltor Scissoes (Hanger dropper assembly of TBC bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)
29	116	400	CHANDRAPUR 2-KUMBHARGAON (NANDED) CKT-1	5-Mar-19	08:00	5-Mar-19	18:00	Daily	Replacement of Polymer Insulator String	MSETCL	MSETCL	
30	117	500	Pole-1 Non base AC filter Z4 (80 MVAR) @Chandrapur HVDC	5-Mar-19	08:00	5-Mar-19	18:00	Daily	For DCRM of 400 KV Breaker	MSETCL	MSETCL	HVDC link can be operated in normal Bi-pole mode with 1500 MW capacity without any power loss
31	127	400	400kv Boisar-Padghe line at Boisar, dia to be kept open at both ends.	5-Mar-19	9:00	5-Mar-19	18:00	Daily	Main-I relay replacement & For tripping and A/R Trials of Main-I relay and line maintenance works (Line will be out of service)	POWERGRID	WRTS-2	
32	131	400	400kv Padghe GIS-1 MAIN BAY (415) at MSETCL KUDUS	5-Mar-19	11:00	5-Mar-19	12:00	Daily	For taking Oil Sample of Bay CT.	WRTS-1	WRTS-1	
33	132	400	400kv Padghe-1 TIE BAY (414) at MSETCL KUDUS	5-Mar-19	13:00	5-Mar-19	14:00	Daily	For taking Oil Sample of Bay CT.	WRTS-1	WRTS-1	
34	147	220	A/r in N/a of WARDHA-BADNERA	5-Mar-19	09:00	16-Mar-19	18:00	Daily	PID work	MSETCL	MSETCL	
35	154	400	Dabhol-Nagothane Line-2 Main Bkr CT (R-Phase)	5-Mar-19	9:00	6-Mar-19	18:00	Daily	Replacement of main bkr CT(407-52 A /R phase)	RGPL	RGPL	
36	160	400	MAIN BAY (411) OF TIRODA CKT-1 @ WARORA	5-Mar-19	09:00	6-Mar-19	18:00	Cont.	Breaker Pole Replacement	ATIL	ATIL	
37	165	400	CHANDRAPUR 2-KUMBHARGAON (NANDED) CKT-1	6-Mar-19	08:00	6-Mar-19	18:00	Daily	Replacement of Polymer Insulator String	MSETCL	MSETCL	
38	166	220	KALMESHWAR-PANDHURNA	6-Mar-19	09:00	6-Mar-19	18:00	Daily	Routine Maintenance work	MSETCL	MSETCL	
39	181	400	400KV PADGHE-2 MAIN BAY (418) at MSETCL KUDUS	6-Mar-19	11:00	6-Mar-19	12:00	Daily	For taking Oil Sample of Bay CT.	WRTS-1	WRTS-1	
40	182	400	400KV PADGHE-2 TIE BAY (417) at MSETCL KUDUS	6-Mar-19	13:00	6-Mar-19	14:00	Daily	For taking Oil Sample of Bay CT.	WRTS-1	WRTS-1	
41	204	400	BUS COUPLER @ KORADI	6-Mar-19	09:00	6-Mar-19	18:00	Daily	CT tan delta work & CB timings	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
42	206	400	DABHOL-NAGOTHANE CKT-1	6-Mar-19	08:00	15-Mar-19	18:00	Daily	L E Scheme for insulator string replacement & Cold washing insulators	MSETCL	MSETCL	Load can be managed on Dabhol-Nagothane CKT-II line

Sr.No.	OCCM Sr.No	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Remarks
				Date	Time	Date	Time					
43	207	400	Dhule(BDTCL)-Dhule (MSETCL) line-1	6-Mar-19	8:00	6-Mar-19	18:00	Daily	AMP Work	BDTCL	BDTCL	Not to be clubbed with A'bad-Dhule, After 6th
44	211	400	MAIN BAY (404) OF AURANGABAD (PG)-1 @ AKOLA	6-Mar-19	10:00	6-Mar-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
45	213	400	PARLI-LONIKAND 2 CKT 1	6-Mar-19	10:30	6-Mar-19	18:00	Daily	Hardware Tightening & Fitting Work	MSETCL	MSETCL	
46	219	400	400KV Talegaon Chakan Line at Talegaon	7-Mar-19	9:00	7-Mar-19	17:00	Daily	For Replacment of Clamps & connectors	MSETCL	WRTS-1	Mah :Please reschedule outage on 10.03.2019
47	220	400	CHANDRAPUR 2-KUMBHARGAON (NANDED) CKT-1	7-Mar-19	08:00	7-Mar-19	18:00	Daily	Replacement of Polymer Insulator String	MSETCL	MSETCL	
48	221	400	CHANDRAPUR 2-WARORA CKT-2	7-Mar-19	08:00	7-Mar-19	17:00	Daily	Tightening of conductor,Earthwire Hardware.	MSETCL	MSETCL	Maharashtra: Outage to be scheduled on 05.03.2019
49	222	220	PUSAD-WARDHA (PG)	7-Mar-19	09:00	8-Mar-19	18:00	Cont.	Replacement of main, line arth auxillary Isolator of 220kv Pusad Deoli Bay under LE Scheme	MSETCL	MSETCL	
50	223	400	WARORA-Wardha(PG)	7-Mar-19	09:00	7-Mar-19	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	heavily loaded >700MW along with koradi wardha>700MW
51	254	400	Dabhol-New Koyna line 2 (Line CT-Y phase)	7-Mar-19	9:00	8-Mar-19	18:00	Cont.	Replacment of Line CT /Y phase)	RGPL	RGPL	
52	258	400	LONIKAND 1-CHAKAN	7-Mar-19	09:00	7-Mar-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	
53	259	400	MAIN BAY (418) OF 400/11.5KV Station Transformer-5 @ Tirora	7-Mar-19	08:00	7-Mar-19	18:00	Daily	Testing & Maintenance of Bay Breaker & CT	APML	APML	
54	261	500	Pole-2 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	7-Mar-19	08:00	7-Mar-19	18:00	Daily	For DCRM of 400 KV Breaker	MSETCL	MSETCL	HVDC link can be operated in normal Bi-pole mode with 1500 MW capacity without any power loss
55	266	220	A/r in N/a of BORIVALI-TARAPUR	8-Mar-19	09:00	8-Mar-19	17:00	Daily	PID IDENTIFIED FAULTY INSULATOR STRING REPLACEMENT & OTHER MAINTENANCE WORK	MSETCL	MSETCL	
56	267	400	A/r in N/a of CHANDRAPUR 2-KUMBHARGAON (NANDED) CKT-1 & 2	8-Mar-19	08:00	14-Mar-19	17:00	Daily	PID work	MSETCL	MSETCL	
57	268	400	PARLI-KUMBHARGAON(NANDED) CKT-2	8-Mar-19	08:00	8-Mar-19	18:00	Daily	String Replacement at Loc. No. 878, CB DCRM & Timing test.	MSETCL	MSETCL	
58	284	400	400KV PADGHE MSETCL-TARAPUR II	8-Mar-19	10:00	8-Mar-19	12:00	Daily	For taking Oil Sample of Line CT and attending Hotspot.	WRTS-1	WRTS-1	
59	299	765	Akola II-Ektuni Line1	8-Mar-19	08:00	8-Mar-19	18:00	Daily	Annual Maintenance of Line Related Equipments	MEGPTCL	MEGPTCL	
60	305	400	MAIN BAY (407) OF AURANGABAD (PG)-2 @ AKOLA	8-Mar-19	10:00	8-Mar-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
61	306	220	OLD GCR PARLI (MSETCL)-PARLY (PG)	8-Mar-19	08:00	8-Mar-19	16:00	Daily	Vibration Damper fixing	MSETCL	MSETCL	
62	307	400	Partial Bus-1 @ Padgha	8-Mar-19	7:00	10-Mar-19	18:00	Cont.	Commissioning of Bus sectionalizer & conductor replacement	MSETCL	MSETCL	Contingency plan by SLDC Maharashtra'
63	309	400	TIE BAY (429) OF WARORA CKT-1 @ CHANDRAPUR 2	8-Mar-19	09:00	8-Mar-19	18:00	Daily	Routine Maintenance and Diagnostic Testing Works	MSETCL	MSETCL	
64	311	400	KORADI 2-WARDHA PGCL	9-Mar-19	09:00	9-Mar-19	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	400KV WARORA-IEPL Line will be in service.
65	312	220	220kv Boisar-Boisar-III line at Boisar	9-Mar-19	9:00	9-Mar-19	14:00	Daily	Main-I relay replacement & For tripping and A/R Trials of Main-I relay (Line will be out of service)	POWERGRID	WRTS-2	
66	318	400	400kv PUNE(GIS)-PUNE(TALEGOAN)_1	9-Mar-19	9:00	9-Mar-19	17:00	Daily	For Replacment of Clamps & connectors	WRTS-1	WRTS-1	
67	331	220	A BUS @ BOISAR II (NOC required for TBC operations from Tarapur & PGCL.)	9-Mar-19	07:00	10-Mar-19	19:00	Cont.	Annual Maintenance of 220kV A Bus Isolators and Bus hot spot attending works.	MSETCL	MSETCL	
68	334	765	Koradi-III-Akola-II Ckt-1	9-Mar-19	08:00	9-Mar-19	18:00	Daily	Annual Maintenance of Line related Equipment	MEGPTCL	MEGPTCL	Maharashtra comment:Subject to Generation available at Tirora
69	335	500	Pole-2 Non base AC filter Z4 (80 MVAR) @ Chandrapur HVDC	9-Mar-19	08:00	9-Mar-19	18:00	Daily	For DCRM of 400 KV Breaker	MSETCL	MSETCL	HVDC link can be operated in normal Bi-pole mode with 1500 MW capacity without any power loss
70	336	220	BHUGAON-WARDHA (PG)	10-Mar-19	11:00	10-Mar-19	14:00	Daily	Tightening of Jumper nut bolt at location no. 14 Y Phase work and Signature analysis Test.	MSETCL	MSETCL	
71	337	400	KALWA-KHARGHAR	10-Mar-19	08:00	10-Mar-19	18:00	Daily	Routine Maintenance	MSETCL	MSETCL	Not to be availed with Kalwa-Padghe outage
72	341	765	Akola II-Ektuni Line2	10-Mar-19	08:00	10-Mar-19	18:00	Daily	Annual Maintenance of Line Related Equipments	MEGPTCL	MEGPTCL	
73	344	400	A/r in N/a of BABHALESHWAR-PADGHE 1	11-Mar-19	09:00	25-Mar-19	18:00	Daily	Online PID Work	MSETCL	MSETCL	
74	345	400	A/r in N/a of DHULE-BABLESHWAR-I & II	11-Mar-19	09:00	12-Mar-19	17:00	Daily	PID testing of insulators	MSETCL	MSETCL	
75	346	400	BABHALESHWAR-PADGHE 1	11-Mar-19	09:00	11-Mar-19	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	
76	360	400	400KV KORADI-BHUSAWAL (Bhusawal end)	11-Mar-19	08:00	15-Mar-19	18:00	Cont.	Restranging of conductor of all three phases of 400 kv Koradi-Bhusawal line due to conversion of Metergauge to Broadgauge of Akot-Akola Railway line	MSETCL	MSETCL	400 kv Akola-Bhusawal, 400 kv Akola-Nandgaonpeth & 400 kv Koradi-Nandgaonpeth are in service.
77	375	400	A/r in N/a of PADGHE-KALWA 2	11-Mar-19	09:00	20-Mar-19	18:00	Daily	PID Testing work of 400 KV Kalwa-Padgha Ckt-2 line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	
78	378	765	BUS-II @ KORADI-3	11-Mar-19	09:00	11-Mar-19	18:00	Daily	Annual Maintenance of Bus Equipments	MEGPTCL	MEGPTCL	Subject to Generation available at Koradi
79	395	400	BABHALESHWAR-PADGHE 2	12-Mar-19	09:00	12-Mar-19	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	
80	396	220	OLD GCR PARLI (MSETCL)-PARLY (PG)	12-Mar-19	08:00	12-Mar-19	16:00	Daily	Vibration Damper fixing	MSETCL	MSETCL	
81	417	400	A/r in N/a of JAIGAD-KARAD-I & II	12-Mar-19	09:00	15-Mar-19	18:00	Daily	Hotline insulator washing	JPTL	JPTL	
82	418	765	BUS-I @ KORADI-3	12-Mar-19	09:00	12-Mar-19	18:00	Daily	Annual Maintenance of Bus Equipments	MEGPTCL	MEGPTCL	
83	419	400	Dabhol-New Koyna line 1 (Line CT/R&Y phase).	12-Mar-19	9:00	13-Mar-19	18:00	Cont.	Replacement of Line CT /R&Y phase)	RGPL	RGPL	
84	432	220	220kv Boisar-Nalasopara Line Boisar	13-Mar-19	9:00	13-Mar-19	14:00	Daily	Main-I relay replacement & For tripping and A/R Trials of Main-I relay (Line will be out of service)	POWERGRID	WRTS-2	mah comment: Please reschedule outage on 15.03.2019
85	434	220	220KV Bus-2 at Pune (Talegaon)	13-Mar-19	9:00	13-Mar-19	17:00	Daily	For Replacment of Clamps & connectors	WRTS-1	WRTS-1	mah comment: Please reschedule outage on 14.03.2019
86	449	400	400KV PADGHE MSETCL-BOISAR	13-Mar-19	10:00	13-Mar-19	18:00	Daily	For AMP works.	WRTS-1	WRTS-1	
87	457	765	765/400KV 500MVA SPARE ICT UNIT @ EKTUNI	13-Mar-19	10:00	13-Mar-19	18:00	Daily	Wdg TAND & CAP Measurement & Routine maintainence	MSETCL	MSETCL	765kv Spare ICT is Hot standy
88	473	220	OSMANABAD-PARLY (PG)	13-Mar-19	08:00	13-Mar-19	16:00	Daily	Vibration Damper fixing	MSETCL	MSETCL	
89	477	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT-2	14-Mar-19	08:00	14-Mar-19	18:00	Daily	Replacement of Broken Spacer cum Vibration Damper	MSETCL	MSETCL	
90	478	400	KOLHAPUR-KOLHAPUR (PG) CKT-1	14-Mar-19	09:00	14-Mar-19	18:00	Daily	Annual Maintenance Work	POWERGRID	MSETCL	
91	479	220	PUSAD-WARDHA (PG)	14-Mar-19	09:00	14-Mar-19	17:00	Daily	Routine Maint. work	MSETCL	MSETCL	
92	509	765	BUS REACTOR (240 MVar) @ EKTUNI	14-Mar-19	10:00	14-Mar-19	18:00	Daily	Wdg TAND & CAP Measurement & Routine maintenance.	MSETCL	MSETCL	Bus reactor will be OUT OF SERVICE

Sr.No.	OCCM Sr.No	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Remarks
				Date	Time	Date	Time					
93	511	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT-2 & CHANDRAPUR-PARLI CKT-3	14-Mar-19	07:00	14-Mar-19	19:00	Daily	(For Replacement of Damaged Earthwire Cross arms on Double Ckt Tower Hence outage on same day on both Ckt i.e CHD-II-Nanded ckt 2 & GCR Chandrapur-Parli ckt-III Line required to carry out work) OR (Tightening of conductor ,Earthwire Hardware & Line Signature Test)	MSETCL	MSETCL	
94	513	400	EKTUNI-BABLESHWAR CKT 1	14-Mar-19	09:00	14-Mar-19	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kV Auragabad ,Bhusawal Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
95	518	400	PARLI-LONIKAND 2 CKT 2	14-Mar-19	10:30	14-Mar-19	18:00	Daily	Hardware Tightening & Fitting Work	MSETCL	MSETCL	
96	521	400	TIE BAY (415) OF CHANDRAPUR-2 & ADANI-2 @ WARORA	14-Mar-19	09:00	14-Mar-19	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintenance work .	MSETCL	MSETCL	Line will be charged through Main CB 416.
97	524	400	A/r in N/a pf CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT-2	15-Mar-19	08:00	30-Mar-19	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	
98	525	400	AKOLA-WARDHA(PG) CKT-2	15-Mar-19	10:00	15-Mar-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
99	526	220	BHUGAON-WARDHA (PG)	15-Mar-19	08:00	17-Mar-19	18:00	Daily	Fixing of vibration Damper at various line location.	MSETCL	MSETCL	
100	527	400	CHANDRAPUR 2-WARORA CKT-1	15-Mar-19	08:00	15-Mar-19	17:00	Daily	Tightening of conductor ,Earthwire Hardware.	MSETCL	MSETCL	
101	528	400	KALWA-KHARGHAR	15-Mar-19	08:00	15-Mar-19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	
102	529	400	KOLHAPUR-KOLHAPUR (PG) CKT-2	15-Mar-19	09:00	15-Mar-19	18:00	Daily	Annual Maintenance work	POWERGRID	MSETCL	
103	536	400	400kV Akola-Aurangabad#2 Main Bay(407) at Akola	15-Mar-19	9:00	15-Mar-19	18:00	Daily	For AMP work	WRTS-1	WRTS-1	
104	537	400	400kV Alkud Line Main bay at KOLHAPUR (MSETCL)	15-Mar-19	9:00	15-Mar-19	18:00	Daily	For Replacement of R-Phase CVT for Secondary Voltage Drift	WRTS-1	WRTS-1	
105	555	765	765/400kV 1500MVA ICT-2 @ EKTUNI	15-Mar-19	10:00	15-Mar-19	18:00	Daily	Wdg TAND & CAP Measurement & Routine maintenance.	MSETCL	MSETCL	Subject to Generation available at Tirora
106	564	220	A/r in N/a of BOISAR II-PGCIL 3	15-Mar-19	09:00	15-Mar-19	17:00	Daily	PID IDENTIFIED FAULTY INSULATOR STRING REPLACEMENT & OTHER MAINTENANCE WORK	MSETCL	MSETCL	
107	565	400	A/r in N/a of CHANDRAPUR-PARLI CKT-3	15-Mar-19	08:00	31-Mar-19	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	
108	567	400	BUS COUPLER @ KORADI	15-Mar-19	09:00	15-Mar-19	18:00	Daily	Relay testing work	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
109	568	400	Bus-1 at BDTCL Dhule	15-Mar-19	8:00	15-Mar-19	18:00	Daily	AMP Work	BDTCL	BDTCL	
110	569	400	Bus-2 at BDTCL Dhule	15-Mar-19	8:00	16-Mar-19	19:00	Daily	AMP Work	BDTCL	BDTCL	
111	571	400	EKTUNI-BABLESHWAR CKT 2	15-Mar-19	09:00	15-Mar-19	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kV Auragabad ,Bhusawal Dhule-Ckt-1&2, Ektuni-ckt-1 will be in service
112	576	765	TIE BAY (711) OF AKOLA CKT-2 & TIRODA CKT-1 @ KORADI-3	15-Mar-19	09:00	15-Mar-19	18:00	Daily	Testing & Maintenance of Bay Breaker & CT	MEGPTCL	MEGPTCL	
113	577	400	A/r in N/a of JAIGAD-NEW KOYNA-I & II	16-Mar-19	09:00	19-Mar-19	18:00	Daily	Hotline insulator washing work	JPTL	JPTL	
114	578	400	CHANDRAPUR-PARLI CKT-3	16-Mar-19	08:00	16-Mar-19	18:00	Daily	Replacement of Broken Spacer cum Vibration Damper & Replacement of faulty Disc	MSETCL	MSETCL	
115	581	400	400kV Akola-Aurangabad#1 Main Bay(404) at Akola	16-Mar-19	9:00	16-Mar-19	18:00	Daily	For AMP work	WRTS-1	WRTS-1	
116	595	765	765/400kV 1500 MVA ICT-1 @ EKTUNI	16-Mar-19	10:00	16-Mar-19	18:00	Daily	Wdg TAND & CAP Measurement & Routine maintenance.	MSETCL	MSETCL	765/400kV ICT-II will be in service.
117	596	765	765/400kV ICT-1 @ TIRODA	16-Mar-19	08:00	16-Mar-19	20:00	Daily	Testing & Maintenance of ICT & its Relays	MEGPTCL	MEGPTCL	Saturday sunhday
118	605	400	A/r in N/a of BABHALESHWAR-PADGHE 2	16-Mar-19	09:00	31-Mar-19	18:00	Daily	For Carrying PID Work	MSETCL	MSETCL	
119	610	400	LONIKAND2-LONIKAND1 (INTERCONNECTOR 1)	16-Mar-19	09:00	16-Mar-19	17:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	
120	611	400	MAIN BAY (416) OF CHANDRAPUR ckt-2 @ WARORA	16-Mar-19	09:00	16-Mar-19	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	Line will be charged through Tie CB 415.
121	612	400	MAIN BUS-2 @ WALUJ	16-Mar-19	10:00	16-Mar-19	17:00	Daily	Routine Maintenance and Testing	MSETCL	MSETCL	Routine Maintenance and Testing
122	614	400	KALWA-TALEGAON (PGCIL)	17-Mar-19	09:00	17-Mar-19	17:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	Mah comment: Outage to be scheduled on 17.03.2019
123	623	400	KHARGHAR-TALEGAON (PG)	17-Mar-19	08:00	17-Mar-19	18:00	Daily	Routine Maintenance	MSETCL	MSETCL	
124	624	400	PARLI-KUMBHARGAON (NANDED) CKT-1	17-Mar-19	09:00	17-Mar-19	18:00	Daily	String Replacement at Loc. No. 843, Bay Maintenance work, C & Tan delta Measurement of Reactor Bushing and winding, CB DCRM & Timing test.	MSETCL	MSETCL	
125	625	400	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT-2	18-Mar-19	08:00	18-Mar-19	18:00	Daily	Replacement of Broken Spacer cum Vibration Damper	MSETCL	MSETCL	
126	626	220	EKLHARA-(OCR)-NAVASARI CKT I	18-Mar-19	09:00	23-Mar-19	18:00	Cont.	replacement of insulator strings to porcelain long rod insulator	MSETCL	MSETCL	
127	627	400	NAGOTHANE-DABHOL 2	18-Mar-19	08:00	18-Mar-19	17:00	Daily	Tree cutting work	MSETCL	MSETCL	
128	637	400	400/220/33 KV 315MVA ICT-1 ON TBC @ BABHALESHWAR	18-Mar-19	08:00	22-Mar-19	18:00	Cont.	Quarterly Maintenance work & Repair scissors of 400KV P.G Isolator and Servicing and alignment of isolators work	MSETCL	MSETCL	400 kV ICT-1 Bay will on TBC only, (Hanger dropper assembly of ICT-1 bay will be remove and connected on 400 kv bus 1 and bus 2 work carried by hot line unit Nashik)
129	638	400	400KV AKOLA-BHUSAWAL (Bhusawal end)	18-Mar-19	08:00	22-Mar-19	18:00	Cont.	Restringing of conductor of all three phases of 400 kV Akola-Bhusawal line due to conversion of Metergauge to Broadgauge of Akot-Akola Railway line	MSETCL	MSETCL	400 kV Koradi-Bhusawal, 400 kV Akola-Nandgaonpeth & 400 kV Koradi-Nandgaonpeth are in service.
130	659	400	A/r in N/a of DHULE-SSNNL I & II	18-Mar-19	09:00	19-Mar-19	17:00	Daily	PID Testing of insulators	MSETCL	MSETCL	
131	671	400	NAGOTHANE-DABHOL 2	19-Mar-19	08:00	19-Mar-19	17:00	Daily	Tree cutting work	MSETCL	MSETCL	
132	672	220	PUSAD-WARDHA (PG)	19-Mar-19	08:00	21-Mar-19	18:00	Daily	Fixing of vibration Damper at various line location.	MSETCL	MSETCL	
133	677	220	220KV Pandhurna-Kamleshwar	19-Mar-19	9:00	19-Mar-19	18:00	Daily	For line maintenance work	MPPTCL	MPPTCL	
134	695	400	MAIN BAY-404 OF SOLAPUR PG @ ALKUD	19-Mar-19	10:00	19-Mar-19	13:30	Daily	Quarterly maintenance work	MSETCL	MSETCL	
135	696	400	TIE BAY-405 OF SOLAPUR PG @ ALKUD	19-Mar-19	14:00	19-Mar-19	17:30	Daily	Quarterly maintenance work	MSETCL	MSETCL	
136	697	765	Tirora-Koradi III ckt-1	19-Mar-19	08:00	19-Mar-19	18:00	Daily	Annual Maintenance of Line Related Equipments	MEGPTCL	MEGPTCL	Subject to Generation available at Tirora
137	700	400	CHANDRAPUR-PARLI CKT-3	20-Mar-19	08:00	20-Mar-19	18:00	Daily	Replacement of Broken Spacer cum Vibration Damper	MSETCL	MSETCL	
138	709	400	400kV Bus-II at Wardha	20-Mar-19	9:00	20-Mar-19	18:00	Daily	Bus isolator alignment	WRTS-1	WRTS-1	C
139	724	400	MAIN BUS-1 @ CHANDRAPUR SWITCHING SS	20-Mar-19	09:00	20-Mar-19	18:00	Daily	Routine Maintenance and Diagnostic Testing Works	MSETCL	MSETCL	Subject to generation at Chandrapur swg stn
140	725	400	MAIN BUS-1 @ LAMBOTI	20-Mar-19	10:00	20-Mar-19	18:00	Daily	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on Main Bus-2
141	727	220	OSMANABAD-PARLY (PG)	20-Mar-19	08:00	20-Mar-19	16:00	Daily	Vibration Damper fixing	MSETCL	MSETCL	
142	730	400	A/r in N/a of KALWA-TALEGAON (PGCIL) & KALWA-KHARGHAR	21-Mar-19	09:00	25-Mar-19	18:00	Daily	PID Testing work of 400 KV Kalwa-Talegaon & 400KV Kalwa-Kharghar (D/C) line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	

Sr.No.	OCCM Sr.No	Voltage Level	Line / Element	From		To		Basis	Reason	System	Agency	Remarks
				Date	Time	Date	Time					
143	736	400	DABHOL-NEW KOYNA CKT-2	21-Mar-19	08:00	27-Mar-19	18:00	Daily	L E Scheme for insulator string replacement & Cold washing insulators	MSETCL	MSETCL	Load can be managed on Dabhol-New koyna CKT-I line
144	739	400	MAIN BUS-2 @ CHANDRAPUR SWITCHING SS	21-Mar-19	09:00	21-Mar-19	18:00	Daily	Routine Maintenance and Diagnostic Testing Works	MSETCL	MSETCL	Subject to generation at Chandrapur swg stn
145	741	400	A/r in N/a of JAIGAD-NEW KOYNA-I & II	22-Mar-19	09:00	23-Mar-19	18:00	Daily	hotline washing work	JPTL	JPTL	
146	765	400	MAIN BAY (412) OF STATION TF 4 @ TIRORA	22-Mar-19	08:00	22-Mar-19	18:00	Daily	Testing & Maintenance of Bay Breaker & CT	APML	APML	
147	766	400	MAIN BUS-1 @ KUMBHARGAON (NANDED)	22-Mar-19	10:00	22-Mar-19	18:00	Daily	Annual maintenance work.	MSETCL	MSETCL	
148	780	400	KALWA-TALEGAON (PGCIL)	24-Mar-19	08:00	24-Mar-19	18:00	Daily	Routine and Bay Maintenance work. Maintenance	MSETCL	MSETCL	
149	781	220	220kV Navsari-Nashik line No. 1	24-Mar-19	9:00	24-Mar-19	17:00	Daily	General bay maint.	GETCO	GETCO	
150	784	400	MAIN BUS-A @ KALWA	24-Mar-19	09:30	24-Mar-19	17:30	Daily	Bus Maintenance work.	MSETCL	MSETCL	Mah comment: Outage to be scheduled on 24.03.2019
151	816	400	A/r in N/a of DHULE-SSNNL I & II	25-Mar-19	09:00	25-Mar-19	17:00	Daily	PID Testinmg of insulators	MSETCL	MSETCL	
152	817	400	A/r in N/a of KHADKA-DEEPNAGAR CKT 1 & 2	25-Mar-19	06:00	26-Mar-19	18:00	Daily	Proposal for On Line PID By PID Unti,Bhusawal	MSETCL	MSETCL	
153	818	400	AKOLA-AURANGABAD(PG) CKT-2	25-Mar-19	08:00	25-Mar-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	
154	821	220	DEOLI(PGCIL)-BADNERA	25-Mar-19	10:00	25-Mar-19	17:00	Daily	Maintenance work on line	MSETCL	MSETCL	
155	822	765	ICT1_765/400kv_PADGHE(GIS)	25-Mar-19	10:00	25-Mar-19	16:00	Daily	For Commissioning of CSD of ICT-1 through Tie Bay 702.	WRTS-1	WRTS-1	
156	824	220	Nasik-NAVASARI II	25-Mar-19	09:00	30-Mar-19	18:00	Cont.	replacement of insulator strings to long rod porcelain under scheme	MSETCL	MSETCL	
157	850	400	8Q MVAR BUS REACTOR-2 @ BABHALESHWAR	26-Mar-19	08:00	26-Mar-19	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	80MVAR Reactor-1 are in service
158	851	400	A/r in N/a of DHULE-SSNNL I & II	26-Mar-19	09:00	26-Mar-19	17:00	Daily	PID Testinmg of insulators	MSETCL	MSETCL	
159	852	400	A/r in N/a of JAIGAD-KARAD-I & II	26-Mar-19	09:00	28-Mar-19	18:00	Daily	Hotline washing work	JPTL	JPTL	
160	853	400	A/r in N/a of KHARGHAR-TALEGAON (PG) & KALWA-TALEGAON (PGCIL)	26-Mar-19	09:00	30-Mar-19	18:00	Daily	PID Testing work of 400 KV Kalwa-Talegaon & 400KV Kharghar-Talegaon (D/C) line Insulator strings at various locations. Auto-Reclose function to be out of service.	MSETCL	MSETCL	
161	855	400	B-BUS @ KHARGHAR	26-Mar-19	08:00	26-Mar-19	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	
162	857	400	BUS COUPLER @ KHARGHAR	26-Mar-19	08:00	27-Mar-19	18:00	Daily	Routine Maintenance & Diagnostic testing work	MSETCL	MSETCL	
163	858	400	BUS REACTOR_400KV_50MVAR_WARDHA	26-Mar-19	9:00	26-Mar-19	18:00	Daily	For CSD rectification and online trials	WRTS-1	WRTS-1	
164	859	220	DEOLI(PGCIL)-BADNERA	26-Mar-19	10:00	26-Mar-19	17:00	Daily	Maintenance work on line	MSETCL	MSETCL	
165	862	400	MAIN BAY (413) OF KORADI 2 LINE @ WARDHA (PG)	26-Mar-19	09:00	26-Mar-19	17:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
166	863	400	MAIN BAY (414) OF TIRODA CKT-2 @ WARORA	26-Mar-19	09:00	27-Mar-19	18:00	Cont.	Breaker Pole Replacement	ATIL	ATIL	
167	864	400	PARLI-SOLAPUR (LAMBOTI)	26-Mar-19	09:00	26-Mar-19	17:00	Daily	C & Tan delta Measurement of Reactor Bushing and winding. Bay Maintenance work.	MSETCL	MSETCL	
168	890	400	MAIN BAY (429) OF WARORA-WARDHA(PG) @400KV WARDHA(PG)	27-Mar-19	09:00	27-Mar-19	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work.	MSETCL	MSETCL	Line will be charged through Tie CB 428.
169	891	220	OSMANABAD-PARLY (PG)	27-Mar-19	08:00	27-Mar-19	16:00	Daily	Vibration Damper fixing	MSETCL	MSETCL	
170	895	220	PUSAD-WARDHA (PG)	28-Mar-19	09:00	28-Mar-19	17:00	Daily	For Routine Maintainance Work	MSETCL	MSETCL	
171	901	220	220kV Navsari-Nashik line No. 2	28-Mar-19	9:00	28-Mar-19	17:00	Daily	General bay maint.	GETCO	GETCO	
172	902	220	220kV Talegaon (MSETCL)-1 Main bay (202) at Pune (Talegaon)	28-Mar-19	9:00	28-Mar-19	17:00	Daily	For AMP works	WRTS-1	WRTS-1	
173	909	765	400KV KORADI-SATPURA	28-Mar-19	9:00	28-Mar-19	18:00	Daily	For AMP work	WRTS-1	WRTS-1	
174	910	400	400kv PARLI-PUNE(GIS)_1	28-Mar-19	9:00	28-Mar-19	18:00	Daily	For Reactor , line terminal equipments and line AMP works.	WRTS-1	WRTS-1	
175	922	400	BUS COUPLER @ LONIKAND-1	28-Mar-19	09:00	28-Mar-19	17:00	Daily	Routine Dignostic testing & maintenance work	MSETCL	MSETCL	
176	924	400	DABHOL-NAGOTHANE CKT-2	28-Mar-19	8:00	28-Mar-19	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on Dabhol-Nagothane CKT-I line
177	926	400	KHARGHAR-TALEGAON (PG)	28-Mar-19	09:00	28-Mar-19	17:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	Mah comment: Outage to be scheduled on 31.03.2019
178	927	400	KOLHAPUR (TALANDGE)-ALKUD	28-Mar-19	09:00	28-Mar-19	18:00	Daily	Annual Maintenance Work	POWERGRID	MSETCL	
179	928	400	MAIN BUS-1 @ KORADI (ONLY BUS BAR PROTECTION WILL BE OUT)	28-Mar-19	09:00	30-Mar-19	20:00	Cont.	New Busbar commissioning work	MSETCL	MSETCL	SUBJECT TO SCHEME COMPLETION (ONLY BUS BAR PROTECTION WILL BE OUT)
180	929	400	MAIN BUS-2 @ KORADI (ONLY BUS BAR PROTECTION WILL BE OUT)	28-Mar-19	09:00	30-Mar-19	20:00	Cont.	New Busbar commissioning work	MSETCL	MSETCL	Subject to scheme completion (ONLY BUS BAR PROTECTION WILL BE OUT)
181	930	400	MAIN BUS-2 @ LAMBOTI	28-Mar-19	10:00	28-Mar-19	18:00	Cont.	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on Main Bus-1
182	932	400	Tirora-Warora Ckt-II	28-Mar-19	09:00	28-Mar-19	18:00	Daily	Annual Maintenance of Line Related Equipments	ATIL	ATIL	
183	933	400	KOLHAPUR-SOLAPUR (PG) CKT-2	29-Mar-19	09:00	29-Mar-19	18:00	Daily	Annual Maintenance Work	POWERGRID	MSETCL	Shall be planned with transmission lincensee
184	937	220	220KV Pune-Talegaon (MSETCL)-2 at Pune (Talegaon)	29-Mar-19	9:00	29-Mar-19	17:00	Daily	For AMP of Line side Equipments at Pune (Talegaon).	MSETCL	WRTS-1	
185	941	765	400KV BHILAI-KORADI	29-Mar-19	9:00	29-Mar-19	18:00	Daily	For Line and SS AMP works	WRTS-1	WRTS-1	
186	954	220	A/r in N/a of NALASOPARA-BOISAR PG	29-Mar-19	09:00	29-Mar-19	17:00	Daily	PID IDENTIFIED FAULTY INSULATOR STRING REPLACEMENT & OTHER MAINTENANCE WORK	MSETCL	MSETCL	
187	958	400	Tirora-Warora Ckt-I	29-Mar-19	09:00	29-Mar-19	18:00	Daily	Annual Maintenance of Line Related Equipments	ATIL	ATIL	Saturday/Sunday
188	959	220	220KV Wardha (PGCIL)-Wardha (Bhugaon) line	30-Mar-19	9:00	30-Mar-19	18:00	Daily	For AMP work	MSETCL	WRTS-1	
189	969	400	LiLO Solapur-Karad Circuit-I (Solapur-Lamboti Circuit)	30-Mar-19	8:00	30-Mar-19	16:00	Daily	Annual maintenance work	WTPL	WTPL	
190	973	765	BUS REACTOR (703) @ AKOLA 2	31-Mar-19	09:00	31-Mar-19	18:00	Daily	Testing and Maintenance of Bus Reactor	MEGPTCL	MEGPTCL	
191	975	400	MAIN BUS-B @ KALWA	31-Mar-19	09:30	31-Mar-19	17:30	Daily	Bus Maintenance work.	MSETCL	MSETCL	
192	976	400	Solapur-Karad line	31-Mar-19	8:00	31-Mar-19	16:00	Daily	Annual maintenance work	WTPL	WTPL	

State Element Outages list for the month of March'19

Sr.No.	Voltage (kV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
1	400	LONIKAND 1 - KOYNA STAGE-IV	01-Mar-19	09:00	31-Mar-19	17:00	Daily	Permission for Auto Reclose to be kept OFF for PID testing work	MSETCL	MSETCL	Permission for AR required in Non Auto mode
2	400	CHANDRAPUR - KHAPERKHEDA	01-Mar-19	08:00	14-Mar-19	17:00	Daily	For PID Work, Shifting of auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID Work, Shifting of auto reclose switch to non auto mode.
3	400	JEJURI- KOYNA STAGE-IV	01-Mar-19	09:00	31-Mar-19	17:00	Daily	Permission for Auto Reclose to be kept OFF for PID testing work	MSETCL	MSETCL	Permission for AR required in Non Auto mode
4	400	400/220KV 315MVA ICT - 1 @ NEW KOYNA	01-Mar-19	09:00	01-Mar-19	12:00	Daily	Busbar scheme commissioning work	MSETCL	MSETCL	Load can be managed on 315 MVA ICT -II
5	400	400/220KV 315MVA ICT - 2 @ NEW KOYNA	01-Mar-19	14:00	01-Mar-19	17:00	Daily	Busbar scheme commissioning work	MSETCL	MSETCL	Load can be managed on 315 MVA ICT -I
6	400	NEW KOYNA - STAGE IV CKT - 1	03-Mar-19	09:00	03-Mar-19	12:00	Daily	Busbar scheme commissioning work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-II line
7	400	NEW KOYNA - STAGE IV CKT - 2	03-Mar-19	14:00	03-Mar-19	17:00	Daily	Busbar scheme commissioning work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-I line
8	400	AKOLA-NANDGAONPETH (RPL-AMT)	04-Mar-19	12:00	09-Mar-19	18:00	Daily	PID testing of insulator strings by PID Uint Akola of O&M Circle Akola. A/R shall be kept in non auto mode.	MSETCL	MSETCL	400 kv Koradi- Bhusawal, 400 kv Akola-Bhusawal & 400 kv Koradi-Nandgaonpeth are in service.
9	400	NEW KOYNA - KARAD CKT - 1	04-Mar-19	09:00	04-Mar-19	12:00	Daily	Busbar scheme commissioning work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-II line
10	400	NEW KOYNA - KARAD CKT - 2	04-Mar-19	14:00	04-Mar-19	17:00	Daily	Busbar scheme commissioning work	MSETCL	MSETCL	Load can be managed on 400KV New Koyna- Stage 4 CKT-I line
11	400	KARAD - TALANDGE CKT 1	05-Mar-19	10:00	05-Mar-19	17:00	Daily	Quarterly. Maint. Work at both end	MSETCL	MSETCL	Load manage on other Two ICT'S
12	400	THAPTI TANDA - WALUJ	05-Mar-19	10:00	05-Mar-19	17:00	Daily	Routine Maintenance & Line Signature	MSETCL	MSETCL	Line should be kept off from both ends.
13	400	WARORA - IEPL	05-Mar-19	09:00	05-Mar-19	17:00	Daily	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	MSETCL	MSETCL	400KV KORADI-WARDHA Line is in ckt
14	400	KHADKA - BABLESHWAR	05-Mar-19	06:00	06-Mar-19	18:00	Daily	For replacement of Faulty/break insulator string	MSETCL	MSETCL	NIL
15	400	400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	05-Mar-19	08:00	05-Mar-19	17:00	Daily	Bushing replacement work and ICT Painting , Isolator maintenance	MSETCL	MSETCL	...
16	400	NEW KOYNA - JAIGAD CKT - 1	05-Mar-19	09:00	05-Mar-19	12:00	Daily	Busbar scheme commissioning work	MSETCL	MSETCL	Load can be managed on 400KV Jaigad CKT-II line
17	400	NEW KOYNA - JAIGAD CKT - 2	05-Mar-19	14:00	05-Mar-19	17:00	Daily	Busbar scheme commissioning work	MSETCL	MSETCL	Load can be managed on 400KV Jaigad CKT-I line
18	400	400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	06-Mar-19	08:00	06-Mar-19	17:00	Daily	Bushing replacement work and ICT Painting , Isolator maintenance	MSETCL	MSETCL	...
19	400	THAPTI TANDA - WALUJ	06-Mar-19	10:00	06-Mar-19	17:00	Daily	Routine Line Maintenance	MSETCL	MSETCL	Line should be kept off from both ends
20	400	TIE BAY (402) of WALUJ @ TAPTITANDA	06-Mar-19	11:00	06-Mar-19	17:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Nil
21	400	400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	06-Mar-19	10:00	06-Mar-19	18:00	Daily	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on 400/220KV ICT-II
22	400	MAIN BAY (403) of WALUJ @ TAPTITANDA	07-Mar-19	11:00	07-Mar-19	17:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Nil
23	400	KARAD - LONIKAND 1	07-Mar-19	10:00	07-Mar-19	17:00	Daily	Annual Maint. work	MSETCL	MSETCL	Load manage on other ckt.
24	400	400/220/33 KV 500 MVA ICT - 1 @ NANDED	07-Mar-19	10:00	07-Mar-19	18:00	Daily	Tan-d measurement.	MSETCL	MSETCL	-
25	400	400/220/33 KV 315 MVA ICT - 2 @ PARLI	07-Mar-19	09:00	07-Mar-19	18:00	Daily	C and Tan delta measurement of Bushing and Winding. Bay Maintenance work.	MSETCL	MSETCL	-
26	400	400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	07-Mar-19	08:00	07-Mar-19	17:00	Daily	Bushing replacement work and ICT Painting , Isolator maintainance	MSETCL	MSETCL	...
27	400	DEEPNAGAR AURANGABAD	07-Mar-19	06:00	09-Mar-19	18:00	Daily	Outage proposal for replacement of faulty Dead end & mid span joint at various LOCs	MSETCL	MSETCL	NIL
28	400	400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	08-Mar-19	08:00	08-Mar-19	18:00	Daily	Routine Maintenance & Dignostic testing work	MSETCL	MSETCL	...
29	400	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	08-Mar-19	08:00	08-Mar-19	18:00	Daily	Routine Maintenance and Testing	MSETCL	MSETCL	Routine Maintenance and Testing
30	400	KHADKA- DEEPNAGAR CKT 1 ON TBC @ KHADKA	08-Mar-19	08:00	08-Mar-19	18:00	Daily	For DCRM of Main breaker	MSETCL	MSETCL	Line will be shifted on TBC
31	400	KORADI-NANDGAONPETH (RPL) ON TBC @ KORADI	08-Mar-19	09:00	08-Mar-19	18:00	Daily	Shifting of Koradi-RPL line on TBC for CB DCRM work	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
32	400	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	09-Mar-19	09:00	09-Mar-19	18:00	Daily	Half yearly maintenance And diagnostic testing	MSETCL	MSETCL	Load will be managed by 400/220 KV 501MVA ICT-I , load effected NIL
33	400	THAPTI TANDA - WALUJ (AR in Non-auto mode)	11-Mar-19	10:00	11-Mar-19	17:00	Daily	Line Maintenance By Hotline Method	MSETCL	MSETCL	A/R To be kept off from Both End
34	400	PADGHE - NAGOTHANE 1	11-Mar-19	08:00	11-Mar-19	17:00	Daily	Faulty string and Jumper replacement work	MSETCL	MSETCL	...
35	400	400/132 KV 200 MVA ICT - 1 ON TBC @ KHADKA	11-Mar-19	08:00	11-Mar-19	18:00	Daily	For DCRM of Main breaker	MSETCL	MSETCL	ICT will be shifted on TBC
36	400	125MVAR BUS REACTOR @ WARORA	11-Mar-19	08:00	11-Mar-19	18:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	During outage reactor is in off condition
37	400	400/220/33 KV 315MVA ICT - 1 @ AKOLA	11-Mar-19	08:00	11-Mar-19	18:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	Nil
38	400	DEEPNAGAR AURANGABAD	11-Mar-19	06:00	16-Mar-19	18:00	Daily	Proposal for Replacement of Faulty Dead end & mid span joint at various LOCs	MSETCL	MSETCL	NIL
39	400	BABLESHWAR- AURANGABAD (WALUJ)	12-Mar-19	09:00	12-Mar-19	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kv Bhusawal,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
40	400	400/220 KV 500 MVA ICT @ ALKUD	12-Mar-19	09:30	12-Mar-19	17:30	Daily	Quarterly maintenance work	MSETCL	MSETCL	NA
41	400	PADGHE - NAGOTHANE 1	12-Mar-19	08:00	12-Mar-19	17:00	Daily	Faulty string and Jumper replacement work	MSETCL	MSETCL	...
42	400	JAIGAD-KARAD-I	12-Mar-19	10:00	12-Mar-19	17:00	Daily	Retrofitting of numerical LBB & overvoltage.Prot relay	MSETCL	MSETCL	Load manage on 400 kv JAIGAD -2
43	400	MAIN BAY (404) OF ICT -1 @ WARORA	12-Mar-19	07:00	12-Mar-19	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	Line will be charged through Tie CB 403 (400KV ICT No -1 handed over to 400kv Bableshtar)
44	400	NEW KOYNA-KARAD -CKT 1	12-Mar-19	08:00	12-Mar-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	N. Koyna-II ckt will be in service
45	400	KHADKA - BABLESHWAR	13-Mar-19	09:00	13-Mar-19	17:00	Daily	Quarterly Maintenance work & Servicing and alignment of PG isolators work	MSETCL	MSETCL	400 kv Auragabad ,Dhule-Ckt-1&2, Ektuni-ckt-2 will be in service
46	400	NEW KOYNA-KARAD -CKT 1	13-Mar-19	08:00	13-Mar-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	N. Koyna-II ckt will be in service
47	400	JAIGAD-KARAD-I	13-Mar-19	10:00	13-Mar-19	17:00	Daily	Retrofitting of numerical LBB & overvoltage.Prot relay	MSETCL	MSETCL	Load manage on 400 kv JAIGAD -2

Sr.No.	Voltage (kV)	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
48	400	TIE BAY (403) OF BUS RECTOR & ICT -1 @ WARORA	13-Mar-19	07:00	13-Mar-19	17:00	Daily	Routine maintenance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	Line will be charged through Main CB 404 (400KV ICT No -1 handed over to 400kv Bableshtar)
49	400	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	13-Mar-19	10:00	13-Mar-19	18:00	Daily	Diagnostic Testing	MSETCL	MSETCL	Load will be managed on 400/220KV ICT-I
50	400	400KV KORADI-BHUSAWAL (Koradi end)	13-Mar-19	09:00	13-Mar-19	18:00	Daily	Koradi - Bhusawal Reactor-Winding resistance, SFRA	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
51	400	MAIN BAY (410) OF STATION TF 8A @ CHANDRAPUR SWG S/S	13-Mar-19	09:00	13-Mar-19	18:00	Daily	Routine Maintenance and Diagnostic Testing Works	MSETCL	MSETCL	Routine Maintenance and Diagnostic Testing Works
52	400	THAPTI TANDA - WALUJ	13-Mar-19	10:00	13-Mar-19	17:00	Daily	Line Maintenance by Hotline Method	MSETCL	MSETCL	A/R Kept off from both ends
53	400	400/220/33 KV 500 MVA ICT - 2 @ JEJURI	14-Mar-19	09:00	14-Mar-19	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	Total load will be fed from 400/220KV ICT-I BH&L & ICT-III Alstom
54	400	JEJURI- KOYNA STAGE-IV	14-Mar-19	08:00	14-Mar-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	Jejuri-Lonikand ckt will be in service
55	400	JAIGAD-KARAD-II	14-Mar-19	10:00	14-Mar-19	17:00	Daily	Retrofitting of numerical LBB & overvoltage.Prot relay	MSETCL	MSETCL	Load manage on 400 kV JAIGAD -1
56	400	PADGHE - NAGOTHANE 2	14-Mar-19	08:00	14-Mar-19	17:00	Daily	Faulty string and Jumper replacement work	MSETCL	MSETCL	...
57	400	400/220/33 KV 500 MVA ICT - 3 @ PARLI	14-Mar-19	09:00	14-Mar-19	17:00	Daily	HV CT C & Tan delta Measurement and HV CB DCRM & Timing, Bay Maintenance work.	MSETCL	MSETCL	-
58	400	400/220/33 KV 500 MVA ICT - 2 @ NANDED	14-Mar-19	10:00	14-Mar-19	18:00	Daily	Tan-d measurement	MSETCL	MSETCL	-
59	400	400/220/33 KV 315MVA ICT - 1 @ CHAKAN	14-Mar-19	09:00	14-Mar-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-
60	400	CHANDRAPUR - KHAPERKHEDA	14-Mar-19	09:00	14-Mar-19	18:00	Daily	Line Maintenance work	MSETCL	MSETCL	NA
61	400	TIE BAY (411) OF STATION TF 8A & CHANDRAPUR 2 CKT - 2 @ CHANDRAPUR SWG S/S	14-Mar-19	09:00	14-Mar-19	18:00	Daily	Routine Maintenance and Diagnostic Testing Works	MSETCL	MSETCL	Routine Maintenance and Diagnostic Testing Works
62	400	DEEPNAGAR - THAPTI TANDA	14-Mar-19	09:00	14-Mar-19	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NIL
63	400	LONIKAND 1 - KOYNA STAGE-IV	15-Mar-19	08:00	15-Mar-19	18:00	Daily	Chemical Cleaning of insulators	MSETCL	MSETCL	N. Koyana-II ckt will be in service
64	400	JAIGAD-KARAD-II	15-Mar-19	10:00	15-Mar-19	17:00	Daily	Retrofitting of numerical LBB & overvoltage.Prot relay	MSETCL	MSETCL	Load manage on 400 kV JAIGAD -1
65	400	DEEPNAGAR - THAPTI TANDA	15-Mar-19	09:00	15-Mar-19	18:00	Daily	Line maintenance work	MSETCL	MSETCL	NIL
66	400	400/132 KV 200 MVA ICT - 2 ON TBC @ KHADKA	15-Mar-19	08:00	15-Mar-19	18:00	Daily	For DCRM of Main breaker	MSETCL	MSETCL	ICT will be shifted on TBC
67	400	PADGHE - NAGOTHANE 2	15-Mar-19	08:00	15-Mar-19	17:00	Daily	Faulty string and Jumper replacement work	MSETCL	MSETCL	...
68	400	400/220/33KV 315MVA ICT - 3 @ LONIKAND	16-Mar-19	09:00	16-Mar-19	17:00	Daily	Routine Dignostic testing & maintenance work	MSETCL	MSETCL	-
69	400	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	16-Mar-19	08:00	16-Mar-19	18:00	Daily	Quarterly Maintenance work & Diagostic work	MSETCL	MSETCL	400/220kv 315MVA ICT- I , 501 MVA ICT -III& IV will be in service
70	400	THAPTI TANDA - WALUJ	16-Mar-19	09:00	16-Mar-19	18:00	Daily	Line maintenance work	MSETCL	MSETCL	Nil
71	400	NEW KOYNA - JAIGAD CKT - 1	16-Mar-19	08:00	17-Mar-19	18:00	Daily	Distance main 1 Relay retrofitting work	MSETCL	MSETCL	Load can be managed on 400KV Jaigad CKT-II line
72	400	400/220/20 KV 500MVA ICT - 3 @ KALWA	17-Mar-19	09:30	17-Mar-19	17:30	Daily	y ph PRV gasket replacement work to attend oil leakage & maintenance work.	MSETCL	MSETCL	-
73	400	400/220/33 KV 315MVA ICT - 2 @ AKOLA	18-Mar-19	08:00	18-Mar-19	08:00	Daily	Routine Maintenance & testing work	MSETCL	MSETCL	Nil
74	400	NEW KOYNA - JAIGAD CKT - 2	18-Mar-19	08:00	19-Mar-19	18:00	Daily	Distance main 2 Relay retrofitting work	MSETCL	MSETCL	Load can be managed on 400KV Jaigad CKT-I line
75	400	THAPTI TANDA - WALUJ	19-Mar-19	10:00	19-Mar-19	17:00	Daily	Line Maintenance by hotline method	MSETCL	MSETCL	A/R To be kept off from both ends
76	400	TBC @ KARAD	20-Mar-19	10:00	20-Mar-19	17:00	Daily	Quarterly. Maint. Work	MSETCL	MSETCL	NA
77	400	400/220/20 KV 300 MVA ICT - 1 @ KORADI	20-Mar-19	09:00	20-Mar-19	18:00	Daily	Relay testing work	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
78	400	125 MVar BUS REACTOR @ ALKUD	21-Mar-19	09:30	21-Mar-19	17:30	Daily	Quarterly maintenance work	MSETCL	MSETCL	NA
79	400	JEJURI- KOYNA STAGE-IV	21-Mar-19	09:00	21-Mar-19	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	Total load will be fed from 400KV Jejuri-Lonikand Line
80	400	400/220/33 KV 315 MVA ICT - 2 @ KORADI	22-Mar-19	09:00	22-Mar-19	18:00	Daily	Relay testing work	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
81	400	400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	23-Mar-19	08:00	23-Mar-19	18:00	Daily	Quarterly Maintenance work & Diagostic work	MSETCL	MSETCL	400/220kv 315MVA ICT- II , 501 MVA ICT -III& IV will be in service
82	400	80 MVar BUS REACTOR - 1 @ BABHALESHWAR	25-Mar-19	08:00	25-Mar-19	18:00	Daily	Quarterly Maintenance work	MSETCL	MSETCL	80MVAR Reactor -2 are in service
83	400	AKOLA-NANDGAONPETH (RPL-AMT)	25-Mar-19	08:00	27-Mar-19	18:00	Daily	Work of replacement of faulty strings having 03 & above no. of punctured discs detected in PID by agency by availing outages (cold line).	MSETCL	MSETCL	400 kV Koradi- Bhusawal, 400 kV Akola-Bhusawal & 400 kV Koradi-Nandgaonpeth are in service.
84	400	GT - 6 @ KORADI	27-Mar-19	09:00	27-Mar-19	18:00	Daily	CT tan Delta measurement	MSETCL	MSETCL	Outages will be availed subject to wheather conditions.
85	400	LONIKAND 1-JEJURI	28-Mar-19	09:00	28-Mar-19	17:00	Daily	Line Maintenance & Routine Dignostic testing work	MSETCL	MSETCL	-
86	400	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	28-Mar-19	09:00	28-Mar-19	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	Total load will be fed from 400/220KV ICT-I BH&L & ICT-II CGL
87	400	TBC @ CHAKAN	28-Mar-19	09:00	28-Mar-19	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	-
88	400	TIE BAY (402) OF ICT -1 AND LONIKAND1 @ JEJURI	28-Mar-19	09:00	28-Mar-19	18:00	Daily	Annual maintenance work & testing work	MSETCL	MSETCL	ICT-I will be in service through 401 CB & Lonikand Line will be in service through 403 CB
89	400	NEW KOYNA - STAGE IV CKT - 1	29-Mar-19	8:00	29-Mar-19	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on 400KV New Koyana- Stage 4 CKT-II line
90	400	NEW KOYNA - STAGE IV CKT - 2	30-Mar-19	8:00	30-Mar-19	18:00	Daily	Cold washing & string replacement of insulator strings	MSETCL	MSETCL	Load can be managed on 400KV New Koyana- Stage 4 CKT-I line