

Maharashtra State Load Despatch Centre

WRPC OCCM approved Monthly Outage list for the Month of March'2020

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	Reason	Daily/Continuous	Name of Requesting Agency	Remarks
1	4	TBC @ WALUJ	1-Mar-20	09:00	7-Mar-20	17:00	CB Overhauling Works	Continuous	MSETCL	CB Overhauling Works
2	8	220KV-WARDHA-PUSAD-1	1-Mar-20	07:00	2-Mar-20	17:00	PID TESTING	Daily	MSETCL	A/R ON NON AUTO MODE
3	9	765KV-AKOLA (2)-KORADI-III-1	1-Mar-20	08:00	6-Mar-20	18:00	A/R mode to be kept off for attending additional earthing in towers.	Daily	MEGPTCL	A/R mode to be kept off for attending additional earthing in towers.
4	10	765KV-AKOLA (2)-KORADI-III-2	1-Mar-20	08:00	6-Mar-20	18:00	A/R mode to be kept off for attending additional earthing in towers.	Daily	MEGPTCL	A/R mode to be kept off for attending additional earthing in towers.
5	11	400KV-PARLI-M-SOLAPUR-M-1	1-Mar-20	10:00	15-Mar-20	18:00	PID Testing of Insulator strings	Daily	MSETCL	A/R Switch is to made off.
6	12	400KV-BABLESHWAR-PADGHE-1	1-Mar-20	08:00	17-Mar-20	18:00	For Carrying PID Work	Daily	MSETCL	-
7	19	400KV-KALWA-KHARGHAR-1	1-Mar-20	09:00	31-Mar-20	17:00	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	Daily	MSETCL	-
8	27	400KV-KALWA-PUNE-PG-1	2-Mar-20	08:00	2-Mar-20	18:00	Line Maintenance & Routine Diagnostic testing work	Daily	MSETCL	Insulator string replacement found in PID.
9	38	220KV-WARDHA-BADNERA-1	2-Mar-20	09:00	2-Mar-20	18:00	For measurement of Tan delta of CTs and CRM and Timing of CB and Line signature analysis	Daily	MSETCL	NIL
10	39	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-1 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1 at Aurangabad-M (Waluj) - 400KV	2-Mar-20	9:00	2-Mar-20	18:00	For replacement of old BHEL CB with new GE CB, Line load shall be shifted on to TBC during the period	D	POWERGRID_WR1	
11	44	220KV-SOLAPUR-KUMBARI-2	2-Mar-20	9:00	2-Mar-20	18:00	For CT and Line terminal equipments AMP at Solapur end.	D	POWERGRID_WR1	
12	65	MAIN BAY - 765KV/400KV KORADI-III-ICT-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	2-Mar-20	10:00	2-Mar-20	14:00	Dew point measurement in circuit breaker.	Daily	MEGPTCL	Dew point measurement in circuit breaker.
13	69	400KV-RGPPL-BUS-1	2-Mar-20	9:00	3-Mar-20	18:00	Bus Diff relay to be tested.	C	RGPPL	Bus-1 shutdown
14	73	220KV-NASIK-NAVSARI-1	2-Mar-20	09:00	5-Mar-20	18:00	Replacement of old disc insulator by porcelain long rod, Dignostic testing, broken/flash over string replacement found during monkey patrolling, signature analysis, TLS fixing if issued.	D	MSETCL	-
15	76	400KV-KALWA-PADGHE-1	2-Mar-20	09:00	19-Mar-20	17:00	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	Daily	MSETCL	No interruption. Line will be service
16	77	400KV-CHANDRAPUR-II-NANDED-2	2-Mar-20	08:00	31-Mar-20	17:00	For PID work, shifting of auto reclose switch to non auto mode.	Daily	MSETCL	400KV Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III are on DC tower so both lines
17	78	400KV-CHANDRAPUR-GCR-PARLI-M-3	2-Mar-20	08:00	31-Mar-20	17:00	For PID work, shifting of auto reclose switch to non auto mode.	Daily	MSETCL	400KV Chandrapur II- Nanded Ckt-II & Chandrapur GCR- Parli Ckt- III are on DC tower so both lines
18	81	220KV-WARDHA-PUSAD-1	3-Mar-20	07:00	3-Mar-20	17:00	ROUTINE MAINT. WORK	Daily	MSETCL	NA
19	82	400KV-SSP-DHULE-MS-1	3-Mar-20	07:00	3-Mar-20	18:00	rusted/damaged Earthwire replacement work. Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-2 should be kept on Non-Auto Mode.
20	91	MAIN BAY - 400KV-AURANGABAD-M (WALUJ)-AURANGABAD-2 AND AURANGABAD-M (WALUJ) - 400KV - BUS 1/2 at Aurangabad-M (Waluj) - 400KV	3-Mar-20	9:00	3-Mar-20	18:00	For replacement of old BHEL CB with new GE CB, Line load shall be shifted on to TBC during the period	D	POWERGRID_WR1	
21	94	220KV-PARLI-HARANGUL-M-1	3-Mar-20	9:00	3-Mar-20	18:00	For collecting CT oil Sample	D	POWERGRID_WR1	
22	113	400KV-KARAD-SOLAPUR-1	3-Mar-20	10:00	3-Mar-20	18:00	Conversion of SSN to DSN	Daily	MSETCL	Line is Dummy i.e., not in service
23	114	400KV-KOLHAPUR GIS-NARENDRA KUDGI-1	3-Mar-20	10:00	3-Mar-20	18:00	For Line bay AMP works, Dia should be kept open & AR of 400KV-KOLHAPUR GIS-NARENDRA KUDGI-2 to be kept in Non-auto mode for safety measures.	D	POWERGRID_WR1	
24	125	400kv Partial Main Bus-I (from Ektuni-2 to ICT-4 section) at 400kv Babhaleshwar SS	3-Mar-20	8:00	8-Mar-20	18:00	Jumping work and Bus Isolator alignment work for 400kv Kudus-I & 400kv Kudus-II bay at 400kv Babhaleshwar SS	Continuous	MSETCL	1) Removing /reconnecting of 400kv main Bus 1 jumpers will be carried out by hot line unit 2) During outage i) 400kv Ektuni-II line will be shifted on bus-II and handtripped while removing /reconnecting of 400kv Main bus-I jumps by hot line unit ii) 400kv Ektuni-I to be shifted on bus-I iii) ICT-III will remain on TBC till outage period
25	159	MAIN BAY - 400KV-CHANDRAPUR-BHADRAWATI-3 AND CHANDRAPUR - 400KV - BUS 1 at CHANDRAPUR - 400KV	4-Mar-20	9:00	4-Mar-20	18:00	For AMP works	D	POWERGRID_WR1	

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	Reason	Daily/Continuous	Name of Requesting Agency	Remarks
26	160	220KV-PARLI-PARLI-M-1	4-Mar-20	9:00	4-Mar-20	18:00	For collecting CT oil Sample	D	POWERGRID_WR1	
27	176	400KV/11.5KV TIRODA-ST-5	4-Mar-20	09:00	6-Mar-20	18:00	Maintenance of 400kv Station Transformer-5.	Continuous	APML	Maintenance of 400kv Station Transformer-5.
28	181	220KV-PARLI-OSMANABAD-M-1	4-Mar-20	08:00	4-Mar-20	16:00	Line maintenance	Daily	MSETCL	-
29	183	BUS COUPLER BAY - KORADI - 400KV - BUS 1 AND KORADI - 400KV - BUS 2 at Koradi - 400KV	4-Mar-20	08:00	4-Mar-20	18:00	CT Tan delta	Daily	MSETCL	Outages will be availed subject to weather conditions.
30	185	132KV-PENCH-MP-KANHAN-1	4-Mar-20	09:00	4-Mar-20	17:00	Replacement of insulator string	Daily	MSETCL	-
31	186	220KV-WARDHA-BADNERA-1	4-Mar-20	10:00	4-Mar-20	18:00	Routine maintainace work	Daily	MSETCL	NA
32	188	400KV-RGPPL-BUS-2	4-Mar-20	9:00	5-Mar-20	18:00	Bus Diff relay to be tested.	C	RGPPL	Bus-2 shutdown
33	189	400KV-PARLI-M-SOLAPUR-M-1	4-Mar-20	10:00	5-Mar-20	18:00	Due to frequent tripping of 400kv GRL-SLR S/C LINE Replacement of old string by new one is necessary on urgent basis	Daily	MSETCL	-
34	190	220KV-WARDHA-PUSAD-1	4-Mar-20	07:00	31-Mar-20	17:00	PID TESTING	Daily	MSETCL	A/R ON NON AUTO MODE
35	199	400KV-SSP-DHULE-MS-2	5-Mar-20	8:00	5-Mar-20	18:00	For CT & CVT Testing work by External Agency M/s. ERDA, Vadodara	Daily	NCA	
36	237	400KV-SSP-DHULE-MS-2	5-Mar-20	08:00	5-Mar-20	17:00	PID Testing work.	Daily	MSETCL	A/R of DHL-SSNNL-I should be kept in Non-Auto Mode.
37	239	400KV-SSP-DHULE-MS-2	5-Mar-20	07:00	5-Mar-20	18:00	Rusted/damaged Earthwire replacement work. Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-1 should be kept on Non-Auto Mode.
38	242	400KV-SSP-DHULE-MS-2	5-Mar-20	08:00	5-Mar-20	18:00	PID Testing work.	Daily	MSETCL	A/R of DHL-SSNNL-I should be kept in Non-Auto Mode.
39	244	220KV-WARDHA-BHUGAON-1	5-Mar-20	10:00	5-Mar-20	18:00	Routine maintainace work	Daily	MSETCL	NA
40	262	220KV-AURANGABAD-CHITEGAON-1	6-Mar-20	09:00	6-Mar-20	18:00	Routine maintenance and diagnostic testing work	Daily	MSETCL	Routine maintenance and diagnostic testing work
41	275	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	6-Mar-20	10:00	6-Mar-20	17:00	Routine Maintenance & testing work	Daily	MSETCL	NIL
42	278	220KV-WARDHA-BADNERA-1	6-Mar-20	10:00	6-Mar-20	18:00	Routine maintainace work	Daily	MSETCL	NA
43	287	400KV/220KV KHARGHAR-ICT-3	6-Mar-20	08:00	11-Mar-20	18:00	For oil filtration work	Continuous	MSETCL	ICT-1 and 2 will be in service
44	289	BOISAR - 220KV - BUS 1	6-Mar-20	9:00	6-Mar-20	17:30	For Amp	D	POWERGRID_WR2	Boisar
45	299	MAIN BAY - 765KV-KORADI-III-AKOLA-1 AND KORADI-III - 765KV - BUS 2 at KORADI-III - 765KV	6-Mar-20	10:00	6-Mar-20	18:00	Maintenance of Circuit breaker.	Daily	MEGPTCL	Maintenance of Circuit breaker.
46	301	400KV-RGPPL-NEW KOYNA-1	6-Mar-20	9:00	12-Mar-20	18:00	Equipment & Relay testing work /402-52 B bkr O/H work	C	RGPPL	RGPPL-New koyna line 1 outage.
47	302	400KV-LONIKHAND-PUNE-PG-1	6-Mar-20	9:00	6-Mar-20	18:00	For AMP works & Replacement of Clamp & connectors	D	POWERGRID_WR1	416
48	311	WARORA - 400KV - BUS 2	7-Mar-20	09:00	7-Mar-20	17:00	Routine maintainance and diagonastic testing such as CVT tandelta,IR values,isolater maintainance work etc	Daily	MSETCL	400KV MAIN BUS-1 WILL BE IN SERVICE
49	312	220KV-BOISAR-NALASOPARA-1	7-Mar-20	09:00	7-Mar-20	17:00	POST MANSON MAINTENANCE WORK	Daily	MSETCL	-
50	313	400KV/220KV BOISAR-ICT-2	7-Mar-20	9:00	7-Mar-20	17:30	For AMP. Dia to be kept open on both sides.	D	POWERGRID_WR2	Boisar
51	336	MAIN BAY - 765KV-TIRODA-KORADI-III-2 AND KORADI-III - 765KV - BUS 1 at KORADI-III - 765KV	7-Mar-20	10:00	7-Mar-20	18:00	Maintenance of Circuit Breaker.	Daily	MEGPTCL	Maintenance of Circuit Breaker.
52	337	220KV-WARDHA-BHUGAON-1	7-Mar-20	10:00	7-Mar-20	18:00	Routine maintainace work	Daily	MSETCL	NA
53	344	400KV-TIRODA-WARORA-2	7-Mar-20	08:00	25-Mar-20	18:00	A/R mode to be kept off for attending additional earthing in towers.	Daily	ATIL	A/R mode to be kept off for attending additional earthing in towers.
54	345	400KV-TIRODA-WARORA-1	7-Mar-20	08:00	25-Mar-20	18:00	A/R mode to be kept off for attending additional earthing in towers.	Daily	ATIL	A/R mode to be kept off for attending additional earthing in towers.
55	354	400KV-SSP-DHULE-MS-2	8-Mar-20	07:00	8-Mar-20	18:00	Rusted/damaged Earthwire replacement work. Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-1 should be kept on Non-Auto Mode.
56	357	220KV-TALEGAON-PUNE-PG-1	8-Mar-20	09:00	8-Mar-20	17:00	Half yearly maintenance, Diagnostic Testing	Daily	MSETCL	---
57	360	220KV-BOISAR-BOISAR-M-3	8-Mar-20	09:00	8-Mar-20	17:00	Diagnostic testing of Circuit Breaker.	Daily	MSETCL	Only TBC operation. Line will remain in service through TBC breaker.

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	Reason	Daily/Continuous	Name of Requesting Agency	Remarks
58	361	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at Akola - 400KV	8-Mar-20	9:00	13-Mar-20	18:00	For Replacement of BHEL CB with GE CB.	C	POWERGRID_WR1	
59	362	400KV/220KV AURANGABAD-M (WALUJ)-ICT-1	8-Mar-20	09:00	15-Mar-20	17:00	CB Overhauling works	Continuous	MSETCL	CB Overhauling works
60	364	400kv Stn. TF No 5 @ C'pur GCR	9-Mar-20	05:00	11-Mar-20	18:00	Permission for shifting of 400KV STN T/F-5 bay on TBC-II bay	Continuous	MSETCL	During this outage 400KV STN T/F-5 bay will be shift on TBC-2 bay, as the work of replacement of bus conductor of Main Bus-I is to be carried out in 400KV STN T/F-5 bay bay.
61	365	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-2	9-Mar-20	05:00	11-Mar-20	18:00	1) For replacement of old damaged quadraple bus conductor of Main Bus-II in HVDC- II and 400KV STN T/F-5 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-II.	Continuous	MSETCL	During this outage 400KV HVDC Ckt. No.- 1 will be in service. The outage on 400KV HVDC Ckt. No.-2 bay is required as the work of replacement of bus conductor of Main Bus-II is to be carried out in HVDC Ckt. No.-2 bay.
62	366	CHANDRAPUR - 400KV - BUS 2	9-Mar-20	05:00	11-Mar-20	18:00	1) For replacement of old damaged quadraple bus conductor of Main Bus-II in HVDC- II and 400KV STN T/F-5 bay section span. 2)Tightening of nut bolts & hardware of Main Bus-II.	Continuous	MSETCL	During outage, all connected bays/feeders of Main Bus-II will be shifted to Main Bus-I by using the TBC-I & TBC-II bay. After shifting of all bays/feeders connected to Main Bus-II on 400KV Main Bus-I, then after the 400KV Bus Coupler bay will be kept off.
63	371	TAPTHITHANDA - 400KV - BUS 2	9-Mar-20	11:00	9-Mar-20	17:00	Attending the HotSpot of 408 bay 898 isolator 'R' phase	Daily	MSETCL	Nil
64	379	BUS COUPLER BAY - KOLHAPUR-MS - 400KV - BUS 1 AND KOLHAPUR-MS - 400KV - BUS 2 at KOLHAPUR-MS - 400KV	9-Mar-20	09:00	9-Mar-20	18:00	Annual Maintenance Work	Daily	MSETCL	Monday is Load staggering day at kolhapur
65	390	MAIN BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at AKOLA - 400KV	9-Mar-20	10:00	9-Mar-20	17:00	Routine Maintenance & testing work	Daily	MSETCL	NIL
66	391	220KV-WARDHA-WARDHA-M-1	9-Mar-20	10:00	9-Mar-20	18:00	Routine maintainace work,Disc replacement	Daily	MSETCL	NA
67	393	MAIN BAY - 400KV-KALWA-PUNE-PG-1 AND PUNE-PG - 400KV - BUS 1 at PUNE-PG - 400KV	9-Mar-20	9:00	9-Mar-20	18:00	For AMP works & Replacement of Clamp & connectors	D	POWERGRID_WR1	417
68	397	400KV-SSP-DHULE-MS-1	9-Mar-20	08:00	9-Mar-20	18:00	PID Testing work.	Daily	MSETCL	A/R of DHU-SSNNL-I should be kept in Non-Auto Mode.
69	400	400KV-KALWA-PADGHE-2	9-Mar-20	09:00	19-Mar-20	17:00	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	Daily	MSETCL	No interruption. Line will be in service.
70	418	400KV-SSP-DHULE-MS-1	11-Mar-20	07:00	11-Mar-20	18:00	Rusted/damaged Earthwire replacement work. Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-2 should be kept on Non-Auto Mode.
71	419	220KV-PARLI-OSMANABAD-M-1	11-Mar-20	08:00	11-Mar-20	16:00	Line maintenance	Daily	MSETCL	-
72	420	220KV-MAHALAXMI(KONALKATTA)-AMONA-1	11-Mar-20	08:00	11-Mar-20	17:00	Routine Maintenance & Dignostic testing work	Daily	MSETCL	-
73	424	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1 LR @ WALUJ	11-Mar-20	9:00	11-Mar-20	18:00	For AMP works, Line outage outage required for isolation & take into service each operation 15 min for non switchable line reactor at Aurangabad (Waluj) end.	D	POWERGRID_WR1	
74	434	MAIN BAY - 400KV-WARDHA-AKOLA-1 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	11-Mar-20	10:00	11-Mar-20	17:00	Routine Maintenance & testing work	Daily	MSETCL	NIL
75	435	400KV-PARLI-M-SOLAPUR-M-1	11-Mar-20	10:00	11-Mar-20	18:00	Due to frequent tripping of 400kv GRL-SLR S/C LINE Replacement of old string by new one is necessary on urgent basis	Daily	MSETCL	-
76	436	SOLAPUR-M - 400KV - BUS 2	11-Mar-20	10:00	11-Mar-20	18:00	Diagnostic Testing	Daily	MSETCL	Load will be Managed on 400KV Main Bus -1
77	437	220KV-WARDHA-WARDHA-M-1	11-Mar-20	10:00	11-Mar-20	18:00	Routine maintainace work,Disc replacement	Daily	MSETCL	NA
78	440	DHULE - SSNNL II	11-Mar-20	08:00	12-Mar-20	18:00	A/R of DHU-SSNNL-I should be kept in Non-Auto mode. PID Testing work.	Daily	MSETCL	A/R of DHL-SSNNL-I should be kept in Non-Auto Mode.
79	442	400KV/11.5KV TIRODA-ST-4	11-Mar-20	09:00	13-Mar-20	18:00	Maintenance of 400kv Station transformer-4.	Continuous	APML	Maintenance of 400KV Station transformer-4.
80	444	400KV-RGPPL-NEW KOYNA-1	11-Mar-20	09:00	11-Mar-20	18:00	Cold washing & Routine maint. Work	Daily	MSETCL	Planned outage
81	453	220KV-NASIK-NAVSARI-2	11-Mar-20	09:00	14-Mar-20	18:00	Replacement of old disc insulator by porcelain long rod, Dignostic testing,broken/flash over string replacement found during monkey patrolling, signature analysis, TLS fixing if issued.	D	MSETCL	-

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	Reason	Daily/Continuous	Name of Requesting Agency	Remarks
82	455	400KV-KHARGHAR-PUNE-PG-1	12-Mar-20	9:00	12-Mar-20	18:00	For AMP works	D	POWERGRID_WR1	403
83	457	KORADI-III - 400KV - BUS 2	12-Mar-20	09:00	12-Mar-20	18:00	Maintenance of Bus related equipments.	Daily	MEGPTCL	Maintenance of Bus related equipments.
84	462	400KV Partial Main Bus-II (from ektuni-2 to ICT-4 section) at 400KV Babhaleshwar SS	12-Mar-20	8:00	15-Mar-20	18:00	Bus Isolator alignment work for 400kv Kudus-I & 400kv Kudus-II bay at 400KV Babhaleshwar SS	Continuous	MSETCL	1) Removing /reconnecting of 400kv main Bus 2 will be carried out by hot line unit 2) During outage i) 400kv Ektuni-II line will be shifted on bus-I and handtripped while removing /reconnecting of 400KV Main bus-II jumps by hot line unit ii) 400KV Ektuni-I to be shifted on bus-II iii) ICT-IV will remain on TBC till outage period
85	463	400 KV-SSP-DHULE-MS-1	12-Mar-20	7:00	12-Mar-20	18:00	PMM work.	Daily	GETCO	Auto reclose of SSP - Dhule line No. 2 will remain out
86	464	400KV-SSP-DHULE-MS-1	12-Mar-20	07:00	12-Mar-20	18:00	Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-2 should be kept on Non-Auto Mode.
87	479	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2 LR @ WALUJ	12-Mar-20	9:00	12-Mar-20	18:00	For AMP works, Line outage required for isolation & take into service each operation 15 min for non switchable line reactor at Aurangabad (Waluj) end.	D	POWERGRID_WR1	
88	490	TIE BAY - 765KV-KORADI-III-AKOLA-1 AND 765KV-AKOLA-EKTUNI-1 at AKOLA - 765KV	12-Mar-20	10:00	12-Mar-20	14:00	Dew point measurement in circuit breaker.	Daily	MEGPTCL	Dew point measurement in circuit breaker.
89	500	400KV-RGPPL-NEW KOYNA-1	12-Mar-20	09:00	12-Mar-20	18:00	Cold washing & Routine maint. Work	Daily	MSETCL	Planned outage
90	512	BUS COUPLER BAY - KARAD - 400KV - BUS 1 AND KARAD - 400KV - BUS 2 at KARAD - 400KV	13-Mar-20	08:00	13-Mar-20	18:00	Insulator Blade assembly	Daily	MSETCL	Load manage on BUS I& II
91	513	400KV-CHAKAN-PUNE-PG-1	13-Mar-20	09:00	13-Mar-20	17:00	Half yearly testing and maintenance activities	Daily	MSETCL	---
92	514	400 KV-SSP-DHULE-MS-2	13-Mar-20	7:00	13-Mar-20	18:00	PMM work.	Daily	GETCO	Auto reclose of SSP - Dhule line No. 1 will remain out
93	515	400KV-SSP-DHULE-MS-2	13-Mar-20	07:00	13-Mar-20	18:00	Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-1 should be kept on
94	519	DHULE-MS - 400KV B/R 1	13-Mar-20	8:30	13-Mar-20	18:00	For internal inspection & repair due to Acetylene violation	D	POWERGRID_WR1	
95	532	MAIN BAY - 765KV-KORADI-III-AKOLA-1 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	13-Mar-20	10:00	13-Mar-20	14:00	Dew point measurement in circuit breaker.	Daily	MEGPTCL	Dew point measurement in circuit breaker.
96	534	400KV-PARLI-M-SOLAPUR-M-1	13-Mar-20	10:00	13-Mar-20	18:00	Due to frequent tripping of 400kv GRL-SLR S/C LINE Replacement of old string by new one is necessary on urgent basis	Daily	MSETCL	-
97	535	220KV-WARDHA-PUSAD-1	13-Mar-20	10:00	13-Mar-20	18:00	Routine maintainace work	Daily	MSETCL	NA
98	538	MAIN BAY - 400KV-PADGHE-BOISAR-1 AND PADGHE - 400KV - BUS 1 at PADGHE - 400KV	13-Mar-20	11:00	13-Mar-20	12:30	For CT oil samples	D	POWERGRID_WR1	
99	539	220KV-AURANGABAD-CHITEGAON-2	13-Mar-20	11:00	13-Mar-20	17:00	Replacement of relay battery by Company repr.	Daily	MSETCL	Replacement of relay battery by Company repr.
100	542	400KV-SSP-DHULE-MS-1	13-Mar-20	08:00	16-Mar-20	18:00	PID Testing work.	Daily	MSETCL	A/R of DHL-SSNNL-II should be kept in Non-Auto Mode.
101	544	SOLAPUR - 765KV - BUS 1	13-Mar-20	9:00	13-Mar-20	18:00	AMP of Bus and related isolators.	D	POWERGRID_WR1	
102	548	400KV-RGPPL-NAGOTHANE-2	13-Mar-20	9:00	19-Mar-20	18:00	Equipment & Relay testing work/ 407-52 A bkr CT (R phase) replacement	C	RGPPL	RGPPL-Nagothane line 2 outage.
103	555	220KV-TALEGAON-PUNE-PG-2	14-Mar-20	09:00	14-Mar-20	17:00	Half yearly maintenance , Diagnostic Testing	Daily	MSETCL	---
104	558	220KV-WARDHA-BADNERA-1	14-Mar-20	09:00	14-Mar-20	18:00	For replacement of CC structure.	Daily	MSETCL	NIL
105	559	400KV-CHANDRAPUR-GCR-CHANDRAPUR HVDC-1	14-Mar-20	09:00	14-Mar-20	18:00	For measurement of CB Timing, DCRM and CRM work.	Daily	MSETCL	During this outage 400KV HVDC-I bay will be shift on 400KV TBC-2 bay, as the work of measurement of CB Timing, DCRM and CRM work is to be carried out in 400KV HVDC-I bay.
106	571	BOISAR-M - 220KV - BUS 1	14-Mar-20	06:00	15-Mar-20	18:00	1) A-Bus Isolator maintenance work. 2) A-Bus Pilot string replacemen identified in PID. 3) Bus to isolator jumpers and Main Y-ph Twin Bus conductor(one section) replacement in view of hot spot.	Continuous	MSETCL	1) During the outage on 220KV A-Bus, all lines/Bays will shifted from A Bus to B-Bus through TBC. 2) Load affected NIL.

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	Reason	Daily/Continuous	Name of Requesting Agency	Remarks
107	574	400KV-KALWA-PADGHE-2	14-Mar-20	07:00	14-Mar-20	18:00	Routine Maintenance & Diagnostic Testing	Daily	MSETCL	-
108	576	400KV-PARLI-M-LONIKHAND-II-1	14-Mar-20	09:00	14-Mar-20	18:00	CVT Testing Work, Bay Maint Work	Daily	MSETCL	-
109	577	EKTUNI - 765KV B/R 1	14-Mar-20	09:00	14-Mar-20	18:00	Tan-Delta & Capacitance measurement of 3*80Mvar Bus Reactor Bushings.	Daily	MSETCL	765KV, 3 - 80MVAR BUS REACTOR will be out of service
110	583	TIE BAY - 400KV-PARLI-M-LONIKHAND-II-2 AND FUTURE at LONIKHAND-II - 400KV	15-Mar-20	09:00	15-Mar-20	18:00	Half yearly maintenance and diagnostic testing.	Daily	MSETCL	One and half breaker system, no line interruption, line will be charge through own bay.
111	592	MAIN BAY - 400KV-AKOLA-AURANGABAD-1 AND AKOLA - 400KV - BUS 1 at Akola - 400KV	15-Mar-20	9:00	20-Mar-20	18:00	For Replacement of BHEL CB with GE CB.	C	POWERGRID_WR1	
112	593	TALEGAON - 220KV - BUS 1	15-Mar-20	9:00	15-Mar-20	18:00	For AMP works & Replacement of Clamp & connectors	D	POWERGRID_WR1	220KV bus 2
113	612	400 KV BUSBAR SCHEME (ZIV MAKE) @KORADI	16-Mar-20	09:00	16-Mar-20	18:00	Relay installation and commissioning	Daily	MSETCL	Outages will be availed subject to weather conditions.
114	621	400KV-DHULE-KHANDWA-2 L/R@ DHULE - 400KV	16-Mar-20	9:00	16-Mar-20	18:00	For AMP works, Line outage outage required for isolation & take into service each operation 15 min for non switchable line reactor at Dhule (MSETCL) end.	D	POWERGRID_WR1	
115	623	TIE BAY - 765KV-KORADI-III-AKOLA-2 AND 765KV-AKOLA-EKTUNI-2 at AKOLA - 765KV	16-Mar-20	10:00	16-Mar-20	14:00	Dew point measurement in circuit breaker.	Daily	MEGPTCL	Dew point measurement in circuit breaker.
116	624	MAIN BAY - 400KV-TALEGAON-AKOLA-2 AND AKOLA - 400KV - BUS 2 at AKOLA - 400KV	16-Mar-20	10:00	16-Mar-20	17:00	Routine Maintenance & testing work	Daily	MSETCL	NIL
117	625	BAY NO. 406 @ KUDUS	16-Mar-20	10:00	16-Mar-20	17:00	Annual Maintenance of bays equipment & Diagnostics Testing Work	Daily	MSETCL	400kV Kala-1 Line will be in service at the time of Outage only respective Tie bay Outage proposed
118	626	TIE BAY (405) OF KALA CKT - 1 @ KUDUS	16-Mar-20	10:00	16-Mar-20	17:00	Annual Maintenance of bays equipment & Diagnostics Testing Work	Daily	MSETCL	400kV Kala-1 Line will be in service at the time of Outage only respective Tie bay Outage proposed
119	627	220KV-MUDSHINGI-CHIKKODI-II-1	16-Mar-20	10:00	16-Mar-20	17:00	Pre-monsoon Maintance i.e. Cold line insulator Cleaning	Daily	MSETCL	-
120	632	MAIN BAY - 220KV-TALEGAON-PUNE-PG-2 AND PUNE-PG - 220KV - BUS 1 at PUNE-PG - 220KV	16-Mar-20	9:00	16-Mar-20	18:00	For AMP works	D	POWERGRID_WR1	ICT#2
121	636	400KV/220KV AURANGABAD-M (WALUJ)-ICT-2	16-Mar-20	09:00	23-Mar-20	17:00	CB Overhauling works	Continuous	MSETCL	CB Overhauling works
122	638	220KV-WARDHA-PUSAD-1	16-Mar-20	10:00	30-Mar-20	18:00	Routine maintainace work	Daily	MSETCL	na
123	656	400KV-KARAD-JAIGAD-1	16-Mar-20	09:00	19-Mar-20	18:00	Hotline insulator washing works	Daily	JPTL	Auto Re-closure to be kept Non-Auto mode.
124	657	400KV-KARAD-JAIGAD-2	16-Mar-20	09:00	19-Mar-20	18:00	Hotline insulator washing works	Daily	JPTL	Auto Re-closure to kept Non-Auto mode.
125	663	220KV-TALEGAON-PUNE-PG-1	16-Mar-20	8:00	27-Mar-20	18:00	For PID testing	Daily	MSETCL	Line will be in service, only A/R switch will be OFF
126	664	220KV-TALEGAON-PUNE-PG-2	16-Mar-20	8:00	27-Mar-20	18:00	For PID testing	Daily	MSETCL	Line will be in service, only A/R switch will be OFF
127	665	400KV-DHULE-MS-BABLESHWAR-2	16-Mar-20	08:00	28-Mar-20	16:00	ON Line PID testing	Daily	MSETCL	ON Line PID testing
128	666	400KV-DHULE-MS-BABLESHWAR-1	16-Mar-20	08:00	28-Mar-20	16:00	ON Line PID testing	Daily	MSETCL	ON Line PID testing
129	667	400KV-SOLAPUR-M-SOLAPUR-1	16-Mar-20	10:00	31-Mar-20	18:00	PID Testing of Insulators	Daily	MSETCL	A/R Switch is to be made off
130	671	400KV-KHARGHAR-PUNE-PG-1	17-Mar-20	08:00	17-Mar-20	18:00	Line Maintenance & Diagnostic testing work	Daily	MSETCL	Insulator string replacement found in PID
131	675	400KV-SSP-DHULE-MS-1	17-Mar-20	07:00	17-Mar-20	18:00	Mostly damaged earthing wire replacement work. Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-2 should be kept on Non-Auto Mode.
132	679	400KV-SSP-DHULE-MS-2	17-Mar-20	08:00	17-Mar-20	18:00	A/R of DHL-SSNNL-II should be kept in Non-Auto Mode. PID Testing work.	Daily	MSETCL	A/R of DHL-SSNNL-II should be kept in Non-Auto Mode.
133	687	400KV-BABLESHWAR-PADGHE-PG-2	17-Mar-20	09:00	17-Mar-20	17:00	PID Faulty String replacement work & Relay Testing	Daily	MSETCL	400KV Padghe ckt I will be inservice
134	688	400KV-WARDHA-WARORA-1	17-Mar-20	09:00	17-Mar-20	17:00	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	Daily	MSETCL	400KV WARORA-IEPL Line is in ckt
135	689	400KV-WARDHA-WARORA-1	17-Mar-20	09:00	17-Mar-20	17:00	Bus/Line/Tie CT's, CVT Tan delta & Routine Maintenance & Diagnostic testing work etc	Daily	MSETCL	400KV WARORA-IEPL Line is in ckt
136	710	400KV SATPURA-KORADI	17-Mar-20	9:00	17-Mar-20	18:00	For AMP works of CB and terminal equipments at MPPGCL Satpura end. Line AMP on opportunity. Dia to be kept open at both ends.	D	POWERGRID_WR2	Itarsi

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	Reason	Daily/Continuous	Name of Requesting Agency	Remarks
137	713	MAIN BAY - 765KV-KORADI-III-AKOLA-2 AND AKOLA - 765KV - BUS 2 at AKOLA - 765KV	17-Mar-20	10:00	17-Mar-20	14:00	Dew point measurement in circuit breaker.	Daily	MEGPTCL	Dew point measurement in circuit breaker.
138	715	MAIN BAY - 400KV-KALA-KUDUS-2 AND KUDUS - 400KV - BUS 1 at KUDUS - 400KV	17-Mar-20	10:00	17-Mar-20	18:00	Annual Maintenance of bays equipment & Diagnostics Testing Work	Daily	MSETCL	400kV Kala-1 Line will be in service at the time of Outage only respective Tie bay Outage proposed
139	723	400KV/11.5KV TIRODA-ST-3	17-Mar-20	09:00	19-Mar-20	18:00	Maintenance of 400kV Station Transformer-3.	Continuous	APML	Maintenance of 400kV Station Transformer-3.
140	732	765KV/400KV EKTUNI-ICT-1	18-Mar-20	09:00	18-Mar-20	18:00	"1) Tan-Delta & Capacitance measurement of 1500MVA ICT-I Bushings.	Daily	MSETCL	765/400kV ICT-II will be in service.
141	733	400KV-SSP-DHULE-MS-2	18-Mar-20	07:00	18-Mar-20	18:00	Rusted/damaged Earthwire replacement work. Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-1 should be kept on Non-Auto Mode.
142	736	765KV/400KV EKTUNI-ICT-1	18-Mar-20	09:00	18-Mar-20	18:00	"1) Tan-Delta & Capacitance measurement of 1500MVA ICT-I Windings.	Daily	MSETCL	765/400kV ICT-II will be in service.
143	739	220KV-PARLI-PARLI-M-1	18-Mar-20	08:00	18-Mar-20	16:00	Line maintenance	Daily	MSETCL	-
144	741	220KV-TILLARI-AMONA-1	18-Mar-20	08:00	18-Mar-20	17:00	Routine Maintenance & Dignostic testing work	Daily	MSETCL	-
145	743	220KV-PANDURNA-KALMESHVAR-1	18-Mar-20	08:00	18-Mar-20	18:00	Routine Maintenance & Dignostic testing work	Daily	MSETCL	-
146	752	400KV-RGPPL-NAGOTHANE-2	18-Mar-20	09:00	18-Mar-20	18:00	Cold washing & Routine maint. Work	Daily	MSETCL	Planned outage
147	766	TIE BAY (402) OF KALA CKT - 2 @ KUDUS	18-Mar-20	10:00	18-Mar-20	17:00	Annual Maintenance of bays equipment & Diagnostics Testing Work	Daily	MSETCL	400kV Kala-1 & 400kV Kala-2 Lines will be in service at the time of Outage (Only Tie bay outage proposed)
148	769	220KV-WARDHA-BHUGAON-1	18-Mar-20	10:00	18-Mar-20	18:00	Routine maintainace work	Daily	MSETCL	NA
149	770	220KV-SOLAPUR-JEUR-1	18-Mar-20	10:00	18-Mar-20	18:00	Conversion of SSN to DSN	Daily	MSETCL	Load will be managed on 220KV Jeur- Tembhurni
150	772	400KV-KALA-KUDUS-1	18-Mar-20	9:00	19-Mar-20	18:00	For replacement of procelain insulators with polymer CLR. A/R OFF of ckt-2 and dia to be kept open at both ends. Proposed by AM T/L	D	POWERGRID_WR2	AM T/L
151	773	400KV-PARLI-M-SOLAPUR-M-1	18-Mar-20	10:00	19-Mar-20	18:00	Due to frequent tripping of 400kv GRL-SLR S/C LINE Replacement of old string by new one is necessary on urgent basis	Daily	MSETCL	-
152	780	765KV/400KV EKTUNI-ICT-2	19-Mar-20	09:00	19-Mar-20	18:00	"1) Tan-Delta & Capacitance measurement of 1500MVA ICT-II Bushings.	Daily	MSETCL	765/400kV ICT-I will be in service.
153	784	400KV-RGPPL-NAGOTHANE-2	19-Mar-20	09:00	19-Mar-20	18:00	Cold washing & Routine maint. Work	Daily	MSETCL	Planned outage
154	787	765KV/400KV EKTUNI-ICT-2	19-Mar-20	09:00	19-Mar-20	18:00	"1) Tan-Delta & Capacitance measurement of 1500MVA ICT-II Windings.	Daily	MSETCL	765/400kV ICT-I will be in service.
155	822	400KV-RGPPL-NEW KOYNA-2	20-Mar-20	09:00	20-Mar-20	18:00	Cold washing & Routine maint. Work	Daily	MSETCL	Planned outage
156	825	400KV-SSP-DHULE-MS-2	20-Mar-20	07:00	20-Mar-20	18:00	Rusted/damaged Earthwire replacement work. Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-1 should be kept on Non-Auto Mode.
157	827	400KV-SSP-DHULE-MS-1	20-Mar-20	08:00	20-Mar-20	18:00	A/R of DHL-SSNNL-1 should be kept in Non-Auto Mode. PID Testing work.	Daily	MSETCL	A/R of DHL-SSNNL-I should be kept in Non-Auto Mode.
158	831	EKTUNI - 765KV B/R 1	20-Mar-20	09:00	20-Mar-20	18:00	Tan-Delta & Capacitance measurement of 3*80Mvar Bus Reactor Windings.	Daily	MSETCL	765KV, 3 - 80MVAR BUS REACTOR will be out of service
159	837	400KV-WARDHA-KORADI-II-1	20-Mar-20	09:00	20-Mar-20	17:00	Routine Maintenance & Dignostic testing work Nut Bolt Tightning work	Daily	MSETCL	400 KV WARORA - DEOLI 2 Line is in ckt
160	841	BUS COUPLER BAY - CHANDRAPUR - 400KV - BUS 1 AND CHANDRAPUR - 400KV - BUS 2 at CHANDRAPUR - 400KV	20-Mar-20	09:00	20-Mar-20	18:00	1) For Measurement of Tan delta & capacitance of CT's. 2)Measurement of Timing, Contact resistance and DCRM of Breaker. 3) Maintenance of PG-1 & PG-2 Isolators.	Daily	MSETCL	During outage 400KV Bus Coupler bay, the tie breaker of HVDC terminal substaion Chandrapur will act as bus coupler for 400KV Main Bus -1 & 2 at 400KV Substation, GCR, MSETCL, Chandrapur.
161	842	765/400KV 500MVA SPARE ICT UNIT @ EKTUNI	20-Mar-20	09:00	20-Mar-20	18:00	Tan-Delta & Capacitance measurement of 1500MVA ICT-I Bushings & Winding.	Daily	MSETCL	765/400kV, 500MVA Spare ICT Unit will be out of service
162	857	400KV-KOLHAPUR-MS-SOLAPUR-2	20-Mar-20	10:00	20-Mar-20	18:00	For Line side bay AMP works at Kolhapur (MSETCL) end.	D	POWERGRID_WR1	
163	861	400KV-KALA-KUDUS-2	20-Mar-20	9:00	21-Mar-20	18:00	For replacement of procelain insulators with polymer CLR. A/R OFF of ckt-1 and dia to be kept open at both ends.	D	POWERGRID_WR2	AM T/L

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	Reason	Daily/Continuous	Name of Requesting Agency	Remarks
164	862	AURANGABAD-M (WALUJ) - 400KV - BUS 2	20-Mar-20	09:00	20-Mar-20	17:00	Routine maintenance	Daily	MSETCL	Routine maintenance
165	868	400KV-WARDHA-KORADI-II-1	20-Mar-20	09:00	20-Mar-20	18:00	Line Signature Test and line maintenance work	Daily	MSETCL	-
166	869	TIE BAY - AKOLA - 765KV B/R 1 AND 765KV/400KV AKOLA-ICT-1 AT AKOLA - 765KV	20-Mar-20	10:00	20-Mar-20	14:00	Dew point measurement in circuit breaker.	Daily	MEGPTCL	Dew point measurement in circuit breaker.
167	872	400KV-KHARGHAR-PUNE-PG-1	20-Mar-20	09:00	25-Mar-20	17:00	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	Daily	MSETCL	No interruption. Line will be in service.
168	873	400KV-KALWA-PUNE-PG-1	20-Mar-20	09:00	31-Mar-20	17:00	PID Testing work for line Insulator strings at various locations. Auto-Reclose function to be out of service.	Daily	MSETCL	-
169	875	400KV-RGPPL-NEW KOYNA-2	21-Mar-20	09:00	21-Mar-20	18:00	Cold washing & Routine maint. Work	Daily	MSETCL	Planned outage
170	880	400KV-SSP-DHULE-MS-2	21-Mar-20	07:00	21-Mar-20	18:00	Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-1 should be kept on Non-Auto Mode.
171	883	400KV-SSP-DHULE-MS-1	21-Mar-20	08:00	21-Mar-20	18:00	PID Testing work.	Daily	MSETCL	A/R of DHL-SSNNL-I should be kept in Non-Auto Mode.
172	886	220KV-TALEGAON-PUNE-PG-1	21-Mar-20	09:00	21-Mar-20	17:00	Half yearly maintenance , Diagnostic Testing	Daily	MSETCL	---
173	889	400KV-PARLI-M-PARLI-1	21-Mar-20	09:00	21-Mar-20	18:00	CB Testing work, Bay Maint Work	Daily	MSETCL	-
174	894	MAIN BAY - 765KV-AKOLA-EKTUNI-1 AND AKOLA - 765KV - BUS 1 at AKOLA - 765KV	21-Mar-20	10:00	21-Mar-20	14:00	Dew point measurement in circuit breaker.	Daily	MEGPTCL	Dew point measurement in circuit breaker.
175	900	HVDC 500KV CHANDRAPUR HVDC POLE 1 & 2	21-Mar-20	06:00	22-Mar-20	18:00	To rectify bent bracing of newly erected Loc. no. 285 of 500KV Chandrapur-Padghe HVDC Line due to construction of Kochi-Ambezary Dam under ORC scheme.	Continuous	MSETCL	ORC work of Height raising at loc. no. 285 & 286 of 500KV Chandrapur-Padghe HVDC Line due to construction of Kochi-Amezary Dam.
176	908	220KV-TALEGAON-PUNE-PG-2	21-Mar-20	09:00	21-Mar-20	17:00	Half yearly maintenance , Diagnostic Testing	Daily	MSETCL	----
177	910	400KV-RGPPL-NAGOTHANE-1	22-Mar-20	09:00	22-Mar-20	18:00	Cold washing & Routine maint. Work	Daily	MSETCL	Planned outage
178	912	400KV-SSP-DHULE-MS-1	22-Mar-20	07:00	22-Mar-20	18:00	Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-2 should be kept on Non-Auto Mode.
179	913	400KV-SSP-DHULE-MS-2	22-Mar-20	08:00	22-Mar-20	18:00	PID Testing work.	Daily	MSETCL	A/R of DHL-SSNNL-II should be kept in Non-Auto Mode.
180	921	400KV-SSP-DHULE-MS-2	22-Mar-20	08:00	22-Mar-20	17:00	PID Testing work.	Daily	MSETCL	A/R of DHL-SSNNL-II should be kept in Non-Auto Mode.
181	929	400KV-PARLI-M-LONIKHAND-II-2	23-Mar-20	09:00	23-Mar-20	18:00	Half yearly maintenance and diagnostic testing.	Daily	MSETCL	One and half breaker system ,no line interruption, line will be charge through Tie bay
182	931	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	23-Mar-20	08:00	25-Mar-20	18:00	Quadruple bus conductor replacement work of 400kv Kalwa and Talegaon	Continuous	MSETCL	Required for 400kv A bus outage
183	932	BUS COUPLER BAY - BHUSAWAL - 400KV - BUS 1 AND BHUSAWAL - 400KV - BUS 2 at BHUSAWAL - 400KV	23-Mar-20	06:00	23-Mar-20	18:00	for CT tan delta,CB DCRM & routine bay maintenance work	Daily	MSETCL	Nil
184	940	400KV-EKTUNI-BABLESHWAR-1	23-Mar-20	09:00	23-Mar-20	17:00	Quarterly Maintenance work & Relay Testing	Daily	MSETCL	400kv Ektuni ckt II,400kv Bhusawal and 400kv Aurangabad lines will be in service
185	957	400KV-JAIGAD-NEW KOYNA-1	23-Mar-20	09:00	24-Mar-20	18:00	Hotline insulator washing works	Daily	JPTL	Auto Re-closure to kept Non-Auto mode.
186	958	400KV-JAIGAD-NEW KOYNA-2	23-Mar-20	09:00	24-Mar-20	18:00	Hotline insulator washing works	Daily	JPTL	Auto Re-closure to kept Non-Auto mode.
187	961	TBC 2 @ CHANDRAPUR	23-Mar-20	09:00	27-Mar-20	18:00	For replacement of old 400kv Pantagraph Isolators of 400KV Main Bus-1 & 2 and Aux. Bus.	Continuous	MSETCL	During outage, 400KV TBC-1 bay will be available.
188	964	400KV-SSP-DHULE-MS-1	23-Mar-20	08:00	23-Mar-20	17:00	PID Testing work.	Daily	MSETCL	A/R of DHL-SSNNL-I should be kept in Non-Auto Mode.
189	971	MAIN BAY - 765KV-AKOLA-EKTUNI-2 AND AKOLA - 765KV - BUS 1 at AKOLA - 765KV	23-Mar-20	10:00	23-Mar-20	14:00	Dew point measurement in circuit breaker.	Daily	MEGPTCL	Dew point measurement in circuit breaker.
190	976	LONIKHAND-II - 400KV - BUS 1	24-Mar-20	09:00	24-Mar-20	18:00	Half yearly maintenance and diagnostic testing.	Daily	MSETCL	One and half breaker system, no line interruption
191	984	400KV-EKTUNI-BABLESHWAR-2	24-Mar-20	09:00	24-Mar-20	17:00	Quarterly Maintenance work & Relay Testing	Daily	MSETCL	400kv Ektuni ckt I,400kv Bhusawal and 400kv Aurangabad lines will be in service
192	998	TIE BAY - 405 OF 765/400KV 1500MVA ICT & FUTURE BAY @ AKOLA 2	24-Mar-20	10:00	24-Mar-20	14:00	Dew point measurement in circuit breaker.	Daily	MEGPTCL	Dew point measurement in circuit breaker.
193	1001	132KV-DHARNI-NEPANAGAR-1	24-Mar-20	11:00	24-Mar-20	17:00	Routine Maintenance & Dignostic testing work	Daily	MSETCL	NIL

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	Reason	Daily/Continuous	Name of Requesting Agency	Remarks
194	1006	400KV-SSP-DHULE-MS-2	24-Mar-20	07:00	24-Mar-20	18:00	Rusted/damaged Earthwire replacement work. Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-1 should be kept on Non-Auto Mode.
195	1014	400KV-SSP-DHULE-MS-2	24-Mar-20	07:00	24-Mar-20	18:00	Rusted/damaged Earthwire replacement work. Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-1 should be kept on Non-Auto Mode.
196	1034	400KV-PARLI-M-SOLAPUR-M-1	25-Mar-20	10:00	25-Mar-20	18:00	Conversion of SSN to DSN. & Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUSI, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.	Daily	MSETCL	Load will be managed on 400KV Lamboti-PGCIL Line
197	1035	400KV/220KV SOLAPUR-M-ICT-1	25-Mar-20	10:00	25-Mar-20	18:00	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUSI, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.	Daily	MSETCL	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUSI, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service. Load will be managed on 400/220/33 KV 500 MVA ICT - 2.
198	1036	SOLAPUR-M - 400KV - BUS 1	25-Mar-20	10:00	25-Mar-20	18:00	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUSI, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.	Daily	MSETCL	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUSI, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service. Load will be managed on 400KV Main Bus - 2.
199	1043	MAIN BAY - 400KV-AKOLA (2)-NANDGAONPETH-2 AND AKOLA (2) - 400KV - BUS 2 at AKOLA (2) - 400KV	25-Mar-20	10:00	25-Mar-20	15:00		D	MEGPTCL	
200	1047	waluj bus coupler	25-Mar-20	09:00	31-Mar-20	17:00	Bus coupler CB Overhauling works	Continuous	MSETCL	Bus coupler CB Overhauling works
201	1051	PUNE-PG - 400KV - BUS 1	26-Mar-20	9:00	26-Mar-20	18:00	For AMP works & Replacement of Clamp & connectors	D	POWERGRID_WR1	400kv bus 2
202	1058	JEIURI - 400KV - BUS 1	26-Mar-20	09:00	26-Mar-20	17:00	Annual testing & maintenance.	Daily	MSETCL	---
203	1059	MAIN BAY - 400KV-WARDHA-WARORA-1 AND WARDHA - 400KV - BUS 2 at Wardha - 400KV	26-Mar-20	09:00	26-Mar-20	17:00	Routine Maintenance & Dignostic testing work .	Daily	MSETCL	Line will be charged through Tie CB 428.
204	1062	400KV-PARLI-M-SOLAPUR-M-1	26-Mar-20	09:00	26-Mar-20	18:00	Hardware tightening & fitting work-	Daily	MSETCL	-
205	1064	BUS COUPLER BAY - PARLI - 220KV BUS-1 AND PARLI - 220KV BUS-2 at PARLI - 220KV	26-Mar-20	9:00	26-Mar-20	18:00	For AMP works	D	POWERGRID_WR1	
206	1073	MAIN BAY - 765KV/400KV AKOLA (2)-ICT-1 AND AKOLA (2) - 400KV - BUS 1 at AKOLA (2) - 400KV	26-Mar-20	10:00	26-Mar-20	14:00	Dew point measurement in circuit breaker.	Daily	MEGPTCL	Dew point measurement in circuit breaker.
207	1079	400KV/11.5KV TIRODA-ST-1	26-Mar-20	09:00	28-Mar-20	18:00	Maintenance of 400kv Station Transformer-1.	Continuous	APML	Maintenance of 400kv Station Transformer-1.
208	1088	400KV-WARORA-CHANDRAPU-II-2	26-Mar-20	06:00	31-Mar-20	17:00	For PID work, shifting of Auto reclose switch to non auto mode.	Daily	MSETCL	For PID work, shifting of Auto reclose switch to non auto mode.
209	1089	400KV-WARORA-CHANDRAPU-II-1	26-Mar-20	06:00	31-Mar-20	17:00	For PID work, shifting of Auto reclose switch to non auto mode.	Daily	MSETCL	For PID work, shifting of Auto reclose switch to non auto mode.
210	1096	400KV-SSP-DHULE-MS-1	27-Mar-20	07:00	27-Mar-20	18:00	Rusted/damaged Earthwire replacement work. Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-2 should be kept on Non-Auto Mode.
211	1100	MAIN BAY - 400KV-WARDHA-KORADI-II-1 AND WARDHA - 400KV - BUS 1 at Wardha - 400KV	27-Mar-20	09:00	27-Mar-20	17:00	Routine Maintenance & Dignostic testing work .	Daily	MSETCL	400KV KORADI-WARDHA Line will be charged through Tie CB 414.
212	1101	MAIN BAY (420) OF WARDHA (PG) CKT @ WARORA	27-Mar-20	09:00	27-Mar-20	17:00	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	Daily	MSETCL	400KV PGCIL Line will be charged through Tie CB 421.
213	1106	KORADI-III - 765KV - BUS 2	27-Mar-20	09:00	27-Mar-20	18:00	Maintenance of bus related equipments.	Daily	MEGPTCL	Maintenance of bus related equipments.
214	1127	TIE BAY - 400KV-PARLI-SOLAPUR-1 AND 400KV-ALKUD-SOLAPUR-1 at Solapur - 400KV	27-Mar-20	9:00	27-Mar-20	18:00	To change Bph CT bellow due to low oil level.	D	POWERGRID_WR1	
215	1128	BUS COUPLER BAY - KHARGHAR - 400KV - BUS 1 AND KHARGHAR - 400KV - BUS 2 at KHARGHAR - 400KV	27-Mar-20	08:00	30-Mar-20	18:00	Quadruple bus conductor replacement work of 400kv Kalwa and Talegaon B bus	Continuous	MSETCL	Required for 400kv B bus outage
216	1129	KHARGHAR - 400KV - BUS 2	27-Mar-20	08:00	30-Mar-20	18:00	Quadruple bus conductor replacement work of 400kv Kalwa and Talegaon B bus	Continuous	MSETCL	400kv A Bus will be in service
217	1134	TALEGAON - 220KV - BUS 2	28-Mar-20	9:00	28-Mar-20	18:00	For AMP works & Replacement of Clamp & connectors	D	POWERGRID_WR1	220kv talegaon line 2

Sr.No.	OCCM Sr. No	Line / Element	From	Time	to	Time	Reason	Daily/Continuous	Name of Requesting Agency	Remarks
218	1136	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	28-Mar-20	9:00	28-Mar-20	18:00	For AMP works of 400kV Aurangabad-2 main bay (411) at Pune-GIS, Line outage required due double main bus scheme at 400kV Pune-GIS end. & 400kV Pune-Aurangabad-1 AR to be kept in non auto mode for safety precautions.	D	POWERGRID_WR1	
219	1138	400KV-SSP-DHULE-MS-1	28-Mar-20	07:00	28-Mar-20	18:00	Insulator string replacement work.	Daily	MSETCL	A/R of 400KV DHL-SSNNL CKT-2 should be kept on
220	1141	TIE BAY - 400KV-WARDHA-WARORA-1 AND FUTURE at Wardha - 400KV	28-Mar-20	09:00	28-Mar-20	17:00	Routine Maintenance & Dignostic testing work .	Daily	MSETCL	Line will be charged through mainCB 429.
221	1150	220KV-KHANDWA-NEPANAGAR-1	28-Mar-20	9:00	28-Mar-20	18:00	AMP WORK. Line outage is required.	D	POWERGRID_WR2	Khandwa
222	1154	KORADI-III - 765KV - BUS 1	28-Mar-20	10:00	28-Mar-20	13:00	Bus CVT Testing.	Daily	MEGPTCL	Bus CVT Testing.
223	1158	BOISAR - 220KV - BUS 2	28-Mar-20	06:00	29-Mar-20	18:00	1) B-Bus Isolator maintenance work. 2) Pilot string replacement identified in PID.	Continuous	MSETCL	1) During the outage on 220kV B-Bus, all lines/Bays will shifted from B-Bus to A-Bus through TBC. 2) Load affected NIL
224	1159	TIE BAY - 400KV-AKOLA-AURANGABAD-2 AND AKOLA - 400KV - BUS 1 at Akola - 400KV	28-Mar-20	9:00	3-Apr-20	18:00	For Replacement of BHEL CB with GE CB.	C	POWERGRID_WR1	
225	1175	KALWA - 400KV - BUS 1	29-Mar-20	09:00	29-Mar-20	18:00	Bus maint. and CVT maint work	Daily	MSETCL	-
226	1177	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-2	29-Mar-20	9:00	29-Mar-20	17:00	Annual Maintenance	Daily	WTPL	
227	1178	400KV-AURANGABAD-M (WALUJ)-PUNE-GIS-1	29-Mar-20	9:00	29-Mar-20	17:00	A/R Mode to be kept off for attending annual shutdown work in 400KV Pune(GIS) - Aurangabad -2	Daily	WTPL	
228	1181	400KV-TIRODA-WARORA-1	30-Mar-20	07:00	30-Mar-20	18:00	Annual Maintenance	Daily	ATIL	Annual Maintenance
229	1182	400KV-TIRODA-WARORA-2	30-Mar-20	07:00	30-Mar-20	18:00	A/R mode to be kept off for attending annual shutdown work in 400kV Tiroda-Warora-I.	Daily	ATIL	A/R mode to be kept off for attending annual shutdown work in 400kV Tiroda-Warora-I.
230	1185	400KV-DHULE-MS-BABLESHWAR-1	30-Mar-20	08:00	30-Mar-20	18:00	if any suspicious string is found in PID testing , it will be replaced in this outage.	Daily	MSETCL	A/R of BBLR -II required to be kept on non auto mode
231	1197	220KV-KOLHAPUR-CHIKKODI-II-1	30-Mar-20	10:00	30-Mar-20	17:00	Pre-monsoon Maintance i.e. Cold line insulator Cleaning	Daily	MSETCL	-
232	1205	220KV-TARAPUR 1&2-BOISAR-M-1	30-Mar-20	8:00	1-Apr-20	19:00	Annual maintenance Works	daily	TAPS 1&2, NPCIL	MSETCL
233	1210	400KV-BABLESHWAR-PADGHE-2	30-Mar-20	08:00	31-Mar-20	18:00	For Carrying PID Work	Daily	MSETCL	-
234	1214	KORADI-III - 400KV - BUS 1	31-Mar-20	09:00	31-Mar-20	18:00	Maintenance of Bus related equipments.	Daily	MEGPTCL	Maintenance of Bus related equipments.
235	1215	400KV-DHULE-MS-BABLESHWAR-2	31-Mar-20	07:00	31-Mar-20	18:00	if any suspicious string is found in PID testing , it will be replaced in this outage.	Daily	MSETCL	A/R of BBLR -I required to be kept on non auto mode.
236	1217	220KV-WARDHA-WARDHA-M-1 Shifting to TBC at Wardha-PG	31-Mar-20	9:00	31-Mar-20	18:00	For shiting it on TBC for Attending Isolator problem & line will be in service through TBC at Wardha end.	D	POWERGRID_WR1	
237	1219	WARDHA - 220KV - BUS 2	31-Mar-20	9:00	31-Mar-20	18:00	For CVT Oil leakage attending, 20689B isolator problem attending.	D	POWERGRID_WR1	
238	1225	220KV-TALEGAON-PUNE-PG-2	31-Mar-20	9:00	31-Mar-20	18:00	For AMP works	D	POWERGRID_WR1	209
239	1227	400KV-TIRODA-WARORA-2	1-Apr-20	07:00	1-Apr-20	18:00	Annual Maintenance	Daily	ATIL	Annual Maintenance
240	1228	400KV-TIRODA-WARORA-1	1-Apr-20	07:00	1-Apr-20	18:00	A/R mode to be kept off for attending annual shutdown work in 400kV Tiroda-Warora-II.	Daily	ATIL	A/R mode to be kept off for attending annual shutdown work in 400kV Tiroda-Warora-II.

NOT CONSIDERED IN THIS OCC (MARCH 2020)

Sr. No	Line / Element	From	Time	to	Time	D	Name of Requesting Agency	reason	Remarks
909	KHARGHAR - 400KV - BUS 1	27-Mar-20	08:00	27-Mar-20	18:00	Continuous	MSETCL	Quadruple bus conductor replacement work o	400kV B Bus will be in service
927	400KV-PARLI-M-LONIKHAND-II-1	29-Mar-20	09:00	29-Mar-20	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.	---
942	400KV-KALWA-PADGHE-1	28-Mar-20	07:00	28-Mar-20	18:00	Daily	MSETCL	Routine Maintenance & Diagnostic Testing	-
1049	400KV-LONIKHAND-CHAKAN-1	29-Mar-20	08:00	29-Mar-20	18:00	Daily	MSETCL	Routine Diagnostic testing work.	---
1139	LONIKHAND-II - 400KV - BUS 2	30-Mar-20	09:00	30-Mar-20	18:00	Daily	MSETCL	Half yearly maintenance and diagnostic testing.	One and half breaker system, no line interruption
1185	400KV-PARLI-M-LONIKHAND-II-1	28-Mar-20	10:00	28-Mar-20	18:00	Daily	MSETCL	Conversion of SSN to DSN	Load will be managed on Parali - Lonikand2 Ckt 2

Maharashtra State Load Despatch Centre

State Element Outages list for the month of March'2020

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,If any.
5	400 KV	400KV-CHANDRAPUR-KHAPARKHEDA-1	01-Mar-20	06:00	11-Mar-20	17:00	Daily	For PID work, shifting of Auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID work, shifting of Auto reclose switch to non auto mode.
11	400 KV	400KV-KARAD-KOLHAPUR-MS-1	02-Mar-20	09:00	02-Mar-20	18:00	Daily	Quarterly Maintenance Work	MSETCL	MSETCL	Monday is load staggering day at Kolhapur
13	400 KV	400KV-BHUSAWAL-BABLESHWAR-1	02-Mar-20	08:00	03-Mar-20	18:00	Daily	For On Line PID Testing	MSETCL	MSETCL	AR Required in NON-AUTO Mode
14	400 KV	400KV-PARLI-M-NANDED-1	02-Mar-20	09:00	02-Mar-20	18:00	Daily	Reactor Testing & CVT Testing, Bay Maint Work	MSETCL	MSETCL	-
25	400 KV	400/220/33 KV 500MVA ICT - 2 @ WARORA	03-Mar-20	09:00	03-Mar-20	17:00	Daily	Bus/Line/Tie CT's,Syn CVT Tan delta & Routine Maintenance & Dignostic testing work etc	MSETCL	MSETCL	400KV ICT No -2handed over to 400kv PADGHA
27	400 KV	400KV-BABLESHWAR-AURANGABAD-M (WALUJ)-1	03-Mar-20	09:00	03-Mar-20	16:00	Daily	PID Works. AR Out only	MSETCL	MSETCL	PID Works. AR Out only
28	400 KV	400KV-AKOLA-NANDGAONPETH-1	03-Mar-20	11:00	15-Mar-20	16:00	Daily	PID testing of insulator string	MSETCL	MSETCL	NIL
31	400 KV	STATION TRANSFORMER - 5B @ KHAPARKHEDA	04-Mar-20	10:00	04-Mar-20	17:00	Daily	Relay Testing Work & Isolator Maintenance Work	MSETCL	MSETCL	-
32	400 KV	400 KV FUTURE BAY II @ WARORA	04-Mar-20	09:00	04-Mar-20	17:00	Daily	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .	MSETCL	MSETCL	400KV Bay No 422 charged on No Load
34	400 KV	500 MVA 400/220 KV ICT - I Chandrapur 2	04-Mar-20	08:00	04-Mar-20	17:00	Daily	Diagnostic testing work on ICT-I	MSETCL	MSETCL	ICT -2 is in service
36	400 KV	400KV-CHANDRAPUR SWITCHING STATION-CHANDRAPUR-II-1	04-Mar-20	09:00	04-Mar-20	09:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
37	400 KV	400KV-BHUSAWAL-DEEPNAGAR-1	04-Mar-20	06:00	05-Mar-20	18:00	Daily	For replacement of Faulty insulator string detected in PID & PG Iso maint work at Khadka substation	MSETCL	MSETCL	During outage 400kv Deepnagar-Khadka-II ckt shall be in service
42	400 KV	400KV/220KV SOLAPUR-M-ICT-1	04-Mar-20	10:00	04-Mar-20	18:00	Daily	Replacement of LV side 220KV Isolator of 400/220KV ICT I	MSETCL	MSETCL	Load will be managed on 400/220KV ICT II
44	400 KV	400KV-CHANDRAPUR-II-NANDED-1	05-Mar-20	08:00	05-Mar-20	17:00	Daily	For replacement of Disc Insulator if found During PID Testing & Line Signature Test	MSETCL	MSETCL	For replacement of Disc Insulator if found During PID Testing & Line Signature Test
45	400 KV	400KV/220KV CHAKAN-ICT-1	05-Mar-20	09:00	05-Mar-20	17:00	Daily	Half yearly testing and maintenance activities	MSETCL	MSETCL	A/R is not applicable for ICT bay. Hence, out of service option is selected.
46	400 KV	400/220 KV 167 MVA ICT @ PARLI	05-Mar-20	10:00	05-Mar-20	17:00	Daily	Bay maintenance work	MSETCL	MSETCL	-
47	400 KV	400KV-AURANGABAD-M (WALUJ)-DEEPNAGAR-1	05-Mar-20	09:00	05-Mar-20	18:00	Daily	Quarterly maintenance	MSETCL	MSETCL	Quarterly maintenance
48	400 KV	400KV/220KV LONIKHAND-II-ICT-1	05-Mar-20	08:00	05-Mar-20	18:00	Daily	RTV Coating of ICT-I	MSETCL	MSETCL	---
49	400 KV	PARLI - KUMBHARGAON (NANDED) CKT - 1	05-Mar-20	10:00	05-Mar-20	18:00	Daily	Annual CT Tan-d, Relay Routine Testing & Equipments Maintenance works.	MSETCL	MSETCL	-
50	400 KV	KARAD - LONIKAND 1	05-Mar-20	08:00	06-Mar-20	18:00	Continuou s	Annual Maint. Work & removing of old 400 KV Busbar wiring from Relay panel	MSETCL	MSETCL	Load manage on other ckt.
51	400 KV	TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	05-Mar-20	09:00	05-Mar-20	12:30	Daily	TIE CB DCRM Testing	MSETCL	MSETCL	Line will be in service throughmain CB
52	400 KV	400/220/33 KV 500 MVA ICT - 1 @ JEJURI	05-Mar-20	09:00	05-Mar-20	17:00	Daily	Annual testing & maintenance	MSETCL	MSETCL	---
53	400 KV	400/220/33 KV 500MVA ICT - 1 @ KORADI 2	05-Mar-20	10:00	05-Mar-20	15:00	Daily	Tan delta measurement Line CT at ICT -I Bay 205	MSETCL	MSETCL	Load will be shifted to 400/220/33KV 501MVA ICT-II
56	400 KV	LONIKAND2-LONIKAND1 (INTERCONNECTOR 2)	06-Mar-20	08:00	06-Mar-20	18:00	Daily	Routine Diagnostic testing work.	MSETCL	MSETCL	---
57	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	06-Mar-20	09:00	06-Mar-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
59	400 KV	500 MVA 400/220 KV ICT - II @ Chandrapur 2	06-Mar-20	08:00	06-Mar-20	17:00	Daily	Diagnostic testing work carried out on 400/220 KV ICT-2	MSETCL	MSETCL	400/220KV ICT-1 is in service.
61	400 KV	KHADKA- DEEPNAGAR CKT 2	06-Mar-20	06:00	07-Mar-20	18:00	Daily	For replacement of faulty insulator string detected in PID & PG Iso maintenance work at 400 KV Khadka substation	MSETCL	MSETCL	During the outage 400kv Deep-KDK-I ckt shall be in service
64	400 KV	TBC @ KORADI-1	06-Mar-20	09:00	06-Mar-20	18:00	Daily	Diagnostic testing work, Reactor SFRA	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
65	400 KV	400/220kv 500MVA ICT-2 @ TAPTITANDA	06-Mar-20	11:00	06-Mar-20	13:00	Daily	Measurement of 'B' phase HV line CT tan D	MSETCL	MSETCL	Nil
70	400 KV	400/220/33 KV 500 MVA ICT - 3 @ WALUJ	06-Mar-20	09:00	06-Mar-20	17:00	Daily	Routine Maintenance	MSETCL	MSETCL	Routine Maintenance

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.
72	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	07-Mar-20	08:00	07-Mar-20	17:00	Daily	For Conductor & Earthwire Hardware Tightening work	MSETCL	MSETCL	For conductor & Earthwire H/W Tightening work
74	400 KV	400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	07-Mar-20	08:00	07-Mar-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220kv 315MVA ICT- I & 501 MVA ICT -III& 501 MVA ICT-IV will be in service
80	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	07-Mar-20	09:00	07-Mar-20	16:00	Daily	PID Works	MSETCL	MSETCL	PID Works
85	400 KV	JAIGAD-NEW KOYNA-I	09-Mar-20	08:00	09-Mar-20	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	Planned Outage
89	400 KV	400/220 KV 315MVA ICT - 2 @ KARAD	09-Mar-20	09:00	09-Mar-20	17:00	Daily	Quarterly Maint. Work & attending on leakages by Cold welding Method	MSETCL	MSETCL	Load manage on other Two ICT'S
91	400 KV	JAIGAD-NEW KOYNA-II	10-Mar-20	08:00	10-Mar-20	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	Planned outage
92	400 KV	DHULE - BABLESHWAR - I	10-Mar-20	09:00	10-Mar-20	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400kv Dhule ckt II,400kv Bhusawal and 400kv Aurangabad lines will be in service
96	400 KV	CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	11-Mar-20	08:00	11-Mar-20	17:00	Daily	Diagnostic testing work carried out on Main-I & Main-II protection.	MSETCL	MSETCL	400KV Chandrapur-2-GCR ckt-2 is in service
101	400 KV	DEEPNAGAR - THAPTI TANDA	11-Mar-20	09:00	11-Mar-20	18:00	Daily	Line routine maintenance	MSETCL	MSETCL	Nil
102	400 KV	DHULE - BABLESHWAR - II	11-Mar-20	09:00	11-Mar-20	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400kv Dhule ckt I,400kv Bhusawal and 400kv Aurangabad lines will be in service
109	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT1	12-Mar-20	09:00	12-Mar-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
112	400 KV	KHADKA - BABLESHWAR	12-Mar-20	06:00	12-Mar-20	18:00	Daily	for replacement of Aux PG Isolator and routine bay maintenance work	MSETCL	MSETCL	Nil
113	400 KV	CHANDRAPUR - KHAPERKHEDA	12-Mar-20	08:00	12-Mar-20	17:00	Daily	For Replacement of Disc Insulator, if found during PID Testing	MSETCL	MSETCL	For Replacement of Disc Insulator, if found during PID Testing
114	400 KV	400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	12-Mar-20	08:00	12-Mar-20	18:00	Daily	RTV Coating of ICT-II	MSETCL	MSETCL	---
118	400 KV	JEJURI- KOYNA STAGE-IV	12-Mar-20	09:00	12-Mar-20	17:00	Daily	Annual testing & maintenance.	MSETCL	MSETCL	----
119	400 KV	THAPTI TANDA - WALUJ	12-Mar-20	09:00	12-Mar-20	18:00	Daily	Line Routine maintenance work	MSETCL	MSETCL	Nil
121	400 KV	400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 2 (CHPR 1 IEND)	13-Mar-20	09:00	13-Mar-20	18:00	Daily	For measurement of CT Tan delta and Capacitance	MSETCL	MSETCL	During, this outage 400KV CHD-2 CKT.1 will be in service. The outage on 400KV CHD-2 CKT.2 bay is
122	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	13-Mar-20	09:00	13-Mar-20	18:00	Daily	quarterly maintenance	MSETCL	MSETCL	quarterly maintenance
125	400 KV	KORADI-KHAPERKHEDA II	13-Mar-20	10:00	13-Mar-20	17:00	Daily	Isolator Maintenance Work	MSETCL	MSETCL	_
128	400 KV	MAIN BAY (402) OF KHADKA CKT - 2 @ DEEPNAGAR	13-Mar-20	09:00	13-Mar-20	12:30	Daily	Main bay CB DCRM testing work	MSETCL	MSETCL	Line will be in service through Tie Bay
130	400 KV	GT 5 @ KORADI	13-Mar-20	09:00	13-Mar-20	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
134	400 KV	CHANDRAPUR - KHAPERKHEDA	13-Mar-20	06:00	31-Mar-20	17:00	Daily	For PID work, shifting of Auto reclose switch to non auto mode.	MSETCL	MSETCL	For PID work, shifting of Auto reclose switch to non auto mode.
143	400 KV	80 MVAR BUS REACTOR - 1 @ BABHALESHWAR	14-Mar-20	08:00	14-Mar-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	All 4 nos of ICT and 400kv Lines will be in service
151	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	16-Mar-20	09:00	16-Mar-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
154	400 KV	400KV AKOLA-BHUSAWAL (Bhusawal end)	16-Mar-20	08:00	21-Mar-20	18:00	Daily	Work of replacement of faulty strings having 02 & above no. of punctured discs detected in PID by agency by availing outages (cold line).	MSETCL	MSETCL	NIL
167	400 KV	CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	17-Mar-20	08:00	17-Mar-20	18:00	Daily	For routine maintenance work	MSETCL	MSETCL	NIL
173	400 KV	THAPTI TANDA - WALUJ	17-Mar-20	09:00	17-Mar-20	18:00	Daily	Quarterly maintenance	MSETCL	MSETCL	Quarterly maintenance
180	400 KV	CHANDRAPUR 2-KUMBHARGAON(NANDED) CKT - 2	18-Mar-20	10:00	18-Mar-20	18:00	Daily	Annual CT Tan-d, Relay Routine Testing & Equipments Maintenance works.	MSETCL	MSETCL	-
182	400 KV	Tie Bay (417) of Chandrapur 2 ckt - 1 @ Chandrapur switching s/s	18-Mar-20	09:00	18-Mar-20	18:00	Daily	for Diagnostic testing & allied bay maintenance work	MSETCL	MSETCL	for Diagnostic testing & allied bay maintenance work
183	400 KV	CHANDRAPUR - KHAPERKHEDA	18-Mar-20	10:00	18-Mar-20	17:00	Daily	Isolator Maintenance Work	MSETCL	MSETCL	_
186	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	18-Mar-20	10:00	18-Mar-20	18:00	Daily	RTV HVIC Coating work for 400/220KV ICT II	MSETCL	MSETCL	Load will Be Managed on 400/220KV 500MVA ICT I
187	400 KV	GT - 7 @ KORADI-1	18-Mar-20	09:00	18-Mar-20	18:00	Daily	Diagnostic testing work	MSETCL	MSETCL	Outages will be availed subject to weather conditions.
188	400 KV	TIE BAY (415) OF 500MVA ICT - 2 & STATION TF 4A @ DEEPNAGAR	18-Mar-20	09:00	18-Mar-20	12:30	Daily	Tie Bay CB DCRM	MSETCL	MSETCL	Both ICT-II HV and STN 4B bay will in service through their main bay

Sr.No.	Voltage	Line Equipment	From Date	From Time	To Date	To Time	Basis	Reason	System	Agency	Remark ,if any.
191	400 KV	WARORA - IEPL	18-Mar-20	09:00	18-Mar-20	17:00	Daily	Routine Maintenance & Dignostic testing work , Nut Bolt of jumper Tightning work.	MSETCL	MSETCL	400 KV KORADI 2-WARDHA PGCIL Line is in ckt
192	400 KV	CHANDRAPUR 2 - CHD SWITCHING CKT2	18-Mar-20	08:00	18-Mar-20	17:00	Daily	Diagnostic testing work carried out on relay RET650 & REF651	MSETCL	MSETCL	400KV chandrapur-2-switching-ckt-1 is in service
201	400 KV	400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	19-Mar-20	10:00	19-Mar-20	18:00	Daily	RTV HVIC Coating work for 400/220KV ICT II	MSETCL	MSETCL	Load will Be Managed on 400/220KV 500MVA ICT I
202	400 KV	400/220/33 KV 500 MVA ICT - 3 @ JEJURI	19-Mar-20	09:00	19-Mar-20	17:00	Daily	Annual testing & maintenance.	MSETCL	MSETCL	---
203	400 KV	NEW KOYNA - STAGE IV CKT 1	19-Mar-20	09:00	19-Mar-20	18:00	Daily	Cold washing & Routine maint. Work	MSETCL	MSETCL	Planned outage
204	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	19-Mar-20	09:00	19-Mar-20	16:00	Daily	PID Works	MSETCL	MSETCL	PID Works
205	400 KV	KARAD - LONIKAND 1	19-Mar-20	08:00	19-Mar-20	18:00	Daily	Line Maintenance & Routine Diagnostic testing work	MSETCL	MSETCL	Insulator string replacement found in PID
206	400 KV	NEW KOYNA-KARAD -CKT 1	20-Mar-20	09:00	20-Mar-20	17:00	Daily	Annual Maint. Work	MSETCL	MSETCL	Load manage on 400 kv Koyana Ckt-2
214	400 KV	NEW KOYNA - STAGE IV CKT 2	20-Mar-20	09:00	20-Mar-20	18:00	Daily	Cold washing & Routine maint. Work	MSETCL	MSETCL	Planned outage
216	400 KV	400/220/33 KV 500 MVA ICT - 1 @ NANDED	20-Mar-20	10:00	20-Mar-20	18:00	Daily	To replace 220kV Bushing Thimble.	MSETCL	MSETCL	-
220	400 KV	NEW KOYNA -KARAD -CKT 2	21-Mar-20	08:00	21-Mar-20	18:00	Daily	Diagnostic testing and Routine maint. Work	MSETCL	MSETCL	Planned outage
225	400 KV	400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	21-Mar-20	08:00	21-Mar-20	18:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	400/220kv 315MVA ICT- I & 315 MVA ICT -II & 501 MVA ICT-IV will be in service
229	400 KV	400 KV WALUJ (400 KV) - BABHALESHWAR CKT	21-Mar-20	09:00	21-Mar-20	16:00	Daily	PID Works	MSETCL	MSETCL	PID Works
235	400 KV	400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	23-Mar-20	10:00	23-Mar-20	17:00	Daily	Isolator Maintenance Work	MSETCL	MSETCL	_
237	400 KV	400/220KV 315 MVA ICT - 1 @ NEW KOYNA	23-Mar-20	08:00	23-Mar-20	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
238	400 KV	AKOLA-NANDGAONPETH (RPL-AMT)	23-Mar-20	08:00	28-Mar-20	18:00	Daily	Work of replacement of faulty strings having 02 & above no. of punctured discs detected in PID by agency by availing outages (cold line).	MSETCL	MSETCL	NIL
239	400 KV	400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	23-Mar-20	16:00	24-Mar-20	08:00	Continuou s	Pre-monsoon Maintenance work, insulation and tube coating of 33kv Delta IPS tube	MSETCL	MSETCL	Monday is load staggering day. And work will be carried out in night hours during low load condition. **Also requires shut down of 220kv Tilawani-Miraj Line to manage load, depends on real time loading conditios**
244	400 KV	MAIN BAY (410) OF RPL CKT-2 @ AKOLA 2	25-Mar-20	10:00	25-Mar-20	14:00	Daily	Dew point measurement in circuit breaker.	MEGPTCL	MEGPTCL	Dew point measurement in circuit breaker.
245	400 KV	400/220/33KV ICT - 167 MVA SPARE ICT @LAMBOTI	25-Mar-20	10:00	25-Mar-20	18:00	Daily	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUSI, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.	MSETCL	MSETCL	Rapid Restoration scheme for ICT TESTING. For scheme testing 400 kv Main Bus-I, 220 KV Main bUSI, Spare ICT and 400 kv Parli Line outage is also required. 400 kv Bus Reactor will be out of service.
254	400 KV	CHANDRAPUR 2 - DHARIWAL CKT - 1	26-Mar-20	08:00	26-Mar-20	17:00	Daily	Diagnostic testing work carried out on relay RET650 & REF615	MSETCL	MSETCL	400KV chandrapur-2-Dhariwal ckt-2 is in service
256	400 KV	400/220/33 KV 315 MVA ICT - 2 @ PARLI	26-Mar-20	09:00	26-Mar-20	18:00	Daily	C & Tan Delta measurement of Bushings & windings of all three Units, HV & IV CTs testing work, Bay Maint Work	MSETCL	MSETCL	-
258	400 KV	DEEPNAGAR - THAPTI TANDA	26-Mar-20	09:00	26-Mar-20	18:00	Daily	Quarterly maintenance of 400KV Deepnagar- Thaptitanda Line @ 400kv Waluj END	MSETCL	MSETCL	Quarterly maintenance of 400kv Deepnagar- Thaptitanda Line @ 400kv Waluj END
265	400 KV	BABLESHWAR- AURANGABAD (WALUJ)	27-Mar-20	09:00	27-Mar-20	17:00	Daily	Quarterly Maintenance work & Relay Testing	MSETCL	MSETCL	All other 400kv lines will be in service at 400kv BBLR End.
267	400 KV	KORADI 2-IEPL	27-Mar-20	09:00	27-Mar-20	18:00	Daily	Line maintenance work	MSETCL	MSETCL	_
268	400 KV	400/220/33 KV 500 MVA ICT - 2 @ NANDED	27-Mar-20	10:00	27-Mar-20	18:00	Daily	To replace 220kV Bushing Thimble.	MSETCL	MSETCL	-
271	400 KV	THAPTI TANDA - WALUJ	27-Mar-20	09:00	27-Mar-20	17:00	Daily	Routine maintenance works	MSETCL	MSETCL	Nil
279	400 KV	400/132 KV 200 MVA ICT - 1 @ KHADKA	28-Mar-20	06:00	28-Mar-20	18:00	Daily	maintenance of PG iso,replacement of CT and Routine bay maintenance work	MSETCL	MSETCL	nil
286	400 KV	400/220KV 315 MVA ICT - 2 @ NEW KOYNA	30-Mar-20	08:00	30-Mar-20	18:00	Daily	Routine maint. Work	MSETCL	MSETCL	Planned outage
295	400 KV	KHADKA-AURANGABAD	31-Mar-20	09:00	31-Mar-20	18:00	Daily	Quarterly maintenance	MSETCL	MSETCL	Quarterly maintenance